



Report of ERPC Protection Team

on

Un-coordinated trippings in JUSNL SYSTEM

July, 2016

**Eastern Regional Power Committee
14, Golf Club Road, Tollygunge
Kolkata: 700 033**

FOREWORD

The primary focus of this Technical Report is the root cause analysis as well as remedial action needed for un-coordinated trippings around 220/132 kV Chandil, Ramchandrapur and 132 kV Adityapur substations of JUSNL system.

The report has been prepared after detailed study and scrutiny of JUSNL sub-stations data (as provided by JUSNL) and site visit of JUSNL sub-stations by the ERPC Protection team (i.e. the Committee) as constituted by 31st TCC/ERPC.

The committee has also recommended the protection settings for all the 220 kV & 132 kV lines and 220/132 kV transformers of the affected sub-stations.

It is important to acknowledge that this report is a collaborative achievement of ERPC. Special thanks are due to the members of ERPC protection team for their sincere efforts. I express appreciation to representatives of JUSNL as this report is only possible because for their hard work and dedication.

Place: Kolkata

Date: 29.07.2016



(A. K. Bandyopadhyaya)

Member Secretary

CONTENTS

Sl. No.	DESCRIPTION	Page No.
1.0	Preface	4 - 5
2.0	Salient History	6 - 25
3.0	Sequence of events adopted by the committee	26 - 27
4.0	Findings of the committee	28 - 41
5.0	Root Cause Analysis	42 - 43
6.0	Recommendations	44 - 49
7.0	Protection Settings of JUSNL System	49
8.0	ANNEXURES:	

8.1: Details of 220/132KV CHANDIL S/STN

Annexure: 8.1.1	SLD
Annexure: 8.1.2	Year of Manufacturing of all equipment's
Annexure: 8.1.3	Comprehensive CT details along with name plate & Adopted Ratio
Annexure: 8.1.4	VT details
Annexure: 8.1.5	Fault Level :- 3 - Phase as well as 1 – phase
Annexure: 8.1.6	Transformer Details (Rating, % Impedance)
Annexure: 8.1.7	Cable details used for CT connection (cross section/core of cable, Junction Box details and length of cable between JB and control Panel)
Annexure: 8.1.8	Grid Earthing Resistance
Annexure: 8.1.9	Breaker details (operating time, closing, tripping TC#1 and TC # 2)
Annexure: 8.1.10	CT/PT secondary earthing details
Annexure: 8.1.11	Relay details (Relay type, Model, setting, manufacturing, basis of setting, etc)
Annexure: 8.1.12	D.C. system details with charger and battery Value of voltage for D.C +ve to earth and -ve to earth
Annexure: 8.1.13	Details of transmission line protection as per the format
Annexure: 8.1.14	Details of transformer protection as per the format

8.2: Details of 220/132KV RAMCHANDRAPUR S/STN

Annexure: 8.2.1	SLD
Annexure: 8.2.2	Year of Manufacturing of all equipment's
Annexure: 8.2.3	Comprehensive CT details along with name plate & Adopted Ratio
Annexure: 8.2.4	VT details
Annexure: 8.2.5	Fault Level :- 3 - Phase as well as 1 – phase
Annexure: 8.2.6	Transformer Details (Rating, % Impedance)

Annexure: 8.2.7	Cable details used for CT connection (cross section/core of cable, Junction Box details and length of cable between JB and control Panel)
Annexure: 8.2.8	Grid Earthing Resistance
Annexure: 8.2.9	Breaker details (operating time, closing, tripping TC#1 and TC # 2)
Annexure: 8.2.10	CT/PT secondary earthing details
Annexure: 8.2.11	Relay details (Relay type, Model, setting, manufacturing, basis of setting, etc)
Annexure: 8.2.12	D.C. system details with charger and battery Value of voltage for D.C +ve to earth and -ve to earth
Annexure: 8.2.13	Details of transmission line protection as per the format
Annexure: 8.2.14	Details of transformer protection as per the format

8.3: Details of 132KV ADITYAPUR S/STN

Annexure: 8.3.1	SLD
Annexure: 8.3.2	Year of Manufacturing of all equipment's
Annexure: 8.3.3	Comprehensive CT details along with name plate & Adopted Ratio
Annexure: 8.3.4	VT details
Annexure: 8.3.5	Fault Level :- 3 - Phase as well as 1 – phase
Annexure: 8.3.6	Cable details used for CT connection (cross section/core of cable, Junction Box details and length of cable between JB and control Panel)
Annexure: 8.3.7	Grid Earthing Resistance
Annexure: 8.3.8	Breaker details (operating time, closing, tripping TC#1 and TC # 2)
Annexure: 8.3.9	CT/PT secondary earthing details
Annexure: 8.3.10	Relay details (Relay type, Model, setting, manufacturing, basis of setting, etc)
Annexure: 8.3.11	D.C. system details with charger and battery Value of voltage for D.C +ve to earth and -ve to earth
Annexure: 8.3.12	Details of transmission line protection as per the format
Annexure: 8.3.13	Details of transformer protection as per the format

1.0 Preface :

Frequent Tripping of 220KV/132KV Lines of JUSNL and BSPTCL system leading to cascading effects and loss of Power on different occasions prompted TCC and ERPC to constitute a core group comprising experts from WBSETCL, OPTCL, DVC, PGCIL, ERLDC and ERPC Secretariat to look into the deficiencies around Chandil, Ramchandrapur & Adityapur substations in JUSNL system and in BSPTCL system and identify suitable remedial measures to prevent recurrence of such incidents. The names of the members of the core group under the auspices of Member Secretary, ERPC, was concurred by ERPC Board in the 31st TCC & ERPC meet on 13th and 14th of November 2015.

Although the committee was constituted for selective Substations where the frequency of outage was high for both BSPTCL and JUSNL system, however firstly the report of four Substations of JUSNL system is hereby submitted.

1.1 COMMITTEE MEMBERS:

- 1) Shri A.K. Bandyopadhyaya, Member Secretary, ERPC.
- 2) Shri Sabyasachi Roy, CE, SLDC, WBSETCL
- 2) Shri L. Nayak, GM, OPTCL.
- 3) Shri Jayanta Dutta, SE, DVC,
- 4) Shri Surajit Banerjee, AGM, ERLDC.
- 5) Shri S.K.Singh, DGM, PGCIL.
- 6) Shri S.B.Prasad, ESE, BSPTCL.
- 7) Shri Vidyasagar Singh, ESE, JUSNL.
- 8) Shri D. K. Bauri, EE, ERPC.

1.2 TERMS & REFERENCE:

- 1) In- depth study to ascertain the cause of tripping and Cascading tripping of 220KV/132KV Chandil, Ramcharapur, Adityapur, & Hatia S/Stns of JUSNL.
- 2) Recommending the corrective measures for non occurrence of similar incidence in future.

1.3 METHODOLOGY:-

From the history of tripping discussed in 34th, 35th, 36th and 37th PCC which is also highlighted in the Salient History, the members of the committee decided to adopt the following methodology towards the submission of the Final Report.

1. Collection of all relevant data's related to Chandil, Ramchandrapur and Adityapur S/Stn's of JUSNL.
2. Scrutiny of the data's submitted to ascertain deficiencies at a preliminary level.
3. Convene a meeting between the authorities of JUSNL and Committee members to propagate the preliminary deficiencies observed.
4. Visit to the Chandil, Ramchandrapur and Adityapur S/Stn's to ascertaining the actual deficiencies by checking the sub-station system of operation, inspect Outdoor Equipment's like CT, PT, Breaker, Transformer etc, Control and Relay Panels including the Protective Relays used and its relevant settings and schematics, D.C. system, Operation and maintenance practices followed etc.
5. Submission of the report along with suggestions and conclusions.


2.0 Salient History:

2.1 Excerpts of minutes of 34th PCC

Total power failure at 220kV Chandil S/s in JSEB system on 29/07/15 at 16:53 Hrs.

At 16:53hrs, total power failed at 220kV Chandil S/s in JUSNL system due to fault in 132kV Chandil-Hatia line. Following feeders from Chandil tripped:

Time (Hrs)	Details of tripping	Relay at local end	Relay at remote end
16:53 hrs	132kV Chandil-Hatia	<u>At Chandil</u> Did not trip	<u>At Hatia</u> Dir. E/F & O/C, trip phase ABC,
	132kV Ramchandrapur-Adityapur-D/C	<u>At Ramchandrapur</u> Power swing trip relay VAJ, O/C, E/F start	
	220kV Chandil-Ranchi	<u>At Chandil</u> Master trip relay 86, contact multi trip relay 86x	<u>At Ranchi</u> Did not trip
	220kV Chandil-Santaldih	<u>At Chandil</u> Master trip relay 86	<u>At Santaldih</u> Did not trip
	220kV Chandil-Ramchandrapur	<u>At Chandil</u> Z-III, LBB relay, tripping relay type VAJ, loc-35.6kM	<u>At Ramchandrapur</u> Z-III, Master trip relay



Points to be discussed:

- i. Reason for non-operation of the primary protection of 132kV Chandil-Hatia line from Chandil end.
- ii. The fault in 132kV system should have been cleared by DEF / DOC protection of the 220/132kV ATRs at Chandil, which needs to be explained.
- iii. Tripping of 220kV Chandil – Ranchi, 220kV Chandil-STPS and 220kV Chandil-Ramchandrapur lines from Chandil end needs to be explained.
- iv. JUSNL may please enlighten the house the reasons for such unexplained tripping with further supporting records like DR, EL etc. despite implementing corrective measures as recommended during last audit.

JUSNL may explain.

Deliberation in the meeting

JUSNL informed that—

- *The fault was in 220kV Chandil-Ramchandrapur line and the fault got cleared from both the ends.*
- *It was informed that the relays of 220kV Chandil-Ramchandrapur at both the end are very old and are under replacement.*
- *JUSNL apprehended that the LBB has operated at Chandil due to mal functioning.*


ERLDC informed that as per the PMU plot, the fault was cleared in 120ms.

PCC felt that on several previous occasions the LBB at 220kV Chandil was mal-operated and tripped all connected lines.

PCC advised JUSNL to check the LBB at 220kV Chandil S/s. JUSNL agreed.

2.2 Excerpts of 35th PCC

2.2.1 Total power failure at 220kV Chandil S/s of JUSNL system on 14/08/15 at 10:10hrs.



At 10:10hrs, total power failed at 220kV Chandil S/s in JUSNL system due to mal-operation of LBB relay. Following feeders from Chandil end got tripped:

Time (Hrs)	Details of tripping	Relay at local end	Relay at remote end
10:10 hrs	220kV Chandil-Ranchi	<u>At Chandil</u> Master trip relay 86	<u>At Ranchi</u> Did not trip
	220kV Chandil-Santaldih	<u>At Chandil</u> Master trip relay 86	<u>At Santaldih</u> Did not trip
	220kV Chandil-Ramchandrapur	<u>At Chandil</u> LBB relay, 86, 86X, Supervision relay	<u>At Ramchandrapur</u> NA
	132kV Ramchandrapur-Adityapur-D/C	<u>At Ramchandrapur</u> O/C, E/F	
	132kV Chandil-Hatia	<u>At Chandil</u> Did not trip	<u>At Hatia</u> Dir. E/F & O/C, trip phase ABC

- The sequences of events were initiated due to mal-operation of LBB relay at Chandil end (there was no voltage dip observed in PMU data of Ranchi S/s).
- Due to which all the other 220kV feeders i.e 220kV Chandil-Ranchi and 220kV Chandil-Santaldih line got tripped from Chandil end.
- With the tripping of all the 220kV feeders, 132kV Chandil-Hatia and 132kV Ramchandrapur-Adityapur-D/C got over loaded and tripped on actuation of Dir. E/F & O/C relay.

Points to be discussed:

- i. LBB operation at 220kV Chandil S/s.
- ii. Testing of LBB at 220kV Chandil S/s needs to be done.
- iii. Tripping of 132kV Chandil-Hatia line from Hatia end to be explained.

JUSNL may explain.

Deliberation in the meeting

JUSNL informed that

- *220kV Chandil-Ramchandrapur line was tripped from both ends at 09:55 hrs due to B-ph jumper snapping at location no 42.*
- *The LBB at 220kV Chandil S/s was triggered while trying to charge the 220kV Chandil-Ramchandrapur line from Chandil end.*
- *The LBB was checked by T&C-Alstom and found it correct.*
- *Old relays are being replaced at both ends of 220kV Chandil-Ramchandrapur line with new Micom P442 relays. The work is expected to be completed by 30th September, 2015.*

PCC felt that LBB at 220kV Chandil S/s had been maloperated during several incidences in the past and advised JUSNL to check the LBB at 220kV Chandil S/s after the installation of new relays.

JUSNL agreed.

2.2.2 Total power failure at 220kV Chandil S/s of JUSNL system on 28/08/15 at 16:05hrs.

At 16:05 hrs, total power failed at 220kV Chandil S/s in JUSNL system due to mal-operation of LBB relay. Following feeders from Chandil end got tripped:

SL No	Name of Bay/Line	Tripping Time	Closing Time	Local End Relay	Remote end Relay
1	220KV Chandil-STPS	16:05Hrs	17:33Hr s	Master Trip 86, Contact multiplier relay 86	Not Tripped

2	220KV Chandil-Ramchandrapur	16:05Hrs	17:41Hr s	Zone-4, LBB Relay	Not Tripped
3	220Kv Chandil - PGCIL	16:05Hrs	16:51Hr s	Master Trip 86	Not Tripped
4	132KV Chandil-Adityapur Ckt-I	16:05Hrs	17:48 Hrs		o/c, Zone-I, 5.9Km, Fault current B Phase 673.4Amp.Y Phase 3.185Kamp
5	132Kv Chandil-Hatia	16:05Hrs	16:33Hr s	Not Tripped	Overcurrent,86
6	132KV Ramchandrapur-Adityapur Ckt-I	16:05Hrs	16:35Hr s	Not Tripped	Overcurrent,87
7	132KV Ramchandrapur-Adityapur Ckt-II	16:05Hrs	16:45Hr s	Not Tripped	Y Phase, Zone-I, 2.978Km, fault Current R Phase 201.8Amp, Y Phase 6.522 Kamp, B Phase 359.2 Amp
8	220kv Bus Coupler at RCP	16:05Hrs	16:48 Hrs	Non directional E/F,O/C,LBB,86	

JUSNL informed that the relay at Chandil & Ramchandrapur of 220KV Chandil-Ramchandrapur Transmission line are very old (Micom P430C). Purchase order has been placed for its replacement.

Points to be discussed:

- i. LBB operation at 220kV Chandil S/s.
- ii. Tripping of 132kV lines from remote end.

JUSNL may explain.

Deliberation in the meeting

JUSNL informed that

- There was a fault in 132 kV side in Ramchandrapur/Adityapur area.
- Due to which the 132KV Ramchandrapur-Adityapur Ckt-II and 132 kV Chandil-Adityapur-I tripped on zone-1 from Adityapur end.
- 132KV Ramchandrapur-Adityapur Ckt-I tripped on over current protection due to overloading.
- Subsequently, the LBB at Chandil operated due to LBB initiation from 220 kV Chandil-Ramchandrapur line.

On enquiry, JUSNL informed that LBB time setting is 400 ms.

JUSNL could not explain the reason for LBB operation at 220kV Chandil S/s.

PCC advised the following:

- *Send the DR output files to ERPC/ERLDC within 2 days for proper analysis of the incident.*
- *Thorough checking of LBB protection at 220kV Chandil S/s.*
- *Revise the LBB time setting to standard time setting i.e. 200 ms.*


2.3 Excerpts of 36th PCC

Total power failure at 220/132 kV Hatia S/s (JUSNL) on 14/09/15 at 11:38hrs.

As per information received from JUSNL---

- The event was initiated at 11:38 hrs, due to occurrence of SLG fault (i.e Y-N) on 220kV Ranchi- Hatia S/c line which tripped from Ranchi end only.
- After tripping of the said line load at Hatia, Namkun, Gumla, Lohardanga, Daltonganj, Latehar etc. were started to being fed from Chandil & PTPS S/s through 132kV Chandil- Hatia S/C & 220kV PTPS- Hatia D/c line.
- This caused the tripping of 132kV Chandil- Hatia S/c line on operation of O/C protection.
- 220kV PTPS- Hatia D/c tripped from PTPS end on indication of earth fault.
- This led to tripping of 220kV Tenughat-PTPS S/C on overvoltage.
- It is suspected that prior to tripping of 220kV Tenughat-PTPS S/C line, fault was also being fed from 132kV PTPS- Hatia D/C (ckt-II via Kanke) caused the tripping of ckt-I on DP, Zn-II from PTPS end while 132kV Kanke- Hatia tripped from Hatia end on Z-I, DP.
- 220/132kV, 150 MVA transformer-II & III at Hatia tripped on operation of master trip and non-directional E/F relay respectively from both side.

- Thus, after tripping of existing 220kV & 132kV lines emanating from PTPS & Hatia S/s, running unit of PTPS & TTPS tripped due to loss of evacuation path.
- Due to non-availability of all 220/132kV lines from Hatia & PTPS S/s approx. 370 MW load loss along with traction power of around 30 MW was interrupted at Namkun, Gumla, Lohardanga, Daltonganj, Latehar.



The following lines got tripped during the incidence:

Time (Hrs)	Details of tripping	Relay at local end	Relay at remote end
11:38 Hrs	220kV Hatia-Ranchi S/C	At Hatia Did Not trip	At Ranchi Y-N, F.D- 133.4KM, F.C- 1.42 KA
	220kV PTPS- Hatia -I	At PTPS E/f	At Hatia Did Not Trip

Report of ERPC Protection team on un-coordinated trippings in JUSNL System

	220kV PTPS- Hatia -II	<u>At PTPS</u> E/f	<u>At Hatia</u> Did Not Trip
	220kV PTPS- TTPS S/c	<u>At PTPS</u> O/V	<u>At TTPS</u> Did Not Trip
	132kV Hatia- Chandil S/C	<u>At Hatia</u> Start ABC Phase, Tripped ABC Phase start element, O/C, E/F	<u>At Chandil</u> Did Not Trip
	132kV Hatia- PTPS - I	<u>At Hatia</u> Did Not Trip	<u>At PTPS</u> Zone-II, F.D- 33.71 KM, F.C- Ir= 377 A, Iy= 1.389 KA, Ib= 1.95 KA
	132kV Kanke- Hatia	<u>At Kanke</u> Did Not Trip	<u>At Hatia</u> Active Gr-I, Start Phase B-N, Tripped ABC start element, E/F, Z-I, Loc- XY, F.D- 10.55 KM, Fault Duration- 240.6 ms
	150 MVA T/F-II	Trip relay 86 A	
	150 MVA T/F-III	Non directional E/F	
	50 MVA T/F-I at Hatia	Trip relay 86	
	50 MVA T/F-II at Hatia	REF protection relay, HV, Trip 86, Differential Protection 87, Directional E/F, Protection 50/51 N	
	50 MVA T/F-III at Hatia	LV Trip ckt, Supervision relay, 195 ABC, LV, Relay 80 C, \$HV side 96 HV, Multiplication relay 4 HV side	
	TTPS U# 2	Electrical Jerk	
	PTPS U# 10	Electrical Jerk	
	Inland Power Ltd	Electrical Jerk	

Analysis of PMU plots:

- 10kV voltage dip has been observed in Y-Ph at 11:38:44:100hrs from the Ranchi PMU plot.
- 60A & 40A rise in Y-Ph line current of 400kV Ranchi- Sipat-I & 400kV Ranchi- Maithon-I have been observed during the said period.
- Fault clearance time was approximately 1080 ms.

JUSNL may explain the following:

- Reason for non-operation of primary and backup protection at 220 kV Hatia.
- JUSNL in their report, have mentioned that 132kV Chandil- Hatia S/c tripped from Hatia end on operation of over current protection. JUSNL may confirm whether the o/c relay installed at Hatia end are non-directional in nature. Reason for non-operation of O/C protection from Chandil end may be explained.
- Tripping of 132kV Kanke- Hatia S/c from Hatia end on indication DP, Z-I is not understood as the fault was in reverse direction from Hatia S/s. Reason for non-operation of O/C protection from Kanke end may be explained.
- After tripping of lines at Hatia, PTPS & TVNL got islanded. This could have caused tripping of 220 kV PTPS-TVNL on O/V. JUSNL may confirm furnish the stage I & II O/V settings at PTPS.

Deliberation in the meeting

JUSNL explained that—

- *There was a fault in 132kV Hatia-Kanke line due to dislocation of earth wire which came in the vicinity of R-ph at location no 13-14.*
- *The fault was identified in zone-1 distance protection from Hatia end but Kanke end failed to identify the fault.*
- *Though the fault was identified at Hatia end, the CB failed to clear the fault in time which resulted in tripping of two 220/132 kV ICTs.*
- *The ICTs would have cleared the fault but one of the ICT (i.e. 150 MVA T/F-I) failed to trip which led to tripping of 220 kV lines from remote end.*
- *JUSNL explained the following:*

<i>Sl. No.</i>	<i>Details of tripping</i>	<i>Reason for Tripping</i>
1.	<i>132kV Patratu-Hatia line was tripped from Patratu end on zone 2 distance protection.</i>	<i>It was understood that even the fault in 132kV Hatia-Kanke line was identified in zone 1 from Hatia end, the CB was failed to clear the fault</i>

		<i>immediately. There may be delayed CB operation at Hatia end which resulted in tripping of 132kV Patratu-Hatia line from Patratu end on zone 2.</i>
2.	<i>132kV Chandil-Hatia S/C line was tripped from Hatia end on O/C protection.</i>	<i>JUSNL informed that P442 relay is installed at both ends of the line and the time setting at Chandil end is 1.5 sec and Hatia end is 1.2 sec. The line was overloaded and tripped from Hatia end as the time setting is less than Chandil end.</i> <i>PCC felt that Hatia end should not be tripped as the power flow was in reverse direction.</i>
3.	<ul style="list-style-type: none">• <i>220kV Hatia- Ranchi S/C tripped from Ranchi end</i>• <i>220kV PTPS- Hatia -I & II tripped from PTPS end</i>	<i>JUSNL explained that two 220/132kV ICTs were tripped at Hatia but third ICT failed to trip, which resulted in tripping of these 220kV lines from Remote end.</i>
4.	<i>220kV PTPS- TTPS tripped from PTPS on O/V protection.</i>	<i>JUSNL explained that since no evacuation path was available for PTPS and TTPS generators, over voltage build up and the line got tripped on O/V protection.</i>


After detailed deliberation, PCC advised JUSNL to check the following and report to ERPC/ERLDC:

1. *The main and backup protection of 132kV Hatia-Kanke line at 132kV Kanke end needs to be tested and JUSNL should find out why the fault was not detected from Kanke end.*
2. *CB of 132kV Hatia-Kanke line at 132kV Hatia end should be tested.*
3. *Protection system of 220/132kV, 150 MVA T/F-I at 220 kV Hatia to be tested.*
4. *The directional feature of over current protection of 132kV Chandil-Hatia S/C at both end to be verified.*
5. *JUSNL was advised to collect the tripping details of ICTs and generators at PTPS.*

2.4 Excerpts of minutes of 37th PCC

2.4.1 Repeated Disturbances at 220kV Chandil S/s of JUSNL System.

1. Total power failure at 220kV Chandil S/s of JUSNL system on 01/10/15 at 10:50hrs



Total power failed at 220kV Chandil S/s on 01/10/15 at 10:50 hrs, due to tripping of 4x100MVA ICTs on O/C, B-Ph from LV side. The following elements got tripped:

- 4x100MVA ICT on O/C, B-Ph , Trip on LV side
- 220kV Chandil-Santaldih (tripped from Chandil end only by Master Trip Relay, Supervision 85/86)
- 132 kV Chandil- Rajkharsawan
- 132 kV Chandil -Adityapur – Rajkharsawan
- 132 KV Chandil-Hatia
- 132 kV Ramchandrapur- Adityapur D/C

Analysis of PMU plots:

- An observation of PMU plot of Ranchi Shows, there was a 6kV dip in Y-Ph voltage and 4 kV dip in B phase voltage during the incident.
- 20 A rise in B-Ph line current of 400kV Ranchi- Maithon has been observed during the said period.
- Fault persistence time was approx. 1000 ms.

Due to non-availability detail tripping report along with DR and EL records from JUSNL, the exact sequence/reason of the above tripping cannot be established.

JUSNL may explain.

Deliberation in the meeting

JUSNL explained with the given diagram that---

- *The above tripping occurred due to B-Ø conductor snapping between location no 2 & 3 of 132kV Adityapur – Ushamartin circuit-I.*
- *Though the 132kV Adityapur – Ushamartin circuit-I tripped from both the end, the fault got extended due to delayed tripping/clearance.*
- *Subsequently, the following elements tripped:*

At Adityapur GSS:

- a) *132 KV Adityapur – Ushamartin circuit –I tripped both end.*
- b) *132 KV Adityapur – Ushamartin circuit –II tripped at Adityapur end.*
- c) *132/33KV 50 MVA Transformer I & II tripped.*

At Ramchandrapur GSS:

- a) *132KV Ramchandrapur-Adityapur circuit-1 tripped at Ramchandrapur end.*
- b) *132 KV Ramchandra-Adiyapur circuit-2 tripped at Adityapur end.*


At Chandil GSS:

- a) *220KV Chandil -STPS T/L Tripped at chandil end.*
- b) *132kv Chandil-Adityapur Tripped at Chandil end.*
- c) *220/132kv 100MVA transformer I, II, III &IV all are triped.*

- *The details of relay indications as furnished by JUSNL are as follows:*

Report of ERPC Protection team on un-coordinated trippings in JUSNL System

Sl.No.	Name of Line	Local end relay	Remote End relay	Remarks
1.	220kV Chandil- STPS T/L	86,95/86	Not tripped	Chandil end- SEL 311C STPS-P442
2.	220kV Chandil- Ramchandrapur	Normal	Normal	Chandil end- Micom P430C RCP end-P430C
3.	220KV Chandil-PGCIL Ranchi.	Normal	Normal	Chandil-SEL 311C
4	132KV Chandil-Adiyapur.	Tripping relay 186	Not tripped	Chandil-P430C Adpur-P441
5	100MVA, 220/132 KvTr.I at Chandil	B Ø , O/C (LV side trip)		
6	100MVA, 220/132 KvTr.II at Chandil	B Ø , O/C (Both side trip)		
7	100MVA, 220/132 KvTr.III at Chandil	B Ø , O/C (LV side trip)		
8	100MVA , 220/132 KvTr.IV at Chandil	Master trip relay 86HV, Diff.operated LV-O/C (Both side trip)		
5	132KV Ramchandrapur- AdityapurCkt-I	12km,Z-III	Not tripped	RCP- P442 Adpur-P442
6	132KV Ramchandrapur- AdityapurCkt-II	Not tripped	O/C & E/F	RCP-P442 Adpur-P442
7	132kv Adityapur- Ushamartinckt.- I	86,O/C,E/F,A/ R relay lock out	O/C & E/F Fault this line BØ	Adpur-Eusion Reyrolle UML- Eusion Reyrolle
8	132kv Adityapur- Ushamartinckt.-II	O/C & E/F	Not tripped	Adpur-P441 UML-P441
9	50 MVA,132/33Kv Tr.no - I at Adpur	O/C,86 (HV & LV both side triped)		
10	50 MVA, 132/33 Kv Tr.no - II at Adpur	O/C, 86 (HV & LV both side triped)		



However, JUSNL failed to explain the tripping sequence & exact cause for un-coordinated trippings in proper manner and also the protection available for each element involved in the said disturbance.

Regarding submission of DR/EL, JUSNL informed that the DR of the relays could not be downloaded as the relays were old and interfacing software is also not available with them. It was further informed that the old relays of Chandil S/s have been replaced with new relays.

After detailed deliberation, PCC felt that JUSNL should carry out the detailed analysis for such un-coordinated trippings (element-wise) and place the report along with DR/EL inputs.

2.4.2 Total power failure at 220kV Chandil S/s of JUSNL system on 02/10/15 at 12:44hrs

At 12:42hrs, total power failed at 220kV Chandil S/s due to bursting of B-Ph Jumper of wave trap of 132kV Chandil- Rajkharsawn S/C at Chandil end. The following elements were tripped:

Time (Hrs)	Details of tripping	Relay at local end	Relay at remote end
12:42hrs	132kV Chandil-Rajkharswan S/C	<u>At Chandil</u> Tripping relay Start, O/C start, E/F start	<u>At Rajkharswan</u> Did Not Trip
	100 MVA, 220/132 kV ICT - I at Chandil	Tripped on O/C from LV side	
	100 MVA, 220/132 kV ICT-II at Chandil	Tripped on O/C from HV side	
	100 MVA, 220/132 kV ICT-III at Chandil	Tripped on O/C from LV side	
	100 MVA, 220/132 kV ICT-IV at Chandil	Master Trip relay, Trip ckt supervision relay, LV side, Non directional E/F	

Analysis of PMU plots:

- An observation of PMU plot of Ranchi Shows that there was a 10kV dip in B-Ph voltage during the incident.
- 40 A rise in B-Ph line current of 400kV Ranchi- Sipat- I have been observed during the said period.
- Fault persistence time was approx. 380 ms.

Detailed Analysis:

It is suspected that non opening/delayed opening of the breaker at Chandil end for 132kV Chandil- Rajkharsawn S/c line could have caused the tripping of all the four 220/132kV, 100 MVA ATRs at Chandil end on operation of Overcurrent protection. Thus after tripping of all the 220/132kV, 100MVA, ATRs at Chandil approx. 190MW load loss occurred at Chandil S/s including traction power of 50 MW at Golmuri and Manique.

JUSNL may explain.

Deliberation in the meeting

JUSNL informed that---

- *Total power failed at 220 kV Chandil S/S due to bursting of B-phase Jumper of wave trap of 132 kV Chandil-Rajkharsawn S/C at Chandil end.*

- Relay indication for tripping was there but Circuit breaker of 132 kV Chandil-Rajkharsawn S/C line failed to trip at Chandil end.
- This led to tripping of all the four 220/132 kV ICTs at Chandil S/s.
- Breaker tripping of 132 kV Chandil-Rajkharsawn S/C line was checked and now it is all right.

2.4.3 Total power failure at 220kV Chandil S/s of JUSNL system on 21/10/15 at 00:15hrs

Total power failed at 220kV Chandil S/s at 00:15 hrs, due to bursting of R-Ph CT of 220/132kV ATR-I at Chandil on 132kV side. The following elements were tripped:

Time (Hrs)	Details of tripping	Relay at local end	Relay at remote end
00:15 hrs	220 KV Chandil -Santaldih S/C	<u>AT Chandil</u> Did not Trip	<u>At Santaldih</u> R-Ph, O/C, E/F
	220 KV Chandil -Ranchi S/C	<u>AT Chandil</u> Master Trip Relay	<u>At Ranchi</u> NA
	220 KV Chandil – Ramchandrapur S/C	<u>AT Chandil</u> Master Trip Relay	<u>At Ramchandrapur</u> E/f , O/C, Tripping relay VAJ
	132kV Ramchandrapur- Adityapur--I	<u>At Ramchandrapur</u> Power Swing, E/F, O/C, Tripping relay type VAJ	<u>At Adityapur</u> Did not Trip
	132kV Ramchandrapur- Adityapur--II	<u>At Ramchandrapur</u> Did not Trip	<u>At Adityapur</u> E/f, O/C
	132 KV Chandil – Adityapur S/C	<u>AT Chandil</u> Did not Trip	<u>At Adityapur</u> E/f, O/C
	132 KV Chandil – Rajkharswan S/C	<u>AT Chandil</u> Did not Trip	<u>AT Rajkharswan</u> O/C
	220/132kV , 100 MVA ATR-I	<u>At HV</u> E/F	<u>At LV</u> E/F, O/C
	220/132kV , 100 MVA ATR-II	<u>At HV</u> E/F	<u>At LV</u> O/C
	220/132kV , 100 MVA ATR-IV	<u>At HV</u> Did not Trip	<u>At LV</u> E/F, Master trip

Analysis of PMU plots:

- An observation of PMU plot of Ranchi Shows, there was a 8kV dip in R-Ph voltage and 6 kV dip in Y phase voltage during the incident.
- 70 A rise in R-Ph line current of 400kV Ranchi- Maithon has been observed during the said period.
- Fault persistence time was approx. 540 ms.

Detailed analysis:

It is suspected that there was a delayed opening of the breaker either at HV or LV side for ATR-I and it caused the tripping of other elements. Due to above mentioned tripping approx. 320 MW load loss occurred at Chandil & their surrounded area including traction loss of 50 MW at Rajkharswan, Goelkera, Kendposi, Chakardharpur, Golmuri, and Manique.

JUSNL may explain the following:

- Any delayed operation of CB of 220/132kV ATR-I.
- Tripping of 132kV Ramchandrapur- Adityapur—II from Adityapur on E/F, O/C

Deliberation in the meeting

JUSNL informed that---

- *There was a fault at 220kV Chandil S/s due to bursting of R-Ph CT of 220/132 kV ATR-I on 132kV side.*
- *Due to delayed clearance of fault by ATR-I the two other 220/132 kV ATRs got tripped at Chandil S/s.*
- *220 kV as well as 132 kV feeders of Chandil and other 132 kV feeders also got tripped.*

However, JUSNL failed to explain the tripping sequence & exact cause for un-coordinated trippings in proper manner and also the protection available for each element involved in the said disturbance.

Regarding submission of DR/EL, JUSNL informed that the DR of the relays could not be downloaded as the relays were old and interfacing software is also not available. It was further informed that the old relays of Chandil S/s have been replaced with new relays.

After detailed deliberation, PCC felt that JUSNL should carry out the detailed analysis for such un-coordinated trippings (element-wise) and place the report along with DR/EL inputs.

2.4.4 Disturbance at 220kV Ramchandrapur S/s on 20/10/15 at 05:38hrs

At 05:38 hrs, 400/220KV, 315 MVA ICT-I & II tripped at Ramchandrapur due to busting of R-phase CT of 220KV Ramchandrapur-Chandil line at Ramchandrapur end. The Following lines tripped:

Time (Hrs)	Details of tripping	Relay at local end	Relay at remote end
05:36 hrs	220 KV Ramchandrapur - Chandil S/C	<u>At Ramchandrapur</u> Zone-III	<u>At Chandil</u> Zone-III, Master trip relay
	220kV Ramchandrapur- Joda S/c	<u>At Ramchandrapur</u> NA	<u>At Joda</u> NA
	400/220kV ICT-I at Jamshedpur	<u>At Jamshedpur</u> O/c	<u>At</u> <u>Ramchandrapur</u> Master Trip
	400/220kV ICT- II at Jamshedpur	<u>At Jamshedpur</u> Back up O/c, R-ph	<u>At</u> <u>Ramchandrapur</u> Master Trip
	132kV Chandil- Adityapur	<u>At Chandil</u> Trip relay 186	<u>At Adityapur</u> Did Not Trip
	132kV Chandil- Rajkharwan S/c	<u>At Chandil</u> Back up E/F, O/C	<u>At Rajkharwan</u> Did Not Trip
	132kV Ramchandrapur- Adityapur-I	<u>At Ramchandrapur</u> Did Not Trip	<u>At Adityapur</u> E/F, O/C
	132kV Ramchandrapur- Adityapur-II	<u>At Ramchandrapur</u> Did Not Trip	<u>At Adityapur</u> E/F, O/C
	220/132kV , 150 MVA ATR-I at RCP	O/C	

Analysis of PMU plots:

- An observation of PMU plot of Jamshedpur Shows, there was a 50kV dip in R-Ph voltage during the incident.
- 540 A rise in R-Ph line current of 400kV Jamshedpur- Chaibasa has been observed during the said period.
- Fault persistence time was approx. 40 ms.

Detailed analysis:

Fault was in 220KV Ramchandrapur-Chandil line close to Ramchandrapur end. Due delayed fault clearance from Ramchandrapur end, 400/220kV ICTs at Jamshedpur, 220/132kV , 150 MVA ATR-I at RCP and 132kV Ramchandrapur- Adityapur-I & II got tripped.

JUSNL may explain the following:

- Tripping of 220 KV Ramchandrapur -Chandil S/C line from both ends on zone 3 distance protection
- Tripping details of 220kV Ramchandrapur- Joda S/c
- Tripping of 132kV Chandil- Adityapur and 132kV Chandil- Rajkharswan S/c

Deliberation in the meeting

JUSNL informed that---

- *There was a fault at 220kV Ramchandrapur S/S due to bursting of R-phase CT of 220kV Ramchandrapur-Chandil line.*
- *Due to delayed fault clearance from Ramchandrapur end, 400/220kV ICTs at Jamshedpur, 220/132kV , 150 MVA ATR-I at Ramchandrapur and 132kV Ramchandrapur- Adityapur-I & II got tripped.*

However, JUSNL failed to explain the tripping sequence & exact cause for un-coordinated trippings in proper manner and also the protection available for each element involved in the said disturbance.

Regarding submission of DR/EL, JUSNL informed that the DR of the relays could not be downloaded as the relays were old and interfacing software is also not available.

After detailed deliberation, PCC felt that JUSNL should carry out the detailed analysis for such un-coordinated trippings (element-wise) and place the report along with DR/EL inputs.

For the disturbances in JUSNL system as given under Item No B.1 (1 to 3) & B.2, PCC took serious note of the non compliance of clause 5.2 (r) of IEGC as no details were made available to ERPC/ERLDC.

It was informed that the issue was also discussed in 31st TCC/ERPC wherein the board with a serious note formed a committee of following protection engineers to review the situation:

- Shri Sabyasachi Roy, CE, WBSETCL,
- Shri L Nayak, GM, OPTCL
- Shri Jayanta Datta, SE, DVC
- Shri Surajit Bannerjee, DGM, ERLDC,
- Shri Jiten Das, Asst GM, PGCIL (Later replaced by Mr. S.K.Singh, AGM, PGCIL)
- Shri S. B. Prasad, ESE, BSPTCL
- Shri Vidyasagar Singh, ESE, JUSNL

Board further advised JUSNL to attend the PCC with all details. But unfortunately details were not submitted and members from JUSNL for the committee formed as above failed to attend the PCC.

PCC took serious note of this and advised JUSNL to clarify their position of not submitting DR/EL/SOE for the disturbances mentioned above. Further, PCC also needs the following information in respect of Chandil, Ramchandrapur, Adityapur and adjoining substations in Jharkhand.

3.0 Sequence of Events adopted by the Committee:

3.1 AS PER PONT NO. :- 1 OF METHODOLOGY

ERPC convened a special meeting of Committee members on 8.12.2015 and the following information's in respect of Chandil, Ramchandrapur and Adityapur and adjoining substations in Jharkhand were requested to be submitted by JUSNL at ERPC secretariat :

- (i) SLD of all Sub-Stations (with CT).
- (ii) Year of manufacture of all equipment's.
- (iii) Comprehensive CT details along with name plate (with connected/ adopted ratio)
- (iv) VT details.
- (v) Fault Level 3-phase as well as 1-phase (line length, conductor details and transformer details for computing the fault level).
- (vi) Transformer details (Rating and % impedance)
- (vii) Availability of Auto – Reclose scheme.
- (viii) Availability of Carrier Protection.
- (ix) Availability of Bus- Differential and LBB Protection.
- (x) Junction Box details.
- (xi) Cable details used for CT connections (Cross section/core of cable, Junction Box details and length of cable between JB and Control Room)
- (xii) Grid Earthing Resistance (With latest Test Report).
- (xiii) Breaker details (operating Time).
- (xiv) CT/PT earthing details.
- (xv) Relay details (Relay type, model, settings, manufacturing, and basis of settings).
- (xvi) Scheme adopted for protection settings for lines and transformers.
- (xvii) DC system details with charger and Battery.

The relevant data's for Chandil Ramchandrapur and Adityapur S/Stns of JUSNL were submitted to ERPC after which members of the committee scrutinised the data's. Discrepancies and missing data's were pointed out to the JUSNL members attending PCC meetings and subsequently they complied.

3.2 AS PER POINT NO. :- 2 OF METHODOLOGY

Finally the complete and corrected data was available for scrutiny and the same was compiled individually by the members of the committee.

3.3 AS PER POINT NO. :- 3 OF METHODOLOGY

On the basis of scrutinised data's a Special Protection Co-ordination Meeting "To review the data submitted by JUSNL and BSPTCL and also to discuss the roadmap for site visit" was convened at ERPC, Kolkata on 29.03.2016. Threadbare discussions took place between the members and representatives of JUSNL and BSPTCL.

Suggestions, Deliberations and recommendations against individual substations are recorded against individual sub-stations as given below.

3.4 AS PER PONT NO. :- 4 OF METHODOLOGY

Members of the Committee visited the following Sub-Stations of JUSNL to have a detailed review their system and practices followed :-

- (i) 220KV Ramchandrapur and 132KV Adityapur GSS on 11.05.15.
- (ii) 220KV Chandil GSS on 12.05.16.

4.0 FINDINGS OF THE COMMITTEE.


- A. Scrutiny of the Submitted data's discussed in the Special Protection Co-ordination Meeting at ERPC, Kolkata on 29.03.2016. in a composite way at Sub-station/ Bay level.**

AND

- B. Findings of other aspects related to healthy protection system during the visits to the Sub-Stations**

4.1 Findings of 220KV / 132KV CHANDIL S/STN

4.1.1 SINGLE LINE DIAGRAM



A. Scrutiny of the submitted data and deliberation of JUSNL in the meeting on 29.03.16

i. Study of CT details reveal that there are many bays of 220kV & 132 kV bay where the CTs are more than 25 years old.

ii. Tan delta & characteristics of the CTs are required to be re-checked.

BREAKERS HAVE ALREADY BEEN CHANGED

iii. 220kV & 132 kV BUS PT is also more than 25 years old and the accuracy class of 132kV PT is 5 while one of the 220kV PT is 1/5.

iv. DP setting not as per ERPC philosophy.

v. Differential relay not numerical.

vi. Earth resistance high: 2Ω

vii. DC positive earthed.

Deliberation in the meeting

JUSNL clarified that—

- *There are many C.Ts which are more than 25 years old and Tan delta characteristics is also not satisfactory as such these C.T's will be replaced after its procurement.*
- *However tan delta test & characteristics of the other C.Ts will be carried out by outsourcing.*
- *One set of 220 kV P.T (accuracy class-0.2) has already been replaced and other sets of 220 kV P.T will be replaced after procurement. One set 132 kV P.T will be also replaced after procurement.*
- *At present only ICT-IV is having REF protection and rest old ICT- I, II & III are not incorporated with REF protection.*
- *DGA test for ICTs had been carried out 4-5 years back and Transformer oil was also replaced once.*

- *Work for relay coordination as per the revised philosophy of ERPC has been awarded to AREVA and it will be carried out soon.*
- *Supply of Second DC supply source is awaited.*

During discussion it was emerged that the in JUSNL system CTs are in bus side instead which should be on line side as per regular practice.

JUSNL informed that in their sub-stations are following these design since inception and this is being taken care by transferring the protection from line CB to the Bus-coupler CB. But their transformers need not to be transferred as they have adequate number of ICTs.

B. Findings during the visit. (Dated :- 12.05.16)

- i. One Number Numerical Distance Protection Relay has been used for all 220KV and 132KV Feeders.
- ii. The Over current and Earth fault protection has been provided in the same Numerical Distance Protection relay for these 220KV Feeders. This is not as per the PART 3 OF CEA (TECHNICAL STANDARDS FOR CONNECTIVITY OF THE GRID) REGULATION, 2007, wherein it is clearly mentioned that 220KV Transmission Lines should have both MAIN 1 and MAIN 2 Distance Protection Schemes applicable for New Sub-Stations and for the Old Sub-Stations, it should be implemented in a reasonable time frame.
- iii. For O/C protection, the Definite Time Delay (100-150mSecs) has been incorporated for a Pick up value > 2 amps(secondry). The Non-Directional feature has been used in this relay.
- iv. The Overcurrent and Earth Fault Protection has been provided in the same Numerical Distance Relay for 132KV Feeders. As per the standard practice, the Distance Protection and the Directional O/C and Earth Fault protection should be two separate relays as main and back-up.

- v. ICT protection is not adequate. Old relays need to be replaced. REF protection needs to be provided.
- vi. No bus bar protection is available. The LBB relays are provided for bays but detail scheme could not be traced. No separate trip relay found for LBB protection (This may cause unwanted/un-coordinated tripping. Which happened in some earlier cases also). Total LBB protection scheme need to be reviewed.
- vii. CTJB AND PTJB are in very poor condition with Terminal Blocks weird in different occasions. Replacement of the CTJB and PTJB are to be carried out and proper earthing of the boxes are to be ensured.
- viii. The D.C. Negative Earth was persisting and the measured value during the visits are as follows:-

D.C. +ve to -ve :- 218 Volt.

D.C. +ve to earth :- 185 volts.

D.C. -ve to earth :- 29 volts

The above results indicate that D.C. system is not healthy.

- ix. Annunciations / Indication system is not up to the mark of any important Grid elements. Many of them are not functioning properly.
- x. Electromagnetic relays for Over current/ Earth fault protection for some of the 220kV,132kV lines and transformers are present in the Panel where the only NUMERICAL RELAY has been installed and connected.


DUE TO NON-AVAILABILITY OF CONTROL AND PROTECTION DRAWINGS OF THE EXISTING SCHEME IN THE SUB-STATION, THE USAGE OF THESE RELAYS COULD NOT BE ASCERTAINED.

PROPER SCHEMES WITH REMOVAL OF REDUNDANT RELAYS AND PROPER WIRING AS PER THE EXISTING SCHEME SHOULD BE IMPLEMENTED TO MITIGATE THE ISSUE.

- xi. Absence of certain basic functions as PT FUSE FAILURE for numerical Distance Protection Relay.
- xii. Absence of Functional Demarcation of LED in the Numerical Relay.
- xiii. The DC supply to CR panels of 220KV Chandil GSS is only from one source. Two source of DC may be provided to CR panels for 220kV and above system for security and redundancy.

4.2 Findings of 220KV/132KV RAMCHANDRAPUR S/STN

4.2.1 SINGLE LINE DIAGRAM



A. Scrutiny of the submitted data and deliberation of JUSNL in the meeting on 29.03.16

- i. The CT rating of 132kV side of 150 MVA transformer is set at 600/1 which seems on the lower side. It requires further analysis and review
- ii. There are only single trip coil in the breakers as seen from the results of Closing and Tripping time in 220kV breakers. However it was latter clarified that Double trip coils are available for the 220KV breakers.
- iii. Provision of two separate DC as Main DC#1 and Main DC#2 for individual bays are to be studied for redundancy.
- iv. Breaker trip time of ICT 220kV Breaker: Y pole- 589 ms, B Pole-589 ms which is very high.
- v. Here also the bay CTs which are more than 25 years requires the characteristics of the CT to be analysed.
- vi. DP setting not as per ERPC philosophy.
- vii. Differential relay not numerical.
- viii. Earth resistance high: 2Ω
- ix. DC positive earthed.

Deliberation in the meeting

JUSNL submitted the SLD of Ramchandrapur GSS and updated the following:

- *220 kV Breaker of Ramchandrapur G/S/S will be checked for operation timing of trip coil-1 trip coil-2 by suitable agency.*

- *Purchase order for second set of sub-station batteries set with charger has already been placed and it will be commissioned after delivery.*
- *Breaker trip time of ICT 220 kV breaker will be rechecked and corrective measures to be taken if required.*
- *There are some C.Ts which are 25 years old their tan delta characteristics and other specifications like knee voltage and ratio errors will be checked very soon with the help of suitable agency.*
- *There are two trip-coil in the breakers but during testing the agency missed to test the second coil as they could not trace the contact of second coil. The same will be traced and tested*

B. Findings during the visit (DATED 11.05.16)

- i. One Number Numerical Distance Protection Relay has been used for 220KV and 132KV Feeders.
- ii. The Over current and Earth fault protection has been provided in the same Numerical Distance Protection relay for these 220KV Feeders. This is not as per the PART 3 OF CEA (TECHNICAL STANDARDS FOR CONNECTIVITY OF THE GRID) REGULATION, 2007, wherein it is clearly mentioned that 220KV Transmission Lines should have both MAIN 1 and MAIN 2 Distance Protection Schemes applicable for New Sub-Stations and for the Old Sub-Stations, it should be implemented in a reasonable time frame.
- iii. For O/C protection, the Definite Time Delay (100-150mSecs) has been incorporated for a Pick up value > 2 amps(secondary). The Non-Directional feature has been used in this relay.
- iv. The Overcurrent and Earth Fault Protection has been provided in the same Numerical Distance Relay for 132KV Feeders. As per the standard practice, the Distance Protection and the Directional O/C and Earth Fault protection should be two separate relays as main and back-up.

- v. Non-directional O/C relay has been used for 220/132 kV ICT- I&II which needs to be replaced with directional relays. ICT protection needs to be reviewed. Old relays need to be replaced.
- vi. GE make Numerical centralised bus bar system with LBB, DR & Event recording facilities are available. **However the complete scheme drawings were not available by which it could be adjudged as to which protections are used and in service.**
- vii. **P122-Non-directional O/C has been used for LBB but the same needs to be put in service after testing. No scheme drawings were available.**
- viii. **Trip coil supervision and its healthy indications was found only for Bus-coupler (Out of six only one is healthy).**
- ix. The D.C. Negative Earth was persisting and the measured value during the visits are as follows:-
 - D.C. +ve to -ve :- 217 Volt.
 - D.C. +ve to earth :- 141 volts.
 - D.C. -ve to earth :- 76 volts

The above results indicate that D.C. -ve is resistively earthed.

- x. Although provided, indications in the CONTROL PANEL for isolator, breaker, CB spring charge, gas pressure, Trip transfer etc. was not glowing in some of the Line Bays.
- xi. Annunciations in most of the cases were out of order.
- xii. Electromagnetic relays for Over current/ Earth fault protection for some of the 220kV,132kV lines and transformers are present in the Panel where the only NUMERICAL RELAY has been installed and connected.


DUE TO NON-AVAILABILITY OF CONTROL AND PROTECTION DRAWINGS OF THE EXISTING SCHEME IN THE SUB-STATION, THE USAGE OF THESE RELAYS COULD NOT BE ASCERTAINED.

PROPER SCHEMES WITH REMOVAL OF REDUNDANT RELAYS AND PROPER WIRING AS PER THE EXISTING SCHEME SHOULD BE IMPLEMENTED TO MITIGATE THE ISSUE.

- xiii. Absence of certain basic functions as PT FUSE FAILURE for numerical Distance Protection Relay.
- xiv. Absence of Functional Demarcation of LED in the Numerical Relay.
- xv. CTJB AND PTJB OF 132KV Switchyard are in very poor condition with Terminal Blocks weird in different occasions. Replacement of the CTJB and PTJB are to be carried out and proper earthing of the boxes are to be ensured.
- xvi. The DC supply to CR panels of 220KV Ramchandrapur GSS is only from one source. Two source of DC may be provided to CR panels for 220kV and above system for security and redundancy.
- xvii. The Control Room cooling for Ramchandrapur GSS was found inadequate. The Air conditioning system may be made available in the Substation control rooms for temperature and dust control which will improve the operation of protective relays and meters.
- xviii. The transformer differential protection in ATR # 1 and ATR # 2 are DTH 31 (electromechanical) while in Transformer # 3 it is numerical based Duo – Bias relay.

4.3 Findings of 132KV ADITYAPUR S/STN

4.3.1 SINGLE LINE DIAGRAM



A. Scrutiny of the submitted data and deliberation of JUSNL in the meeting on 29.03.16

- i. Breaker time test result not provided.
- ii. Distance Protection with O/C & E/F used in AREVA make P441 relay. Separate back up protection relay was suggested.
- iii. Distance Protection setting not as per ERPC philosophy.
- iv. Differential relay used for Transformers were not of Numerical type.
- v. DC negative is earthed.
- vi. Only One trip coil time test results have been provided for 132kV CB.

vii. JUSNL submitted the Breaker time test result during the meeting

- There are two trip-coil in the breakers but during testing the agency missed to test the second coil as they could not trace the contact of second coil. The same will be traced and tested.

B. Findings during the visit (DATED 11.05.16)

- i. One Number Numerical Distance Protection Relay has been used for 132KV Feeders.
- ii. For O/C protection, the Definite Time Delay (200-250mSecs) has been incorporated for a Pick up value > 1.3 -1.5. The Non-Directional feature has been used in this relay.
- iii. The Overcurrent and Earth Fault Protection has been provided in the same Numerical Distance Relay for 132KV Feeders. As per the standard practice, the Distance Protection and the Directional O/C and Earth Fault protection should be two separate relays as main and back-up.
- iv. Regarding Transformer Protection :-
 - a. 50 MVA Transformer I&II- No REF on either HV or LV side
 - b. Transformer -III- UE make very old relay which needs to be replaced.
 - c. Transformer IV:- only LV REF is not available
- v. The D.C. Negative Earth was persisting and the measured value during the visits are as follows:-

D.C. +ve to -ve :-	250 Volt.
D.C. +ve to earth :-	246 volts.
D.C. -ve to earth :-	3 volts

The above results indicate that D.C. -ve is earthed.

- vi. Although provided, indications in the CONTROL PANEL for isolator, breaker, CB spring charge, gas pressure, Trip transfer etc. was not glowing in some of the Line Bays.
- vii. Annunciations in most of the cases were out of order.
- viii. Except Transformer -IV, provision of Trip Coil Supervision could not be ascertained as there was no schematic drawing available in the Sub-Station.
- ix. Electromagnetic relays for Over current/ Earth fault protection for some of the 132kV lines and transformers are present in the Panel where the only NUMERICAL RELAY has been installed and connected.

DUE TO NON-AVAILABILITY OF CONTROL AND PROTECTION DRAWINGS OF THE EXISTING SCHEME IN THE SUB-STATION, THE USAGE OF THESE RELAYS COULD NOT BE ASCERTAINED.

PROPER SCHEMES WITH REMOVAL OF REDUNDANT RELAYS AND PROPER WIRING AS PER THE EXISTING SCHEME SHOULD BE IMPLEMENTED TO MITIGATE THE ISSUE.

- x. Absence of certain basic functions as PT FUSE FAILURE for numerical Distance Protection Relay.
- xi. Absence of Functional Demarcation of LED in the Numerical Relay.
- xii. CTJB AND PTJB OF 132KV Switchyard are in very poor condition with Terminal Blocks weird in different occasions. Replacement of the CTJB and PTJB are to be carried out and proper earthing of the boxes are to be ensured.

4.4 COMMON ISSUES (KNEE PT VOLTAGE and RCT not provided) discussed in the meeting on 29.03.16

- i. Earth resistance values provided have been found to be 2 ohm.
--Improvement of these values and the values more than 1 have to be reduced to less than 1 ohm.
- ii. DC system of all the three sub-stations are to be reviewed

Results signifies that -ve is more or less earthed.

DC earthing is the root of many mal-operation and mal-tripping which has to be addressed.
- iii. Auto reclosure and carrier is not active. This has to be brought to service.

Deliberation in the meeting

JUSNL informed that following actions are being taken to resolve the above common issues:

- *D.C system of all three sub-stations will be reviewed and necessary rectification work will be carried out.*
- *Auto reclose of 220 kV Chandil-Ramchandrapur, 220 Kv Chandil-PGCIL had been make active and it is in service.*
- *Auto reclose of 220 kV Chandil-STPS has done at Chandil end PLCC panel has also checked and terminated.*
- *Auto reclose of 220 kV Ramchandrapur-JODA has done at Ramchandrapur end and PLCC panel has also checked and terminated at RCP end. Both will be enabled in service after installation of CVT and PLCC panel at remote end i.e. STPS end and JODA end. Hence they requested to take up the issue with consultation of ULDC, JUSNL and with the coordinator STPS and JODA for restoring the PLCC scheme of both transmission lines.*

4.5 GENERAL OBSERVATION DURING THE VISIT TO THE SUB-STATIONS

4.5.1 CT ARRANGEMENT:

In many of the Sub-Stations the CT's are placed in the BUS SIDE. While diverting any line through the Bus Coupler, proper setting of the Relays are to be implemented in Distance Protection Relay of Bus Coupler (with selectable group setting through switch) so that isolation in same coordinated manner is assured. Protection Transfer during Diversion of Transformer through Bus coupler also need to be taken care. The relocation of CTs may be considered for security & availability.

4.5.2 CTJB, PTJB, ISOLATOR CONTROL CUBICLE:-

The Junction Boxes should be repaired, with proper gasket arrangement in the cover to avoid ingress of water and dust. The Junction box earthing & CT PT star point earthing should be made with the earth flat instead of the structure.

4.5.3 OTHER OBSERVATIONS:-

1. Grid Earth Resistance value should be reduced in Adityapur & Ramchandrapur S/Stn.
2. DC earth fault observed in all the substations need to be traced and removed.
3. Adityapur switchyard need to be cleaned and weeds to be cleared to avoid fire hazard.
4. Auto reclosure and carrier is not in service for 220KV Transmission Line at Chandil and Ramchandrapur S/Stn. This has to be brought to service.

5.0 Root Cause Analysis:

Apparently the cause of such types of tripping could be attributed to the following :-

- (I) Absence of appropriate setting philosophy for the 220KV/132KV lines wherein Non-Directional O/C protection has been used with improper characteristics which definitely lead to un-coordinated trippings in system.
- (ii) In many of the cases absence of basic functions as PT fuse failure for distance Protection Relay may be enabled, but indication and annunciation was not available. So such serious events may be unnoticed during real time operation. This was observed in one of the Fault records of a line provided wherein the FUSE FAILURE condition was persisting in the pre-fault condition also.
- (iii) Since only one (1) Numerical based Distance Protection Relay is used for transmission lines for both Distance and Back-up function, non-availability of this relay may keep the line unprotected which may cause such types of mal-tripping.
- (iv) DC earthing is a menace to Protection system and on many occasions spurious tripping have occurred due to this earthing. Hence this has to be removed at the very first instant.
- (v) Auto – reclose and Carrier is not available for 220KV system for better protection management.

- (vi) Certain intricate Operational procedures like hooking a Transmission line through the TRANSFER BUS, BUS PT shutdown of a Sub-Station, Transformer transferred through 220/132KV Bus Coupler where LINE SIDE CT is not available etc. require certain modifications in relay settings and scheme which are to be implemented before the commencement of the process. Any shortcoming in these may also lead to cascaded tripping in case of a Fault in the transmission lines during such period of time.
- (vii) Electromagnetic relays for Overcurrent and Earth Fault protection for 220KV and 132KV Lines have been used. Annual testing of these relays to ascertain its proper operation should be carried out. However TEST TAGS indicating the last date of testing of the all the RELAYS including the Numerical ones may be followed as better practice.
- (viii) Non-availability of Proper Indications in the Relay and annunciations/ indication sometimes deter the Operation personals from taking corrective actions at a proper juncture leading to subsequent cascaded tripping during actual faults.

6.0 Recommendations:-

6.1 During the meeting on 29.03.16

6.1.1 220KV/132KV CHANDIL S/STN

- i. *Carry out Tan-delta measurement of all CTs and replace the CTs which are violating Tan-delta characteristics.*
- ii. *Identify and connect the proper protection core of PT for protection purpose.*
- iii. *All old PTs may be replaced with proper ratings, core and class of PTs.*
- iv. *JUSNL should incorporate REF protection for other ICTs (ICT- I, II & III) and if required external neutral CTs may be mounted for the purpose.*
- v. *To carry out DGA analysis of ICTs once in every 2 years.*
- vi. *Take suitable measure for detection and rectification of the DC earth fault.*
- vii. *While commissioning of second set of Battery Bank, proper measures to be taken for proper connection & segregation of DC#1 & DC#2 for redundancy & segregation as per the standard practices followed.*

6.1.2 220KV/132KV RAMCHANDRAPUR S/STN

- i. *Carry out Tan-delta measurement of all CTs and replace the CTs which are violating Tan-delta characteristics.*
- ii. *Identify and connect the proper protection core of PT for protection purpose.*
- iii. *All old PTs may be replaced with proper ratings, core and class.*
- iv. *Old EM relays are to be replaced with Numerical relay for ICT-I&II.*
- v. *Circuit Breakers are to be tested with both the trip-coils and results to be submitted.*
- vi. *Circuit Breaker of ICT-I may be checked as the CB trip time is very high (589 ms).*
- vii. *Take suitable measure for detection and rectification of the DC earth fault.*
- viii. *While commissioning of second set of Battery Bank, proper measures to be taken for proper connection & segregation of DC#1 & DC#2 for redundancy & segregation as per the standard practices followed.*

During discussion it was informed that usually JUSNL is keeping two ICTs in service as per their load requirement and one ICT in standby mode under charged condition.

It was advised to JUSNL that all the three ICTs may be kept in service during peak hours for meeting the n-1 criterion and during off-peak hours they may keep any of the two ICTs in service.

6.1.3 132KV ADITYAPUR S/STN

- i. *Circuit Breakers are to be tested with both the trip-coils and results to be submitted.*
- ii. *The breaker timings of ASEA make breakers need to be checked and if possible may be reduced.*
- iii. *Take suitable measure for detection and rectification of the DC earth fault.*

6.1.4 COMMON ISSUES DISCUSSED IN THE MEETING

- i. *Take suitable measure for detection and rectification of the DC earth fault.*
- ii. *To carry out relay coordination as per the revised protection philosophy of ERPC.*
- iii. *To complete the DPR for PSDF funding towards improvement/development of JUSNL protection system at the earliest.*

As agreed in the 41st PCC & 119th OCC meetings, JUSNL to share their standby PLCC panels (BPL make) with WBPDCL (for remote end of 220 kV Chandil -Santaldih) and OPTCL (for remote end of 220 kV Ramchandrapur -Joda) to complete the PLCC schemes of both the lines

6.2 Recommendations after the visit of the Sub-Stations

- i.** As per PART 3 OF CEA (TECHNICAL STANDARDS FOR CONNECTIVITY OF THE GRID) REGULATION, 2007, wherein it is clearly mentioned that 220KV Transmission Lines should have both MAIN 1 and MAIN 2 Distance Protection Schemes applicable for New Sub-Stations and for the Old Sub-Stations, it should be implemented in a reasonable time frame. **The same should be implemented.**
- ii.** One Number Numerical Distance Protection Relay has been used for 132KV Feeders. One Numerical Distance Protection Relay and another Back-up O/C and E/F protection relay (Two separate units) should be used.
- iii.** In order to provide protection in case of high resistive fault, directional earth fault protection may be used where Main 1 and Main 2 protection is suggested i.e. for 220KV Transmission Lines. The characteristics should be IDMT (Normal Inverse). The ground over current threshold should be set to ensure detection of all ground faults, but above any continuous residual current under normal system operation. The timing should be coordinated with the Zone-3 timing for a remote end bus fault.
- iv.** Availability of Carrier Protection and Single Phase Auto-reclosure for all 220KV and above transmission lines.
- v.** Replacement of Electromechanical Relays with Numerical Relays, wherever applicable for Transmission Lines and Transformers.
- vi.** Connectivity of GPRS clock in every substation with Time synchronisation facility to the Numerical Relays.
- vii.** As per PART 3 OF CEA (TECHNICAL STANDARDS FOR CONNECTIVITY OF THE GRID) REGULATION, 2007, wherein it is clearly mentioned that Bus bar protection shall be provided on all sub-stations at and above 220 kV levels for all new sub-stations. For existing sub-stations, this shall be implemented in a reasonable time frame.
Local Breaker Back-Up (LBB) protection shall be provided for all sub-stations with proper scheme.

The above two protections should be implemented as per the recommendations as per the approved scheme and this should be available in the Sub-Stations.

- viii. Removal of D.C. earth from the Sub-stations whenever it is detected. For the same detection instruments are available by which D.C. leakage can be easily identified and remedial measures can be taken instantly.
- ix. All Panel Indications wherever applicable for Isolators, Breakers, Circuit Breaker Spring Charge, Trip Circuit Healthy or any other indications as per the scheme should be made healthy.
- x. Pre and Post Close Trip circuit supervision for Trip Coil 1 (TC # 1) and Trip Coil 2 (TC # 2) should be made healthy wherever applicable.
- xi. Annunciation Circuitry should be made proper for all trip and non-trip functions as per the schematic.
- xii. CTJB, PTJB should be changed wherever applicable and terminations of the cables should be completed with proper specification of Terminal Blocks and LUGS. The CTJB and PTJB should be earthed through Earthing Strips.
- xiii. All relevant drawings required during trouble shooting should be made available in each of the Control Rooms of every sub-stations. Updated Drawings related to Protection and control Panel of individual bays, CT's, PT's, Circuit breakers, Isolators, Transformers etc. are to be made available at sub-station level. LOGICS and configuration of the NUMERICAL RELAYS should be made proper with the availability of relevant protection as per CEA guidelines and the same should be made available at the sub-station level.
- xiv. Redundant relays which are not in use should be removed from the Protection Panels and the NUMERICAL RELAYS and Auxiliaries installed should be newly wired as per the approved scheme.

- xv. 220KV and 132KV CT's should be tested for characteristics and proper cores should be used for proper protection purpose, i.e. PS for Differential, PS/5P (with proper ALF) for Distance/Backup protection, 0.2/0.5 for metering purpose. Kindly note that for both 220KV and 132KV CT protection schemes, separate cores should be used for separate protection purpose.
- xvi. Earth Resistance of Sub-Station should be measured at regular intervals and the value should be less than 1 ohms. The Test result should be marked in the Sub-Station Earth Pit with the date of testing.
- xvii. Two source of D.C may be provided to Control and Relay panels for 220kV and above system for security and redundancy. Accordingly the Bus Wire of the panel is to be segregated and scheme developed accordingly.
- xviii. Meticulous Patrolling of 220KV and 132KV Transmission lines along with availability of Earth Wires should be ensured to reduce transient faults.
- xix. Individual Tower Earthing should also be ensured to provide earth paths to lightning strikes through the shortest path.
- xx. CONDITION MONITORING OF SUB-STATION EQUIPMENTS

Regular conditioning monitoring of substation equipment (Transformer, CT, CVT, PT, LA, CB etc.) may be done as per CEA recommendation and proper record may be maintained.

The types of tests on the substation equipment's along with the technology used with its duration is provided and the same should be meticulously followed for all 220KV and 132KV sub-station. (**Annexure - 6.2: Equipment Technology Matrix**).

7.0 Protection Settings of JUSNL System

In the special meeting with JUSNL held on 08.06.16 to discuss the observations of the site visit, it was emphasized that the distance protection along with the back-up protection of JUSNL system (comprising of 220kV Ramchandrapur, Chandil & Hatia-II and 132 kV Adityapur & Hatia-I) needs to be reviewed for proper protection co-ordination. It was decided that the Protection team will carry out the setting calculations for all the 220 kV & 132 kV lines along with the 220/132 kV ICTs based on the data provided by JUSNL which shall be implemented by JUSNL. The same was ratified by 33rd TCC/ERPC also.

Subsequently after getting all the authenticated information from JUSNL, a special meeting was convened on 28.07.16 and the committee members finalized the distance protection settings along with the back-up over-current settings of all the 220 kV & 132 kV feeders of following Sub-stations:

1. 220/132 kV Chandil S/s,
2. 220/132 kV Ramchandrapur S/s,
3. 220/132 kV Hatia-II S/s
4. 132 kV Hatia-I S/s
5. 132 kV Adityapur S/s

The details of recommended distance protection settings along with back-up Over current settings is placed at **Annexure-7.1**.

The committee also reviewed the over current settings of 220/132 kV Transformers of 220/132 kV Chandil, Ramchandrapur and Hatia-II sub-stations and recommended the new settings which is given at **Annexure-7.2**.

=====

Sub Station Equipment Technology Matrix

Equipment Technologies	IR	Tan δ	Thermography	Op. Time. Anlyz.	Static Cont. Res.	BDV	3 rd Harmonic Res. Cur. Analyzer	DGA	(i)Moisture Content (ii)Sp. Res (iii) D.D.F. (iv) Acidity (v)IFT (vi) Sludge content	Furan Analysis	D.C. Wdg. Res.	Partial Discharge	TTR	CT Analyzer	Magnetic Balance	Hydrometer	Earth Tester	DCRM	Relay Testing Kit	Dew point measurement kit
Transformer	Δ	Δ	m																	
	Φ	Φ	Φ																	
CB	Δ		m	Δ	Δ														Φ	
	Φ		Φ	Φ	Φ															
CT	Δ	Δ	m																	
	Φ	Φ	Φ																	
PT	Δ	Δ	m																	
	Φ	Φ	Φ																	
LA	Δ		m				Δ													
	Φ		Φ				Φ													
Isolator			m		Δ															
			Φ		Φ															
Ins. Oil (Trans.)						Δ		Δ	Δ						Φ					
Ins. Oil (CT,PT,CVT)							Δ		Φ	Φ										
Ins. Oil (Gr. Tr.)							Δ		Φ	Φ										
CVT	Δ	Δ	m																	
	Φ	Φ	Φ																	
Battery																m	Φ			
Earth Pit																		Δ		
Protective Relays																			Δ	Φ
Tariff Meters																				
SF6 Gas Dew point																			Ω	Φ

Periodic Glossary:- Δ :- Yearly

m :- Monthly

Φ :- SOS

Ω:- Every 3 year

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **120**
 2> SYSTEM VOLTAGE= **220**
 (RESISTANCE)- Per Km **0.0749**
 (REACTANCE)- Per Km **0.41**
 (IMPEDANCE)- Per Km **0.41678**
 LINE ANGLE= **79**
 3>FAULT MVA OF THE S/S= **5403**
 4>C.T.RATIO= **600**
 5>P.T.RATIO= **2000**
 6>NEXT SHORTEST SECTION= (IN KM)(STPS-HURA) **48**
 7>NEXT LONGEST SECTION= (IN KM)(STPS-N.BISHNUPUR) **111**
 8>INFEED RATIO=[I_{act}/I_{infeed})] **0**
 9>ARC RESISTANCE=(Pri Value) **25**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **200**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **251**
 13>X₀/X₁=R₀/R₁= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **S**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **245**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **53.34**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **8.71**
 D>ARC RESISTANCE=(Sec Value) **7.50**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **7.50**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **4.32**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **21.58**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **988**

CHANDIL-STPS

MICOM P442

ZONE-1	Z1=	12.00
	R1G=	15.00
	R1Ph=	7.50
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	18.00
	R2G=	18.75
	R2Ph=	9.38
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	34.66
	Z4(Reverse)=	1.50
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	23.44
	R3Ph/R4Ph=	11.72
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.13
	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	120
	Z=	15.00408
	ANGLE=	79

OTHERS(MHO)

ZONE-1	12.00
ZONE-2	18.00
ZONE-3(For)	34.66
ZONE-4(Rev)	1.50
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	23.72
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	0.0749
220 KV---"X"	0.41
220 KV---"Z"	0.41678
132 KV---"R"	FALSE
132 KV---"X"	FALSE
132 KV---"Z"	FALSE

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **35**
 2> SYSTEM VOLTAGE= **220**
 (RESISTANCE)- Per Km **0.0749**
 (REACTANCE)- Per Km **0.41**
 (IMPEDANCE)- Per Km **0.41678**
 LINE ANGLE= **79**
 3>FAULT MVA OF THE S/S= **5403**
 4>C.T.RATIO= **600**
 5>P.T.RATIO= **2000**
 6>NEXT SHORTEST SECTION= (IN KM)(RAMCHANDAPUR-JODA) **130**
 7>NEXT LONGEST SECTION= (IN KM)(RAMCHANDAPUR-JODA) **130**
 8>INFEED RATIO=[I_(act)/I_(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **25**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **300**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **251**
 13>X₀/X₁=R₀/R₁= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **S**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **245**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **53.34**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **5.81**
 D>ARC RESISTANCE=(Sec Value) **7.50**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **7.50**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **10.25**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **51.23**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **2346**

CHANDIL-RAMCHANDAPUR

MICOM P442

ZONE-1	Z1=	3.50
	R1G=	15.00
	R1Ph=	7.50
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	10.18
	R2G=	18.75
	R2Ph=	9.38
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	24.76
	Z4(Reverse)=	0.88
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	23.44
	R3Ph/R4Ph=	11.72
	tZ3=	1.00
Dir.O/C	Char.=	NI
	%PLUG SET=	100%
	TIME SET=	0.20
Dir.E/F	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	35
	Z=	4.37619
	ANGLE=	79

OTHERS(MHO)

ZONE-1	3.50
ZONE-2	10.18
ZONE-3(For)	24.76
ZONE-4(Rev)	0.88
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	10.18
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	0.0749
220 KV---"X"	0.41
220 KV---"Z"	0.41678
132 KV---"R"	FALSE
132 KV---"X"	FALSE
132 KV---"Z"	FALSE

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **93.5**
 2> SYSTEM VOLTAGE= **220**
 (RESISTANCE)- Per Km **0.0749**
 (REACTANCE)- Per Km **0.41**
 (IMPEDANCE)- Per Km **0.41678**
 LINE ANGLE= **79**
 3>FAULT MVA OF THE S/S= **5403**
 4>C.T.RATIO= **600**
 5>P.T.RATIO= **2000**
 6>NEXT SHORTEST SECTION= (IN KM)(RANCHI-HATIA) **35**
 7>NEXT LONGEST SECTION= (IN KM)(RANCHI-HATIA) **35**
 8>INFEED RATIO=[I(act)/I(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **25**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **630**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **251**
 13>X0/X1=R0/R1= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **S**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **245**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **53.34**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **2.77**
 D>ARC RESISTANCE=(Sec Value) **7.50**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **7.50**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **5.27**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **26.33**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **1206**

CHANDIL-RANCHI

MICOM P442

ZONE-1	Z1=	9.35
	R1G=	15.00
	R1Ph=	7.50
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	13.88
	R2G=	18.75
	R2Ph=	9.38
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	19.28
	Z4(Reverse)=	2.34
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	23.44
	R3Ph/R4Ph=	11.72
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.14
	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	93.5
	Z=	11.69068
	ANGLE=	79

OTHERS(MHO)

ZONE-1	9.35
ZONE-2	13.88
ZONE-3(For)	19.28
ZONE-4(Rev)	2.34
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	14.46
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	0.0749
220 KV---"X"	0.41
220 KV---"Z"	0.41678
132 KV---"R"	FALSE
132 KV---"X"	FALSE
132 KV---"Z"	FALSE

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **66**
 2> SYSTEM VOLTAGE= **132**
 (RESISTANCE)- Per Km **0.1402**
 (REACTANCE)- Per Km **0.401**
 (IMPEDANCE)- Per Km **0.42473**
 LINE ANGLE= **68**
 3>FAULT MVA OF THE S/S= **4092**
 4>C.T.RATIO= **600**
 5>P.T.RATIO= **1200**
 6>NEXT SHORTEST SECTION= (IN KM)(IDLE CHARGED LINE) **30**
 7>NEXT LONGEST SECTION= (IN KM)(IDLE CHARGED LINE) **30**
 8>INFEED RATIO=[I(act)/I(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **20**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **100**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **151**
 13>X0/X1=R0/R1= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **S**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **95**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **82.53**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **10.45**
 D>ARC RESISTANCE=(Sec Value) **10.00**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **12.50**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **4.76**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **23.78**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **0.60**
 K>FAULT MVA AT 80% OF THE LINE= **653**

CHANDIL-TOMAR

MICOM P442

ZONE-1	Z1=	11.21
	R1G=	22.50
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	17.20
	R2G=	28.13
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	24.46
	Z4(Reverse)=	2.80
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	35.16
	R3Ph/R4Ph=	15.63
Dir.O/C	tZ3=	0.60
	Char.=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.13
	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	66
	Z=	14.01609
	ANGLE=	68

OTHERS(MHO)

ZONE-1	11.21
ZONE-2	17.20
ZONE-3(For)	24.46
ZONE-4(Rev)	2.80
Time-(Z-2)	0.35
Time-(Z-3)	0.60
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	24.47
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = 30
 2> SYSTEM VOLTAGE= 132
 (RESISTANCE)- Per Km 0.1402
 (REACTANCE)- Per Km 0.3976
 (IMPEDANCE)- Per Km 0.42159
 LINE ANGLE= 68
 3>FAULT MVA OF THE S/S= 4092
 4>C.T.RATIO= 400
 5>P.T.RATIO= 1200
 6>NEXT SHORTEST SECTION= (IN KM)(GOLMURI-JADUGORA) 25
 7>NEXT LONGEST SECTION= (IN KM)(GOLMURI-CHANDIL) 30
 8>INFEED RATIO=[I(act)/I(infeed)] 0
 9>ARC RESISTANCE=(Pri Value) 20
 10>TOWER- FOOTING RESISTANCE=(Pri Value) 25
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) 100
 12>MAXIMUM LOAD (110% CT)= (IN MVA) 101
 13>X0/X1=R0/R1= 3.1
 14>SINGLE CKT (S) / DOUBLE CKT (D)= D
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) NO
 16>In 1
 17> CT SECONDARY= 1
 18>THARMAL CAPACITY[40-75°C](MVA)= 95
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) 55.02
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] 51.96

DERIVED VALUES

A) COMPENSATION (K)= 0.70
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) 51.96305
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) 6.97
 D>ARC RESISTANCE=(Sec Value) 6.67
 E>TOWER FOOTING RESISTANCE=(Sec Value) 8.33
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= 13.24
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) 0.60
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= 66.21
 I>Time- (ZONE-2)= (In Sec) 0.35
 J>Time- (ZONE-3)= (In Sec) 0.60
 K>FAULT MVA AT 80% OF THE LINE= 1212

CHANDIL-GOLMURI

MICOM P442

ZONE-1	Z1=	3.37
	R1G=	15.00
	R1Ph=	6.67
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	5.97
	R2G=	18.75
	R2Ph=	8.33
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	10.12
	Z4(Reverse)=	0.84
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	23.44
	R3Ph/R4Ph=	10.42
Dir.O/C	tZ3=	0.60
	Char.=	NI
	%PLUG SET=	100%
	TIME SET=	0.22
Dir.E/F	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	30
	Z=	4.2159
	ANGLE=	68

OTHERS(MHO)

ZONE-1	3.37
ZONE-2	5.97
ZONE-3(For)	10.12
ZONE-4(Rev)	0.84
Time-(Z-2)	0.35
Time-(Z-3)	0.60
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	11.19
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = 40
 2> SYSTEM VOLTAGE= 132
 (RESISTANCE)- Per Km 0.1402
 (REACTANCE)- Per Km 0.401
 (IMPEDANCE)- Per Km 0.42473
 LINE ANGLE= 68
 3>FAULT MVA OF THE S/S= 4092
 4>C.T.RATIO= 600
 5>P.T.RATIO= 1200
 6>NEXT SHORTEST SECTION= (IN KM)(RKSN-CHAIBASA) 20
 7>NEXT LONGEST SECTION= (IN KM)(RKSN-GOELKERA) 58
 8>INFEED RATIO=[I_{act}/I_{infeed}] 0
 9>ARC RESISTANCE=(Pri Value) 20
 10>TOWER- FOOTING RESISTANCE=(Pri Value) 25
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) 70
 12>MAXIMUM LOAD (110% CT)= (IN MVA) 151
 13>X₀/X₁=R₀/R₁= 3.1
 14>SINGLE CKT (S) / DOUBLE CKT (D)= S
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) NO
 16>In 1
 17> CT SECONDARY= 1
 18>THARMAL CAPACITY[40-75°C](MVA)= 95
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) 82.53
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] 51.96

DERIVED VALUES

A) COMPENSATION (K)= 0.70
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) 51.96305
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) 14.93
 D>ARC RESISTANCE=(Sec Value) 10.00
 E>TOWER FOOTING RESISTANCE=(Sec Value) 12.50
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= 7.11
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) 0.60
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= 35.55
 I>Time- (ZONE-2)= (In Sec) 0.35
 J>Time- (ZONE-3)= (In Sec) 1.00
 K>FAULT MVA AT 80% OF THE LINE= 976

CHANDIL-RKSN(DIR)

MICOM P442

ZONE-1	Z1=	6.80
	R1G=	22.50
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	10.62
	R2G=	28.13
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	24.97
	Z4(Reverse)=	1.70
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	35.16
	R3Ph/R4Ph=	15.63
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.17
	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	40
	Z=	8.4946
	ANGLE=	68

OTHERS(MHO)

ZONE-1	6.80
ZONE-2	10.62
ZONE-3(For)	24.97
ZONE-4(Rev)	1.70
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	23.43
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = 19
 2> SYSTEM VOLTAGE= 132
 (RESISTANCE)- Per Km 0.1402
 (REACTANCE)- Per Km 0.401
 (IMPEDANCE)- Per Km 0.42473
 LINE ANGLE= 68
 3>FAULT MVA OF THE S/S= 4092
 4>C.T.RATIO= 600
 5>P.T.RATIO= 1200
 6>NEXT SHORTEST SECTION= (IN KM)(ADITYAPUR-UM) 4
 7>NEXT LONGEST SECTION= (IN KM)(ADITYAPUR-RKSN) 35
 8>INFEED RATIO=[I(act)/I(infeed)] 0
 9>ARC RESISTANCE=(Pri Value) 20
 10>TOWER- FOOTING RESISTANCE=(Pri Value) 25
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) 200
 12>MAXIMUM LOAD (110% CT)= (IN MVA) 151
 13>X0/X1=R0/R1= 3.1
 14>SINGLE CKT (S) / DOUBLE CKT (D)= S
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) NO
 16>In 1
 17> CT SECONDARY= 1
 18>THARMAL CAPACITY[40-75°C](MVA)= 95
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) 82.53
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] 51.96

DERIVED VALUES

A) COMPENSATION (K)= 0.70
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) 51.96305
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) 5.23
 D>ARC RESISTANCE=(Sec Value) 10.00
 E>TOWER FOOTING RESISTANCE=(Sec Value) 12.50
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= 11.84
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) 0.60
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= 59.22
 I>Time- (ZONE-2)= (In Sec) 0.35
 J>Time- (ZONE-3)= (In Sec) 1.00
 K>FAULT MVA AT 80% OF THE LINE= 1626

CHANDIL-ADITYAPUR

MICOM P442

ZONE-1	Z1=	3.23
	R1G=	22.50
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	4.46
	R2G=	28.13
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	13.76
	Z4(Reverse)=	0.81
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	35.16
	R3Ph/R4Ph=	15.63
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.22
	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	19
	Z=	4.034935
	ANGLE=	68

OTHERS(MHO)

ZONE-1	3.23
ZONE-2	4.46
ZONE-3(For)	13.76
ZONE-4(Rev)	0.81
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	9.26
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = 54
 2> SYSTEM VOLTAGE= 132
 (RESISTANCE)- Per Km 0.1402
 (REACTANCE)- Per Km 0.401
 (IMPEDANCE)- Per Km 0.42473
 LINE ANGLE= 68
 3>FAULT MVA OF THE S/S= 4092
 4>C.T.RATIO= 600
 5>P.T.RATIO= 1200
 6>NEXT SHORTEST SECTION= (IN KM)(RKSN-CHAIBASA) 20
 7>NEXT LONGEST SECTION= (IN KM)(RKSN-GOELKERA) 58
 8>INFEED RATIO=[I(act)/I(infeed)] 0
 9>ARC RESISTANCE=(Pri Value) 20
 10>TOWER- FOOTING RESISTANCE=(Pri Value) 25
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) 70
 12>MAXIMUM LOAD (110% CT)= (IN MVA) 151
 13>X0/X1=R0/R1= 3.1
 14>SINGLE CKT (S) / DOUBLE CKT (D)= S
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) NO
 16>In 1
 17> CT SECONDARY= 1
 18>THARMAL CAPACITY[40-75°C](MVA)= 95
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) 82.53
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] 51.96

DERIVED VALUES

A) COMPENSATION (K)= 0.70
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) 51.96305
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) 14.93
 D>ARC RESISTANCE=(Sec Value) 10.00
 E>TOWER FOOTING RESISTANCE=(Sec Value) 12.50
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= 5.61
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) 0.60
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= 28.07
 I>Time- (ZONE-2)= (In Sec) 0.35
 J>Time- (ZONE-3)= (In Sec) 1.00
 K>FAULT MVA AT 80% OF THE LINE= 771

CHANDIL-RKSN(ADTY)

MICOM P442

ZONE-1	Z1=	9.17
	R1G=	22.50
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	13.59
	R2G=	28.13
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	28.54
	Z4(Reverse)=	2.29
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
Dir.O/C	R3G/R4G=	35.16
	R3Ph/R4Ph=	15.63
	tZ3=	1.00
	Char..=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.15
	Char..=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char..=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char..=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	54
	Z=	11.46771
	ANGLE=	68

OTHERS(MHO)

ZONE-1	9.17
ZONE-2	13.59
ZONE-3(For)	28.54
ZONE-4(Rev)	2.29
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	26.40
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **35**
 2> SYSTEM VOLTAGE= **220**
 (RESISTANCE)- Per Km **0.0749**
 (REACTANCE)- Per Km **0.3993**
 (IMPEDANCE)- Per Km **0.406**
 LINE ANGLE= **79**
 3>FAULT MVA OF THE S/S= **4329**
 4>C.T.RATIO= **1200**
 5>P.T.RATIO= **2000**
 6>NEXT SHORTEST SECTION= (IN KM)(PATRATU-HATIA) **35**
 7>NEXT LONGEST SECTION= (IN KM)(PATRATU-TENUGHAT) **70**
 8>INFEED RATIO=[I(act)/I(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **25**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **300**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **503**
 13>X0/X1=R0/R1= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **D**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **245**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **106.68**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **11.62**
 D>ARC RESISTANCE=(Sec Value) **15.00**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **15.00**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **4.69**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **23.43**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **2146**

HATIA(N)-PATRATU

MICOM P442

ZONE-1	Z1=	6.82
	R1G=	30.00
	R1Ph=	15.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	12.79
	R2G=	37.50
	R2Ph=	18.75
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	30.69
	Z4(Reverse)=	1.71
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	41.57
	R3Ph/R4Ph=	23.44
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
	TIME SET=	0.13
Dir.E/F	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	35
	Z=	8.526
	ANGLE=	79

OTHERS(MHO)

ZONE-1	6.82
ZONE-2	12.79
ZONE-3(For)	30.69
ZONE-4(Rev)	1.71
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	20.14
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	0.0749
220 KV---"X"	0.3993
220 KV---"Z"	0.406
132 KV---"R"	FALSE
132 KV---"X"	FALSE
132 KV---"Z"	FALSE

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

HATIA(N)-RANCHI		MICOM P442	OTHERS(MHO)
RELAY TYPE			
1> LINE LENGTH =	35	ZONE-1	Z1= 6.82
2> SYSTEM VOLTAGE=	220		R1G= 30.00
(RESISTANCE)- Per Km	0.0749		R1Ph= 15.00
(REACTANCE)- Per Km	0.3993		tZ1= 0.00
(IMPEDANCE)- Per Km	0.406		KZ1 Res Comp= 0.70
LINE ANGLE=	79		KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	4329	ZONE-2	Z2= 12.79
4>C.T.RATIO=	1200		R2G= 37.50
5>P.T.RATIO=	2000		R2Ph= 18.75
6>NEXT SHORTEST SECTION= (IN KM)(RANCHI-HATIA)	35		tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(RANCHI-CHANDIL)	93.5		KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0		KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	25	ZONE-3/4	Z3= 37.56
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25		Z4(Reverse)= 1.71
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	630		KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	503		KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1		R3G/R4G= 41.57
14>SINGLE CKT (S) / DOUBLE CKT (D)=	D		R3Ph/R4Ph= 23.44
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	Dir.O/C	tZ3= 1.00
16>In	1		Char..= NI
17> CT SECONDARY=	1		%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	245	Dir.E/F	TIME SET= 0.13
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	106.68		Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96		%PLUG SET= 20%
			TIME SET= 0.27
		Non-Dir.O/C	Char..= DT
			%PLUG SET= 100%
			TIME SET= 2Sec
		Non-Dir.E/F	Char..= DT
			%PLUG SET= 20%
			TIME SET= 2Sec
		LINE	LENGTH= 35
			Z= 8.526
			ANGLE= 79
<u>DERIVED VALUES</u>			
A) COMPENSATION (K)=	0.70		
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305		
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	5.53		
D>ARC RESISTANCE=(Sec Value)	15.00		
E>TOWER FOOTING RESISTANCE=(Sec Value)	15.00		
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	4.69		
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	0.60		
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	23.43		
I>Time- (ZONE-2)= (In Sec)	0.35		
J>Time- (ZONE-3)= (In Sec)	1.00		
K>FAULT MVA AT 80% OF THE LINE=	2146		

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	0.0749
220 KV---"X"	0.3993
220 KV---"Z"	0.406
132 KV---"R"	FALSE
132 KV---"X"	FALSE
132 KV---"Z"	FALSE

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE	HATIA(N)-LOHARDAGA	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	65	Z1= 10.96	ZONE-1 10.96
2> SYSTEM VOLTAGE=	132	R1G= 22.50	ZONE-2 20.55
(RESISTANCE)- Per Km	0.1402	R1Ph= 10.00	ZONE-3(For) 33.64
(REACTANCE)- Per Km	0.3976	tZ1= 0.00	ZONE-4(Rev) 2.74
(IMPEDANCE)- Per Km	0.42159	KZ1 Res Comp= 0.70	Time-(Z-2) 0.35
LINE ANGLE=	68	KZ1 Angle= 0.00	Time-(Z-3) 1.00
3>FAULT MVA OF THE S/S=	2689	Z2= 20.55	Time-(Z-4) 0.50
4>C.T.RATIO=	600	R2G= 28.13	IMP UPTO NEXT LEVEL 24.16
5>P.T.RATIO=	1200	R2Ph= 12.50	(80% OF TR IMP)
6>NEXT SHORTEST SECTION= (IN KM)(LOHARDAGA-HATIA)	65	tZ2= 0.35	Compensation 0.70
7>NEXT LONGEST SECTION= (IN KM)(LOHARDAGA-GUMLA)	68	KZ2 Res Comp= 0.70	
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00	
9>ARC RESISTANCE=(Pri Value)	20	Z3= 33.64	
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 2.74	
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	100	KZ3/KZ4 Res Comp= 0.70	
12>MAXIMUM LOAD (110% CT)= (IN MVA)	151	KZ3/KZ4Angle= 0.00	
13>X0/X1=R0/R1=	3.1	R3G/R4G= 35.16	
14>SINGLE CKT (S) / DOUBLE CKT (D)=	D	R3Ph/R4Ph= 15.63	
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 1.00	
16>In	1	Char..= NI	
17> CT SECONDARY=	1	%PLUG SET= 100%	
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.13	
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	82.53	Dir.O/C Char..= NI	
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%	
		TIME SET= 0.27	
		Non-Dir.O/C Char..= DT	
		%PLUG SET= 100%	
		TIME SET= 2Sec	
		Non-Dir.E/F Char..= DT	
		%PLUG SET= 20%	
		TIME SET= 2Sec	
		LINE LENGTH= 65	
		Z= 13.70168	
		ANGLE= 68	

LINE PARAMERERS
400 KV---"R"
400 KV---"X"
400 KV---"Z"
220 KV---"R"
220 KV---"X"
220 KV---"Z"
132 KV---"R"
132 KV---"X"
132 KV---"Z"

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

HATIA(N)-NAMKUM		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	27	ZONE-1 4.59
2> SYSTEM VOLTAGE=	132	R1G= 22.50
(RESISTANCE)- Per Km	0.1402	R1Ph= 10.00
(REACTANCE)- Per Km	0.401	tZ1= 0.00
(IMPEDANCE)- Per Km	0.42473	KZ1 Res Comp= 0.70
LINE ANGLE=	68	KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	2689	Z2= 6.58
4>C.T.RATIO=	600	R2G= 28.13
5>P.T.RATIO=	1200	R2Ph= 12.50
6>NEXT SHORTEST SECTION= (IN KM)(NAMKUM-UM)	8	tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(NAMKUM-SIKIDRI)	34	KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	20	Z3= 15.55
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 1.15
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	150	KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	151	KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1	R3G/R4G= 35.16
14>SINGLE CKT (S) / DOUBLE CKT (D)=	S	R3Ph/R4Ph= 15.63
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 1.00
16>In	1	Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.18
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	82.53	Dir.O/C Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.27
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305	Non-Dir.O/C Char..= DT
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	6.97	%PLUG SET= 100%
D>ARC RESISTANCE=(Sec Value)		TIME SET= 2Sec
E>TOWER FOOTING RESISTANCE=(Sec Value)	10.00	Non-Dir.E/F Char..= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	12.50	%PLUG SET= 20%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	8.11	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	0.60	LINE LENGTH= 27
I>Time- (ZONE-2)= (In Sec)	40.53	Z= 5.733855
J>Time- (ZONE-3)= (In Sec)	0.35	ANGLE= 68
K>FAULT MVA AT 80% OF THE LINE=	1.00	
	1113	

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

HATIA(O)-HEC-8C				
RELAY TYPE	MICOM P442	OTHERS(MHO)		
1> LINE LENGTH =	8	ZONE-1	Z1= 0.67	ZONE-1 0.67
2> SYSTEM VOLTAGE=	132	R1G= 11.25	ZONE-2 1.26	
(RESISTANCE)- Per Km	0.1402	R1Ph= 5.00	ZONE-3(For) 2.02	
(REACTANCE)- Per Km	0.3976	tZ1= 0.00	ZONE-4(Rev) 0.17	
(IMPEDANCE)- Per Km	0.42159	KZ1 Res Comp= 0.70	Time-(Z-2) 0.35	
LINE ANGLE=	68	KZ1 Angle= 0.00	Time-(Z-3) 0.60	
3>FAULT MVA OF THE S/S=	2689	Z2= 1.26	Time-(Z-4) 0.50	
4>C.T.RATIO=	300	R2G= 14.06	IMP UPTO NEXT LEVEL 6.37	
5>P.T.RATIO=	1200	R2Ph= 6.25	(80% OF TR IMP)	
6>NEXT SHORTEST SECTION= (IN KM)(HEC-HATIA)	8	tZ2= 0.35	Compensation 0.70	
7>NEXT LONGEST SECTION= (IN KM)(HEC-HATIA)	0	KZ2 Res Comp= 0.70		
8>INFEED RATIO=[I(act)/I(infeed)]	20	KZ2 Angle= 0.00		
9>ARC RESISTANCE=(Pri Value)	25	Z3= 2.02		
10>TOWER- FOOTING RESISTANCE=(Pri Value)	94.5	Z4(Reverse)= 0.17		
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	75	KZ3/KZ4 Res Comp= 0.70		
12>MAXIMUM LOAD (110% CT)= (IN MVA)	3.1	KZ3/KZ4Angle= 0.00		
13>X0/X1=R0/R1=	D	R3G/R4G= 17.58		
14>SINGLE CKT (S) / DOUBLE CKT (D)=	NO	R3Ph/R4Ph= 7.81		
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	1	tZ3= 0.60		
16>In	1	Char..= NI		
17> CT SECONDARY=		%PLUG SET= 100%		
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.27		
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	41.27	Dir.E/F Char..= NI		
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%		
		TIME SET= 0.27		
		Non-Dir.O/C Char..= DT		
		%PLUG SET= 100%		
		TIME SET= 2Sec		
		Non-Dir.E/F Char..= DT		
		%PLUG SET= 20%		
		TIME SET= 2Sec		
		LINE LENGTH= 8		
		Z= 0.84318		
		ANGLE= 68		
<u>DERIVED VALUES</u>				
A) COMPENSATION (K)=	0.70			
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305			
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	5.53			
D>ARC RESISTANCE=(Sec Value)				
E>TOWER FOOTING RESISTANCE=(Sec Value)	5.00			
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	6.25			
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	27.65			
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	0.60			
I>Time- (ZONE-2)= (In Sec)	138.27			
J>Time- (ZONE-3)= (In Sec)	0.35			
K>FAULT MVA AT 80% OF THE LINE=	0.60			
	1898			

LINE PARAMERERS
400 KV---"R" FALSE
400 KV---"X" FALSE
400 KV---"Z" FALSE
220 KV---"R" FALSE
220 KV---"X" FALSE
220 KV---"Z" FALSE
132 KV---"R" 0.1402
132 KV---"X" 0.3976
132 KV---"Z" 0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

HATIA(O)-HEC-8C			
RELAY TYPE	MICOM P442	OTHERS(MHO)	
1> LINE LENGTH =	8	ZONE-1	Z1= 0.34
2> SYSTEM VOLTAGE=	132	R1G= 5.63	
(RESISTANCE)- Per Km	0.1402	R1Ph= 2.50	
(REACTANCE)- Per Km	0.3976	tZ1= 0.00	
(IMPEDANCE)- Per Km	0.42159	KZ1 Res Comp= 0.70	
LINE ANGLE=	68	KZ1 Angle= 0.00	
3>FAULT MVA OF THE S/S=	2689	ZONE-2	Z2= 0.63
4>C.T.RATIO=	150	R2G= 7.03	
5>P.T.RATIO=	1200	R2Ph= 3.13	
6>NEXT SHORTEST SECTION= (IN KM)(HEC-HATIA)	8	tZ2= 0.35	
7>NEXT LONGEST SECTION= (IN KM)(HEC-HATIA)	8	KZ2 Res Comp= 0.70	
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00	
9>ARC RESISTANCE=(Pri Value)	20	ZONE-3/4	Z3= 1.01
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 0.08	
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	94.5	KZ3/KZ4 Res Comp= 0.70	
12>MAXIMUM LOAD (110% CT)= (IN MVA)	38	KZ3/KZ4Angle= 0.00	
13>X0/X1=R0/R1=	3.1	R3G/R4G= 8.79	
14>SINGLE CKT (S) / DOUBLE CKT (D)=	D	R3Ph/R4Ph= 3.91	
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 0.60	
16>In	1	Dir.O/C	Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%	
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.27	
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	20.63	Dir.E/F	Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%	
		TIME SET= 0.27	
		Non-Dir.O/C Char..= DT	
		%PLUG SET= 100%	
		TIME SET= 2Sec	
		Non-Dir.E/F Char..= DT	
		%PLUG SET= 20%	
		TIME SET= 2Sec	
		LINE	LENGTH= 8
		Z= 0.42159	
		ANGLE= 68	
<u>DERIVED VALUES</u>			
A) COMPENSATION (K)=	0.70		
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305		
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END	2.77		
TRANSFORMER (%Z=12)= (Sec Value)			
D>ARC RESISTANCE=(Sec Value)	2.50		
E>TOWER FOOTING RESISTANCE=(Sec Value)	3.13		
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	55.31		
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	0.60		
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	276.54		
I>Time- (ZONE-2)= (In Sec)	0.35		
J>Time- (ZONE-3)= (In Sec)	0.60		
K>FAULT MVA AT 80% OF THE LINE=	1898		

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **44**
 2> SYSTEM VOLTAGE= **132**
 (RESISTANCE)- Per Km **0.1402**
 (REACTANCE)- Per Km **0.3976**
 (IMPEDANCE)- Per Km **0.42159**
 LINE ANGLE= **68**
 3>FAULT MVA OF THE S/S= **2689**
 4>C.T.RATIO= **300**
 5>P.T.RATIO= **1200**
 6>NEXT SHORTEST SECTION= (IN KM)(PTPS-KANKE) **25**
 7>NEXT LONGEST SECTION= (IN KM)(PTPS-KANKE) **25**
 8>INFEED RATIO=[I(act)/I(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **20**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **300**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **75**
 13>X0/X1=R0/R1= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **D**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **95**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **41.27**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **1.74**
 D>ARC RESISTANCE=(Sec Value) **5.00**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **6.25**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **11.90**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **59.52**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **817**

HATIA(O)-PTPS

MICOM P442

ZONE-1	Z1=	3.71
	R1G=	11.25
	R1Ph=	5.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	5.95
	R2G=	14.06
	R2Ph=	6.25
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	8.73
	Z4(Reverse)=	0.93
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	17.58
	R3Ph/R4Ph=	7.81
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.22
	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	44
	Z=	4.63749
	ANGLE=	68

OTHERS(MHO)

ZONE-1	3.71
ZONE-2	5.95
ZONE-3(For)	8.73
ZONE-4(Rev)	0.93
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	6.38
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

HATIA(O)-KANKE		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	28	ZONE-1 4.72
2> SYSTEM VOLTAGE=	132	R1G= 22.50
(RESISTANCE)- Per Km	0.1402	R1Ph= 10.00
(REACTANCE)- Per Km	0.3976	tZ1= 0.00
(IMPEDANCE)- Per Km	0.42159	KZ1 Res Comp= 0.70
LINE ANGLE=	68	KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	2689	Z2= 8.54
4>C.T.RATIO=	600	R2G= 28.13
5>P.T.RATIO=	1200	R2Ph= 12.50
6>NEXT SHORTEST SECTION= (IN KM)(KANKE-PTPS)	25	tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(KANKE-PTPS)	25	KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	20	Z3= 13.41
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 1.18
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	100	KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	151	KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1	R3G/R4G= 35.16
14>SINGLE CKT (S) / DOUBLE CKT (D)=	D	R3Ph/R4Ph= 15.63
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 0.60
16>In	1	Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.18
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	82.53	Dir.O/C Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.27
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305	Non-Dir.O/C Char..= DT
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	10.45	%PLUG SET= 100%
D>ARC RESISTANCE=(Sec Value)		TIME SET= 2Sec
E>TOWER FOOTING RESISTANCE=(Sec Value)	10.00	Non-Dir.E/F Char..= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	12.50	%PLUG SET= 20%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	7.97	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	0.60	LINE LENGTH= 28
I>Time- (ZONE-2)= (In Sec)	39.85	Z= 5.90226
J>Time- (ZONE-3)= (In Sec)	0.35	ANGLE= 68
K>FAULT MVA AT 80% OF THE LINE=	0.60	
	1094	

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

HATIA(O)-KAMDARA		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	60.2	ZONE-1 5.11
2> SYSTEM VOLTAGE=	132	R1G= 11.25
(RESISTANCE)- Per Km	0.1402	R1Ph= 5.00
(REACTANCE)- Per Km	0.401	tZ1= 0.00
(IMPEDANCE)- Per Km	0.42473	KZ1 Res Comp= 0.70
LINE ANGLE=	68	KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	2689	Z2= 7.03
4>C.T.RATIO=	300	R2G= 14.06
5>P.T.RATIO=	1200	R2Ph= 6.25
6>NEXT SHORTEST SECTION= (IN KM)(KAMDARA-RAILWAY+)	12	tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(KAMDARA-GUMLA)	60	KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	20	Z3= 15.32
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 1.28
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	90	KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	75	KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1	R3G/R4G= 17.58
14>SINGLE CKT (S) / DOUBLE CKT (D)=	S	R3Ph/R4Ph= 7.81
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 1.00
16>In	1	Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.19
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	41.27	Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.27
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305	Non-Dir.O/C Char..= DT
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	5.81	%PLUG SET= 100%
D>ARC RESISTANCE=(Sec Value)		TIME SET= 2Sec
E>TOWER FOOTING RESISTANCE=(Sec Value)	5.00	Non-Dir.E/F Char..= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	6.25	%PLUG SET= 20%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	9.42	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	0.60	LINE LENGTH= 60.2
I>Time- (ZONE-2)= (In Sec)	47.12	Z= 6.392187
J>Time- (ZONE-3)= (In Sec)	0.35	ANGLE= 68
K>FAULT MVA AT 80% OF THE LINE=	1.00	
	647	

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

HATIA(O)-SIKIDRI		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	58	ZONE-1
2> SYSTEM VOLTAGE=	132	Z1= 9.85
(RESISTANCE)- Per Km	0.1402	R1G= 22.50
(REACTANCE)- Per Km	0.401	R1Ph= 10.00
(IMPEDANCE)- Per Km	0.42473	tZ1= 0.00
LINE ANGLE=	68	KZ1 Res Comp= 0.70
3>FAULT MVA OF THE S/S=	2689	KZ1 Angle= 0.00
4>C.T.RATIO=	600	ZONE-2
5>P.T.RATIO=	1200	Z2= 13.38
6>NEXT SHORTEST SECTION= (IN KM)(SIKIDRI-IPP+)	10	R2G= 28.13
7>NEXT LONGEST SECTION= (IN KM)(SIKIDRI-NAMKUM)	34	R2Ph= 12.50
8>INFEED RATIO=[I(act)/I(infeed)]	0	tZ2= 0.35
9>ARC RESISTANCE=(Pri Value)	20	KZ2 Res Comp= 0.70
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	KZ2 Angle= 0.00
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	32.5	ZONE-3/4
12>MAXIMUM LOAD (110% CT)= (IN MVA)	151	Z3= 23.45
13>X0/X1=R0/R1=	3.1	Z4(Reverse)= 2.46
14>SINGLE CKT (S) / DOUBLE CKT (D)=	S	KZ3/KZ4 Res Comp= 0.70
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	KZ3/KZ4Angle= 0.00
16>In	1	R3G/R4G= 35.16
17> CT SECONDARY=	1	R3Ph/R4Ph= 15.63
18>THARMAL CAPACITY[40-75°C](MVA)=	95	Dir.O/C
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	82.53	Char.= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 100%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.14
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305	Dir.E/F
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END	32.17	Char.= NI
TRANSFORMER (%Z=12)= (Sec Value)		%PLUG SET= 20%
D>ARC RESISTANCE=(Sec Value)		TIME SET= 0.27
E>TOWER FOOTING RESISTANCE=(Sec Value)	10.00	Non-Dir.O/C Char.= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	12.50	%PLUG SET= 100%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	4.85	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	0.60	Non-Dir.E/F Char.= DT
I>Time- (ZONE-2)= (In Sec)	24.23	%PLUG SET= 20%
J>Time- (ZONE-3)= (In Sec)	0.35	TIME SET= 2Sec
K>FAULT MVA AT 80% OF THE LINE=	0.60	LINE LENGTH= 58
	665	Z= 12.31717
		ANGLE= 68

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **35**
 2> SYSTEM VOLTAGE= **220**
 (RESISTANCE)- Per Km **0.0749**
 (REACTANCE)- Per Km **0.41**
 (IMPEDANCE)- Per Km **0.41678**
 LINE ANGLE= **79**
 3>FAULT MVA OF THE S/S= **6873**
 4>C.T.RATIO= **800**
 5>P.T.RATIO= **2000**
 6>NEXT SHORTEST SECTION= (IN KM)(CHANDIL-POWERGRID) **93.5**
 7>NEXT LONGEST SECTION= (IN KM)(CHANDIL-STPS) **120**
 8>INFEED RATIO=[I(act)/I(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **25**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **400**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **335**
 13>X0/X1=R0/R1= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **S**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **245**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **71.12**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **5.81**
 D>ARC RESISTANCE=(Sec Value) **10.00**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **10.00**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **8.47**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **42.36**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **2587**

RAMCHANDAPUR-CHANDIL

MICOM P442

ZONE-1	Z1=	4.67
	R1G=	20.00
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	11.64
	R2G=	25.00
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	31.01
	Z4(Reverse)=	1.17
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	31.25
	R3Ph/R4Ph=	15.63
	tZ3=	1.00
Dir.O/C	Char.=	NI
	%PLUG SET=	100%
	TIME SET=	0.19
Dir.E/F	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	35
	Z=	5.83492
	ANGLE=	79

OTHERS(MHO)

ZONE-1	4.67
ZONE-2	11.64
ZONE-3(For)	31.01
ZONE-4(Rev)	1.17
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	11.64
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	0.0749
220 KV---"X"	0.41
220 KV---"Z"	0.41678
132 KV---"R"	FALSE
132 KV---"X"	FALSE
132 KV---"Z"	FALSE

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RAMCHANDAPUR-JODA		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	130	ZONE-1 13.00
2> SYSTEM VOLTAGE=	220	R1G= 15.00
(RESISTANCE)- Per Km	0.0749	R1Ph= 7.50
(REACTANCE)- Per Km	0.41	tZ1= 0.00
(IMPEDANCE)- Per Km	0.41678	KZ1 Res Comp= 0.70
LINE ANGLE=	79	KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	6873	Z2= 17.50
4>C.T.RATIO=	600	R2G= 18.75
5>P.T.RATIO=	2000	R2Ph= 9.38
6>NEXT SHORTEST SECTION= (IN KM)(JODA-TSIL+)	20	tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(JODA-TTPS)	147	KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	25	Z3= 41.56
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 1.63
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	300	KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	251	KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1	R3G/R4G= 23.44
14>SINGLE CKT (S) / DOUBLE CKT (D)=	S	R3Ph/R4Ph= 11.72
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 1.00
16>In	1	Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	245	TIME SET= 0.12
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	53.34	Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.27
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.963048	Non-Dir.O/C Char..= DT
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	5.81	%PLUG SET= 100%
D>ARC RESISTANCE=(Sec Value)	7.50	TIME SET= 2Sec
E>TOWER FOOTING RESISTANCE=(Sec Value)	7.50	Non-Dir.E/F Char..= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	4.19	%PLUG SET= 20%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	0.60	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	20.97	LINE LENGTH= 130
I>Time- (ZONE-2)= (In Sec)	0.35	Z= 16.25442
J>Time- (ZONE-3)= (In Sec)	1.00	ANGLE= 79
K>FAULT MVA AT 80% OF THE LINE=	961	

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	0.0749
220 KV---"X"	0.41
220 KV---"Z"	0.41678
132 KV---"R"	FALSE
132 KV---"X"	FALSE
132 KV---"Z"	FALSE

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RAMCHANDAPUR-ADITYAPUR (TB C-R)		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	8.3	ZONE-1 1.40
2> SYSTEM VOLTAGE=	132	R1G= 22.50
(RESISTANCE)- Per Km	0.1402	R1Ph= 10.00
(REACTANCE)- Per Km	0.3976	tZ1= 0.00
(IMPEDANCE)- Per Km	0.42159	KZ1 Res Comp= 0.70
LINE ANGLE=	68	KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	3459	ZONE-2 Z2= 2.12
4>C.T.RATIO=	600	R2G= 28.13
5>P.T.RATIO=	1200	R2Ph= 12.50
6>NEXT SHORTEST SECTION= (IN KM)(ADITYAPUR-UM)	3.5	tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(ADITYAPUR-RAMCHANDAPUR)	8.3	KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	20	ZONE-3/4 Z3= 4.20
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 0.35
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	200	KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	151	KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1	R3G/R4G= 35.16
14>SINGLE CKT (S) / DOUBLE CKT (D)=	D	R3Ph/R4Ph= 15.63
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 0.60
16>In	1	Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.24
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	82.53	Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.27
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305	Non-Dir.O/C Char..= DT
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	5.23	%PLUG SET= 100%
D>ARC RESISTANCE=(Sec Value)	10.00	TIME SET= 2Sec
E>TOWER FOOTING RESISTANCE=(Sec Value)	12.50	Non-Dir.E/F Char..= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	16.19	%PLUG SET= 20%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	0.60	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	80.97	LINE LENGTH= 8.3
I>Time- (ZONE-2)= (In Sec)	0.35	Z= 1.749599
J>Time- (ZONE-3)= (In Sec)	0.60	ANGLE= 68
K>FAULT MVA AT 80% OF THE LINE=	2223	

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **8.3**
 2> SYSTEM VOLTAGE= **132**
 (RESISTANCE)- Per Km **0.1402**
 (REACTANCE)- Per Km **0.3976**
 (IMPEDANCE)- Per Km **0.42159**
 LINE ANGLE= **68**
 3>FAULT MVA OF THE S/S= **3459**
 4>C.T.RATIO= **600**
 5>P.T.RATIO= **1200**
 6>NEXT SHORTEST SECTION= (IN KM)(ADITYAPUR-UM) **3.5**
 7>NEXT LONGEST SECTION= (IN KM)(ADITYAPUR-RKSN) **35**
 8>INFEED RATIO=[I(act)/I(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **20**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **200**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **151**
 13>X0/X1=R0/R1= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **D**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **95**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **82.53**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **5.23**
 D>ARC RESISTANCE=(Sec Value) **10.00**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **12.50**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **16.19**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **80.97**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **2223**

RAMCHANDAPUR-ADITYAPUR

MICOM P442

ZONE-1	Z1=	1.40
	R1G=	22.50
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	2.12
	R2G=	28.13
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	10.95
	Z4(Reverse)=	0.35
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	35.16
	R3Ph/R4Ph=	15.63
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
	TIME SET=	0.24
Dir.E/F	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	8.3
	Z=	1.749599
	ANGLE=	68

OTHERS(MHO)

ZONE-1	1.40
ZONE-2	2.12
ZONE-3(For)	10.95
ZONE-4(Rev)	0.35
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	6.98
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RAMCHANDAPUR-AAPL		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	4.26	ZONE-1 0.36
2> SYSTEM VOLTAGE=	132	ZONE-2 11.25
(RESISTANCE)- Per Km	0.1402	R1Ph= 5.00
(REACTANCE)- Per Km	0.3976	tZ1= 0.00
(IMPEDANCE)- Per Km	0.42159	KZ1 Res Comp= 0.70
LINE ANGLE=	68	KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	3459	Z2= 0.67
4>C.T.RATIO=	300	R2G= 14.06
5>P.T.RATIO=	1200	R2Ph= 6.25
6>NEXT SHORTEST SECTION= (IN KM)(AAPL-RAMCHANDAPUR)	4.26	tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(AAPL-RAMCHANDAPUR)	4.26	KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	20	Z3= 1.08
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 0.09
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	90	KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	75	KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1	R3G/R4G= 17.58
14>SINGLE CKT (S) / DOUBLE CKT (D)=	D	R3Ph/R4Ph= 7.81
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 0.60
16>In	1	Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.27
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	41.27	Dir.E/F Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.27
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305	Non-Dir.O/C Char..= DT
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	5.81	%PLUG SET= 100%
D>ARC RESISTANCE=(Sec Value)		TIME SET= 2Sec
E>TOWER FOOTING RESISTANCE=(Sec Value)	5.00	Non-Dir.E/F Char..= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	6.25	%PLUG SET= 20%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	39.20	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	0.60	LINE LENGTH= 4.26
I>Time- (ZONE-2)= (In Sec)	196.02	Z= 0.448993
J>Time- (ZONE-3)= (In Sec)	0.35	ANGLE= 68
K>FAULT MVA AT 80% OF THE LINE=	0.60	
	2691	

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = **8.3**
 2> SYSTEM VOLTAGE= **132**
 (RESISTANCE)- Per Km **0.1402**
 (REACTANCE)- Per Km **0.3976**
 (IMPEDANCE)- Per Km **0.42159**
 LINE ANGLE= **68**
 3>FAULT MVA OF THE S/S= **3045**
 4>C.T.RATIO= **600**
 5>P.T.RATIO= **1200**
 6>NEXT SHORTEST SECTION= (IN KM)(RAMCHANDAPUR-AAPL) **4.26**
 7>NEXT LONGEST SECTION= (IN KM)(RAMCHANDAPUR-ADITYAPUR) **8.3**
 8>INFEED RATIO=[I(act)/I(infeed)] **0**
 9>ARC RESISTANCE=(Pri Value) **20**
 10>TOWER- FOOTING RESISTANCE=(Pri Value) **25**
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) **450**
 12>MAXIMUM LOAD (110% CT)= (IN MVA) **151**
 13>X0/X1=R0/R1= **3.1**
 14>SINGLE CKT (S) / DOUBLE CKT (D)= **D**
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) **NO**
 16>In **1**
 17> CT SECONDARY= **1**
 18>THARMAL CAPACITY[40-75°C](MVA)= **95**
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) **82.53**
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] **51.96**

DERIVED VALUES

A) COMPENSATION (K)= **0.70**
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) **51.96305**
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) **2.32**
 D>ARC RESISTANCE=(Sec Value) **10.00**
 E>TOWER FOOTING RESISTANCE=(Sec Value) **12.50**
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= **14.89**
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) **0.60**
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= **74.46**
 I>Time- (ZONE-2)= (In Sec) **0.35**
 J>Time- (ZONE-3)= (In Sec) **1.00**
 K>FAULT MVA AT 80% OF THE LINE= **2045**

ADITYAPUR-RAMCHANDAPUR

MICOM P442

ZONE-1	Z1=	1.40
	R1G=	22.50
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	2.20
	R2G=	28.13
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	4.20
	Z4(Reverse)=	0.35
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	35.16
	R3Ph/R4Ph=	15.63
	tZ3=	1.00
Dir.O/C	Char..=	NI
	%PLUG SET=	100%
	TIME SET=	0.24
Dir.E/F	Char..=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char..=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char..=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	8.3
	Z=	1.749599
	ANGLE=	68

OTHERS(MHO)

ZONE-1	1.40
ZONE-2	2.20
ZONE-3(For)	4.20
ZONE-4(Rev)	0.35
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	4.07
Compensation	0.70

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE	ADITYAPUR-UM(CPP)	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	3.5	Z1= 0.59	ZONE-1 0.59
2> SYSTEM VOLTAGE=	132	R1G= 22.50	ZONE-2 1.11
(RESISTANCE)- Per Km	0.1402	R1Ph= 10.00	ZONE-3(For) 1.77
(REACTANCE)- Per Km	0.3976	tZ1= 0.00	ZONE-4(Rev) 0.15
(IMPEDANCE)- Per Km	0.42159	KZ1 Res Comp= 0.70	Time-(Z-2) 0.35
LINE ANGLE=	68	KZ1 Angle= 0.00	Time-(Z-3) 0.60
3>FAULT MVA OF THE S/S=	3045	Z2= 1.11	Time-(Z-4) 0.50
4>C.T.RATIO=	600	R2G= 28.13	IMP UPTO NEXT LEVEL 5.96
5>P.T.RATIO=	1200	R2Ph= 12.50	(80% OF TR IMP)
6>NEXT SHORTEST SECTION= (IN KM)(UM-ADITYAPUR)	3.5	tZ2= 0.35	Compensation 0.70
7>NEXT LONGEST SECTION= (IN KM)(UM-ADITYAPUR)	3.5	KZ2 Res Comp= 0.70	
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00	
9>ARC RESISTANCE=(Pri Value)	20	Z3= 1.77	
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 0.15	
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	200	KZ3/KZ4 Res Comp= 0.70	
12>MAXIMUM LOAD (110% CT)= (IN MVA)	151	KZ3/KZ4Angle= 0.00	
13>X0/X1=R0/R1=	3.1	R3G/R4G= 35.16	
14>SINGLE CKT (S) / DOUBLE CKT (D)=	D	R3Ph/R4Ph= 15.63	
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 0.60	
16>In	1	Char..= NI	
17> CT SECONDARY=	1	%PLUG SET= 100%	
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.25	
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	82.53	Dir.O/C Char..= NI	
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%	
<u>DERIVED VALUES</u>			
A) COMPENSATION (K)=	0.70	TIME SET= 0.27	
B>MAXIMUM LOADING (IN OHM)= (Sec Value)	51.96305	Non-Dir.O/C Char..= DT	
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value)	5.23	%PLUG SET= 100%	
D>ARC RESISTANCE=(Sec Value)		TIME SET= 2Sec	
E>TOWER FOOTING RESISTANCE=(Sec Value)	10.00	Non-Dir.E/F Char..= DT	
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	12.50	%PLUG SET= 20%	
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	18.39	TIME SET= 2Sec	
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	0.60	LINE LENGTH= 3.5	
I>Time- (ZONE-2)= (In Sec)	91.93	Z= 0.737783	
J>Time- (ZONE-3)= (In Sec)	0.35	ANGLE= 68	
K>FAULT MVA AT 80% OF THE LINE=	0.60		
	2524		

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.3976
132 KV---"Z"	0.42159

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

RELAY TYPE

1> LINE LENGTH = 19
 2> SYSTEM VOLTAGE= 132
 (RESISTANCE)- Per Km 0.1402
 (REACTANCE)- Per Km 0.401
 (IMPEDANCE)- Per Km 0.42473
 LINE ANGLE= 68
 3>FAULT MVA OF THE S/S= 3045
 4>C.T.RATIO= 600
 5>P.T.RATIO= 1200
 6>NEXT SHORTEST SECTION= (IN KM)(CHANDIL-GOLMURI) 30
 7>NEXT LONGEST SECTION= (IN KM)(CHANDIL-TOMAR) 60
 8>INFEED RATIO=[I_{act}/I_{infeed}] 0
 9>ARC RESISTANCE=(Pri Value) 20
 10>TOWER- FOOTING RESISTANCE=(Pri Value) 25
 11>TRANSFORMER AT OTHER END S/S=(IN MVA) 400
 12>MAXIMUM LOAD (110% CT)= (IN MVA) 151
 13>X₀/X₁=R₀/R₁= 3.1
 14>SINGLE CKT (S) / DOUBLE CKT (D)= S
 15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO) NO
 16>In 1
 17> CT SECONDARY= 1
 18>THARMAL CAPACITY[40-75°C](MVA)= 95
 19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING) 82.53
 20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE] 51.96

DERIVED VALUES

A) COMPENSATION (K)= 0.70
 B>MAXIMUM LOADING (IN OHM)= (Sec Value) 51.96305
 C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)= (Sec Value) 2.61
 D>ARC RESISTANCE=(Sec Value) 10.00
 E>TOWER FOOTING RESISTANCE=(Sec Value) 12.50
 F>If/In (PHASE FAULT AT 80%OF THE LINE)= 10.42
 G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec) 0.60
 H>If/In (EARTH FAULT AT 80% OF THE LINE)= 52.10
 I>Time- (ZONE-2)= (In Sec) 0.35
 J>Time- (ZONE-3)= (In Sec) 1.00
 K>FAULT MVA AT 80% OF THE LINE= 1431

ADITYAPUR-CHANDIL

MICOM P442

ZONE-1	Z1=	3.23
	R1G=	22.50
	R1Ph=	10.00
	tZ1=	0.00
	KZ1 Res Comp=	0.70
	KZ1 Angle=	0.00
ZONE-2	Z2=	6.65
	R2G=	28.13
	R2Ph=	12.50
	tZ2=	0.35
	KZ2 Res Comp=	0.70
	KZ2 Angle=	0.00
ZONE-3/4	Z3=	20.13
	Z4(Reverse)=	0.81
	KZ3/KZ4 Res Comp=	0.70
	KZ3/KZ4Angle=	0.00
	R3G/R4G=	35.16
	R3Ph/R4Ph=	15.63
Dir.O/C	tZ3=	1.00
	Char.=	NI
	%PLUG SET=	100%
Dir.E/F	TIME SET=	0.20
	Char.=	NI
	%PLUG SET=	20%
	TIME SET=	0.27
Non-Dir.O/C	Char.=	DT
	%PLUG SET=	100%
	TIME SET=	2Sec
Non-Dir.E/F	Char.=	DT
	%PLUG SET=	20%
	TIME SET=	2Sec
LINE	LENGTH=	19
	Z=	4.034935
	ANGLE=	68

OTHERS(MHO)

ZONE-1	3.23
ZONE-2	6.65
ZONE-3(For)	20.13
ZONE-4(Rev)	0.81
Time-(Z-2)	0.35
Time-(Z-3)	1.00
Time-(Z-4)	0.50
IMP UPTO NEXT LEVEL (80% OF TR IMP)	6.65
Compensation	0.70

LINE PARAMERERS

400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

DISTANCE RELAY SETTING CALCULATION

SYSTEM DATA

ADITYAPUR-RKSN		
RELAY TYPE	MICOM P442	OTHERS(MHO)
1> LINE LENGTH =	35	ZONE-1 3.96
2> SYSTEM VOLTAGE=	132	R1G= 15.00
(RESISTANCE)- Per Km	0.1402	R1Ph= 6.67
(REACTANCE)- Per Km	0.401	tZ1= 0.00
(IMPEDANCE)- Per Km	0.42473	KZ1 Res Comp= 0.70
LINE ANGLE=	68	KZ1 Angle= 0.00
3>FAULT MVA OF THE S/S=	3045	Z2= 6.37
4>C.T.RATIO=	400	R2G= 18.75
5>P.T.RATIO=	1200	R2Ph= 8.33
6>NEXT SHORTEST SECTION= (IN KM)(RKSN-CHAIBASA)	20	tZ2= 0.35
7>NEXT LONGEST SECTION= (IN KM)(RKSN-GOELKERA)	58	KZ2 Res Comp= 0.70
8>INFEED RATIO=[I(act)/I(infeed)]	0	KZ2 Angle= 0.00
9>ARC RESISTANCE=(Pri Value)	20	Z3= 15.80
10>TOWER- FOOTING RESISTANCE=(Pri Value)	25	Z4(Reverse)= 0.99
11>TRANSFORMER AT OTHER END S/S=(IN MVA)	70	KZ3/KZ4 Res Comp= 0.70
12>MAXIMUM LOAD (110% CT)= (IN MVA)	101	KZ3/KZ4Angle= 0.00
13>X0/X1=R0/R1=	3.1	R3G/R4G= 23.44
14>SINGLE CKT (S) / DOUBLE CKT (D)=	S	R3Ph/R4Ph= 10.42
15>ADDITIONAL Dir.O/C,E/F RELAY USED=(YES/NO)	NO	tZ3= 1.00
16>In	1	Dir.O/C Char..= NI
17> CT SECONDARY=	1	%PLUG SET= 100%
18>THARMAL CAPACITY[40-75°C](MVA)=	95	TIME SET= 0.21
19>LOAD IMP..(90% VOLTAGE & [40-75°C]THER.. RATING)	55.02	Dir.E/F Char..= NI
20>MAX LOAD IMP= (Sec)[110% CT RATING with 90% VOLTAGE]	51.96	%PLUG SET= 20%
<u>DERIVED VALUES</u>		
A) COMPENSATION (K)=	0.70	TIME SET= 0.27
B>MAXIMUM LOADING (IN OHM)=(Sec Value)	51.96305	Non-Dir.O/C Char..= DT
C>IMPEDANCE/REACTANCE UPTO 80% OF OTHER END TRANSFORMER (%Z=12)=(Sec Value)	9.96	%PLUG SET= 100%
D>ARC RESISTANCE=(Sec Value)	6.67	TIME SET= 2Sec
E>TOWER FOOTING RESISTANCE=(Sec Value)	8.33	Non-Dir.E/F Char..= DT
F>If/In (PHASE FAULT AT 80%OF THE LINE)=	10.81	%PLUG SET= 20%
G>FIRST STAGE BACK UP O/C & E/F TIME=(In Sec)	0.60	TIME SET= 2Sec
H>If/In (EARTH FAULT AT 80% OF THE LINE)=	54.03	LINE LENGTH= 35
I>Time- (ZONE-2)= (In Sec)	0.35	Z= 4.955183
J>Time- (ZONE-3)= (In Sec)	1.00	ANGLE= 68
K>FAULT MVA AT 80% OF THE LINE=	989	

LINE PARAMERERS	
400 KV---"R"	FALSE
400 KV---"X"	FALSE
400 KV---"Z"	FALSE
220 KV---"R"	FALSE
220 KV---"X"	FALSE
220 KV---"Z"	FALSE
132 KV---"R"	0.1402
132 KV---"X"	0.401
132 KV---"Z"	0.42473

OVER CURRENT TIME 220kV Chandil S/s

220kV Chandil S/s

BASE MVA=	100
BASE VOLTAGE=	400
Ω/KM=	0.4
HV LINES=	0
TRANSFORMER=	3
LV LINES=	1

OVER CURRENT TIME 220kV HATIA S/s

220kV Hatia S/s

BASE MVA= **100**
 BASE VOLTAGE= **132**
 Ω/KM= **0.4**
 HV LINES= **0**
 TRANSFORMER= **3**
 LV LINES= **1**

	SOURCE	HV			LV			HV			LV			FAULT
		220	220	220	220	132	220	132	220	132	132	132	132	
(actual fault level)	MVA	(KM)	(KM)	(KM)	MVA	(%) IMP	MVA	(%) IMP	MVA	(%) IMP	(KM)	(KM)	(KM)	(Ω)
4329	4329	1E-28	1E-13	1E-20	150	12	150	12	150	12	21.6	1E+20	1E+41	0
(Ω)		4E-29	4E-14	4E-21		13.9392		13.9392		13.9392	8.64	4E+19	4E+40	0
PU=	0.0231	8.26446E-32	8.26446E-17	8.26E-24		0.08		0.08		0.08	0.049587	2.3E+17	2.3E+38	0
TOTAL PU=	0.099353													
FAULT MVA=	1006.507													
Req=			8.26446E-32					0.02667			0.049587			

OVER CURRENT TIME 220kV RCP S/s

220kV Ramchandrapur S/s

BASE MVA= **100**
 BASE VOLTAGE= **132**
 Ω/KM= **0.4**
 HV LINES= **0**
 TRANSFORMER= **3**
 LV LINES= **1**

	SOURCE	220	220	220	HV	LV	HV	LV	HV	LV	132	132	132	132
		LINE-1	LINE-2	LINE-3	220	132	220	132	220	132	132	132	132	132
(actual fault level)	MVA	(KM)	(KM)	(KM)	TR#1		TR#2		TR#3		LINE-1	LINE-2	LINE-3	FAULT
6873	6873	1E-28	1E-13	1E-20	150	12	150	12	150	12	4	1E+20	1E+41	0
(Ω)		4E-29	4E-14	4E-21		13.9392		13.9392		13.9392	1.6	4E+19	4E+40	0
PU=	0.01455	8.26446E-32	8.26446E-17	8.26E-24		0.08		0.08		0.08	0.009183	2.3E+17	2.3E+38	0
TOTAL PU=	0.050399													
FAULT MVA=	1984.163													
Req=			8.26446E-32					0.02667			0.009183			

Annexure-7.2

Over current Settings of 220/132 kV Transformers of JUSNL

1. 220/132 kV Chandil S/s: 4x100 MVA Auto-transformers

Considerations: 220 kV Fault level: 5403 MVA

Recommended settings for all 100 MVA Auto-transformer:			
	HV side (220 kV)	LV side (132 kV)	Remarks
Available CT Ratio	600/1	600/1	
PSM	0.4	0.6	Standard Inverse Characteristics
TSM	0.175	0.175	
High Set	10	8	To be implemented if directional feature is available.

2. 220/132 kV Ramchandrapur S/s: 3x150 MVA Auto-transformers

Considerations: 220 kV Fault level: 6873 MVA

Recommended settings for all 150 MVA Transformer:			
	HV side (220 kV)	LV side (132 kV)	Remarks
Available CT Ratio	600/1	600/1	
PSM	0.75	1.1	Standard Inverse Characteristics
TSM	0.2	0.1	
High Set	10	8	To be implemented if directional feature is available.


3. 220/132 kV Hatia-II S/s: 3x150 MVA Auto-transformers

Considerations: 220 kV Fault level: 4329 MVA

Recommended settings for 150 MVA Transformer I & II:			
	HV side (220 kV)	LV side (132 kV)	Remarks
Available CT Ratio	600/1	800/1	
PSM	0.75	0.9	Standard Inverse Characteristics
TSM	0.175	0.175	
High Set	10	8	To be implemented if directional feature is available.

Recommended settings for 150 MVA Transformer III:			
	HV side (220 kV)	LV side (132 kV)	Remarks
Available CT Ratio	1200/1	800/1	
PSM	0.375	0.9	Standard Inverse Characteristics
TSM	0.175	0.175	
High Set	10	8	To be implemented if directional feature is available.

Annexure-8.1.1



Annexure- 8.1.2

Sl. No.	Name of Feeders	Name of Equipment	Details of equipment	Year of Manufacturing
1	220Kv PGCIL	CT	R Phase	2009
		CT	Y Phase	2006
		CT	B Phase	2007
2	220Kv RCP	CT	R Phase	1996
		CT	Y Phase	2006
		CT	B Phase	1996
3	220Kv STPS	CT	R Phase	2013
		CT	Y Phase	2013
		CT	B Phase	2013
4	100 MVA Tr-I (220kv SIDE)	CT	R Phase	2005
		CT	Y Phase	1981
		CT	B Phase	1981
5	100 MVA Tr-II (220kv SIDE)	CT	R Phase	1975
		CT	Y Phase	1975
		CT	B Phase	1975
6	100 MVA Tr-III (220kv SIDE)	CT	R Phase	1975
		CT	Y Phase	1975
		CT	B Phase	1975
7	100 MVA Tr-IV (220kv SIDE)	CT	R Phase	2013
		CT	Y Phase	2013
		CT	B Phase	2013
8	220Kv B/C	CT	R Phase	1981
		CT	Y Phase	1981
		CT	B Phase	2007
9	132KV Hatia (IDEAL BAY)	CT	R Phase	2005
		CT	Y Phase	2005
		CT	B Phase	2005
10	132Kv MIK	CT	R Phase	1981
		CT	Y Phase	1981
		CT	B Phase	1981
11	132Kv Golmuri-I	CT	R Phase	1984
		CT	Y Phase	1984
		CT	B Phase	1984
12	132Kv Golmuri-II	CT	R Phase	1992
		CT	Y Phase	1992
		CT	B Phase	1992
13	100 MVA Tr-I (132kv SIDE)	CT	R Phase	2007
		CT	Y Phase	1981
		CT	B Phase	1981
14	100 MVA Tr-II (132kv SIDE)	CT	R Phase	1975
		CT	Y Phase	1975
		CT	B Phase	1975
15	100 MVA Tr-III (132kv SIDE)	CT	R Phase	1975
		CT	Y Phase	1975
		CT	B Phase	1975
16	100 MVA Tr-IV (132kv SIDE)	CT	R Phase	2007
		CT	Y Phase	2007
		CT	B Phase	2012
17	132Kv B/C	CT	R Phase	1997
		CT	Y Phase	1997
		CT	B Phase	1986
18	132Kv RKSН	CT	R Phase	2013
		CT	Y Phase	2013
		CT	B Phase	2013
19	132Kv ADPUR	CT	R Phase	1997
		CT	Y Phase	1997
		CT	B Phase	1986
		PT	R Phase	1981

20	132 KV Main Bus PT	PT	Y Phase	1981
		PT	B Phase	1981
21	220 KV Main Bus PT-I	PT	R Phase	1984
		PT	Y Phase	1984
22	220 KV Main Bus PT-II	PT	B Phase	1984
		PT	R Phase	2012
		PT	Y Phase	2012
23	220Kv PGCIL	Breaker		2005
24	220Kv RCP	Breaker		2006
25	220Kv STPS	Breaker		2014
26	100 MVA Tr-I (132kv SIDE)	Breaker		1987
27	100 MVA Tr-II (132kv SIDE)	Breaker		2005
28	100 MVA Tr-III (132kv SIDE)	Breaker		1993
29	100 MVA Tr-IV (132kv SIDE)	Breaker		2013
30	220Kv B/C	Breaker		1993
31	132KV Hatia (IDEAL BAY)	Breaker		2005
32	132Kv MIK	Breaker		2008
33	132Kv Golmuri-I	Breaker		2008
34	132Kv Golmuri-II	Breaker		2008
35	100 MVA Tr-I (132kv SIDE)	Breaker		2001
36	100 MVA Tr-II (132kv SIDE)	Breaker		2008
37	100 MVA Tr-III (132kv SIDE)	Breaker		2008
38	100 MVA Tr-IV (132kv SIDE)	Breaker		2008
39	132Kv B/C	Breaker		2008
40	132Kv RKSН	Breaker		2005

41	132Kv ADPUR	Breaker		2008
42	220/132 KV 100 MVA Tr.-I	Transformer		2001
43	220/132 KV 100 MVA Tr.-II	Transformer		2006
44	220/132 KV 100 MVA Tr.-III	Transformer		1966
45	220/132 KV 100 MVA Tr.-IV	Transformer		2013

CT details of 220/132 KV Chandil GSS

Sl. No.	Name of Feeders	Comprehensive C.T. details	Make	CT ratio	Connected Ratio	Core No.	Class of accuracy	Protection class use	Knee voltage
1	220Kv PGCL	R Phase	Areva	1200/600/300/150/1A	600/1Amp	4 core	0.2	PS	
		Y Phase	Areva	1200/600/300/150/1A			0.2	PS	
		B Phase	BHEL	1200/600/300/150/1A			0.2	PS	
2	220Kv RCP	R Phase	Balteau	1200/600/300/150/1A	600/1Amp	4 core	1	PS	
		Y Phase	Areva	1200/600/300/150/1A			0.2	PS	
		B Phase	Balteau	1200/600/300/150/1A			1	PS	
3	220Kv STPS	R Phase	SCT LTD.(UP)	600/300/150/1A	600/1Amp	3 core	0.5	PS	
		Y Phase	SCT LTD.(UP)	600/300/150/1A			0.5	PS	
		B Phase	SCT LTD.(UP)	600/300/150/1A			0.5	PS	
4	100 MVA Tr-I (220kv SIDE)	R Phase	BHEL	800/400/200/1A	800/1 Amp	3 core	0.2	PS	
		Y Phase	Balteau	800/400/200/1A			1	PS	
		B Phase	Balteau	800/400/200/1A			1	PS	
5	100 MVA Tr-II (220kv SIDE)	R Phase	Balteau	800/400/200/1A	800/1 Amp	3 core	1	PS	
		Y Phase	Balteau	800/400/200/1A			1	PS	
		B Phase	Balteau	800/400/200/1A			1	PS	
6	100 MVA Tr-III (220kv SIDE)	R Phase	Balteau	800/400/200/1A	800/1 Amp	3 core	1	PS	
		Y Phase	Balteau	800/400/200/1A			1	PS	
		B Phase	Balteau	800/400/200/1A			1	PS	
7	100 MVA Tr-Iv (220kv SIDE)	R Phase	BHEL	800/400/200/1A	800/1 Amp	3 core	0.5	PS	
		Y Phase	BHEL	800/400/200/1A			0.5	PS	
		B Phase	BHEL	800/400/200/1A			0.5	PS	
8	220Kv B/C	R Phase	Balteau	1200/600/300/150/1A	600/1 Amp	4 core	1	PS	
		Y Phase	Balteau	1200/600/300/150/1A		4 core	1	PS	
		B Phase	SCT LTD.(UP)	1200/600/300/1A		3 core	0.5	PS	
9	132KV Hatia (IDEAL)	R Phase	SCT LTD.(UP)	600/300/150/1A	600/1A	3 core	0.5	PS	
		Y Phase	SCT LTD.(UP)	600/300/150/1A			0.5	PS	
		B Phase	SCT LTD.(UP)	600/300/150/1A			0.5	PS	
10	132KV MIK	R Phase	ASEA	800/400/200/1A	800/1A	3 core	1	PS	
		Y Phase	ASEA	800/400/200/1A			1	PS	
		B Phase	ASEA	800/400/200/1A			1	PS	
	132Kv	R Phase	BHEL	400/200/100/1A			1	PS	

11	Golmuri-I	Y Phase	BHEL	800/400/200/1A	400/1A	3 core	1	PS	
		B Phase	BHEL	800/400/200/1A			1	PS	
12	132Kv Golmuri-II	R Phase	SCT LTD.(UP)	400/200/100/1A	400/1A	3 core	1	PS	
		Y Phase	SCT LTD.(UP)	400/200/100/1A			1	PS	
		B Phase	SCT LTD.(UP)	400/200/100/1A			1	PS	
13	100 MVA Tr-I	R Phase	SCT LTD.(UP)	800/400/200/1A	800/1A	3 core	0.5	PS	
		Y Phase	ASEA	800/400/200/1A			1	PS	
		B Phase	ASEA	800/400/200/1A			1	PS	
14	100 MVA Tr-II	R Phase	ASEA	800/400/200/1A	800/1A	3 core	1	PS	
		Y Phase	ASEA	800/400/200/1A			1	PS	
		B Phase	ASEA	800/400/200/1A			1	PS	
15	100 MVA Tr-III	R Phase	ASEA	800/400/200/1A	800/1A	3 core	1	PS	
		Y Phase	ASEA	800/400/200/1A			1	PS	
		B Phase	ASEA	800/400/200/1A			1	PS	
16	100 MVA Tr-IV	R Phase	Victrans eng.	800/400/200/1A	800/1A	3 core	0.5	PS	
		Y Phase	Victrans eng.	800/400/200/1A			0.5	PS	
		B Phase	SCT LTD.(UP)	800/400/200/1A			0.5	PS	
17	132Kv B/C	R Phase	SCT LTD.(UP)	1200/600/1A	600/1A	2 core	1	PS	
		Y Phase	SCT LTD.(UP)	1200/600/1A		2 core	1	PS	
		B Phase	Brown Bowri	600/300/150/1A		3 core	1	PS	
18	132Kv RKSN	R Phase	SCT LTD.(UP)	1200/600/300/1A	600/1A	3 core	0.2	PS	
		Y Phase	SCT LTD.(UP)	1200/600/300/1A			0.2	PS	
		B Phase	SCT LTD.(UP)	1200/600/300/1A			0.2	PS	
19	132Kv ADPUR	R Phase	Brown Bowri	600/300/150/1A	600/1A	3 core	1	PS	
		Y Phase	Brown Bowri	600/300/150/1A			1	PS	
		B Phase	Brown Bowri	600/300/150/1A			1	PS	

Annexure-8.1.4

VT details of 220/132 KV Chandil GSS

Sl. No.	V.T. details	Comprehensive P.T. details	Make	Core No.	Class of accuracy
1	132 KV Main Bus PT	R Phase	ASEA	4 Core	5
		Y Phase	ASEA	4 Core	5
		B Phase	ASEA	4 Core	5
2	220 KV Main Bus PT-I	R Phase	Balteau	2 Core	1/5
		Y Phase	Balteau	2 Core	1/5
		B Phase	Balteau	2 Core	1/5
3	220 KV Main Bus PT-II	R Phase	SCT LTD.(UP)	3 Core	0.2/3P/3P
		Y Phase	SCT LTD.(UP)	3 Core	0.2/3P/3P
		B Phase	SCT LTD.(UP)	3 Core	0.2/3P/3P

Fault level at JUSNL Sub-stations

Bus Name	Bus Voltage	3 Ph Fault current	SLG Fault current
CHANDIL 220	220	14514	9735
RAMCHANDRAPUR 220	220	18450	15443
CHANDIL	132	18105	12652
ADITPUR	132	12098	8624
RAMCHANDRAPUR 132	132	13000	11126

Note: Data received from ERLDC

TRANSFORMERS DETAILS OF GSS CHANDIL -1

1. 100MVA TR NO.1:- EMCO TRANSFORMER (MAHARASTRA).

YEAR OF MANUFACTURE-2000-2001

Voltage: -220/132/33kv

100/80/50MVA

Impedance voltage

HV-LV tap1-7.49%, tap5 (normal)-7.41%, tap17-7.56%

2. 100MVA TR-2:- KANOHAR ELECTRICALS LTD, MERUT (INDIA).

YEAR OF MANUFACTURE-2006

Voltage: -220/132/33kv

100/80/50MVA

Impedance voltage

HV-LV tap1-7.03%, tap5 (normal)-6.98%, tap17-7.08%

HV-TER -25.54%, LV-TER- 15.99%

3. 100MVA TR- 3:- CANADIAN WESTING HOUSE CO.LTD.HAMILTON CANADA.

YEAR OF MANUFACTURE-2006

Voltage: -220/132/33k

100/80/60MVA

Impedance voltage

HV-LV-7.4%, HV-TV-25.5%, LV-TV-17.4% (at normal tap)

4. 100MVA TR 4:- TRANSFORMERS & RECTIFIERS (INDIA) LTD, VILL – CHANGODAR , TA – SANAND,DIST –AHMEDABAD (GUJARAT).

YEAR OF MANUFACTURE-2013

Voltage: -220/132/33k

100/80/60MVA

Impedance voltage

HV-IV-7.22%, IV-LV-16.19%, HV-LV-25.36% (at normal tap no.5)

HV-IV-7.35% (at tap no.1)

HV-IV-7.27% (at tap no.17)

A9

*DLBhu
24/11/15*

Assistant Executive Engineer
Transmission Sub-Division
Chandil - I

Annexure-8.1.7

Cable details used for C.T. connection of Chandil S/s

Sl No.	Name of Feeder	No. of Cable use C.T.		Cross section of cable	Length of cable J/B to C/R panel
1	Hatia	10 Core	1 No.	2.5 Sq. mm	115 mtr
2	PGCIL	18	1	2.5 Sq. mm	137 mtr
3	220 KV Tr.-I	4	3	2.5 Sq. mm	148 mtr
4	STPS	20	1	2.5 Sq. mm	159 mtr
5	220 KV Tr.-II	4	3	2.5 Sq. mm	181 mtr
6	220 KV B/C	4	3	2.5 Sq. mm	214 mtr
7	220 KV Tr.-III	4	3	2.5 Sq. mm	226 mtr
8	220 KV Tr.-IV	18,10,4,2	1,1,1,4	2.5 Sq. mm	248 mtr
9	220 KV RCP	4	3	2.5 Sq. mm	270 mtr
10	132 KV Hatia	12	1	2.5 Sq. mm	104 mtr
11	MIK	12	1	2.5 Sq. mm	106 mtr
12	132 KV Tr.-I	4	3	2.5 Sq. mm	119 mtr
13	132 KV Tr.-II	4	3	2.5 Sq. mm	130 mtr
14	132 KV B/C	4	3	2.5 Sq. mm	152 mtr
15	GOL-I	12	1	2.5 Sq. mm	163 mtr
16	GOL-II	12	1	2.5 Sq. mm	176 mtr
17	132 KV Tr.-III	4	3	2.5 Sq. mm	186 mtr
18	132 KV Tr.-IV	12,6,2	1,1,2	2.5 Sq. mm	218 mtr
19	ADPUR	6	2	2.5 Sq. mm	253 mtr
20	RKSN	6	2	2.5 Sq. mm	285 mtr

Annexure-8.1.8

Measurement of Earth Resistance Name of G/S/S = 220/132KV Chandil

132KV Side

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	132KV Hatia	2 Ohm	
2	132KV Maniqui	2 Ohm	
3	132 KV Golmuri-I	1 Ohm	
4	132KV Golmuri-II	0.5 Ohm	
5	132 KV RKSN		

220 KV side

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	220 KV STPS earth pit-1	0.7 ohm	
2	220 KV STPS earth pit-2	0.4 ohm	
3	220KV STPS south side-1	0.6 ohm	
4	220KV STPS south side-2	0.4 ohm	
5	220KV B/C pit 1	0.3 ohm	
6	220KV B/C pit 2	0.4 ohm	

Near Transformer Side

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	Tr.No-1 (132Kv Side)	0.4 ohm	
2	Tr.No-2 (132Kv Side)	0.3 ohm	
3	Tr.No-2 (SST Side)	0.2 ohm	
4	Tr.No-3 (132Kv Side)1	0.3 ohm	
5	Tr.No-3 (132Kv Side)2	0.2 ohm	
6	Tr.No-3 (220Kv Side)	0.2 ohm	
7	Tr.No-4 (132Kv Side)	0.4 ohm	
8	Tr.No-4 (220Kv Side)	0.2 ohm	

Control room Side

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	220 KV Side	0.70 ohm	
2	132 KV Side	0.70 ohm	
3	Near Control Room	0.75 ohm	

CIRCUIT BREAKER TEST REPORT

Site Name :- Chandi 220 / 132 kV S/S.
 Date of testing :- 10.09.14.
 Feeder name :- Transformer - 1 (132 kV side).

Name Plate details

Make	:- CGT L.	Serial number	:- 13782C
Rated Current	:- 3150A.	Type	:- 120-SFM-32A.
Rated Voltage	:- 145 kV.	Short Time Amps	:- 40kA / 3sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	90	89	88
Opening time for trip coil 1	24	24	25
Closing-Opening time for trip coil 1	—	—	—
Opening time for trip coil 2	23	23	24
Closing-Opening time for trip coil 2	—	—	—

Remarks:-

ok. for closing & opening. But C-O timing is "0" ms. hence Mechanical Adjustment - for closing spring.

	Tested By	Witness By	Witness By
Signature	Aitash Ghosh	J. P. Bhattacharya 11/9/14	D. K. Banerjee 11/9/14
Name			
Date	10.09.14.	AEE/T&E	ARZ/Chandil-I

CIRCUIT BREAKER TEST REPORT

Site Name
Date of testing
Feeder name

:- Chandi 220 KV / 132 KV S/S.
:- 10.09.14.
:- 220 KV Transformer -1.

Name Plate details

Make	:- HINDUSTAN BROWN BOVERE	Serial number	:- 1B103398.
Rated Current	:- 3150A.	Type	:- ELF Q45 NO-2.
Rated Voltage	:- 245 KV	Short Time Amps	:- 76KA/3sec.

TEST RESULTS :-

A. Operating time (In milli Secor.):-

Conditions	R-R'	Y-Y'	B-B'
Closing time	117	110	109.
Opening time for trip coil 1	21	21	36
Closing-Opening time for trip coil 1	29	29	31
Opening time for trip coil 2	21	21	36
Closing-Opening time for trip coil 2	29	29	31.

Remarks. OK. No problem found during testing.

	Tested By	Witness By	Witness By
Signature	Amit sharma	J. H. J. H.	J. H. J. H.
Name		11/09/14	11/09/14
Date	11.09.14.	REC/TSC	AZB/Chandik

(21)

CIRCUIT BREAKER TEST REPORT

Site Name :- Chardhi 220 kV / 132 kV S/S.
 Date of testing :- 11.09.14.
 Feeder name :- Transformer -2 (132 kV side).

Name Plate details

Make	AREVA.	Serial number	102834.
Rated Current	3150 A.	Type	40 KA / 3 SEC ↑↓
Rated Voltage	145 kV	Short Time Amps	FK3 - 1

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	73	69	69
Opening time for trip coil 1	39	39	39
Closing-Opening time for trip coil 1	69	71	72
Opening time for trip coil 2	40	40	39
Closing-Opening time for trip coil 2	69	71	72

Remarks: OK. No problem found during testing.

	Tested By	Witness By	Witness By
Signature	Adarsh Chaturvedi	J. J. Shinde 11/09/14	M. M. Pawar 11/09/14
Name		PEETI TEC	
Date	11.09.14.		A. B. Chandil

D. R. Bhosle
16.12.15
Electrical Executive

D. R. Bhosle
16.12.15
Assistant Manager

(24)

CIRCUIT BREAKER TEST REPORT

Site Name :- Chandi [220/132 s/s].
 Date of testing :- 09.09.14.
 Feeder name :- Transformer - 3 (132 KV side).

Name Plate details

Make	CGT L.	Serial number	26418C
Rated Current	3150 A.	Type	120-SFM-32B
Rated Voltage	145 KV	Short Time Amps	40 KA / 3 SEC.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	93	94	93
Opening time for trip coil 1	27	26	27
Closing-Opening time for trip coil 1	34	33	34
Opening time for trip coil 2	27	26	27
Closing-Opening time for trip coil 2	34	33	34

Remarks :- ok, no problem carried out during testing.

	Tested By	Witness By	Witness By
Signature	Avinash Chaturvedi	H.H.	V.Kumar
Name		11/09/14	11/09/14
Date	09.09.14.	Asst/ PEC	ABB/Chadilal

CIRCUIT BREAKER TEST REPORT

Site Name :- Chandil 220/132 S/C.
 Date of testing :- 09.09.14.
 Feeder name :- 132 KV Adityapur line.

Name Plate details

Make	:- CGL.	Serial number	:- 26417C.
Rated Current	:- 3150A.	Type	:- 120-SFM-32B.
Rated Voltage	:- 145KV.	Short Time Amps	:- 40KA /3 sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	94	97	96
Opening time for trip coil 1	26	24	26
Closing-Opening time for trip coil 1	38	36	38
Opening time for trip coil 2	24	24	26
Closing-Opening time for trip coil 2	38	34	38

Remarks :- ok. No problem carried out during testing.

	Tested By	Witness By	Witness By
Signature	Anil Bhowmik	Subho 11/09/14	Subho 11/09/14
Name			
Date	11.09.14	SEC/TSC	Abhishek Khadilkar

CIRCUIT BREAKER TEST REPORT

Site Name :- 220 kV / 132 kV chandil s/s.
 Date of testing :- 10.09.14.
 Feeder name :- Transformer - 2 [220 kV side].

Name Plate details

Make	:- CGL.	Serial number	:- 20130C(R)
Rated Current	:- 3150 A.	Type	:- 20131C(LY)
Rated Voltage	:- 245 kV	Short Time Amps	:- 200-SFM-40-S 40 kA / 3 sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	132	125	136
Opening time for trip coil 1	24	22	24
Closing-Opening time for trip coil 1	31	28	37
Opening time for trip coil 2	24	22	24
Closing-Opening time for trip coil 2	31	38	37

Remarks. For closing mechanism adjustment needed.

	Tested By	Witness By	Witness By
Signature Name	Anil Kumar	15th 11/09/14	20th 11/09/14
Date	10.09.14.	REC/TDC	ABD/Chandil-L

(19)

CIRCUIT BREAKER TEST REPORT

Site Name :- chandil 220 /132 KV S/S.
 Date of testing :- 10.09.14.
 Feeder name :- 220 KV side "Toyo - 3" (Transformer - 3).

Name Plate details

Make	- CGL.	Serial number	- 6067-C
Rated Current	- 1600 A.	Type	- not visible at site.
Rated Voltage	- 245 KV	Short Time Amps	- 90 KA / 3 sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	94	97	84.
Opening time for trip coil 1	24	25	23
Closing-Opening time for trip coil 1	12	14	18
Opening time for trip coil 2	22	25	23.
Closing-Opening time for trip coil 2	12	14	18

Remarks. OK. No Problem found during testing.

	Tested By	Witness By	Witness By
Signature	Amit Ghosh.	Jitendra 11/09/14	Dinesh 11/09/14
Name			
Date	11.09.14	08/12/14	Amit Chandi - I

CIRCUIT BREAKER TEST REPORT

Site Name :- Chandil 220 kV / 132 kV S/S.
 Date of testing :- 09.09.14.
 Feeder name :- Goli mori - 1

Name Plate details

Make	AREVA.	Serial number	102829
Rated Current	3150A.	Type	FK3-1
Rated Voltage	145 kV	Short Time Amps	40 kA / 3 sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	69	68	71
Opening time for trip coil 1	39	39	40
Closing-Opening time for trip coil 1	62	62	61
Opening time for trip coil 2	39	39	40
Closing-Opening time for trip coil 2	62	62	61

Remarks :- ok. no problem carried out during testing.

	Tested By	Witness By	Witness By
Signature	Arvind Ghosh	Subhash	Subhash
Name		11/09/14	11/09/14
Date	11.09.14.	ASSETTEC	ABBP/Chandil

16.12.15
Electrical Executive Engg.

Mr. B. K. Assistant Electrical Engineer

CIRCUIT BREAKER TEST REPORT

Site Name
Date of testing
Feeder name

:- Darhi 220 / 132 kv S/S.
:- 09.09.14.
:- Golmuri - 2.

Name Plate details

Make	:- CGL	Serial number	:- 26419C
Rated Current	:- 43150 A	Type	:- 120-SFM-32-B
Rated Voltage	:- 145 KV	Short Time Amps	:- 40 KA / SSR.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	91	92	91
Opening time for trip coil 1	29	28	29
Closing-Opening time for trip coil 1	40	41	41
Opening time for trip coil 2	30	29	30
Closing-Opening time for trip coil 2	41	41	41

Remarks :- ok. no problem carried out - during testing.

	Tested By	Witness By	Witness By
Signature	Arun Sharma	11/09/14	20/09/14
Name		BOE/T&C	
Date	11.09.14		ABD/Chaitil - 1

CIRCUIT BREAKER TEST REPORT

Site Name
Date of testing
Feeder name

- Chandil 220 KV / 132 KV S/S.
- 10.09.14.
- Hatia.

Name Plate details

Make	- CGT L.	Serial number	- 20146C
Rated Current	- 3150 A.	Type	- 120-SFM-32-B
Rated Voltage	- 145 KV	Short Time Amps	- 40 KA (3sec.)


TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	94	94	93
Opening time for trip coil 1	28	27	28
Closing-Opening time for trip coil 1	45	45	44
Opening time for trip coil 2	28	28	28
Closing-Opening time for trip coil 2	45	45	44

Remarks:- - ok. No problem carried out during testing.

	Tested By	Witness By	Witness By
Signature	Amit Chandra	AJKS 11/09/14	ZBKL 11/09/14
Name			
Date	11.09.14.	AEET REC	ABD/Chaitanya


Amit Chandra
16/12/15

CIRCUIT BREAKER TEST REPORT

Site Name :- Chandi 220 / 132 kV S/S.
 Date of testing :- 10.09.14.
 Feeder name :- Mankui - feeder.

Name Plate details

Make	:- AREVA.	Serial number	:- 102848
Rated Current	:- 3150 A.	Type	:- FK3-1
Rated Voltage	:- 145 kV	Short Time Amps	:- 40kA 13 sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	70	70	68
Opening time for trip coil 1	37	36	37
Closing-Opening time for trip coil 1	54	54	56
Opening time for trip coil 2	38	37	36
Closing-Opening time for trip coil 2	57	54	56

Remarks:- OK. No problem carried out during testing.

	Tested By	Witness By	Witness By
Signature	Anil Kumar	J. H. B.	J. H. B.
Name		11/09/14	11/09/14
Date	10.09.14.	AEETEC	ABR/Chandit-I

D. K. B.
 16.12.15
 Electrical -

D. K. B.
 Assistant EEE 12/15

CIRCUIT BREAKER TEST REPORT

Site Name :- Chandil 220 KV / 132 KV S/S.
 Date of testing :- 11.9.14.
 Feeder name :- 220 KV (P.G.C.I.L) Line.

Name Plate details

Make	:- CGL.	Serial number	:- 20130C
Rated Current	:- 3150 A.	Type	:-
Rated Voltage	:- 245 KV	Short Time Amps	:- 40KA / 3sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	136	133	114.
Opening time for trip coil 1	24	25	25
Closing-Opening time for trip coil 1	37	41	35
Opening time for trip coil 2	24	25	25
Closing-Opening time for trip coil 2	37	41	35

Remarks. Mechanical adjustment needed for closing mechanism.

	Tested By	Witness By	Witness By
Signature	Anubhashan	Artha 11/9/14	Deeksha 11/9/14
Name			
Date	11.09.14.	EE/TSE	EE/Chandil-1

S. R. T. S.

Deeksha
T6/12/14

CIRCUIT BREAKER TEST REPORT

Site Name
Date of testing
Feeder name

:- chandi 220/132 KV S/S.
:- 11.09.14
:- 220 KV Ramchandrapur line.

Name Plate details

Make	:- AREVA.	Serial number	:- 150420
Rated Current	:- 3150 A.	Type	:-
Rated Voltage	:- 245 KV	Short Time Amps	:- 40KA 13sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	70	60	70
Opening time for trip coil 1	42	42	42
Closing-Opening time for trip coil 1	42	42	42
Opening time for trip coil 2	42	42	44
Closing-Opening time for trip coil 2	42	41	44

Remarks : No Problem found during testing.

	Tested By	Witness By	Witness By
Signature	Anil Chander	H.S. Bhattacharya	D.B. Bhattacharya
Name			11/09/14
Date	11.09.14.	REC/TEC	Anil Chander

S. K. Bhattacharya
11/09/14

Q. K. Bhattacharya
16/10/15

(26)

CIRCUIT BREAKER TEST REPORT

Site Name :- Chandi 220/132 S/S.
 Date of testing :- 09.09.14.
 Feeder name :- 132 KV R.S.S.M

Name Plate details

Make	CGI	Serial number	20145C
Rated Current	3150 A.	Type	120-SFM-32B
Rated Voltage	145 KV.	Short Time Amps	40KA/3sec.

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	105	105	109.
Opening time for trip coil 1	26	25	23
Closing-Opening time for trip coil 1	42	40	41
Opening time for trip coil 2	26	25	24
Closing-Opening time for trip coil 2	41	44	38

Remarks :- OK. No fault found carried out during testing.

	Tested By	Witness By	Witness By
Signature	Aijaz Khan	ftha 11/9/14	Zehra 11/9/14
Name			
Date	11.09.14.	AEC/1722	ATBB/Chandi-L

CIRCUIT BREAKER TEST REPORT

Site Name :- Chardil 220 KV / 132 S/S.
 Date of testing :- 11.09.14.
 Feeder name :- 220 KV S.T.P.S Line.

Name Plate details

Make	:- CGT L.	Serial number	:- 6070C
Rated Current	:- 1600 A.	Type	:- A
Rated Voltage	:- 245 KV.	Short Time Amps	:- 40 KA / 3 sec

TEST RESULTS :-

A. Operating time (In milli Second) :-

Conditions	R-R'	Y-Y'	B-B'
Closing time	121	114	118
Opening time for trip coil 1	21	22	26
Closing-Opening time for trip coil 1	12	—	19
Opening time for trip coil 2	21	22	26
Closing-Opening time for trip coil 2	12	—	19

Remarks:- "C-O" timing value comes "0ms" every time for Y-Y' hence its suggest mechanical adjustment is needed.

	Tested By	Witness By	Witness By
Signature	Arvind Shrivastava	J. S. Jha 11/09/14	J. S. Jha 11/09/14
Name		MEE/TSE	
Date	11.09.14.		AEB/Chardil-1

Annexure-8.1.10

CT/PT earthing details

Sl No	Name of GSS	CT earthing details	PT earthing details
1	Chandil	All CT neutral earthing provided in field junction Box.	All PT neutral earthing provided in field junction Box.

Annexure-8.1.11
220 KV PGCIL

Micom P442,
Model- P44291AB6M0550K
No-33219527/02/15

Serial

Line Length	93.5 ohm
Z1	9.25 ohm
Z2	13.95 ohm
Z3	16.55 ohm
Z4	2.85 ohm
tZ1	0 s
tZ2	300.0 ms
tZ3	600.0 ms
tZ4	1.000 s

Back UP>I

I> 1Directional FWD
I>1 current set= 1.1A
I> Time delay= 1 sec
I> 2Non Directional
I>2 current set= 2A
I>2 Time delay= 100ms

Earth fault O/C

IN> 1Directional FWD
IN>1 current set= 200ma
IN> Time delay= 1 sec
IN> 2Non Directional
IN>2 current set= 300ma
IN>2 Time delay= 2 sec

220 KV STPS

Micom P442,
Model-P44291AB6MO550K,
Serial No-33219526/02/15

Line Length 120 km

Z1 11.85 ohm

Z2 17.70 ohm

Z3 25.05 ohm

Z4 3.7 ohm

tZ1 0 s

tZ2 300.0 ms

tZ3 600.0 ms

tZ4 1.000 s

Back UP>I

I> 1Directional FWD

I>1 current set= 1A

I> Time delay= 400ms

I> 2Non Directional

I>2 current set= 2.5A

I>2 Time delay= 100ms

Earth fault O/C

IN> 1Directional FWD

IN>1 current set= 200ma

IN> Time delay= 300ms

IN> 2Non Directional

IN>2 current set= 300ma

IN>2 Time delay= 100ms

220 KV RCP

Micom P442,

Model- P44291AB6M0550K

Serial No-33219529/02/15

Line Length	35 km
Line Impedance	14.21 ohm
Line Angle	79.3
kz1	1
kz1 Angle	79.3
Z1	4.590 ohm
R1G	8.000 ohm
R1Ph	2.200 ohm
tz1	0s
kz2 Res comp	840.0 m
kz2 Angle	0
Z2	6.820 ohm
R2G	8.000 ohm
R2ph	2.200 ohm
tz2	300.0 ms
kz3/4Res comp	840.0 m
kz3/4 Angle	0
Z3	11.68 ohm
R3G-R4G	8.000 ohm
R3ph-R4ph	2.200 ohm
tZ3	600.00 ms
Z4	1.130 ohm
tZ4	1.000 s

Back UP>I

- I> 1Directional FWD
- I>1 current set= 1.2A
- I> Time delay= 1sec
- I> 2Non Directional
- I>2 current set= 2.0A
- I>2 Time delay= 1sec

Earth fault O/C

- IN> 1Directional FWD
- IN>1 current set= 200ma
- IN> Time delay= 1sec
- IN> 2Non Directional
- IN>2 current set= 300ma
- IN>2 Time delay= 2sec

132 KV RKS N

Micom P442,
P442316BMO550K,
31963042/11/11

Model-
Serial No-

Line Length	40 km
Line Impedance	8.334
Line Angle	68.2
kz1	820.0m
kz1 Angle-	0
Z1-	6.667 ohm
R1G-	38.11 ohm
R1Ph	19.13 ohm
tz1	0s
kz2 Res comp	820.0m
kz2 Angle	0
Z2	10 ohm
R2G	31.11 ohm
R2ph	19.13 ohm
tz2	300 ms
kz3/4Res comp	820.0 m
kz3/4 Angle	0
Z3	17.9 ohm
R3G-R4G	38.11 ohm
R3ph-R4ph	19.13 ohm
tZ3	1.5 ms
Z4	1.666 ohm
tZ4	1.2 s

Back UP>I

- I> 1Directional FWD
- I>1 current set= 700ma
- I> Time delay= 2 sec
- I> 2Non Directional
- I>2 current set= 1.5A
- I>2 Time delay= 1.4 sec

Earth fault O/C

- IN> 1Directional FWD
- IN>1 current set= 200ma
- IN> Time delay= 2 sec
- IN> 2Non Directional
- IN>2 current set= 500ma
- IN>2 Time delay= 1.4 sec

132 KV ADPUR

Micom P442,
P442316BMO550K,
31963040/11/11

Model-
Serial No-

Line Length	19 km
Line Impedance	3.959 ohm
Line Angle	68.2
kz1	820.0m
kz1 Angle-	0
Z1-	3.167
R1G-	38.11
R1Ph	19.13
tz1	0s
kz2 Res comp	820
kz2 Angle	0
Z2	4.75
R2G	38.11
R2ph	19.13
tz2	300.0ms
kz3/4Res comp	820.0m
kz3/4 Angle	0
Z3	9.580 ohm
R3G-R4G	38.11 ohm
R3ph-R4ph	19.13 ohm
tZ3	1.00 s
Z4	792.0 m ohm
tZ4	1.200 s

Back UP>I

- I> 1Directional FWD
- I>1 current set= 700ma
 - I> Time delay= 2 sec
 - I> 2Non Directional
 - I>2 current set= 1.5A
 - I>2 Time delay= 1.4 sec

Earth fault O/C

- IN> 1Directional FWD
- IN>1 current set= 200ma
 - IN> Time delay= 2 sec
 - IN> 2Non Directional
- IN>2 current set= 500ma
- IN>2 Time delay= 1.4 sec

132 KV GOL-I

Micom P442,
Model-P44231A2A0300G
Serial No-140311640628002

Line Length	30 km
Line Impedance	4.13 Ohm
Line Angle	70
kz1	819.0m
kz1 Angle-	0
Z1-	3.330 ohm
R1G-	25 ohm
R1Ph	20 ohm
tz1	0s
kz2 Res comp	819.0m
kz2 Angle	0
Z2	5 ohm
R2G	25 ohm
R2ph	20 ohm
tz2	300 ms
kz3/4Res comp	819.0 m
kz3/4 Angle	0
Z3	10.93 ohm
R3G-R4G	25 ohm
R3ph-R4ph	20 ohm
tZ3	1 ms
Z4	0.683 ohm
tZ4	1.2 s

Back UP>I

I> 1Directional FWD
I>1 current set= 850ma
I> Time delay= 1.5 sec

Earth fault O/C

IN> 1Directional FWD
IN>1 current set= 200ma
IN> Time delay= 0.1 TMS

132 KV GOL-II

Micom P442,
Model-P4423111A2A0300G
No-140311640628017

Line Length	30 km
Line Impedance	4.13 Ohm
Line Angle	70
kz1	819.0m
kz1 Angle-	0
Z1-	3.330 ohm
R1G-	25 ohm
R1Ph	20 ohm
tz1	0s
kz2 Res comp	819.0m
kz2 Angle	0
Z2	5 ohm
R2G	25 ohm
R2ph	20 ohm
tz2	300 ms
kz3/4Res comp	819.0 m
kz3/4 Angle	0
Z3	10.93 ohm
R3G-R4G	25 ohm
R3ph-R4ph	20 ohm
tZ3	1 ms
Z4	0.683 ohm
tZ4	1.2 s

Back UP>I

I> 1Directional FWD
I>1 current set= 850ma
I> Time delay= 1.5 sec

Earth fault O/C

IN> 1Directional FWD
IN>1 current set= 200ma
IN> Time delay= 0.1 TMS

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132 KV B/C			Remarks
Line	Length – NA Conductor - ZEBRA		
Panel	Make – ENGLISH ELECTRIC Model – NA	DoM - NA DoC - NA	
Relay	DPR	Make – MICOM Model – P442 Sr. No. - 140311640628003	
	O/C	Make – MICOM Model –P442(P442311A2A0300G Sr. No. - 140311640628003	PSM -1.250A TMS -1.500S
	E/F	Make – MICOM Model –P442(P442311A2A0300G Sr. No. - 140311640628003	PSM -1.250A TMS -1.500S
	LBB	Make – NA Model – NA Sr. No. -NA	PSM -NA TMS -NA
CT	R Ph	Make – SCT LTD Type – O.D.D.T. Current Ratio – 1200/ <u>600</u> /1A Rated Voltage – 145KV	Sr. No. – 96/813 DoM - NA DoC - NA
	Y Ph	Make – SCT LTD Type – O.D.D.T. Current Ratio – 1200/ <u>600</u> /1A Rated Voltage – 145KV	Sr. No. – 96/803 DoM - NA DoC - NA
	B Ph	Make – BROWN BOVRI Type – TMBRK-145 Current Ratio – <u>600</u> /300/150/1A Rated Voltage –20KA1SEC	Sr. No. – IB069449 DoM - NA DoC - NA
Breaker	Make – CGL LTD. Type – 120-SFM-32-B Rated Voltage – 145KV Rated Current – 3150A Short Time Amp –40KA/3SEC	Serial No. – 26422C DoM - NA DoC - NA	
EM	Make – SECURE METERE LTD Model – C3V021 MTR – 600/1A Class –0.2S	Serial No. –BEBOO387 DoM - NA DoC - NA	

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132 KV RKSН			Remarks
Line	Length – 40 Conductor - PANTHER		
Panel	Make – ENGLISH ELECTRIC Model – NA	DoM - NA DoC - NA	
Relay	DPR	Make – ALSTOM Model – P430 Sr. No. – P4309893020MDB000	
	O/C	Make – ALSTOM(MICOM) Model – P430 Sr. No. – P4309893020MDB000	
	E/F	Make – ALSTOM(MICOM) Model – P430 Sr. No. – P4309893020MDB000	
	LBB	Make – NA Model – NA Sr. No. -NA	
CT	R Ph	Make – SCT LTD. Type – O.D.D.T Current Ratio – 1200/ <u>600</u> /300/1A Rated Voltage – 145KV	Sr. No. -2010/667 DoM - NA DoC - NA
	Y Ph	Make – NA Type – NA Current Ratio – 1200/ <u>600</u> /300/1A Rated Voltage – NA	Sr. No. - NA DoM - NA DoC - NA
	B Ph	Make – SCT LTD. Type – O.D.D.T Current Ratio – 1200/ <u>600</u> /300/1A Rated Voltage – 145KV	Sr. No. -2010/665 DoM - NA DoC - NA
Breaker	Make – CGL Type – 120-SFM-32B Rated Voltage – 145KV Rated Current – 3150A Short Time Amp – 40KA/3SEC	Serial No. – 20145C DoM - NA DoC - NA	
EM	Make – SECURE METER LTD. Model – C3V021 MTR – 600/1A Class – 0.2S	Serial No. – BEB00382 DoM -NA DoC - NA	

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132KV GOL-II			Remarks
Line	Length – 33KV Conductor - PANTHER		
Panel	Make – ENGLISH ELECTRIC Model – NA	DoM - NA DoC - NA	
Relay	DPR	Make – MICOM Model – P442311A2A0300G Sr. No. - 140311640628017	
	O/C	Make – MICOM Model – P442311A2A0300G Sr. No. - 140311640628017	PSM -1.250A TMS -1.500SEC
	E/F	Make – MICOM Model – P442311A2A0300G Sr. No. - 140311640628017	PSM -200mA TMS -0.100SEC
	LBB	Make – NA Model –NA Sr. No. -NA	PSM -NA TMS -NA
CT	R Ph	Make – SCT LTD. Type – O.D.D.T. Current Ratio – <u>400</u> /200/100/1A Rated Voltage –145KA	Sr. No. – 2003/191 DoM - NA DoC - NA
	Y Ph	Make – SCT LTD. Type – O.D.D.T. Current Ratio – <u>400</u> /200/100/1A Rated Voltage –145KA	Sr. No. – 2003/192 DoM - NA DoC - NA
	B Ph	Make – SCT LTD. Type – O.D.D.T. Current Ratio – <u>400</u> /200/100/1A Rated Voltage –145KA	Sr. No. – 2003/191 DoM - NA DoC - NA
Breaker	Make – CGL LTD. Type – 120-SFM-32-B Rated Voltage – 145KV Rated Current – 3150A Short Time Amp –40KA/3SEC	Serial No. – 26419C DoM - NA DoC - NA	
EM	Make – SECURE METERS LTD Model – E3V021 MTR – 800/1A Class –0.2S	Serial No. – JSE00002 DoM - NA DoC - NA	

Name of GSS: - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132KV GOL-1			Remarks	
Line	Length – 33KV Conductor - PANTHER			
Panel	Make – ENGLISH ELECTRIC Model – NA		DoM - NA DoC - NA	
Relay	DPR	Make – MICOM Model – P442 (P44231182A0300G) Sr. No. – 062802C		
	O/C	Make – MICOM Model – P442(P44231182A0) Sr. No. - 0628002	PSM -1.250A TMS -1.500S	
	E/F	Make – MICOM Model – P442(P44231182A0) Sr. No. - 0628002	PSM -200.0mA TMS -0.100SEC	
	LBB	Make – NA Model – NA Sr. No. - NA	PSM -NA TMS -NA	
CT	R Ph	Make – BHEL LTD. Type – NA Current Ratio – <u>400</u> /200/100/1A Rated Voltage – 145KV	Sr. No. - 6142241 DoM -NA DoC – NA	
	Y Ph	Make – BHEL LTD. Type – NA Current Ratio – <u>800</u> / <u>400</u> /200/1A Rated Voltage – 145KV	Sr. No. - 2208749 DoM -NA DoC – NA	
	B Ph	Make – BHEL LTD. Type – NA Current Ratio – <u>800</u> / <u>400</u> /200/1A Rated Voltage – 145KV	Sr. No. - 2208730 DoM -NA DoC – NA	
Breaker	Make – AREVA Type – FK3-1 Rated Voltage – 145KV Rated Current – 3150A Short Time Amp –40KA/3SEC		Serial No. – 102829 DoM - NA DoC - NA	
EM	Make – SECURE METER LTD. Model – E3V021 MTR – 400/1A Class –0.2S		Serial No. – JSE00022 DoM - NA DoC - NA	

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132 KV MIK			Remarks
Line	Length – NA Conductor - ZEBRA		
Panel	Make – ENGLISH ELECTRIC Model – NA		DoM - NA DoC - NA
Relay	DPR	Make – NA Model –NA Sr. No. - NA	
	O/C	Make – ENGLISH ELECTRIC Model – CAG(SPECM3BF45B)) Sr. No. – M162955	PSM -2 TMS -2SEC
	E/F	Make – ENGLISH ELECTRIC Model – CAG(SPECM3BF45B)) Sr. No. – M162955	PSM -0.2 TMS -0.2SEC
	LBB	Make – NA Model – NA Sr. No. -NA	PSM -NA TMS -NA
CT	R Ph	Make – ASEA LTD. Type – MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV	Sr. No. - 6069/612 DoM - NA DoC - NA
	Y Ph	Make – NA Type – NA Current Ratio –200/400/800/1A Rated Voltage –NA	Sr. No. - NA DoM - NA DoC - NA
	B Ph	Make – ASEA LTD. Type – MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV	Sr. No. - 6069/611 DoM - NA DoC - NA
Breaker	Make – AREVA LTD Type – FK3-1 Rated Voltage – 145KV Rated Current – 3150A Short Time Amp –40KA/3SEC		Serial No. – 102848 DoM -NA DoC - NA
EM	Make – SECURE METERE LTD Model – E3V021 MTR – 800/1A Class –0.2S		Serial No. – JSB44823 DoM - NA DoC - NA

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132 KV HATIA	Remarks

Line	Length – 82 Conductor - ZEBRA			
Panel	Make – EASUN REYROLLE LTD Model –NA			DoM - NA DoC - NA
Relay	DPR	Make – SEL Model – SEL-311C Sr. No. - NA		
	O/C	Make – EASUN REYROLL Model – 2TJMI2 Sr. No. – HR0802036		
	E/F	Make – EASUN REYROLL Model – 2TJMI2 Sr. No. –HR0802036		
	LBB	Make – NA Model – NA Sr. No. - NA		
CT	R Ph	Make – SCT LTD Type –O.D.D.T Current Ratio – 600/300/150/1A Rated Voltage – 145 KV		
	Y Ph	Make – SCT LTD Type –O.D.D.T Current Ratio – 600/300/150/1A Rated Voltage – 145 KV		
	B Ph	Make – SCT LTD Type –O.D.D.T Current Ratio – 600/300/150/1A Rated Voltage – 145 KV		
Breaker	Make – CGL Type – 120-SFM-32B Rated Voltage – 145KV Rated Current – 3150A Short Time Amp –40KA/3SEC			Serial No. – 20146C DoM - NA DoC - NA
EM	Make – SECURE METER LTD Model – E3MO21 MTR –150/1A Class –0.2S			Serial No. – KAU08740 DoM - NA DoC - NA

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132 KV TR.3			Remarks
Line	Length – NA Conductor - ZEBRA		
Panel	Make – ASEA Model – NA		DoM - NA DoC - NA
Relay	DPR	Make – NA Model – NA Sr. No. - NA	
	O/C	Make – ASEA Model – NA Sr. No. - NA	PSM -0.30 TMS -0.6SEC
	E/F	Make – ASEA Model – NA Sr. No. -NA	PSM -0.2 TMS -0.4SEC
	LBB	Make – MICOM Model – P127 Sr. No. -140422340815004	PSM -0.50 TMS -0.50SEC
CT	R Ph	Make – ASEA Type – 1MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV	Sr. No. – 6069/635 DoM - NA DoC - NA
	Y Ph	Make – ASEA Type – 1MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV	Sr. No. – 6069/634 DoM - NA DoC - NA
	B Ph	Make – ASEA Type – 1MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV	Sr. No. – 6069/640 DoM - NA DoC - NA
Breaker	Make – CGL Type – 120-SFM-32B Rated Voltage – 145KV Rated Current – 3150A Short Time Amp –40KA/3SEC		Serial No. –26418C DoM - NA DoC - NA
EM	Make – SECURE METER Model – E3V021 MTR – 800/1A Class –0.2S		Serial No. – JSE00009 DoM - NA DoC - NA

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132 KV TR2	Remarks

Line	Length – NA Conductor - ZEBRA				
Panel	Make – ASEA Model – NA		DoM - NA DoC - NA		
Relay	DPR	Make – NA Model –NA Sr. No. - NA			
	O/C	Make – ASEA Model – NA Sr. No. -NA			
	E/F	Make – ASEA Model – NA Sr. No. -NA			
	LBB	Make – MICOM Model –P127 Sr. No. -140422340815001			
CT	R Ph	Make – ASEA Type – 1MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV			
	Y Ph	Make – ASEA Type – 1MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV			
	B Ph	Make – ASEA Type – 1MBA-145A3 Current Ratio – 200/400/800/1A Rated Voltage –132KV			
Breaker	Make – AREVA Type – FK3-1 Rated Voltage – 145KV Rated Current – 3150A Short Time Amp –40KA/3SEC		Serial No. – 102834 DoM -NA DoC -NA		
EM	Make – SECURE METER Model – E3V021 MTR – 800/1A Class –0.2S		Serial No. – JSE00007 DoM - NA DoC -NA		

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 132 KV Tr-1			Remarks
Line	Length – NA Conductor - ZEBRA		
Panel	Make – EASUN REYROLLE Model – NA		DoM - NA DoC - NA
Relay	DPR	Make – Model – Sr. No. -	
	O/C	Make – Model – Sr. No. -	
	E/F	Make – Model – Sr. No. -	
	LBB	Make – Model – Sr. No. -	
CT	R Ph	Make – Type – Current Ratio – Rated Voltage –	Sr. No. - DoM - DoC -
	Y Ph	Make – Type – Current Ratio – Rated Voltage –	Sr. No. - DoM - DoC -
	B Ph	Make – Type – Current Ratio – Rated Voltage –	Sr. No. - DoM - DoC -
Breaker	Make – Type – Rated Voltage – Rated Current – Short Time Amp –		Serial No. – DoM - DoC -
EM	Make – Model – MTR – Class –		Serial No. – DoM - DoC -

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 220 KV B/C			Remarks
Line	Length – NA Conductor - ZEBRA		
Panel	Make – EASUN REYROLLE Model – NA	DoM - NA DoC - NA	
Relay	DPR	Make – ABB Model – REL650 Sr. No. – I1314009	
	O/C	Make – ABB Model – REL650 Sr. No. – I 1314009	PSM -100 % TMS -0.250 SEC
	E/F	Make – ABB Model –REL650 Sr. No. –I 1314009	PSM -30% TMS -0.150 SEC
	LBB	Make – NA Model –NA Sr. No. -NA	PSM -NA TMS -NA
CT	R Ph	Make –BALTEAU Type –NA Current Ratio – 150-300- <u>600</u> -1200/1A Rated Voltage –460 KV	Sr. No. - 53392/6805 DoM - NA DoC - NA
	Y Ph	Make –BALTEAU Type –NA Current Ratio – 150-300- <u>600</u> -1200/1A Rated Voltage –460 KV	Sr. No. - 53392/6809 DoM - NA DoC - NA
	B Ph	Make –SCT LTD Type –O.D.D.T Current Ratio – 1200- <u>600</u> -300/1A Rated Voltage –245 KV	Sr. No. - 2001/2313 DoM - NA DoC - NA
Breaker	Make – CGL Type – 200-SFM-40A Rated Voltage – 245KV Rated Current – 3150A Short Time Amp –40KA 3 SEC	Serial No. – 6070C DoM -NA DoC - NA	
EM	Make – SECURE METER LTD Model – E3V021 MTR – 100/1A Class –0.2S	Serial No. – KAB00519 DoM - NA DoC - NA	

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 220 KV TR.3	Remarks

Line	Length – NA Conductor - ZEBRA				
Panel	Make – ASEA LTD Model – NA		DoM - NA DoC - NA		
Relay	DPR	Make – NA Model – NA Sr. No. -NA			
	O/C	Make – ASEA. Model – NA Sr. No. - NA			
	E/F	Make – ASEA Model – NA Sr. No. -NA			
	LBB	Make – MICOM Model – P217 Sr. No. -140422340815004			
CT	R Ph	Make – BALTEAU Type –NA Current Ratio – 100-200-400- <u>800</u> /1A Rated Voltage – 460KV			
	Y Ph	Make – BALTEAU Type –NA Current Ratio – 100-200-400- <u>800</u> /1A Rated Voltage – 460KV			
	B Ph	Make – BALTEAU Type –NA Current Ratio – 100-200-400- <u>800</u> /1A Rated Voltage – 460KV			
Breaker	Make – CGL Type – 200-SFM-40A Rated Voltage – 245KV Rated Current – 3150A Short Time Amp –40KA3SEC		Serial No. – 6067C DoM - NA DoC - NA		
EM	Make – SECURE METRE LTD Model – E3V021 MTR – 800/1A Class –0.2S		Serial No. – JSE00009 DoM - NA DoC - NA		

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 220 KV TR.2		Remarks
Line	Length – NA Conductor - ZEBRA	

Panel	Make – ASEA Model – NA	DoM - NA DoC - NA	
Relay	DPR	Make – NA Model –NA Sr. No. -NA	
	O/C	Make – ASEAN Model –NA Sr. No. - NA	
	E/F	Make – Model – Sr. No. -	
	LBB	Make – MICOM Model – P127 Sr. No. -140422340815001	
CT	R Ph	Make – BALTEAU Type – NA Current Ratio – 100-200-400- <u>800</u> /1A Rated Voltage – 480KV	Sr. No. - 53393/6908 DoM - NA DoC - NA
	Y Ph	Make – BALTEAU Type – NA Current Ratio – 100-200-400- <u>800</u> /1A Rated Voltage – 480KV	Sr. No. - 53393/6901 DoM - NA DoC - NA
	B Ph	Make – BALTEAU Type – NA Current Ratio – 100-200-400- <u>800</u> /1A Rated Voltage – 460KV	Sr. No. - 53393/6903 DoM - NA DoC - NA
Breaker	Make – CGL Type – 200-SFM-40S Rated Voltage – 245 KV Rated Current – 3150A Short Time Amp –40KA/3SEC	Serial No. – 20130C DoM - NA DoC - NA	
EM	Make – SECURE METER LTD Model – E3V021 MTR – 800/1A Class –0.2S	Serial No. – JSE00007 DoM - NA DoC - NA	

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 220KV TR NO.01	Remarks
--	----------------

Line	Length –NA Conductor - ZEBRA				
Panel	Make – ASEA Model – NA		DoM - NA DoC - NA		
Relay	DPR	Make –NA Model – NA Sr. No. -NA			
	O/C	Make –ASEA Model – NA Sr. No. - NA			
	E/F	Make – ASEA Model –NA Sr. No. -NA			
	LBB	Make – MICOM Model – P127 Sr. No. -14042230815002			
CT	R Ph	Make – BHEL LTD. Type – IS:2705 Current Ratio –200/400/ <u>800</u> /1A Rated Voltage –245KV			
	Y Ph	Make – BALTEAU Type – NA Current Ratio – 100/200/400/ <u>800</u> /1A Rated Voltage – 460KV			
	B Ph	Make – BALTEAU Type – NA Current Ratio – 100/200/400/ <u>800</u> /1A Rated Voltage – 460KV			
Breaker	Make – HINDUSTAN BROWN BOVRI LTD Type – ELF 245 no-2 Rated Voltage – 245KV Rated Current – 3150A Short Time Amp –40KA/3SEC		Serial No. – 1B103398 DoM - DoC -		
EM	Make – SECURE METERS LTD Model – E3V021 MTR –800/1A Class –0.2S		Serial No. – JSE00008 DoM -NA DoC - NA		

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 220 KV STPS		Remarks
Line	Length – 120 KM Conductor - ZEBRA	

Panel	Make – EASUN REYROLLE Model – NA	DoM -NA DoC - NA	
Relay	DPR	Make – SEL Model – 311C-SEL Sr. No. - NA	
	O/C	Make – EASUN RAEYROLLE Model – 2TJM12 Sr. No. –HR0802037	PSM -1.00 TMS -0.2 SEC
	E/F	Make – EASUN RAEYROLLE Model –2TJM12 Sr. No. –HR0802075	PSM -0.20 TMS -0.15 SEC
	LBB	Make – NA Model – NA Sr. No. - NA	PSM - NA TMS - NA
CT	R Ph	Make – SCT LTD Type – O.D.D.T Current Ratio – <u>600</u> -300-150/1A Rated Voltage – 245 KV	Sr. No. - 2013/664 DoM - NA DoC - NA
	Y Ph	Make – SCT LTD Type – O.D.D.T Current Ratio – <u>600</u> -300-150/1A Rated Voltage – 245 KV	Sr. No. - 2013/662 DoM - NA DoC - NA
	B Ph	Make – SCT LTD Type – O.D.D.T Current Ratio – <u>600</u> -300-150/1A Rated Voltage – 245 KV	Sr. No. - 2013/663 DoM - NA DoC - NA
Breaker	Make – CGL Type – 200-SFM-50A Rated Voltage – 245KV Rated Current – 3150A Short Time Amp –50KA/3 SEC	Serial No. – 42525C DoM -NA DoC - NA	
EM	Make – SECURE METER LTD Model – E3M021 MTR –150/1A Class –0.2S	Serial No. – KAU08742 DoM - NA DoC - NA	

Name of GSS: - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 220 KV PGCIL		Remarks
Line	Length – 78KM Conductor -ZEBRA	
Panel	Make – EASUN REYROLLE LTD Model – ER771	DoM - NA DoC -NA

Relay	DPR	Make – NA Model – NA Sr. No. - NA	
	O/C	Make – EASUN REYROLLE LTD Model – 2TJM12 Sr. No. – HRO602172	
	E/F	Make – EASUN REYROLLE LTD Model – 2TJM12 Sr. No. – HR0601417	
	LBB	Make – NA Model – NA Sr. No. - NA	
CT	R Ph	Make – AREVA Type – IT-245 Current Ratio – 1200-600-300-150/1A Rated Voltage – 245/220KV	Sr. No. – 20061080/2006 DoM - NA DoC - NA
	Y Ph	Make – AREVA Type – IT-245 Current Ratio – 1200-600-300-150/1A Rated Voltage – 245/220KV	Sr. No. -20061082/2006 DoM - NA DoC - NA
	B Ph	Make – NA Type – NA Current Ratio – NA Rated Voltage –NA	Sr. No. - NA DoM - NA DoC - NA
Breaker	Make – CGL Type – 200-SFM-40S Rated Voltage –245KV Rated Current – 3150A Short Time Amp –40KA/3SEC	Serial No. – 20130C DoM - NA DoC - NA	
EM	Make – SECURE METER LTD Model – E3V021 MTR –300/1A Class –0.2S	Serial No. – KAU03192 DoM - NA DoC - NA	

Name of GSS : - 220/132 KV CHANDIL-1, GSS.

Details:

Name of Feeder – 220 kv Ramchandrapur		Remarks
Line	Length – 35km Conductor - Panther	
Panel	Make – English Electric Model – NA	DoM - NA DoC - NA

Relay	DPR	Make – NA Model – NA Sr. No. -	
	O/C	Make – NA Model – NA Sr. No. - NA	
	E/F	Make – NA Model – NA Sr. No. - NA	
	LBB	Make – MICOM Model – P127 Sr. No. -1403161506310001	
CT	R Ph	Make – Balteau Type – NA Current Ratio – 150/300/600/1200/1a Rated Voltage – 460kv	Sr. No. - 53392/6813 DoM - DoC -
	Y Ph	Make – Areva Type – IT-245 Current Ratio – 1200-600-300-150/A Rated Voltage – 245/220kv	Sr. No. -20060718/2006 DoM - NA DoC - NA
	B Ph	Make – Balteau Type – NA Current Ratio – 150/300/600/1200/1a Rated Voltage – 460kv	Sr. No. - 53392/6801 DoM - DoC -
Breaker	Make – AREVA Type – NA Rated Voltage – 245KV Rated Current – 3150A Short Time Amp – 40KA/3SEC	Serial No. – 150420 DoM - NA DoC - NA	
EM	Make – SECURE METER LTD. Model – E3M021 MTR – 600/1A Class – 0.2S	Serial No. – JSB44797 DoM - NA DoC - NA	

Annexure-8.1.12

D.C. system details with Charger and battery									
Sl. nO.	Name of G/s/s	Details of Battery Charger	Single /Double	Total voltage	Capacity	no. of Cells	D.C. system Earth fault	D.C. positive to earth	D.C. Nigative to earth
1	Chandil	Mode- Float Ac- 400+-10% v Amp- 15A DC- 262+-1%V Phase-3 Sl.No- CE480/36 Mode- Boost DC- 205-325 V Amp.- 38A	Single	223V	2V- 300Amp H	112	Not tested	191V	20V

Annexure-8.1.13

Name of the Sub-station:-Chandil		
Name of the line	Line length(KM)	Conductor type
220KV PGCIL	93.5	ZEBRA
220KV STPS	120	ZEBRA
220KV RAMCHANDRAPUR	35	ZEBRA
132KV MANIQUI	0.5	ZEBRA
132KV GOLMURI 1	30	PANTHER
132KV GOLMURI 2	30	PANTHER
132KV RAJKHARSAWAN	40	PANTHER
132KV ADITYAPUR	19	PANTHER

Annexure-8.1.14

Name of the Sub-station: Chandil GSS		
--------------------------------------	--	--

Transformer Details	EMCO,2000 Vector-YNn0d11	
Transformer Number	1	
MVA Rating	100	
% Impedance	Tap no. 1- 7.49, Tap no. 5(Normal)- 7.41, Tap no. 17- 7.56	
Ratio	220/132KV	

Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT		Core details	Setting	High set setting
			Ratio	Core number			
	HV	R-phase(BHEL) Y & B-phase(BALTEAU), Rated voltage(BHEL)-245KV Rated voltage(BALTEAU)-460KV Class of Accuracy- 0.2(BHEL),1(BALTEAU)	800/1A	3 PS			
		R-phase(SCT), Y & B phase(ASEA) Rated voltage-132KV Class of Accuracy- 0.5(R), 1(Y&B)					
Nomenclature		Make & model					
Differential Protection	Asea sweden	RIDI				BIAS-40%	
Restricted E/F (HV)	Asea sweden	RIDI				N.A.	
Restricted E/F (LV)	Asea sweden	RIDI				N.A.	
HV O/C	Asea sweden	RIDI				PSM-0.6, TMS-0.3	

LV O/C	Asea sweden	RIDI					PSM-0.6, TMS-0.3	
HV E/F	Asea sweden	RIDI					PSM-0.4, TMS-0.2	
LV E/F	Asea sweden	RIDI					PSM-0.5, TMS-0.2	
Over flux	English Electrical	GTT21AF8001A					2.585	

Trip relay	Master trip relay	86
-------------------	-------------------	----

Name of the Sub-station: Chandil GSS

Transformer Details	Kanohar Electricals LTD,2006 Vector-YNn0d11				
Transformer Number	2				
MVA Rating	100				
% Impedance	Tap no. 1-07.03, Tap no. 5(Normal)-06.98, Tap no. 17-07.08				
Ratio	220/132KV				
Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number &	Setting	High set setting
	HV	(BALTEAU), Rated voltage-460KV Class of Accuracy- 1	800/1A	3	800/400/ 200/1A
	LV	ASEA Rated Voltage-145KV Class-1	800/1A	3	800/400/ 200/1A
Nomenclature	Make & model				
Differential Protection	ASEA	RIDI			BIAS-32%
Restricted E/F (HV)					
Restricted E/F (LV)					
HV O/C	Asea sweden	RIDI			PSM-0.6, TMS-0.3
LV O/C	Asea sweden	RIDI			PSM-0.6, TMS-0.3
HV E/F	Asea sweden	RIDI			PSM-0.4, TMS-0.2

LV E/F	Asea sweden	RIDI					PSM-0.4, TMS-0.2	
Over flux								

Trip relay	MASTER TRIP	86
------------	-------------	----

Name of the Sub-station: CHANDIL GSS		
--------------------------------------	--	--

Transformer Details	CANADIAN MAKE, 1766 Vector-YNn0d11	
Transformer Number	3	
MVA Rating	100	
% Impedance	HV-LV-7.4, HV-TV-25.5, LV-TV-17.4 (AT NORMAL TAP)	
Ratio	220/132KV	

Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number & Details			Setting	High set setting
			Ratio	Core number	Core details		
	HV	(BALTEAU), Rated voltage-460KV Class of Accuracy- 1	800/1A	3	800/400/200/1A		
	LV	ASEA Rated Voltage-145KV Class-1	800/1A	3	800/400/200/1A		
Nomenclature		Make & model					
Differential Protection						BIAS-25	
Restricted E/F (HV)							
Restricted E/F (LV)							
HV O/C	Asea sweden	RIDI				PSM-0.6, TMS-0.3	

LV O/C	Asea sweden	RIDI					PSM-0.6, TMS-0.3	
HV E/F	Asea sweden	RIDI					PSM-0.4, TMS-0.2	
LV E/F	Asea sweden	RIDI					PSM-0.4, TMS-0.2	
Over flux								


Trip relay	Master trip	86
-------------------	-------------	----

Name of the Sub-station: CHANDIL GSS		
--------------------------------------	--	--

Transformer Details	TRANSFORMER RECTIFIERS INDIA LTD.,2013 Vector-YNn0d11						
Transformer Number	4						
MVA Rating	100						
% Impedance	TAP NO 1-7.35 TAP NO.5-7.22 (AT NORMAL TAP) TAP NO. 17- 7.27						
Ratio	220/132KV						
Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number &			Setting	High set setting
			Ratio	Core number	Core details		
	HV	BHEL, Rated voltage-245KV Class of Accuracy- 0.5	800/1A		800/400/ 3 200/1A		
	LV	R&Y -VICTRANS B-SCT Rated Voltage-145 Class-0.5	800/1A		800/400/ 3 200/1A		
Nomenclature	Make & model						
Differential Protection						BIAS-30	
Restricted E/F (HV)							
Restricted E/F (LV)	EASUN REYYOLLE	5B380				80	
HV O/C	EASUN REYYOLLE	2TJM11				PSM-0.5, TMS-1	
LV O/C	EASUN REYYOLLE	2TJM11				PSM-0.5, TMS-1	

HV E/F	EASUN REYYOLLE	2TJM11					PSM-0.2, TMS-1	
LV E/F	EASUN REYYOLLE	2TJM11					PSM-0.2, TMS-1	
Over flux								

Trip relay	Master trip	86
-------------------	-------------	----



Year of Manufacturing of 220/132kV Ramchandrapur S/s

Sl. No.	Name of Feeders	Name of Equipment	Details of equipment	Year of Manufacturing
1	220 Chandil	CT	R Phase	2012
		CT	Y Phase	2005
		CT	B Phase	2005
2	220KV Joda	CT	R Phase	2012
		CT	Y Phase	2012
		CT	B Phase	2012
3	220 KV Tr.-I	CT	R Phase	1991
		CT	Y Phase	1991
		CT	B Phase	1991
4	220 KV Tr.-II	CT	R Phase	2005
		CT	Y Phase	2005
		CT	B Phase	2005
5	220 KV Tr.-III	CT	R Phase	2007
		CT	Y Phase	2007
		CT	B Phase	2006
6	220 KV Bar Coupler	CT	R Phase	1991
		CT	Y Phase	1991
		CT	B Phase	1991
7	220 KV ICT-I	CT	R Phase	2006
		CT	Y Phase	2006
		CT	B Phase	2006
8	220 KV ICT-II	CT	R Phase	2006
		CT	Y Phase	2006
		CT	B Phase	2006
9	132 KV Tr.-I	CT	R Phase	1997
		CT	Y Phase	1997
		CT	B Phase	1997
10	132 KV Tr.-II	CT	R Phase	2007
		CT	Y Phase	2007
		CT	B Phase	2007
11	132 KV Tr.-III	CT	R Phase	2007
		CT	Y Phase	2007
		CT	B Phase	2007
12	132 KV B/C	CT	R Phase	1997
		CT	Y Phase	1997
		CT	B Phase	1997
13	132 KV Adityapur-I	CT	R Phase	2009
		CT	Y Phase	2009
		CT	B Phase	2009
14	132 KV Adityapur-II	CT	R Phase	2009
		CT	Y Phase	2009
		CT	B Phase	2009
15	132 KV M/S Adhunik Power -I	CT	R Phase	2008
		CT	Y Phase	2008
		CT	B Phase	2008

16	220 KV PT-I	PT	R Phase	1994
		PT	Y Phase	1994
		PT	B Phase	1994
17	220 KV PT-II	PT	R Phase	1992
		PT	Y Phase	1992
		PT	B Phase	1992
18	132 KV PT	PT	R Phase	2001
		PT	Y Phase	2001
		PT	B Phase	2001
19	220 KV Chandil	Breaker		1987
20	220 KV Joda	Breaker		2006
21	220/132 KV 150 MVA Tr.-I	Breaker		1993
22	220/132 KV 150 MVA Tr.-II	Breaker		2005
23	220/132 KV 150 MVA Tr.-III	Breaker		2006
24	220 KV Bar Coupler	Breaker		1993
25	220 KV ICT-I	Breaker		1987
26	220 KV ICT-II	Breaker		1993
27	132 KV Tr.-I	Breaker		1995
28	132 KV Tr.-II	Breaker		2008
29	132 KV Tr.-III	Breaker		2007
30	132 KV B/C	Breaker		2006
31	132 KV Adityapur-I	Breaker		1997
32	132 KV Adityapur-II	Breaker		2008

33	132 KV M/S Adhunik Power -I	Breaker		2008
34	150 MVA Transformer-I	Transformer		1992
35	150 MVA Transformer-II	Transformer		2005
36	150 MVA Transformer-III	Transformer		2006

CT details of 220/132 KV Ramchandrapur GSS

Sl. No.	Name of Feeders	Comprehensive C.T. details	Make	CT ratio	Connected Ratio	Core No.	Class of accuracy	Protection class use	Knee voltage
1	220 KV Chandil	R Phase	SCT LTD.(UP)	800/400/200/1A	800/1A	5 Core	0.2	PS	
		Y Phase	Areva	800/400/200/1A		4 Core	0.2	PS	
		B Phase	Areva	800/400/200/1A		4 Core	0.2	PS	
2	220KV Joda	R Phase	SCT LTD.(UP)	1200/600/300/150/1A	600/1A	4 Core	0.5	PS	
		Y Phase	SCT LTD.(UP)	1200/600/300/150/1A		4 Core	0.5	PS	
		B Phase	SCT LTD.(UP)	1200/600/300/150/1A		4 Core	0.5	PS	
3	220 KV Tr.-I	R Phase	SCT LTD.(UP)	1200/600/300/150/1A	600/1A	5 Core	1	PS	
		Y Phase	SCT LTD.(UP)	1200/600/300/150/1A		5 Core	1	PS	
		B Phase	SCT LTD.(UP)	1200/600/300/150/1A		5 Core	1	PS	
4	220 KV Tr.-II	R Phase	Areva	1200/600/300/1A	600/1A	4 Core	0.2	PS	
		Y Phase	Areva	1200/600/300/1A		4 Core	0.2	PS	
		B Phase	Areva	1200/600/300/1A		4 Core	0.2	PS	
5	220 KV Tr.-III	R Phase	SCT LTD.(UP)	1200/600/300/1A	600/1A	4 Core	0.5	PS	
		Y Phase	SCT LTD.(UP)	1200/600/300/1A		4 Core	0.5	PS	
		B Phase	Areva	1200/600/300/150/1A		5 Core	0.2	PS	
6	220 KV Bar Coupler	R Phase						PS	
		Y Phase						PS	
		B Phase						PS	
7	220 KV ICT-I	R Phase	Areva	1200/600/300/150/1A	1200/1A	5 Core	0.2	PS	
		Y Phase	Areva	1200/600/300/150/1A		5 Core	0.2	PS	
		B Phase	Areva	1200/600/300/150/1A		5 Core	0.2	PS	
8	220 KV ICT-II	R Phase	Areva	1200/600/300/150/1A	1200/1A	5 Core	0.2	PS	
		Y Phase	Areva	1200/600/300/150/1A		5 Core	0.2	PS	
		B Phase	Areva	1200/600/300/150/1A		5 Core	0.2	PS	
9	132 KV Tr.-I	R Phase	SCT LTD.(UP)	1200/600/1A	600/1A	4 Core	1	PS	
		Y Phase	SCT LTD.(UP)	1200/600/1A		4 Core	1	PS	
		B Phase	SCT LTD.(UP)	1200/600/1A		4 Core	1	PS	
10	132 KV Tr.-II	R Phase	Victrans eng.	600/300/150/1A	600/1A	4 Core	0.5	PS	
		Y Phase	Victrans eng.	600/300/150/1A		4 Core	0.5	PS	
		B Phase	Victrans eng.	600/300/150/1A		4 Core	0.5	PS	
11	132 KV Tr.-III	R Phase	Victrans eng.	600/300/150/1A	600/1A	4 Core	0.5	PS	
		Y Phase	Victrans eng.	600/300/150/1A		4 Core	0.5	PS	
		B Phase	Victrans eng.	600/300/150/1A		4 Core	0.5	PS	
12	132 KV B/C	R Phase	SCT LTD.(UP)	1200/600/1A	600/1A	4 Core	1	PS	
		Y Phase	SCT LTD.(UP)	1200/600/1A		4 Core	1	PS	
		B Phase	SCT LTD.(UP)	1200/600/1A		4 Core	1	PS	
13	132 KV Adityapur-I	R Phase	Victrans eng.	1200/600/300/1A	600/1A	4 Core	0.2	PS	
		Y Phase	Victrans eng.	1200/600/300/1A		4 Core	0.2	PS	
		B Phase	Victrans eng.	1200/600/300/1A		4 Core	0.2	PS	
14	132 KV Adityapur-II	R Phase	Victrans eng.	1200/600/300/1A	600/1A	4 Core	0.2	PS	
		Y Phase	Victrans eng.	1200/600/300/1A		4 Core	0.2	PS	
		B Phase	Victrans eng.	1200/600/300/1A		4 Core	0.2	PS	
15	132 KV M/S Adhunik Power - I	R Phase	CGL	600/300/150/1A	300/1A	4 Core	0.2	PS	
		Y Phase	CGL	600/300/150/1A		4 Core	0.2	PS	
		B Phase	CGL	600/300/150/1A		4 Core	0.2	PS	

Annexure-8.2.4**VT details of 220/132 KV Ramchandrapur GSS**

Sl. No.	V.T. details	Comprehensive P.T. details	Make	Core No.	Class of accuracy
1	220 KV PT-I	R Phase	BHEL	3 Core	0.5/3P/0.5
		Y Phase	BHEL	3 Core	0.5/3P/0.5
		B Phase	BHEL	3 Core	0.5/3P/0.5
2	220 KV PT-II	R Phase	BHEL	3 Core	0.5/3P/0.5
		Y Phase	BHEL	3 Core	0.5/3P/0.5
		B Phase	BHEL	3 Core	0.5/3P/0.5
3	132 KV PT	R Phase	SCT LTD.(UP)	3 Core	0.2/3P/3P
		Y Phase	SCT LTD.(UP)	3 Core	0.2/3P/3P
		B Phase	SCT LTD.(UP)	3 Core	0.2/3P/3P

Fault level at JUSNL Sub-stations

Bus Name	Bus Voltage	3 Ph Fault current	SLG Fault current
CHANDIL 220	220	14514	9735
RAMCHANDRAPUR 220	220	18450	15443
CHANDIL	132	18105	12652
ADITPUR	132	12098	8624
RAMCHANDRAPUR 132	132	13000	11126

Note: Data received from ERLDC

Annexure: 8.2.6

Transformer Details

(a) 220/132 KV, 150 MVA Transformer No. - I

	HV - IV	HV - LV	IV - LV
Tap No. - 01	12.44	-	-
Tap No. - 05 (Normal Tap)	12.03	40.42	27
Tap No. - 17	12	-	-

(b) 220/132 KV, Transformer No. - II (150 MVA)

	HV - IV	HV - LV	IV - LV
Tap No. - 01	11.87	-	-
Tap No. - 05 (Normal Tap)	11.64	41.55	27.55
Tap No. - 17	11.53	-	-

(c) 220/132 KV, Transformer No. - III (150 MVA)

	HV - IV	HV - LV	IV - LV
Tap No. - 01	11.59	-	-
Tap No. - 05 (Normal Tap)	11.33	42.07	28.27
Tap No. - 17	11.2	-	-

Cable details used for C.T. connection of Ramchandrapur S/s

SI No.	Name of Feeder	No. of Cable use C.T	Cross section of cable	Length of cable J/B to C/R panel
1	220 KV Chandil	12,12	2.5, 6.0 Sq. mm	115 mtr.
2	220KV Joda	12	6 Sq. mm	105 mtr
3	220 KV Tr.-I	12	6 Sq. mm	164 mtr.
4	220 KV Tr.-II	12,12	2.5, 6.0 Sq. mm	150 mtr
5	220 KV Tr.-III	12,12	2.5, 6.0 Sq. mm	205 mtr
6	220 KV Bar Coupler	10,4	6.0, 2.5 Sq. mm	205 mtr
7	220 KV ICT-I	10,12	2.5, 6.0 Sq. mm	129 mtr.
8	220 KV ICT-II	10,12	2.5, 6.0 Sq. mm	129 mtr.
9	132 KV Tr.-I	10	6 Sq. mm	150 mtr
10	132 KV Tr.-II	10	6 Sq. mm	136 mtr.
11	132 KV Tr.-III	10	6 Sq. mm	175 mtr.
12	132 KV B/C	12	6 Sq. mm	162 mtr
13	132 KV Adityapur-I	10	6 Sq. mm	236 mtr
14	132 KV Adityapur-II	10	6 Sq. mm	230 mtr
15	132 KV M/S Adhunik Power -I	4	6 Sq. mm	250 mtr.

Annexure-8.2.8**Measurement of Earth Resistance Name of G/S/S = 220/132KV Ramchandrapur****132KV Side**

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	132KV Adityapur ckt I	2 Ohm	
2	132KV Adityapur ckt II	2 Ohm	
3	132 KV AAPL	1 Ohm	
4	132KV Tr.-III bay	0.5 Ohm	

220KV Side

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	220kv Tr-3	2 Ohm	
2	220KV Chandil breaker	1 Ohm	
3	Near main bus-1 of Chandil-II	2 Ohm	

Near Transformer

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	Tr.No-I		
	HV	2 Ohm	
	Lv	1 Ohm	
2	Tr.No-II		
	HV	1 Ohm	
	Lv	0.5 Ohm	
3	Tr.No-III		
	HV	1 Ohm	
	Lv	0.5 Ohm	

Test Report
220/132 Kv Grid Sub-Station, Adityapur-II (RCP)

1. Breaker Specification:

Date 22.12.2015

Name of feeder	-	220 Kv Transformer - I
Make	-	CGL
Type	-	200-SPM-40A
Sl. No.	-	6071C
Year	-	1993

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	87	85	84
Tripping Coil 1	45	45	44
C/o Coil 1	16	21	13

2. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv Chandil - II
Make	-	HBB
Type	-	ELF-245-nc2
Sl. No.	-	IB103411
Year	-	1987

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	146	145	135
Tripping Coil 1	19	18	18
C/o Coil 1	18	42	876

3. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv Transformer - II
Make	-	CGL
Type	-	200-SFM-40S
Sl. No.	-	20132C
Year	-	2005

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	123	140	114
Tripping Coil 1	24	24	22
C/o Coil 1	34	42	31

4. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv ICT-I
Make	-	HBB
Type	-	ELF-245-nc2
Sl. No.	-	N.A
Year	-	1987

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	159	131	144
Tripping Coil 1	22	589	589
C/o Coil 1	44	640	628

5. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv ICT-II
Make	-	CGL
Type	-	200-SFM-40A
Sl. No.	-	6072C
Year	-	1993

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	93	79	85
Tripping Coil 1	49	40	40
C/o Coil 1	16	16	17

6. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv Joda
Make	-	AREVA
Type	-	GL314
Sl. No.	-	150418
Year	-	2006

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	68	68	67
Tripping Coil 1	42	42	42
C/o Coil 1	40	42	40

7. Breaker Specification:

Date 22.12.2015

Name of feeder	-	220 Kv Transformer - III
Make	-	AREVA
Type	-	GL314
Sl. No.	-	150419
Year	-	2006

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	70	68	69
Tripping Coil 1	41	40	40
C/o Coil 1	42	42	42

8. Breaker Specification:

Date 22.12.2015

Name of feeder	-	220 Kv Bar-Coupler
Make	-	CGL
Type	-	200-SFM-40A
Sl. No.	-	6068C
Year	-	1993

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	92	84	81
Tripping Coil 1	39	41	41
C/o Coil 1	0	11	15

9. Breaker Specification:

Date 20.12.2015

Name of feeder	-	132 Kv Transformer - I
Make	-	CGL
Type	-	120-SFM-32A
Sl. No.	-	EC7429C
Year	-	1995

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	87	87	88
Tripping Coil 1	28	28	28
C/o Coil 1	0	0	0
Tripping Coil 2	26	26	26
C/o Coil 2	0	0	0

10. Breaker Specification:

Date 21.12.2015

Name of feeder	-	132 Kv Adityapur -II
Make	-	CGL
Type	-	120-SFM-32B
Sl. No.	-	264220C
Year	-	2008

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	92	92	92
Tripping Coil 1	25	25	26
C/o Coil 1	37	36	38
Tripping Coil 2	25	25	26
C/o Coil 2	37	37	38

11. Breaker Specification:

Date 21.12.2015

Name of feeder	-	132 Kv Adityapur -I
Make	-	BHEL
Type	-	3ARS 3*DLG-302C
Sl. No.	-	403039
Year	-	1997

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	108	85	84
Tripping Coil 1	39	38	32
C/o Coil 1	56	60	65

12. Breaker Specification:

Date 21.12.2015

Name of feeder	-	132 Kv Transformer - II
Make	-	AREVA
Type	-	GL312
Sl. No.	-	102832
Year	-	2008

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	73	72	71
Tripping Coil 1	40	41	38
C/o Coil 1	62	65	60

13. Breaker Specification:

Date 22.12.2015

Name of feeder	-	132 Kv Transformer - III
Make	-	AREVA
Type	-	GL312
Sl. No.	-	101740
Year	-	2007

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	71	67	68
Tripping Coil 1	35	35	35
C/o Coil 1	53	56	56
Tripping Coil 2	35	35	35
C/o Coil 2	52	55	55

14. Breaker Specification:

Date 22.12.2015

Name of feeder	-	132 Kv Bus-Coupler
Make	-	CGL
Type	-	120-SFM-32B
Sl. No.	-	22169C
Year	-	2006

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	91	91	91
Tripping Coil 1	29	29	29
C/o Coil 1	38	39	39
Tripping Coil 2	28	27	28
C/o Coil 2	39	39	39

Annexure-8.2.10

CT/PT earthing details

SI No	Name of GSS	CT earthing details	PT earthing details
2	Ramchandrapur	All CT neutral earthing provided in field junction Box.	All PT neutral earthing provided in field junction Box.

Annexure-8.2.11

220 KV JODA

Micom P442,	
Line Length	130KM
Line Impedance	15.84 ohm
Line Angle	79
kz1	0.789
kz1 Angle	0
Z1	12.67 ohm
R1G	25.00 ohm
R1Ph	20.00 ohm
tz1	0s
kz2 Res comp	0.789
kz2 Angle	0
Z2	19.01 ohm
R2G	25.00 ohm
R2ph	20.32 ohm
tz2	300.0 ms
kz3/4Res comp	0.789
kz3/4 Angle	0
Z3	25.00 ohm
R3G-R4G	20.00 ohm
R3ph-R4ph	20.32 ohm
tz3	1.000 s
Z4	3.168 ohm
tz4	1.200 s

Back UP>I

I> 1Directional Directional FWD
I>1 VTS Block Non Directional
I> 1 Current Set 750.0 A
I> 1 Time Delay 500.0mA
I> Time VTS 500.0ms

Earth fault O/C

IN> Directional Directional FWD
IN>1 VTS Block Non Directional
IN> 1 Current Set 200.0 m A
IN> 1 Time VTS 100.0 ms
IN> TMS 0.100

Name of GSS:220/132KV RAMCHANDRAPUR G/S/S

Details:

Name of Feeder -B/C (132 KV)			Remarks
Line	Length -N.A Conductor - N.A		
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A	DoM - N.A	
Relay	DPR	Make – Alstom DoM - N.A Model – P442 DoC – 25.11.2015 Sr. No. - 33219530/02/15	
	O/C	Make – Alstom PSM -0.90 Model –P442 TMS -0.30s Sr. No. -33219530/02/15	
	E/F	Make – Alstom PSM -0.2 Model –P442 TMS -0.20sec Sr. No. -33219530/02/15	
	LBB	Make – N.A PSM - N.A Model – N.A TMS - N.A Sr. No. - N.A	
CT	R Ph	Make – SCT, Limited Sr. No. -96/810 Type – O.D.D.T DoM - 1997 Current Ratio –1200-600/1A DoC - Rated Voltage –145 kv No. of Core – 4	Length of control cable from JB to Panel -162 Meter
	Y Ph	Make – SCT, Limited Sr. No. -96/808 Type – O.D.D.T DoM -1997 Current Ratio –1200-600/1A DoC - N.A Rated Voltage –145 kv No. of Core – 4	Cross Section of C.T. Control Cable Core-12 core*6mm ²
	B Ph	Make – SCT, Limited Sr. No. -96/805 Type – O.D.D.T DoM -1997 Current Ratio –1200-600/1A DoC - N.A Rated Voltage –145 kv No. of Core – 4	
Breaker	Make – CGL Type –120-SFM-32B Rated Voltage – 145KV Rated Current –3150 A Short Time Amp –40 KA	Serial No. –22169C DoM -2006 DoC - N.A	
EM	Make – N.A Serial No. – N.A Model – N.A DoM - N.A MTR – N.A DoC - N.A Class – N.A		

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder –132 KV AADHUNIK POWER LTD.				Remarks	
Line	Length – 4.26 KM Conductor - N.A				
Panel	Make – IMP POWER LTD. DoM - N.A Sr. No. –SCA/183/08-09				
Relay	DPR	Make – Micom, AREVA/ALSTOM Model – P442314B2M0360J Sr. No. -082701C	DoM- N.A DoC - N.A		
	O/C	Make – Micom, AREVA/ALSTOM Model – P442314B2M0360J Sr. No. -082701C	PSM -1.5 A TMS -1.0sec		
	E/F	Make – Micom, AREVA/ALSTOM Model – P442314B2M0360J Sr. No. -082701C	PSM -200.0mA TMS -1.0 sec		
	LBB	Make – N.A PSM - N.A Model – N.A TMS - N.A Sr. No. - N.A			
CT	R Ph	Make – CGL Type – CT: 145/275/650 Current Ratio –150-300-600/1A Rated Voltage –145 kv	Sr. No. -80698 DoM - 2008 DoC - N.A No. of Core – 4	Length of control cable from JB to Panel -250Met & 162 Meter Cross Section of C.T. Control Cable Core- 4 core*6mm ²	
	Y Ph	Make – CGL Type – CT: 145/275/650 Current Ratio –150-300-600/1A Rated Voltage –145 kv	Sr. No. -80697 DoM -2008 DoC - N.A No. of Core – 4		
	B Ph	Make – CGL Type – CT: 145/275/650 Current Ratio –150-300-600/1A Rated Voltage –145 kv	Sr. No. -80696 DoM -2008 DoC - N.A No. of Core – 4		
Breaker	Make – CGL Type –120-SFM-32B Rated Voltage –145KV Rated Current –3150 A Short Time Amp –40 KA				
EM	Make – APEX Meter (Secure Meter Limited), (MAIN)Serial No. –ORBR4829 Model – R3M021-436, 3P- 4W MTR – /1A Class – 0.2 s				
	Make – APEX Meter (Secure Meter Limited), (CHECK) Serial No. –APMA9980 Model – R3M021-436, 3P- 4W MTR – /1A Class – 0.2 s				

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder –132 KV ADITYAPUR-2				Remarks
Line	Length – 8 KM Conductor -Panther			
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A			DoM - N.A
Relay	DPR	Make –Micom, AREVA/ALSTOM Model –P442318B2A0300G Sr. No. -062713C	DoM-N.A DoC – 28.03.2014	
	O/C	Make – Micom, AREVA/ALSTOM Model –P442318B2A0300G Sr. No. –062713C	PSM -900.0mA TMS -0.5 sec	
	E/F	Make – Micom, AREVA/ALSTOM Model – P442318B2A0300G Sr. No. –062713C	PSM -200.0mA TMS -0.1 sec	
	LBB	Make – N.A PSM - N.A Model – N.A TMS - N.A Sr. No. - N.A		
CT	R Ph	Make – Victrans Engineers Type – C-114D Current Ratio –1200-600-300/1A Rated Voltage –145 kv	Sr. No. –VE/C 19510596 DoM - 2009 DoC - N.A No. of Core – 4	Length of control cable from JB to Panel -230 Meter Cross Section of C.T. Control Cable Core-10 core*6mm ²
	Y Ph	Make – Victrans Engineers Type – C-114D Current Ratio –1200-600-300/1A Rated Voltage –145 kv	Sr. No. –VE/C 19510588 DoM -2009 DoC - N.A No. of Core – 4	
	B Ph	Make – Victrans Engineers Type – C-114D Current Ratio –1200-600-300/1A Rated Voltage –145 kv	Sr. No. –VE/C 19510603 DoM -2009 DoC - N.A No. of Core – 4	
Breaker	Make – CGL Type –120-SFM-32B Rated Voltage –145KV Rated Current –3150 A Short Time Amp –40 KA			Serial No. –26420C DoM -2008 DoC - N.A
EM	Make – Secure Meter Ltd. Model –E3M021, 3P- 4W MTR – 600/1A Class –0.2 s			Serial No. –JSB44794 DoM - 2013 DoC - 2014
	Make – APEX Meter (Secure Meter Limited) Model – R3M021-334, 3P- 4W MTR – -/1 Class – 0.2 s			Serial No. –APM99574 DoM –June, 2007 DoC - N.A

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder –132 KV ADITYAPUR-1				Remarks
Line	Length – 8 KM Conductor -			
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A		DoM - N.A	
Relay	DPR	Make – Micom, AREVA/ALSTOM Model – P442318B2A0300G Sr. No. -062706C	DoM-27/03/2014 DoC - N.A	
	O/C	Make – Micom, AREVA/ALSTOM Model – P442318B2A0300G TMS -0.5 sec Sr. No. -062706C	PSM -900.0mA	
	E/F	Make – Micom, AREVA/ALSTOM Model – P442318B2A0300G TMS -0.1 sec Sr. No. -062706C	PSM -200.0mA	
	LBB	Make – N.A PSM - N.A Model – N.A TMS - N.A Sr. No. - N.A		
CT	R Ph	Make – Victrans Engineers Type – C-114D Current Ratio – 1200-600-300/1A Rated Voltage – 145 kv	Sr. No. –VE/C 19510586 DoM - 2009 DoC - N.A No. of Core – 4	Length of control cable from JB to Panel -236 Meter Cross Section of C.T. Control Cable Core- 10 core*6mm ²
	Y Ph	Make – Victrans Engineers Type – C-114D Current Ratio – 1200-600-300/1A Rated Voltage – 145 kv	Sr. No. –VE/C 19510612 DoM -2009 DoC - N.A No. of Core – 4	
	B Ph	Make – Victrans Engineers Type – C-114D Current Ratio – 1200-600-300/1A Rated Voltage – 145 kv	Sr. No. –VE/C 19510591 DoM -2009 DoC - N.A No. of Core – 4	
Breaker	Make – BHEL Type – SF6 145KV 3ARS3XBLG-302C Rated Voltage – 145KV Rated Current – 1600 A Short Time Amp – 31.5 KA		Serial No. –403039 DoM -1997 DoC - N.A	
EM	Make – Secure Meter Ltd. Model – E3V021, 3P, 3W MTR – 600/1A Class – 0.2 s		Serial No. –JSE00016 DoM - 2001 DoC - N.A	
	Make – APEX Meter (Secure Meter Limited) Model – R3M021-334, 3P-3W MTR – -/1 DoC - N.A Class – 0.2 s		Serial No. –APM99577 DoM –June, 2007	

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder –Tr. No.-3 (132 KV)			Remarks
Line	Length – N.A Conductor - N.A		
Panel	Make – EASUN REYROLLE DoM - N.A Model – N.A DoC - N.A		
Relay	DIFF. RELAY	Make – N.A Model – N.A Sr. No. - N.A	DoM - N.A DoC - N.A
	O/C	Make – EASUN REYROLLE PSM -1.25 Model –2TJM11 TMS -0.15 sec Sr. No. –HR0601412	
	E/F	Make – EASUN REYROLLE PSM -0.5 Model – 2TJM11 TMS -0.15 sec Sr. No. –HR0601380	
	LBB	Make – N.A PSM - N.A Model – N.A TMS - N.A Sr. No. - N.A	
CT	R Ph	Make – Victrans Engineers Type – C-114D Current Ratio – <u>600</u> -300-150/1A Rated Voltage –145 kv	Sr. No. –VE/C 1448362 DoM - 2007 DoC - N.A No. of Core – 4
	Y Ph	Make – Victrans Engineers Type – – C-114D Current Ratio – <u>600</u> -300-150/1A Rated Voltage –145 kv	Sr. No. –VE/C 1448371 DoM -2007 DoC - N.A No. of Core – 4
	B Ph	Make – Victrans Engineers Type – – C-114D Current Ratio – <u>600</u> -300-150/1A Rated Voltage –145 kv	Sr. No. –VE/C 1448382 DoM -2007 DoC - N.A No. of Core – 4
Breaker	Make – AREVA Type –GL 312 Rated Voltage – 145KV Rated Current –3150 A Short Time Amp –40 KA		Serial No. –101740 DoM -2007 DoC - N.A
EM	Make – Secure Meter Ltd. Model –E3M021, 3P- 4W MTR – 600/1A Class –0.2 s		Serial No. –JSB44795 DoM - 2013 DoC - 2014

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder –Tr. No.-2 (132 KV)			Remarks
Line	Length – N.A Conductor - N.A		
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A	DoM - N.A	
Relay	DIFF. RELAY	Make – N.A Model – N.A Sr. No. - N.A	DoM - N.A DoC - N.A
	O/C	Make – ENGLISH ELECTRIC Model – CDG11AF002SA(M) Sr. No. -11192037401008, 16, 15	PSM -1.25 TMS -0.15 sec
	E/F	Make – ENGLISH ELECTRIC Model – CDG11AF005SA(M) Sr. No. - N.A	PSM - N.A TMS - N.A
	LBB	Make – N.A PSM - N.A Model – N.A TMS - N.A Sr. No. - N.A	
CT	R Ph	Make – Victrans Engineers Type – C-114D Current Ratio –600-300-150/1A Rated Voltage –145 kv	Sr. No. –VE/C 1448381 DoM - 2007 DoC - N.A No. of Core – 4
	Y Ph	Make – Victrans Engineers Type – – C-114D Current Ratio –600-300-150/1A Rated Voltage –145 kv	Sr. No. –VE/C 1448364 DoM -2007 DoC - N.A No. of Core – 4
	B Ph	Make – Victrans Engineers Type – – C-114D Current Ratio –600-300-150/1A Rated Voltage –145 kv	Sr. No. –VE/C 1448361 DoM -2007 DoC - N.A No. of Core – 4
Breaker	Make – AREVA Type –GL 312 Rated Voltage – 145KV Rated Current –3150 A Short Time Amp –40 KA	Serial No. –102832 DoM -2008 DoC - N.A	
EM	Make – Secure Meter Ltd. Model –E3M021, 3P- 3W MTR – 600/1A Class –0.2 s	DoM - 2005 DoC - N.A	Serial No. –WBB04206

Name of GSS :220/132KV RAMCHANDRAPUR G/S/S

Details:

Name of Feeder –Tr. No.-1 (132 KV)			Remarks
Line	Length – N.A Conductor - N.A		
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A	DoM - N.A	
Relay	DIFF. RELAY	Make – N.A Model – N.A Sr. No. - N.A	DoM - N.A DoC - N.A
	O/C	Make – ENGLISH ELECTRIC PSM -1.25 Model – CDG11AF002SA(M) Sr. No. -95088559005	TMS -0.15 sec
	E/F	Make – ENGLISH ELECTRIC Model – CDG11AF005SA(M) Sr. No. -95103476002(B)	PSM -0.2 TMS -0.1 sec
	LBB	Make – N.A PSM - N.A Model – N.A TMS - N.A Sr. No. - N.A	
CT	R Ph	Make – SCT, Limited Type – O.D.D.T Current Ratio –1200-600/1A Rated Voltage –245 kv	Sr. No. -96/809 DoM - 1997 DoC - N.A No. of Core – 4
	Y Ph	Make – SCT, Limited Type – O.D.D.T Current Ratio –1200-600/1A Rated Voltage –245 kv	Sr. No. -96/804 DoM -1997 DoC - N.A No. of Core – 4
	B Ph	Make – SCT, Limited Type – O.D.D.T Current Ratio –1200-600/1A Rated Voltage –245 kv	Sr. No. -96/807 DoM -1997 DoC - N.A No. of Core – 4
Breaker	Make – CGL Type –200-SFM-32A Rated Voltage – 145KV Rated Current –1600 A Short Time Amp –31.5 KA	Serial No. –EC 7429C DoM -1995 DoC - N.A	
EM	Make – N.A Model – N.A MTR – N.A Class – N.A	Serial No. – N.A DoM - N.A DoC - N.A	

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:-

Name of Feeder –Tr. No-3 (220 KV)			Remarks
Line	Length – N.A Conductor - N.A		
Panel	Make – EASUN REYROLLE DoM - N.A Model – N.A DoC - N.A		
Relay	DIFF. RELAY	Make – EASUN REYROLLE Model –DUOBIAS-M Sr. No. - 100909302/010	Type- N.A Bias-30 %
	O/C	Make – EASUN REYROLLE Model –2TJM11 Sr. No. –HR0601402	PSM -1.25 TMS -0.15 sec
	E/F	Make – EASUN REYROLLE Model – 2TJM11 Sr. No. –HR0601382	PSM -0.2 TMS -0.15 sec
	LBB	Make – EASUN REYROLLE Model –2DAB Sr. No. –BR0531822	PSM -200 ma TMS -192 ms
	REF	Make – EASUN REYROLLE Model –5B3 Sr. No. –BR0600194	PSM - 0.2 TMS – N.A Vs-30
CT	R Ph	Make – SCT, Limited Type – O.D.D.T Current Ratio –1200-600-300/1A Rated Voltage –245 kv	Sr. No. -2007/2316 DoM - 2007 DoC - N.A No. of Core – 4
	Y Ph	Make – SCT, Limited Type – O.D.D.T Current Ratio –1200-600-300/1A Rated Voltage –245 kv	Sr. No. -2007/2317 DoM -2007 DoC - N.A No. of Core –4
	B Ph	Make – AREVA Sr. No. -20060837 Type – IT-245DoM -2006 Current Ratio –1200-600-300-150/1A Rated Voltage –245 kv	DoC - N.A No. of Core – 5
Breaker	Make – AREVA Serial No. –150419 Type –GL 314 Rated Voltage – 245KV Rated Current –3150 A Short Time Amp –40 KA		
EM	Make – Secure Meter Ltd. Model – E3V 021, 3ph- 3w MTR – 200/1 Class –0.2 s		

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:-

Name of Feeder –Tr. No-2 (220 KV)				Remarks	
Line	Length – N.A Conductor - N.A				
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A				
Relay	DIFF. RELAY	Make – ENGLISH ELECTRIC Model – DTH32HG8014A(M) Sr. No. - 92037498002	Type-DTH 32 Bias-30%		
	O/C	Make – ENGLISH ELECTRIC Model – CDG21AF0032M(M) Sr. No. -11192037406001, 08, 05	PSM -1.25 TMS -0.15 sec		
	E/F	Make – ENGLISH ELECTRIC Model – CDD21PF905SE(M) Sr. No. -11192037399001	PSM -0.2 TMS -0.15 sec		
	LBB	Make – MICOM, Schneider Model – P122B00Z112CF0 Sr. No. -36234276/07/13	PSM -0.2 TMS -200 ms		
	REF	Make – AREVA Model – CAG 4AF144 TMS – N.A Sr. No. -140311680627001	PSM - 0.2		
CT	R Ph	Make –ALSTOM Instrument Trans. Pvt. Ltd. Type – IT-245 Current Ratio –1200-600-300/1A Rated Voltage –245 kv	Sr. No. -20050631/2005 DoM - 2005 DoC - N.A No. of Core – 4	Length of control cable from JB to Panel -150 Meter Cross Section of C.T. Control Cable Core-12 core*2.5mm ² 12 core*6.0mm ²	
	Y Ph	Make – ALSTOM Instrument Trans. Pvt. Ltd. Type – – IT-245 Current Ratio –1200-600-300/1A Rated Voltage –245 kv	Sr. No. -20050630 DoM -2005 DoC - N.A No. of Core –4		
	B Ph	Make – ALSTOM Instrument Trans. Pvt. Ltd. Type – – IT-245 Current Ratio –1200-600-300/1A Rated Voltage –245 kv	Sr. No. -20050629 DoM -2005 DoC - N.A No. of Core –4		
Breaker	Make – CGL Type –200-SFM-40S Rated Voltage –245KV Rated Current –3150 A Short Time Amp –40 KA				
EM	Make – Secure Meter Ltd. Model – E3M 021, 3ph- 4w MTR – 600/1 Class –0.2 s				
	Sr. No. –JSB44798 DoM - 2013 DoC - 2014				

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:-

Name of Feeder –Tr. No-1 (220 KV)				Remarks
Line	Length – N.A Conductor - N.A			
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A			DoM - N.A
Relay	DIFF. RELAY	Make – ENGLISH ELECTRIC Model – DTH32HG8014A(M) Sr. No. - 92037498001	Type-DTH 32 Bias-30%	
	O/C	Make – ENGLISH ELECTRIC Model – CDG21AF0032M(M) Sr. No. -11192037406002, 03, 04	PSM -1.25 TMS -0.15 sec	
	E/F	Make – ENGLISH ELECTRIC Model – CDD21PF905SE(M) Sr. No. -11192037399002	PSM -0.2 TMS -0.15 sec	
	LBB	Make – MICOM, Schneider Model – P122B00Z112CF0 Sr. No. -36234273/07/13	PSM -0.2 TMS -200 ms	
	REF	Make – ENGLISH ELECTRIC Model – CAG 14AF14A TMS – N.A Sr. No. – 11192037412001	PSM - 0.2	
CT	R Ph	Make –System Controls & Trans. Pvt. Ltd. Type – O.D.D.T Current Ratio –1200-600-300-150/1A Rated Voltage –245 kv	Sr. No. -91/828 DoM - 1991 DoC - N.A No. of Core – 5	Length of control cable from JB to Panel -164 Meter Cross Section of C.T. Control Cable Core- 12 core*6mm ²
	Y Ph	Make – System Controls & Trans. Pvt. Ltd. Type – – O.D.D.T Current Ratio –1200-600-300-150/1A Rated Voltage –245 kv	Sr. No. -91/827 DoM -1991 DoC - N.A No. of Core – 5	
	B Ph	Make – System Controls & Trans. Pvt. Ltd. Type – – O.D.D.T Current Ratio –1200-600-300-150/1A Rated Voltage –245 kv	Sr. No. -91/826 DoM -1991 DoC - N.A No. of Core – 5	
Breaker	Make –CGL Type –200-SFM-40A Rated Voltage – 245KV Rated Current –1600 A Short Time Amp –40 KA			Serial No. –6071 C DoM -1993 DoC - N.A
EM	Make – Secure Meter Ltd. Sr. No. –JSB44798 Model – E3V 021, 3ph- 3w DoM - 2005 MTR – 600/1 DoC - N.A Class –0.2 s			

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder –220 KV CHANDIL LINE			Remarks
Line	Length – 35 KM Conductor - Zebra		
Panel	Make – ENGLISH ELECTRIC Model –	DoM - N.A DoC - N.A	
Relay	DPR	Make – Micom ,AREVA/ALSTOM Model – P442 DoC – 25.11.2015 Sr. No. – 332219528/02/15	DoM - N.A
	O/C	Make – Micom ,AREVA/ALSTOM Model –P430c TMS -1 sec Sr. No. -	PSM -0.75
	E/F	Make – Micom ,AREVA/ALSTOM Model – P430c TMS –1.0 sec Sr. No. -	PSM –0.20
	LBB	Make – MICOM, Schneider Model –P122B00Z112CFO Sr. No. -36234278/07/13	PSM -0.2 TMS -200 ms
CT	R Ph	Make –SCT Gaziabad Ltd. Type – N.A Current Ratio –800-400-200/1A Rated Voltage –245 kv	Sr. No. -2012/1023 DoM - 2012 DoC - N.A No. of Core – 5
	Y Ph	Make – ALSTOM, Limited Type – – IT-245 Current Ratio –800-400-200/1A Rated Voltage –245 kv	Sr. No. -20050626 DoM -2005 DoC - N.A No. of Core – 4
	B Ph	Make – ALSTOM, Limited Type – – IT-245 Current Ratio –800-400-200/1A Rated Voltage –245 kv	Sr. No. -20050627 DoM -2005 DoC - N.A No. of Core – 4
Breaker	Make – Hindustan Brown Boveri Type –ELF 245nc2 Rated Voltage – 245KV Rated Current –3150 A Short Time Amp –40 KA	Serial No. –IB103411 DoM -1987 DoC - N.A	
EM	Make –APEX Meter (Secure Meter Limited) Model – R3M021-334, 3 ph- 4 wire MTR – -/1 A Class –0.2 s	Serial No. – APM 99579 DoM - June, 2007 DoC - N.A	

Name of GSS :220/132KV RAMCHANDRAPUR G/S/S

Details:

Name of Feeder –220 KV JODA LINE				Remarks
Line	Length – 130 KM Conductor - Zebra			
Panel	Make – ENGLISH ELECTRIC Model – N.A DoC - N.A			
Relay	DPR	Make – Micom, AREVA/ALSTOM Model – P442 Sr. No. -062707C	DoC -29/03/2014 DoC - N.A	
	O/C	Make – Micom ,AREVA/ALSTOM Model –P442318B2A030G Sr. No. -062707C	PSM -750 ma TMS -0.5 sec	
	E/F	Make – Micom ,AREVA/ALSTOM Model – P442318B2A030G TMS -0.1 sec Sr. No. -062707C	PSM -200 ma	
	LBB	Make – MICOM, Schneider Model –P122B00Z112CFO Sr. No. -36234280/07/13	PSM -0.2 TMS -200 ms	
CT	R Ph	Make –SCT, Limited Type – O.D.D.T Current Ratio –1200-600-300-150/1A Rated Voltage –245 kv	Sr. No. -2012/1017 DoM - 2012 DoC - N.A No. of Core – 4	Length of control cable from JB to Panel -105 Meter
	Y Ph	Make – SCT, Limited Sr. No. -2012/1010 Type – O.D.D.T Current Ratio –1200-600-300-150/1A Rated Voltage –245 kv	DoM -2012 DoC - N.A No. of Core – 4	Cross Section of C.T. Control Cable Core-12 core*6mm ²
	B Ph	Make – SCT, Limited Sr. No. -2012/1016 Type – O.D.D.T Current Ratio –1200-600-300-150/1A Rated Voltage –245 kv	DoM -2012 DoC - N.A No. of Core – 4	
Breaker	Make –AREVA Type –GL 314 (SF6) Rated Voltage – 245KV Rated Current –3150 A Short Time Amp –40 KA			
EM	Make – APEX Meter (Secure Meter Limited) Serial No. –APM 99576 Model – R3M021-334, 3 ph- 4 wire MTR – -/1 A Class –0.2 s			

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder -ICT-2			Remarks
Line	Length – 1.5 km Conductor -Zebra		
Panel	Make – ENGLISH ELECTRIC DoM - N.A Model – N.A DoC - N.A		
Relay	DPR	Make – N.A Model – N.A Sr. No. - N.A	DoM - N.A DoC - N.A
	O/C	Make – ENGLISH ELECTRIC PSM -1 Model – CDD TMS -0.4 sec Sr. No. -2082166002	
	E/F	Make – ENGLISH ELECTRIC PSM -0.2 Model – CDD TMS -0.7 sec Sr. No. - N.A	
	LBB	Make – ENGLISH ELECTRIC PSM -0.2 Model – CTIG39BF8002AG TMS -1 Sr. No. -91083261003	
CT	R Ph	Make – AREVA Type – IT-245 Current Ratio – <u>1200</u> -600-300-150/1A Rated Voltage –245 kv	Sr. No. -20060848 DoM - 2006 DoC - N.A No. of Core – 5
	Y Ph	Make – AREVA Type – IT-245 DoM -2006 Current Ratio – <u>1200</u> -600-300-150/1A Rated Voltage –245 kv	Sr. No. -20060851 DoC - N.A No. of Core – 5
	B Ph	Make – AREVA Sr. No. -20060849 Type – IT-245 DoM -2006 Current Ratio – <u>1200</u> -600-300-150/1A Rated Voltage –245 kv	Sr. No. -20060849 DoC - N.A No. of Core – 5
Breaker	Make – CROMPTON GREAVES Type – 200-SFM-40A Rated Voltage – 245KV Rated Current – 1600 A Short Time Amp – 40 KA	Serial No. –6072 C DoM - 1993 DoC - N.A	
EM	Make – APEX Meter (Secure Meter Limited) Model – R3M021-334, 3 ph- 4 wire MTR – /1 A DoC - N.A Class –0.2 s	Serial No. – APM 99578 DoM - June, 2007	

Name of GSS :220/132KVRAMCHANDRAPUR G/S/S

Details:

Name of Feeder- ICT-1			Remarks
Line	Length –1.5 km Conductor -Zebra		
Panel	Make – ENGLISH ELECTRIC DoM - N.A Model – N.A DoC - N.A		
Relay	DPR	Make – N.A Model – N.A Sr. No. - N.A	DoM - N.A DoC - N.A
	O/C	Make – ENGLISH ELECTRIC PSM - 1 Model – CDD TMS - 0.4 sec Sr. No. - N.A	
	E/F	Make – ENGLISH ELECTRIC PSM - 0.2 Model – CDD TMS - 0.7sec Sr. No. - N.A	
	LBB	Make – ENGLISH ELECTRIC PSM - 0.2 Model – CTIG 39BF8002ACMJ Sr. No. -91126328001	TMS - 1 sec
CT	R Ph	Make – AREVA Type – IT-245 Current Ratio – <u>1200</u> -600-300-150/1 AMP Rated Voltage –245 KV	Sr. No. - 20060853 DoM - 2006 DoC - N.A No. of Core – 5
	Y Ph	Make – AREVA Sr. No. - 20060845 Type – IT-245 Current Ratio - <u>1200</u> -600-300-150/1 AMP Rated Voltage –245 KV	DoM - 2006 DoC - N.A No. of Core - 5
	B Ph	Make – AREVA Sr. No. - 20060712 Type – IT-245 DoM - 2006 Current Ratio – <u>1200</u> -600-300-150/1 AMP DoC - N.A Rated Voltage –245 KV	No. of Core – 5
Breaker	Make – Hindustan Brown Boveri Type – N.A DoM - N.A Rated Voltage –245 kv DoC - N.A Rated Current – N.A Short Time Amp – N.A	Serial No. – N.A	
EM	Make – APEX Meter (Secure Meter Limited) Model – R3M021-334, 3 ph- 4 wire MTR --/1 A Class –0.2 s	Serial No. – APM 99578 DoM – June, 2007 DoC - N.A	

Annexure-8.2.12

D.C. system details with Charger and battery									
Sl. No.	Name of G/s/s	Details of Battery Charger	Single /Double	Total voltage	Capacity	no. of Cells	D.C. system Earth fault	D.C. positive to earth	D.C. Negative to earth
2	Ramchandrapur	<u>DC charger-1</u> TYPE- H3V3FMM Input-400V Float charger output- 260V Boost charger output- 330v 3 phase, 50Hz, 3% Ripple Make- Best and Crompton Engineering LTD. <u>DC charger-II</u> 300AH HBL make Battery Float cum Boost Charger Model- FCBC340036 AC voltage range- 370v to 460v Frequency-50Hz Output DC voltage-250v Output Current- 36A Make- Signotron India Pvt.LTD	Double	240v	300AH	112	Not tested	227V	7V

Annexure-8.2.13

Name of the Sub-station:-Ramchandrapur		
Name of the line	Line length(KM)	Conductor type
JODA	130	ZEBRA
ADITYAPUR 1	8	PANTHER
ADITYAPUR 2	8	PANTHER
CHANDIL	35	ZEBRA
ADHUNIC	4.26	PANTHER

Name of the Sub-station: Ramchandrapur GSS

Transformer Details	BHEL,1992 Vector-YNn0d11	
Transformer Number	1	
MVA Rating	150	
% Impedance	Tap no. 1-12.44, Tap no. 5(Normal)- 12.03, Tap no. 17-12	
Ratio	220/132KV	

Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core			Setting	High set setting
			Ratio	Core number	Core details		
	HV	SCT, Rated voltage- 245KV Class of Accuracy- 1	600/1A	5	1200/600 /300/150 /1A		
		SCT, Rated voltage- 245KV Class of Accuracy- 1					
	LV	SCT, Rated voltage- 245KV Class of Accuracy- 1	600/1A	4	1200/600 /1A		
	Nomenclature	Make & model					
Differential Protection	English Electrical	DTH32HG8014A(M)				BIAS-30%	
Restricted E/F (HV)	English Electrical	CAG14AF14A				PSM-0.2, TMS-	
Restricted E/F (LV)							
HV O/C	English Electrical	CDG21AF0032M(M)				PSM-1.25, TMS-0.15	
LV O/C	English Electrical	CDG11AF002SA(M)				PSM-1.25, TMS-0.15	
HV E/F	English Electrical	CDD21PF905SE(M)				PSM-0.2, TMS-0.15	
LV E/F	English Electrical	CDG11AF005SA(M)				PSM-0.2, TMS-0.1	
Over flux	AREVA	GTT21AFA001ACH				1.2K, T-12 Sec,	

Trip relay	English Electrical	VAJAMI3SF54D
-------------------	--------------------	---------------------

Name of the Sub-station: Ramchandrapur GSS


Transformer Details	BHEL,1992 Vector-YNn0d11						
Transformer Number	2						
MVA Rating	150						
% Impedance	Tap no. 1-11.87, Tap no. 5(Normal) 11.64, Tap no. 17-11.53						
Ratio	220/132KV						
Name of the Protection		C.T.	C.T. Details (Make & Model)	Connected CT/PT core number & Details			
		HV	AREVA, Rated voltage-245KV Class of Accuracy- 0.2	600/1A	4	1200/600/300/1A	Setting
		LV	VICTRANS ENG., Rated voltage-145KV Class of Accuracy- 0.5	600/1A	4	600/300/150/1A	High set setting
Nomenclature		Make & model					
Differential Protection	English Electrical	DTH32HG8014A(M)					BIAS-30%
Restricted E/F (HV)	AREVA	CAG4AF144					PSM-0.2, TMS-
Restricted E/F (LV)							
HV O/C	English Electrical	CDG21AF0032M(M)					PSM-1.25, TMS-0.15
LV O/C	English Electrical	CDG11AF002SA(M)					PSM-1.25, TMS-0.15
HV E/F	English Electrical	CDD21PF905SE(M)					PSM-0.2, TMS-0.15
LV E/F	English Electrical	CDG11AF005SA(M)					PSM-0.2, TMS-0.1
Over flux	AREVA	GTT21AFA001ACH					1.2K, T-12 Sec,
Trip relay	English Electrical	VAJAM13SF54D					

Annexure-8.2.14.2

Name of the Sub-station: Ramchandrapur GSS

Transformer Details	AREVA,2006 Vector-YNn0d11							
Transformer Number	1							
MVA Rating	150							
% Impedance	Tap no. 1-11.59, Tap no. 5(Normal)- 11.33, Tap no. 17-11.20							
Ratio	220/132KV							
Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number & Details			Setting	High set setting	
		HV	R & Y Phase -SCT, B Phase-AREVA, Rated voltage- 245KV Class of Accuracy- 0.5(R&Y-phase), 0.2(B-phase)	600/1A	R & Y phase -4 B-phase-5	R & Y phase- 1200/600/300/1A B phase- 1200/600/300/150 /1A		
		LV	VICTRANS ENG., Rated voltage- 145KV Class of Accuracy- 0.5	600/1A	4	600/300/150/1A		
Nomenclature	Make & model							
Differential Protection	EASUN REYROLLE	DUOBIAS-M				BIAS-30%		
Restricted E/F (HV)	EASUN REYROLLE	5B3				PSM-0.2, TMS-		
Restricted E/F (LV)								
HV O/C	EASUN REYROLLE	2TJM11				PSM-1.25, TMS-0.15		
LV O/C	EASUN REYROLLE	2TJM11				PSM-1.25, TMS-0.15		
HV E/F	EASUN REYROLLE	2TJM11				PSM-0.2, TMS-0.15		
LV E/F	EASUN REYROLLE	2TJM11				PSM-0.5, TMS-0.15		
Over flux	AREVA	GTT21AFA001ACH				1.2K, T-12 Sec,		

Trip relay	EASUN REYROLLE	TR221
------------	----------------	-------



Sl. No.	Name of G/S/S	Name of Feeders	Type of Equipment	Year of Manufacturing
1	132 KV UML-I	CT	R Phase	2009
		CT	Y Phase	2009
		CT	B Phase	2009
2	132 KV UML-II	CT	R Phase	2010
		CT	Y Phase	2010
		CT	B Phase	2010
3	132 KV RKSН	CT	R Phase	2011
		CT	Y Phase	2011
		CT	B Phase	2011
4	132 KV B/C	CT	R Phase	
		CT	Y Phase	
		CT	B Phase	
5	132 KV 50MVA Tr.-I	CT	R Phase	2009
		CT	Y Phase	2009
		CT	B Phase	2009
6	132 KV 50 MVA Tr.-I	CT	R Phase	
		CT	Y Phase	
		CT	B Phase	
7	132 KV MVA Tr.-IV	CT	R Phase	2007
		CT	Y Phase	2007
		CT	B Phase	2007
8	132 KV Chandil	CT	R Phase	
		CT	Y Phase	
		CT	B Phase	
9	132 KV RCP-I	CT	R Phase	1992
		CT	Y Phase	1992
		CT	B Phase	1992
10	132 KV RCP-II	CT	R Phase	2006
		CT	Y Phase	2006
		CT	B Phase	2006
11	132 KV PT-I connected (UML-I)	PT	R Phase	2011
		PT	Y Phase	2011
		PT	B Phase	2011
12	132 KV PT-I connected (UML-II)	PT	R Phase	2011
		PT	Y Phase	2011
		PT	B Phase	2011
13	132KV Main-Bus	PT	R Phase	20 Years Old
		PT	Y Phase	20 Years Old
		PT	B Phase	20 Years Old
14	132 KV UML-I	Breaker		1998
15	132 KV UML-II	Breaker		2008
16	132 KV RKSН	Breaker		2007
17	132 KV Tr.-I	Breaker		20 Years Old
18	132 KV Tr.-II	Breaker		20 Years Old
19	132 KV Tr.-IV	Breaker		2006
20	132 KV Chandil	Breaker		20 Years Old
21	132 KV RCP-I	Breaker		1999
22	132 KV RCP-II	Breaker		1999
23	2KV Main-Bus Coup	Breaker		20 Years Old
24	50 MVA Transformer-I	Transformer		1994
25	50 MVA Transformer-II	Transformer		1994
26	50 MVA Transformer-IV	Transformer		2006

Adityapur

Annexure-8.3.3

Sl. No.	Name of G/S/S	Name of Feeders	Comprehensive C.T. details	Make	CT ratio	Connected Ratio	Core No.	Class of accuracy	Protection class use	Knee voltage	
1	132KV GSS Adityapur	132 KV UML-I	R Phase	CGL	600/300/150/1A	600/1A	5 Core	0.2	PS		
			Y Phase	CGL	600/300/150/1A			0.2	PS		
			B Phase	CGL	600/300/150/1A			0.2	PS		
2		132 KV UML-II	R Phase	CGL	600/300/150/1A	600/1A	5 Core	0.2	PS		
			Y Phase	CGL	600/300/150/1A			0.2	PS		
			B Phase	CGL	600/300/150/1A			0.2	PS		
3		132 KV RKSН	R Phase	SCT LTD.(UP)	800/400/200/1A	400/1A	4 Core	0.5	PS		
			Y Phase	SCT LTD.(UP)	800/400/200/1A			0.5	PS		
			B Phase	SCT LTD.(UP)	800/400/200/1A			0.5	PS		
4		132 KV B/C	R Phase	ASEA	600/300/150/1A	300/1A	3 Core		PS		
			Y Phase	ASEA	600/300/150/1A				PS		
			B Phase	ASEA	600/300/150/1A				PS		
5		132 KV 50MVA Tr.-I	R Phase	Victrans eng.	600/300/150/1A	300/1A	4 Core	0.2	PS		
			Y Phase	Victrans eng.	600/300/150/1A			0.2	PS		
			B Phase	Victrans eng.	600/300/150/1A			0.2	PS		
6		132 KV 50 MVA Tr.-II	R Phase	Bhel	600/300/150/5A	300/1A	4 Core	1	PS		
			Y Phase	Bhel	600/300/150/5A			1	PS		
			B Phase	Alstrom	600/300/150/5A			1	PS		
7		132 KV MVA Tr.-IV	R Phase	SCT LTD.(UP)	600/300/150/1A	300/1A	4 Core	0.5	PS		
			Y Phase	SCT LTD.(UP)	600/300/150/1A			0.5	PS		
			B Phase	SCT LTD.(UP)	600/300/150/1A			0.5	PS		
8		132 KV Chandil	R Phase	ASEA	600/300/150/1A	600/1A	3 Core	0.2	PS		
			Y Phase	Victrans eng.	1200/600/300/1A			0.2	PS		
			B Phase	ASEA	600/300/150/1A			0.2	PS		
9		132 KV RCP-I	R Phase	SCT LTD.(UP)	600/300/150/1A	600/1A	4 Core	1	PS		
			Y Phase	SCT LTD.(UP)	600/300/150/1A			1	PS		
			B Phase	SCT LTD.(UP)	600/300/150/1A			1	PS		
10		132 KV RCP-II	R Phase	SCT LTD.(UP)	600/300/150/1A	600/1A	4 Core	1	PS		
			Y Phase	SCT LTD.(UP)	600/300/150/1A			1	PS		
			B Phase	SCT LTD.(UP)	600/300/150/1A			1	PS		

Sl. No.	Name of G/S/S	V.T. details	Comprehensive P.T. details	Make	Core No.
1	Adityapur	132 KV PT-I connected (UML-I)	R Phase	CGL	3 Core
			Y Phase	CGL	3 Core
			B Phase	CGL	3 Core
2		132 KV PT-I connected (UML-II)	R Phase	CGL	3 Core
			Y Phase	CGL	3 Core
			B Phase	CGL	3 Core
3		132KV Main-Bus	R Phase	Seimans	3 Core
			Y Phase	Seimans	3 Core
			B Phase	Seimans	3 Core

Class of accuracy
0.5/3/0.2
0.5/3/0.2
0.5/3/0.2
0.5/3/0.2
0.5/3/0.2
0.5/3/0.2
0.5/3/0.5
0.5/3/0.5
0.5/3/0.5

Fault level at JUSNL Sub-stations

Bus Name	Bus Voltage	3 Ph Fault current	SLG Fault current
CHANDIL 220	220	14514	9735
RAMCHANDRAPUR 220	220	18450	15443
CHANDIL	132	18105	12652
ADITPUR	132	12098	8624
RAMCHANDRAPUR 132	132	13000	11126

Note: Data received from ERLDC

Cable details used for C.T. connection

Sl No.	Name of G/S/S	Name of Feeder	No. of Cable use C.T.		Cross section of cable	Length of cable J/B to C/R panel
1	Adityapur	132KV UML-I	6		2.5 Sq. mm	65 mtrs
2		132KV UML-II	4		2.5 Sq. mm	70 mtrs
3		132KV RKS N	4		2.5 Sq. mm	65 mtr
4		132Kv Tr-II Bay	12		2.5 Sq. mm	100 mtr
5		132 Kv Chandil	4		2.5 Sq. mm	112 mtr
6		132KV B/C Bay	10		2.5 Sq. mm	127 mtr
7		132Kv Tr.-I bay	10		2.5 Sq. mm	138 mtr
8		132Kv RCP -I	10		6 Sq. mm	152 mtr
9		132Kv RCP- II	10		6 Sq. mm	165 mtr
10		132Kv Tr.-IV	10		2.5 Sq. mm	177mtr

Measurement of Earth Resistance
Name of G/S/S = 132/33KV

33 KV Side Feeder

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	Tr.No-1	0.8 Ohm	
2	Tr.No-2	0.6 Ohm	
3	Tr.No-3	0.6 Ohm	
4	Tr.No-4	0.7 Ohm	
5	Between Nit & Aiada	0.5 Ohm	
6	Between B/C and Kumar Basti	0.7 Ohm	

Near Transformer (New earth Pit)

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	Tr.No-1	1.5 Ohm	
2	Tr.No-2	2.2 Ohm	
3	Tr.No-3	1.8 Ohm	

Near 132Kv Side

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	Tr.No-1	0.4 Ohm	
2	Between RCP I & RCp II	0.6 Ohm	

Near Transformer (Old Earth Pit)

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	Tr.No-1	1 Ohm	
2	Tr.No-2	0.6 Ohm	
3	Tr.No-3	0.9 Ohm	

Control Panel

SL NO	Name of Earth Pit	Earth Resistance in Ohm	Remarks
1	33 Kv Side	0.5 Ohm	
2	132 KV Side	0.4 Ohm	

Test Report
220/132 Kv Grid Sub-Station, Adityapur-II (RCP)

1. Breaker Specification:

Date 22.12.2015

Name of feeder	-	220 Kv Transformer - I
Make	-	CGL
Type	-	200-SPM-40A
Sl. No.	-	6071C
Year	-	1993

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	87	85	84
Tripping Coil 1	45	45	44
C/o Coil 1	16	21	13

2. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv Chandil - II
Make	-	HBB
Type	-	ELF-245-nc2
Sl. No.	-	IB103411
Year	-	1987

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	146	145	135
Tripping Coil 1	19	18	18
C/o Coil 1	18	42	876

3. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv Transformer - II
Make	-	CGL
Type	-	200-SFM-40S
Sl. No.	-	20132C
Year	-	2005

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	123	140	114
Tripping Coil 1	24	24	22
C/o Coil 1	34	42	31

4. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv ICT-I
Make	-	HBB
Type	-	ELF-245-nc2
Sl. No.	-	N.A
Year	-	1987

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	159	131	144
Tripping Coil 1	22	589	589
C/o Coil 1	44	640	628

5. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv ICT-II
Make	-	CGL
Type	-	200-SFM-40A
Sl. No.	-	6072C
Year	-	1993

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	93	79	85
Tripping Coil 1	49	40	40
C/o Coil 1	16	16	17

6. Breaker Specification:

Date 21.12.2015

Name of feeder	-	220 Kv Joda
Make	-	AREVA
Type	-	GL314
Sl. No.	-	150418
Year	-	2006

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	68	68	67
Tripping Coil 1	42	42	42
C/o Coil 1	40	42	40

7. Breaker Specification:

Date 22.12.2015

Name of feeder	-	220 Kv Transformer - III
Make	-	AREVA
Type	-	GL314
Sl. No.	-	150419
Year	-	2006

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	70	68	69
Tripping Coil 1	41	40	40
C/o Coil 1	42	42	42

8. Breaker Specification:

Date 22.12.2015

Name of feeder	-	220 Kv Bar-Coupler
Make	-	CGL
Type	-	200-SFM-40A
Sl. No.	-	6068C
Year	-	1993

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	92	84	81
Tripping Coil 1	39	41	41
C/o Coil 1	0	11	15

9. Breaker Specification:

Date 20.12.2015

Name of feeder	-	132 Kv Transformer - I
Make	-	CGL
Type	-	120-SFM-32A
Sl. No.	-	EC7429C
Year	-	1995

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	87	87	88
Tripping Coil 1	28	28	28
C/o Coil 1	0	0	0
Tripping Coil 2	26	26	26
C/o Coil 2	0	0	0

10. Breaker Specification:

Date 21.12.2015

Name of feeder	-	132 Kv Adityapur -II
Make	-	CGL
Type	-	120-SFM-32B
Sl. No.	-	264220C
Year	-	2008

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	92	92	92
Tripping Coil 1	25	25	26
C/o Coil 1	37	36	38
Tripping Coil 2	25	25	26
C/o Coil 2	37	37	38

11. Breaker Specification:

Date 21.12.2015

Name of feeder	-	132 Kv Adityapur -I
Make	-	BHEL
Type	-	3ARS 3*DLG-302C
Sl. No.	-	403039
Year	-	1997

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	108	85	84
Tripping Coil 1	39	38	32
C/o Coil 1	56	60	65

12. Breaker Specification:

Date 21.12.2015

Name of feeder	-	132 Kv Transformer - II
Make	-	AREVA
Type	-	GL312
Sl. No.	-	102832
Year	-	2008

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	73	72	71
Tripping Coil 1	40	41	38
C/o Coil 1	62	65	60

13. Breaker Specification:

Date 22.12.2015

Name of feeder	-	132 Kv Transformer - III
Make	-	AREVA
Type	-	GL312
Sl. No.	-	101740
Year	-	2007

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	71	67	68
Tripping Coil 1	35	35	35
C/o Coil 1	53	56	56
Tripping Coil 2	35	35	35
C/o Coil 2	52	55	55

14. Breaker Specification:

Date 22.12.2015

Name of feeder	-	132 Kv Bus-Coupler
Make	-	CGL
Type	-	120-SFM-32B
Sl. No.	-	22169C
Year	-	2006

Operating time in Mille Second:

	R Ph	Y Ph	B Ph
Closing	91	91	91
Tripping Coil 1	29	29	29
C/o Coil 1	38	39	39
Tripping Coil 2	28	27	28
C/o Coil 2	39	39	39

14. CT/PT earthing details

SI No	Name of GSS	CT earthing details	PT earthing details
3	Adityapur	All CT neutral earthing provided in field junction Box.	All PT neutral earthing provided in field junction Box.

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder: 132KV B/C

Particular				Remarks
Line	Length – N.A. Conductor - Panther			
Panel	Make – ENGLISH ELECTRIC Model –		DoM - DoC -	
Relay	DPR	Make – Quadramho Model – Sr. No. -	DoC-	
	O/C	Make – UE Model – R1117 Sr. No. – H827980C	PSM -1.0 TMS -0.3	
	E/F	Make – UE Model – H1117 Sr. No. – H827964B	PSM -0.2 TMS -0.20	
	LBB	Make – NA Model – Sr. No. -	PSM - TMS -	
CT	R Ph	Make – ASEA LTD, SWEDEN Type – Current Ratio – 600-300-150/1A Rated Voltage – 145KV No. of Core-03	Sr. No. - 5854815 DoM - DoC - Class-	
	Y Ph	Make – ASEA LTD, SWEDEN Type – Current Ratio – 600-300-150/1A Rated Voltage – 145KV	Sr. No. – 58545813 DoM - DoC - No. of Core-03 Class-	
	B Ph	Make – ASEA LTD, SWEDEN Type – Current Ratio – 600-300-150/1A Rated Voltage – 145KV	Sr. No. -5854812 DoM - DoC - No. of Core-03 Class-	
Breaker	Make – ASEA LTD, SWEDEN Type – Rated Voltage –145 KV Rated Current – Short Time Amp –		Serial No. – DoM - DoC –	
LA				
EM	Make –Secure Meter Ltd. Model – MTR – 600/1A Class –0.2 s		Serial No. – BEB00381 DoM - 2000 DoC -	

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder: 132KV RKSN

Particular			Remarks
Line	Length – 35 KM Conductor - Panther		
Panel	Make – ENGLISH ELECTRIC Model –	DoM - DoC -	
Relay	DPR	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	DoC-29/03/2014
	O/C	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -1 TMS -300
	E/F	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -0.2 TMS -0.2
	LBB	Make – Model – Sr. No. -	PSM - TMS -
CT	R Ph	Make – SCT, Limited Type – Current Ratio – 800-400-200/1A Rated Voltage – 145KV No. of Core-04	Sr. No. - 2005/1137 DoM - 2006 DoC - Class-
	Y Ph	Make – SCT, Limited Type – Current Ratio – 800-400-200/1A Rated Voltage – 145KV No. of Core-04	Sr. No. – 2005/1134 DoM - 2006 DoC - Class-
	B Ph	Make – SCT, Limited Type – Current Ratio – 800-400-200/1A Rated Voltage – 145KV No. of Core-04	Sr. No. -2005/1129 DoM - 2006 DoC - Class-
Breaker	Make – AREVA Type – GL 312 Rated Voltage –145 KV Rated Current – 3150 A Short Time Amp –40 KA		Serial No. –101739 DoM - 2007 DoC – 16/08/2008
LA			
EM	Make –Secure Meter Ltd. Model – MTR – 400/1A Class –0.2 s	Serial No. – BEB00401 DoM - 2000 DoC -	

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder: 132KV CHANDIL

Particular			Remarks
Line	Length – 16 KM Conductor - Panther		
Panel	Make – ENGLISH ELECTRIC Model –	DoM - DoC -	
Relay	DPR	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	DoC-29/03/2014
	O/C	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -1 TMS -300ms
	E/F	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -0.1 TMS -0.05
	LBB	Make – Model – Sr. No. -	PSM - TMS -
CT	R Ph	Make – ASEA LTD, SWEDEN Type – Current Ratio – <u>600</u> -300-150/1A Rated Voltage – 145KV	Sr. No. - 5854781 DoM - DoC - No. of Core- Class-
	Y Ph	Make – VICTRNS, Nagpur Type – Current Ratio – 1200- <u>600</u> -300/1A Rated Voltage – 145KV	Sr. No. - 19510590 DoM - 2009 DoC - No. of Core- Class-
	B Ph	Make – ASEA LTD, SWEDEN Type – Current Ratio – <u>600</u> -300-150/1A Rated Voltage – 145KV	Sr. No. - DoM - DoC - No. of Core- Class-
Breaker	Make – ASEA LTD, SWEDEN Type – Rated Voltage – 145kv Rated Current – Short Time Amp –	Serial No. – DoM - DoC -	
LA			
EM	Make –Secure Meter Ltd. Model – MTR – 600/1A Class –0.2 s	Serial No. – BEB00384 DoM - 2000 DoC -	

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder: 132KV RCP-2

Particular				Remarks	
Line	Length – 8 KM Conductor - Panther				
Panel	Make – ALSTHOM Model – DoM - DoC -				
Relay	DPR	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	DoC-28/03/2014		
	O/C	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -0.85 TMS -0.30s		
	E/F	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -0.20 TMS -0.20s		
	LBB	Make – Model – Sr. No. –	PSM – TMS –		
CT	R Ph	Make – SCT Ghaziabad Ltd. Type – Current Ratio – 600/1 Rated Voltage –	Sr. No. - DoM - 1992 DoC – No. of Core-04 Class-		
	Y Ph	Make – SCT Ghaziabad Ltd. Type – Current Ratio – 600/1 Rated Voltage –	Sr. No. - DoM - 1992 DoC – No. of Core-04 Class-		
	B Ph	Make – SCT Ghaziabad Ltd. Type – Current Ratio – 600/1 Rated Voltage –	Sr. No. - DoM - 1992 DoC – No. of Core-04 Class-		
Breaker	Make – CGL Type – Rated Voltage – Rated Current – Short Time Amp –				
LA					
EM	Make –Secure Meter Ltd. Model – MTR – 300/1A Class –0.5 s				
	Serial No. – BEB00326 DoM - 1995 DoC -				

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder: 132KV RCP-1

Particular			Remarks
Line	Length – 8 KM Conductor -		
Panel	Make – GEC ALSTHOM Model –	DoM - DoC -	
Relay	DPR	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	DoC-28/03/2014
	O/C	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -0.85 TMS -0.30
	E/F	Make – Micom, AREVA/ALSTOM Model – P441 Sr. No. -	PSM -0.20 TMS -0.20
	LBB	Make – Model – Sr. No. -	PSM - TMS -
CT	R Ph	Make – SCT Ghaziabad Type – Current Ratio – Rated Voltage –	Sr. No. - DoM - 1992 DoC - No. of Core-04 Class-
	Y Ph	Make – SCT Ghaziabad Type – Current Ratio – Rated Voltage –	Sr. No. - DoM - 1992 DoC - No. of Core-04 Class-
	B Ph	Make – SCT Ghaziabad Type – Current Ratio – 600/1 Rated Voltage –	Sr. No. - DoM - 1992 DoC - No. of Core-04 Class-
Breaker	Make – Type – Rated Voltage – Rated Current – Short Time Amp –	Serial No. – DoM - DoC -	
LA			
EM	Make –Secure Meter Ltd. Model – MTR – 300/1A Class –0.5 s	Serial No. – BEB00332 DoM - 1995 DoC -	

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder: 33KV UBL

Particular				Remarks	
Line	Length – Conductor -				
Panel	Make – ENGLISH ELECTRIC Model –				
Relay	DPR	Make – N.A. Model – Sr. No. -	DoC-		
	O/C	Make – SCHNEIDER Model – MICOM127 Sr. No. –	PSM -0.750 TMS -0.100		
	E/F	Make – SCHNEIDER Model – MICOM127 Sr. No. –	PSM -0.050 TMS -0.025		
	LBB	Make –N.A. Model – Sr. No. -	PSM - TMS -		
CT	R Ph	Make – MAGRINI Type – AMT36S Current Ratio – 600-300-150/5 Rated Voltage – 36KV	Sr. No. - 670675 DoM - DoC - No. of Core- Class-		
	Y Ph	Make – VISHAL LTD Type – O/D,D/T Current Ratio – 600-300-150/5 Rated Voltage –36KV	Sr. No. – DoM - DoC - No. of Core- Class-		
	B Ph	Make – MAGRINI Type – AMT36S Current Ratio – 600-300-150/5 Rated Voltage –36KV	Sr. No. - 670681 DoM - DoC - No. of Core- Class-		
Breaker	Make – AREVA Type – PCOB-36 Rated Voltage –36 KV Rated Current – Short Time Amp – 25KA FOR 3SEC				
LA					
EM	Make –Secure Meter Ltd. Model – C3V025 MTR – 300/5A Class –0.2 s				
	Serial No. –BEB00364 DoM – 2000 DoC -				

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder: 33 KV RKFL

Particular				Remarks	
Line	Length – Conductor -				
Panel	Make – VENSON ELECTRIC Model –				
Relay	DPR	Make – Model – Sr. No. -	DoC-		
	O/C	Make – JVS Model – Sr. No. –	PSM - TMS -		
	E/F	Make – JVS Model – Sr. No. –C20980	PSM - TMS -		
	LBB	Make – Model – Sr. No. -	PSM - TMS -		
CT	R Ph	Make – VISHAL Type – O/D,D/T Current Ratio – <u>400</u> -200-100/1 Rated Voltage – 36KV	Sr. No. - 1162 DoM - DoC - No. of Core- Class-		
	Y Ph	Make – VISHAL Type – O/D,D/T Current Ratio – <u>400</u> -200-100/1 Rated Voltage – 36KV	Sr. No. – 1160 DoM - DoC - No. of Core- Class-		
	B Ph	Make – SCT Ghaziabaad Type – ODDT Current Ratio – 400-200-100/1 Rated Voltage –36KV	Sr. No. – 2012/1111 DoM - 2012 DoC - No. of Core- Class-		
Breaker	Make – AREVA Type – PCOB-36 Rated Voltage –36KV Rated Current – Short Time Amp – 25KA FOR 3SEC				
LA					
EM	Make –Secure Meter Ltd. Model – MTR – 300/1A Class –0.2 s	DoC -	Serial No. – KAB01502 DoM – 2003		

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder – 33 KV KYS

Particular			Remarks
Line	Length – Conductor -		
Panel	Make – ENGLISH ELECTRIC Model –	DoM - DoC -	
Relay	DPR	Make – Model – Sr. No. -	DoC-
	O/C	Make – ENGLISH ELECTRIC Model – SPECM1AF61H Sr. No. – M37738	PSM -3.75 TMS -0.05
	E/F	Make – ENGLISH ELECTRIC Model – SPECM1AF60H Sr. No. – M37814	PSM -1.0 TMS -0.05
	LBB	Make – Model – Sr. No. -	PSM - TMS -
CT	R Ph	Make – Type – Current Ratio – Rated Voltage – 145KV	Sr. No. - DoM - DoC -
	Y Ph	Make – Type – Current Ratio – Rated Voltage – 145KV	Sr. No. – DoM - DoC -
	B Ph	Make – Type – Current Ratio – Rated Voltage – 145KV	Sr. No. - DoM - DoC -
Breaker	Make – Type – Rated Voltage – 145 KV Rated Current – Short Time Amp –	Serial No. – DoM - DoC –	
EM	Make –Secure Meter Ltd. Model – MTR --/1A Class –0.5 s	Serial No. – JSE44431 DoM – 06/10/2005 DoC -	

Name of GSS: 132/33KV ADITYAPUR-1
Details:

Name of Feeder – 33KV RF-2				Remarks
Line	Length – Conductor -			
Panel	Make – ENGLISH ELECTRIC Model –		DoM - DoC -	
Relay	DPR	Make – Model – Sr. No. -	DoC-	
	O/C	Make – ENGLISH ELECTRIC Model – CDG31EG202A5 Sr. No. – M37678	PSM -3.75 TMS -0.05	
	E/F	Make – ENGLISH ELECTRIC Model – CDG13AF204A5 Sr. No. – M38347	PSM -1.0 TMS -0.05	
	LBB	Make – Model – Sr. No. -	PSM - TMS -	
CT	R Ph	Make – Type – Current Ratio – Rated Voltage – 145KV	Sr. No. - DoM - DoC -	
	Y Ph	Make – Type – Current Ratio – Rated Voltage – 145KV	Sr. No. – DoM - DoC -	
	B Ph	Make – Type – Current Ratio – Rated Voltage – 145KV	Sr. No. - DoM - DoC -	
Breaker	Make – Type – Rated Voltage – 145 KV Rated Current – Short Time Amp –		Serial No. – DoM - DoC –	
EM	Make –Secure Meter Ltd. Model – MTR --/1A Class –0.5 s		Serial No. – JSE45089 DoM – 06/10/2005 DoC -	

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder : 33 KV RF-1

Particular				Remarks	
Line	Length – Conductor -				
Panel	Make – ENGLISH ELECTRIC Model –		DoM - DoC -		
Relay	DPR	Make – Model – Sr. No. -	DoC-		
	O/C	Make – SCHNEIDER Model – MICOM P127 Sr. No. –	PSM -0.750 TMS -0.100		
	E/F	Make – SCHNEIDER Model – MICOM P127 Sr. No. –	PSM -0.050 TMS -0.025		
	LBB	Make – N.A. Model – Sr. No. -	PSM - TMS -		
CT	R Ph	Make – SCT Ghaziabad Type – ODDT Current Ratio – 600-300-150/1 Rated Voltage – 36KV	Sr. No. – 2012/1104 DoM - 1992 DoC - No. of Core- Class-		
	Y Ph	Make – SCT Ghaziabad Type – ODDT Current Ratio – 600-300-150/1 Rated Voltage – 36KV	Sr. No. – 2012/1102 DoM - 1992 DoC - No. of Core- Class-		
	B Ph	Make – SCT Ghaziabad Type – ODDT Current Ratio – 600-300-150/1 Rated Voltage – 36KV	Sr. No. – 2012/1103 DoM - 1992 DoC - No. of Core- Class-		
Breaker	Make –BHEL Serial No. – 9081791 Type – PNB-36 Rated Voltage –36KV Rated Current – 1250A Short Time Amp –25KA FOR 3SEC				
LA					
EM	Make –Secure Meter Ltd. Model – MTR – /1A Class –0.5 s		Serial No. – JSE45058 DoM –Nov, 2005 DoC -		

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder : 33KV NIT

Particular			Remarks
Line	Length – Conductor -		
Panel	Make – ENGLISH ELECTRIC Model –	DoM - DoC -	
Relay	DPR	Make – Model – Sr. No. -	DoC-
	O/C	Make – SCHNEIDER Model – MICOM P127 Sr. No. –	PSM -0.750 TMS -0.100
	E/F	Make – SCHNEIDER Model – MICOM P127 Sr. No. –	PSM -0.050 TMS -0.025
	LBB	Make – N.A. Model – Sr. No. -	PSM - TMS -
CT	R Ph	Make – VISHAL LTD Type – ODDT Current Ratio – 1200-600-300/5 Rated Voltage – 36KV	Sr. No. – 10205/1229 DoM - 2006 DoC - No. of Core- Class-
	Y Ph	Make – VISHAL LTD Type – ODDT Current Ratio – 1200-600-300/5 Rated Voltage – 36KV	Sr. No. – 10806/548 DoM - 2006 DoC - No. of Core- Class-
	B Ph	Make – VISHAL LTD Type – ODDT Current Ratio – 1200-600-300/5 Rated Voltage – 36KV	Sr. No. – 10806/549 DoM - 2006 DoC - No. of Core- Class-
Breaker	Make – AREVA Type – PCOB-36 Rated Voltage –36KV Rated Current – 1250A Short Time Amp –25KA FOR 3SEC	Serial No. – 247627P3 DoM –04/06 DoC –	
LA			
EM	Make –Secure Meter Ltd. Model – E3V055 MTR –-/110, -/1A Class –0.5 s	Serial No. – JSE45058 DoM – Nov, 2005 DoC -	

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder : 33KV AIADA

Particular				Remarks
Line	Length – Conductor -			
Panel	Make – ENGLISH ELECTRIC Model –			
Relay	DPR	Make – Model – Sr. No. -	DoC-	
	O/C	Make – SCHNEIDER Model – MICOM P127 Sr. No. – 36280071	PSM -0.750 TMS -0.100	
	E/F	Make – SCHNEIDER Model – MICOM P127 Sr. No. – 36280071	PSM -0.050 TMS -0.025	
	LBB	Make – N.A. Model – Sr. No. -	PSM - TMS -	
CT	R Ph	Make – VISHAL LTD Type – ODDT Current Ratio – 1200-600-300/5 Rated Voltage – 36KV	Sr. No. – 10806/546 DoM - 2006 DoC - No. of Core- Class-	
	Y Ph	Make – VISHAL LTD Type – ODDT Current Ratio – 1200-600-300/5 Rated Voltage – 36KV	Sr. No. – 10806/1221 DoM - 2006 DoC - No. of Core- Class-	
	B Ph	Make – VISHAL LTD Type – ODDT Current Ratio – 1200-600-300/5 Rated Voltage – 36KV	Sr. No. – 10806/550 DoM - 2006 DoC - No. of Core- Class-	
Breaker	Make – AREVA Type – PCOB-36 Rated Voltage –36KV Rated Current – 1250A Short Time Amp –25KA FOR 3SEC			Serial No. – 247631P3 DoM – 04/06 DoC –
LA				
EM	Make –Secure Meter Ltd. Model – E3V055 MTR – 150/5A Class –0.5 s			Serial No. – JSE00802 DoM – Nov, 2005 DoC -

Name of GSS: 132/33KV ADITYAPUR-1
Name of Feeder : 33KV ULIAN/KUWAR BASTI

Particular				Remarks	
Line	Length – Conductor -				
Panel	Make – ENGLISH ELECTRIC Model –				
Relay	DPR	Make – Model – Sr. No. -	DoC-		
	O/C	Make – SCHNEIDER Model – MICOM P127 Sr. No. – 36270571	PSM -0.750 TMS -0.100		
	E/F	Make – SCHNEIDER Model – MICOM P127 Sr. No. – 36270571	PSM -0.050 TMS -0.025		
	LBB	Make – N.A. Model – Sr. No. -	PSM - TMS -		
CT	R Ph	Make – SCT Ghaziabaad Type – ODDT Current Ratio – <u>400</u> -200-100/5 Rated Voltage –36KV	Sr. No. – 2003/397 DoM - 2012 DoC - No. of Core- Class-		
	Y Ph	Make – SCT Ghaziabaad Type – ODDT Current Ratio – <u>400</u> -200-100/5 Rated Voltage –36KV	Sr. No. – 2003/395 DoM - 2012 DoC - No. of Core- Class-		
	B Ph	Make – SCT Ghaziabaad Type – ODDT Current Ratio – 400-200-100/5 Rated Voltage –36KV	Sr. No. – 2003/392 DoM - 2012 DoC - No. of Core- Class-		
Breaker	Make – ANDREWYULE Type – 36/26.2 Rated Voltage –36KV Rated Current – 1250A Short Time Amp –25KA FOR 3SEC				
LA					
EM	Make –Secure Meter Ltd. Model – E3V055 MTR – /110, /1A Class –0.5 s				

Name of GSS: 132/33KV ADITYAPUR-1

Name of Feeder : 33KV SS4

Particular				Remarks
Line	Length - Conductor -			
Panel	Make – VENSON ELECTRIC Model –		DoM - DoC -	
Relay	DPR	Make – Model – Sr. No. -	DoC-	
	O/C	Make – SCHNEIDER Model – MICOM P127 Sr. No. – 36270570	PSM -0.750 TMS -0.100	
	E/F	Make – SCHNEIDER Model – MICOM P127 Sr. No. – 36270570	PSM -0.050 TMS -0.025	
	LBB	Make – N.A. Model – Sr. No. -	PSM - TMS -	
CT	R Ph	Make – SCT Ghaziabaad Type – ODDT Current Ratio – <u>600</u> -300-150/1 Rated Voltage –36KV	Sr. No. – 2005/1106 DoM - 2005 DoC - No. of Core- Class-	
	Y Ph	Make – SCT Ghaziabaad Type – ODDT Current Ratio – <u>600</u> -300-150/1 Rated Voltage –36KV	Sr. No. – 2005/1104 DoM - 2005 DoC - No. of Core- Class-	
	B Ph	Make – SCT Ghaziabaad Type – ODDT Current Ratio – <u>600</u> -300-150/1 Rated Voltage –36KV	Sr. No. – 2005/1083 DoM - 2005 DoC - No. of Core- Class-	
Breaker	Make – ANDREWYULE Type – 36/26.2 Rated Voltage –36KV Rated Current – 1250A Short Time Amp –25KA FOR 3SEC		Serial No. – 804 DoM – 2012-13 DoC –	
LA				
EM	Make –Secure Meter Ltd. Model – E3V055 MTR – /110, /1A Class –0.5 s		Serial No. – JSE44931F DoM – Nov, 2005 DoC -	

132 KV CHANDIL

Micom P441,

Model- P441311B3M0350J

Serial No-140405340749004 , DIAG NO.-10P441 01

CTR- 600/1A

Line Length 19 km

Line Impedance 3.959 ohm

Line Angle 68.2

kz1 820.0m

kz1 Angle 0

Z1 3.167

R1G 38.11

R1Ph 19.13

tz1 0s

kz2 Res comp 820

kz2 Angle 0

Z2 4.75

R2G 38.11

R2ph 19.13

tz2 300.0ms

kz3/4Res comp 820.0m

kz3/4 Angle 0

Z3 9.580 ohm

R3G-R4G 38.11 ohm

R3ph-R4ph 19.13 ohm

tz3 1.00 s

Z4 792.0 m ohm

tz4 1.200 s

Back UP>I

I>1Directional Non Directional

I>1 current set= 630.0mA

I>1 Tms =0. 250

132 KV RCP-I

Micom P441,
Model- P441311B3M0350J
Serial No-140405340749003 , DIAG NO.-10P441 01
CTR - 600/1A

Line Length	8KM
Line Impedance	3.330 ohm
Line Angle	68
kz1	0.819
kz1 Angle	0
Z1	1.330 ohm
R1G	38.10 ohm
R1Ph	38.10 ohm
tz1	0s
kz2 Res comp	0.819
kz2 Angle	0
Z2	2.000 ohm
R2G	38.10 ohm
R2ph	38.10 ohm
tz2	300 ms
kz3/4Res comp	0.819
kz3/4 Angle	0
Z3	2.500 ohm
R3G-R4G	38.10 ohm
R3ph-R4ph	38.10 ohm
tZ3	1.000 s
Z4	333.0m ohm
tZ4	1.200 s

Back UP>I

I> 1Directional Non Directional
I>1 current set= 850.0mA
I>1 Tms = 250

Earth fault O/C

IN> 1Directional Non Directional
IN>1 current set= 200ma
IN> Tms= 0.100

132 KV RCP-II

Micom P441,
Model- P441311B3M0350J
Serial No-140405340749003 , DIAG NO.-10P441 01
CTR-600/1A

Line Length	8KM
Line Impedance	3.330 ohm
Line Angle	68
kz1	0.819
kz1 Angle	0
Z1	1.330 ohm
R1G	38.10 ohm
R1Ph	38.10 ohm
tz1	0s
kz2 Res comp	0.819
kz2 Angle	0
Z2	2.000 ohm
R2G	38.10 ohm
R2ph	38.10 ohm
tz2	300 ms
kz3/4Res comp	0.819
kz3/4 Angle	0
Z3	2.500 ohm
R3G-R4G	38.10 ohm
R3ph-R4ph	38.10 ohm
tZ3	1.000 s
Z4	333.0m ohm
tZ4	1.200 s

Back UP>I

I> 1Directional Non Directional
I>1 current set= 850.0mA
I>1 Tms = 250

Earth fault O/C

IN> 1Directional Non Directional
IN>1 current set= 200ma
IN> Tms= 0.100

132 KV RKS

Micom P441,
Model- P441311B3M0350J
Serial No-140405340749003 , DIAG NO.-10P441 01
CTR-400/1A

Line Length	35KM
Line Impedance	4.810 ohm
Line Angle	68.2
kz1	0.819
kz1 Angle	0
Z1	3.880 ohm
R1G	25.40 ohm
R1Ph	25.40 ohm
tz1	0s
kz2 Res comp	0.819
kz2 Angle	0
Z2	5.830 ohm
R2G	25.40 ohm
R2ph	25.80 ohm
tz2	300 ms
kz3/4Res comp	0.819
kz3/4 Angle	0
Z3	11.80 ohm
R3G-R4G	25.40 ohm
R3ph-R4ph	25.40 ohm
tz3	1.000 s
Z4	972.0 m ohm
tz4	1.200 s

Back UP>I

- I> 1Directional Directional FWD
- I>1 VTS Block Non Directional
- I> 1 Current Set 1.250 A
- I> 1 Time VTS 1.500 s
- I> TMS 1.000

132 KV UML Ckt II

Micom P441,
 Model- P441311B2M0360S
 Serial No-31051100
 CTR-600/1A

Line Length	3.500KM
Line Impedance	729.0 mA
Line Angle	69.2
kz1	0.12
kz1 Angle	-59.6
Z1	583.0 mΩ
R1G	22.89Ω
R1Ph	20.35Ω
tz1	0s
kz2 Res comp	0.12
kz2 Angle	-59.6
Z2	2.187Ω
R2G	22.89Ω
R2ph	20.35Ω
tz2	300 ms
kz3/4Res comp	0.12
kz3/4 Angle	-59.6
Z3	15.31Ω
R3G-R4G	22.89Ω
R3ph-R4ph	20.35Ω
tZ3	600.0ms
Z4	182.0mΩ
tZ4	1.000 s
Back UP>I	
I> 1Directional	Directional FWD
I>1 VTS Block	Block
I> 1 Current Set	1.500 A
I> 1 Time delay	500 ms
I> 2 Function in DT	
I>2 Directional non Directional	
I>2 current set	2.000A
I>2 Time delay	1.000 s
Neg. sequence O/C	
I2>1 Function DT	
I2>1 Directional non Directional	
I2>1 current set	200.0mA
I2>1 Time delay	10.00s
I2>2 Directional non Directional	
I2>2 Current set	200.0mA
I2>2 Time delay	10.00s
I2>Angle	-45.00

Annexure-8.3.11

D.C. system details with Charger and battery									
Sl. nO.	Name of G/s/s	Details of Battery Charger	Single /Double	Total voltage	Capacity	no. of Cells	D.C. system Earth fault	D.C. positive to earth	D.C. Nigative to earth
3	Adityapur	<p>DC charger-1 300AH star make battery capacity-300AH,250V(DC) Input- 400+ - 10% Frequency-50Hz</p> <p>DC charger-II 300AH HBL make Battery Float cum Boost Charger Model- FCBC340036 AC voltage range- 370v to 460v Frequency-50Hz Output DC voltage-250v Output Current- 36A Make- Signotron India Pvt.LTD</p>	Double	240V	300AH	110	Not tested	210V	34V

Annexure-8.3.12

Name of the Sub-station: ADITYAPUR GSS

Transformer Details	NGEF,1994 Vector-YNn0d11						
Transformer Number	1						
MVA Rating	50						
% Impedance	Tap no. 1-14.37, Tap no. 5(Normal)-14, Tap no. 15-13.12						
Ratio	132/33KV						
Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number & Details		Setting	High set setting	
	HV	VICTRANS, Rated voltage-145KV Class of Accuracy- 1	300/1A	4	600/300/150/1A		
	LV		1200/1A				
Nomenclature	Make & model						
Differential Protection	ALSTOM	DTH31FF8024ACH				BIAS-30%	
Restricted E/F (HV)							
Restricted E/F (LV)							
HV O/C	English Electrical	CDG21AF0032M(M)				PSM-0.75, TMS-0.35	
LV O/C	English Electrical	CDG11AF002SA(M)				PSM-0.75, TMS-0.1	
HV E/F	English Electrical	CDD21PF905SE(M)				PSM-0.2, TMS-0.2	
LV E/F	English Electrical	CDG11AF005SA(M)				PSM-0.1, TMS-0.025	
Over flux							

Name of the Sub-station: ADITYAPUR GSS

Transformer Details	NGEF,1994 Vector-YNn0d11	
Transformer Number	1	
MVA Rating	50	
% Impedance	Tap no. 1-14.37, Tap no. 5(Normal)-14, Tap no. 15-13.12	
Ratio	132/33KV	

Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number & Details			Setting	High set setting
			Ratio	Core number	Core details		
	HV	VICTRANS, Rated voltage-145KV Class of Accuracy- 1	300/1A	4	600/300/150/1A		
	LV		1200/1A				
	Nomenclature	Make & model					
Differential Protection	ALSTOM	DTH31FF8024ACH				BIAS-30%	
Restricted E/F (HV)							
Restricted E/F (LV)							
HV O/C	English Electrical	CDG21AF0032M(M)				PSM-0.75, TMS-0.35	
LV O/C	English Electrical	CDG11AF002SA(M)				PSM-0.75, TMS-0.1	
HV E/F	English Electrical	CDD21PF905SE(M)				PSM-0.2, TMS-0.2	
LV E/F	English Electrical	CDG11AF005SA(M)				PSM-0.1, TMS-0.025	
Over flux							

Name of the Sub-station: ADITYAPUR GSS

Transformer Details	NGEF,1994 Vector-YNn0d11						
Transformer Number	2						
MVA Rating	50						
% Impedance	Tap no. 1-14.8 Tap no. 5(Normal)-14.33, Tap no. 15-13.53						
Ratio	132/33KV						
Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number &			Setting	High set setting
	HV		Ratio	Core number	Core details		
	LV	BHEL	300/1A	4	600/300/ 150/5A		
Nomenclature	Make & model						
Differential Protection	ALSTOM	DTH31FF8024ACH				BIAS-30%	
Restricted E/F (HV)							
Restricted E/F (LV)							
HV O/C	English Electrical	CDG21AF0032M(M)				PSM-0.75, TMS-0.325	
LV O/C	English Electrical	CDG11AF002SA(M)				PSM-0.75, TMS-0.1	
HV E/F	English Electrical	CDD21PF905SE(M)				PSM-0.2, TMS-0.2	
LV E/F	English Electrical	CDG11AF005SA(M)				PSM-0.1, TMS-0.025	
Over flux							

Trip relay	MASTER TRP	86
------------	------------	----

Name of the Sub-station: ADITYAPUR GSS		
--	--	--

Transformer Details	AREVA,2006 Vector-YNn0d11	
Transformer Number	3	
MVA Rating	50	
% Impedance	Tap no. 1-15.24, Tap no. 4(Normal)- 15.02, Tap no. 15-11.04	
Ratio	132/33KV	

Name of the Protection	C.T.	C.T. Details (Make & Model)	Connected CT/PT core number & Details			Setting	High set setting
			Ratio	Core number	Core details		
	HV	SCT CLASS-1	300/1A	4	600/300/150/1A		
		LV	1200/1A				
Nomenclature		Make & model					
Differential Protection	EASUN REYROLLE					BIAS-30%	
Restricted E/F (HV)							
Restricted E/F (LV)							
HV O/C	EASUN REYROLLE					PSM-1.5, TMS-0.2	
LV O/C	EASUN REYROLLE					PSM-0.75, TMS-0.1	
HV E/F	EASUN REYROLLE					PSM-1, TMS-0.2	
LV E/F	EASUN REYROLLE					PSM-0.1, TMS-0.025	
Over flux							

Trip relay		
------------	--	--