

**EASTERN REGIONAL LOAD DESPATCH CENTRE
KOLKATA**

TRANSMISSION ELEMENTS OUTAGE APPROVED IN 128TH OCC MEETING OF ERPC

| Sr. No | NAME OF THE ELEMENTS | DATE | TIME | DATE | TIME | REMARKS | S/D availed BY | Reason | SUBJECT TO CONSENT FROM AGENCY |
|--------|--|------------|-----------|------------|-----------|---------|----------------|---|--------------------------------|
| 1 | Auto-reclose of 400kv Quad, New Siliguri-Kishanganj -Ckt-1 line of Powerlinks. | 24-12-2016 | 10:00 | 24-12-2016 | 17:00 | OCB | POWERLINK | For Online PID testing of 120 KN Porcelain insulators for New Siliguri-Kishanganj line under Siliguri operation office. | NLDC |
| 2 | 220kv Birpara Line#1 Bay AT BINAGURI | 24-12-2016 | 09:30 HRS | 26-12-2016 | 17:30 HRS | OCB | ER-II/KOL | CB Ovrhauling | |
| 3 | 400KV Rourkela -Talcher#1 | 25-12-2016 | 09:00 | 10-01-2017 | 18:00 hrs | ODB | ER-II/ODISHA | For PID Scanning. | |
| 4 | 220KV BALASORE LINE-I BAY-201 AT BARIPADA | 26-12-2016 | 09:00 | 29-12-2016 | 18:00 | OCB | ER-II/ODISHA | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM | ODISHA |
| 5 | 400kv Keonjhar Line at Rengali | 26-12-2016 | 10:00Hrs: | 26-12-2016 | 12:00Hrs: | ODB | ER-II/ODISHA | Construction of Main Cable trench for 125MVAR Bay extension work at Rengali S/s. | |
| 6 | 400 KV Raigarh #2 - 400KV Ranchi #2 Tie Bay (Bay No.- 420). | 26-12-2016 | 09:00 | 28-12-2016 | 18:00 | OCB | ER-II/ODISHA | Overhauling of Driving Mechanism of ABB make Tie Bay CB (42052) | NLDC |
| 7 | 400 KV Sundargarh #1 Main Bay (Bay No.- 418) | 26-12-2016 | 09:00 | 28-12-2016 | 18:00 | OCB | ER-II/ODISHA | Overhauling of Driving Mechanism of ABB make Main Bay CB | |
| 8 | RANCHI-ROURKELA-II MAIN BAY-412 AT RANCHI | 26-12-2016 | 10:00 | 26-12-2016 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 9 | 400 KV BUS-3 AT BSF | 26-12-2016 | 09:00 | 31-12-2016 | 18:00 | OCB | ER-I | FOR DISCONNECTION OF CT CORE-1 FROM OLD BUS BAR PANNEL AND TERMINATION OF CT CORE-1 & 2 IN NEW BUS BAR PANNEL | |
| 10 | 765/400 KV ICT-1 AT NEW RANCHI | 26-12-2016 | 10:00 | 27-12-2016 | 15:00 | ODB | ER-I | FOR TAKING B-PH UNIT BACK INTO SERVICE AFTER ATTENDING OIL LEAKAGE | NLDC |
| 11 | 200 MVA ICT-1 AT LAKHISARAI | 26-12-2016 | 08:00 | 29-12-2016 | 18:00 | ODB | ER-I | HVWS WORK AND CONSTRUCTION OF FIREWALL | BIHAR |
| 12 | 220kv Bus Coupler Bay AT BINAGURI | 26-12-2016 | 09:30 HRS | 28-12-2016 | 17:30 HRS | OCB | ER-II/KOL | CB Ovrhauling | |
| 13 | Bay-08 at NTPC Farakka | 26-12-2016 | 10:00 | 27-12-2016 | 18:00 | OCB | ER-II/KOL | Testing and commissioning of CSD of CB of Bay-08 | |
| 14 | 400 KV TTPS-Biharshariff | 07-01-2017 | 09:00 | 19-01-2017 | 17:00 | OCB | JUSNL | FOR RAISING THE TOWER HEIGHT ON EITHER SIDE OF RAILWAY TRACTION AT LOC NO-07 TO 17 | BIHAR, DVC |
| 15 | 400kv Indravati Line at Rengali | 27-12-2016 | 10:00Hrs: | 27-12-2016 | 14:00Hrs: | ODB | ER-II/ODISHA | On line testing of CSD | |
| 16 | 220kv SLG-Kishanganj Ckt-II | 27-12-2016 | 9.00 hrs | 28-12-2016 | 17.00 hrs | ODB | ER-II/KOL | PG clamp removal | |
| 17 | TIE BAY OF ROURKELA-I & FUTURE LINE BAY -414 AT RANCHI | 27-12-2016 | 10:00 | 27-12-2016 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 18 | 500MVA ICT-I AT SASARAM | 27-12-2016 | 10:00 | 27-12-2016 | 18:00 | ODB | ER-I | TERTIARY CABLE TERMINATION AND MAIN BAY CSD RE- | |
| 19 | MAIN BAY OF 400KV RANCHI-RANCHI CKT-1 (406) AT NEW RANCHI | 27-12-2016 | 08:00 | 27-12-2016 | 18:00 | ODB | ER-I | BAY AMP | |
| 20 | BARH -2 MAIN BAY AT PATNA | 27-12-2016 | 09:00 | 27-12-2016 | 17:00 | ODB | ER-I | AMP WORK | |
| 21 | 400 kv KAHALGAON - BARH - II AND 400 kv PATNA - BARH - I | 27-12-2016 | 08:00 | 27-12-2016 | 17:00 | ODB | ER-I | FOR OPGW INSTALLATION WORK | |
| 22 | 132kv Kurseong - Rangit | 27-12-2016 | 9.00 hrs | 27-12-2016 | 15.00 hrs | ODB | ER-II/KOL | Insulator fitting | WEST BENGAL |

| | | | | | | | | | |
|----|---|------------|-----------|------------|-----------|-----------|--------------|--|-------------|
| 23 | 132kV Siliguri - Melli | 27-12-2016 | 9.00 hrs | 28-12-2016 | 16.00 hrs | ODB | ER-II/KOL | Insulator fitting | SIKKIM |
| 24 | Bus reactor -2 Main bay CB (421) AT BINAGURI | 27-12-2016 | 9.30 hrs | 27-12-2016 | 17.30 hrs | ODB | ER-II/KOL | CB Ovrhauling | |
| 25 | 400 KV BONG- NEW SLG-1&2- LINE | 27-12-2016 | 07:00 | 29-12-2016 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE OUT-AP10/0 -AP11/0 | NLDC |
| 26 | 400 KV BONG- NEW SLG-1&2- LINE | 27-12-2016 | 09:00 | 29-12-2016 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE OUT-AP10/0 -AP11/0 | NLDC |
| 27 | 220 KV SIDE OF 315 MVA ICT-II, BAY-204 | 28-12-2016 | 09:00 | 31-12-2016 | 18:00 | OCB | ER-II/ODISHA | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING | ODISHA |
| 28 | 132 KV TRANSFER BUS AT PURNEA | 28-12-2016 | 09:00 | _____ | | PERMANENT | ER-I | GIS WORK PERMANENT REMOVAL OF TRANSFER BUS IS REQUIRED FOR GIS BUILDING AND ASSOCIATED CIVIL THE 132 KV TRANSFER | BIHAR |
| 29 | 132 KV PURNEA - PURNEA BSPTCL#3 LINE | 28-12-2016 | 09:00 | 28-12-2016 | 17:00 | ODB | ER-I | WORK OF DISMANTLING OF LM TOWER TO FACILITATE CONSTRUCTION OF GIS BUS DUCT AND SF6 TO AIR BUSHING FOUNDATIONS. | BIHAR |
| 30 | ROURKELA-I MAIN BAY-415 AT RANCHI | 28-12-2016 | 10:00 | 28-12-2016 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 31 | MAIN BAY OF 765KV ICT-2 (407) AT NEW RANCHI | 28-12-2016 | 08:00 | 28-12-2016 | 18:00 | ODB | ER-I | BAY AMP | |
| 32 | 132kV Siliguri - Kurseong | 28-12-2016 | 9.00 hrs | 28-12-2016 | 15.00 hrs | ODB | ER-II/KOL | Jumper Cone Repairing / Insulator fitting | WEST BENGAL |
| 33 | 400 KV BUS-II of NTPC Farakka | 28-12-2016 | 10:00 | 28-12-2016 | 16:00 | ODB | ER-II/KOL | For conducting Bus bar-II stability test for integration of bay-12 after upgradation of bay-12 from 2000A to 3150A rating under ERSS-XIII projects | |
| 34 | 220kV birpara Line#2 Bay AT BINAGURI | 29-12-2016 | 09:30 HRS | 31-12-2016 | 17:30 HRS | OCB | ER-II/KOL | CB Ovrhauling | |
| 35 | 400kV Bus-I at Rengali | 29-12-2016 | 09:00Hrs: | 29-12-2016 | 17:00Hrs: | ODB | ER-II/ODISHA | For erection of Beam structure of New Bay extension work at Rengali. | |
| 36 | 400 KV Raigarh #2 Main Bay (Bay No.- 419). | 29-12-2016 | 09:00 | 31-12-2016 | 18:00 | OCB | ER-II/ODISHA | Overhauling of Driving Mechanism of ABB make Main Bay CB | |
| 37 | 132 KV PURNEA - PURNEA BSPTCL#3 LINE | 29-12-2016 | 09:00 | 29-12-2016 | 17:00 | ODB | ER-I | WORK OF DISMANTLING OF LM TOWER TO FACILITATE CONSTRUCTION OF GIS BUS DUCT AND SF6 TO AIR BUSHING FOUNDATIONS. | BIHAR |
| 38 | HATIA-I MAIN BAY-206 AT RANCHI | 29-12-2016 | 10:00 | 29-12-2016 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 39 | MAIN BAY OF 400KV B/R-1 (410) AT NEW RANCHI | 29-12-2016 | 08:00 | 29-12-2016 | 18:00 | ODB | ER-I | BAY AMP | |
| 40 | BARH -3 MAIN BAY AT PATNA | 29-12-2016 | 09:00 | 29-12-2016 | 17:00 | ODB | ER-I | AMP WORK | |
| 41 | 220kV TBC Bay AT BINAGURI | 29-12-2016 | 09:30 HRS | 31-12-2016 | 17:30 HRS | OCB | ER-II/KOL | CB Ovrhauling | |
| 42 | 400 KV Farakka- Behrampur S/c | 29-12-2016 | 09:00 | 29-12-2016 | 17:00 | ODB | ER-II/KOL | AMP for 2016-17 | NLDC |
| 43 | 220KV BALASORE LINE-II BAY-202 AT BARIPADA | 30-12-2016 | 09:00 | 30-12-2016 | 18:00 | OCB | ER-II/ODISHA | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING | ODISHA |
| 44 | Non-Auto mode of Auto-Reclousure in 400KV Indravati-Rengali Line at Rengali | 30-12-2016 | 08:00 | 15-01-2017 | 17:00 | ODB | ER-II/ODISHA | Live line OPGW stringing works | |
| 45 | 400kV Bus-II at Rengali | 30-12-2016 | 09:00Hrs: | 30-12-2016 | 17:00Hrs: | ODB | ER-II/ODISHA | For erection of Beam structure of New Bay extension work at Rengali. | |
| 46 | 132 KV PURNEA - PURNEA BSPTCL#3 LINE | 30-12-2016 | 09:00 | 30-12-2016 | 17:00 | ODB | ER-I | WORK OF DISMANTLING OF LM TOWER TO FACILITATE CONSTRUCTION OF GIS BUS DUCT AND SF6 TO AIR BUSHING FOUNDATIONS. | BIHAR |

| | | | | | | | | | |
|----|---|------------|-----------|------------|-----------|-----|--------------|---|--|
| 47 | 400 KV BUS -1 AT BIHARSHARIF | 31-12-2016 | 09:00 | 31-12-2016 | 18:00 | ODB | ER-I | STABILITY TEST AND COMMISSIONING OF BUS BAR PANNEL | |
| 48 | Non-Auto mode of Auto-Reclosure in 400KV Rourkela-Sundargarh-Ind Bharat Line (LILO-1) | 01-01-2017 | 09:00 | 31-01-2017 | 17:00 | ODB | ER-II/ODISHA | For attending PID testing of LILO-1 Line | |
| 49 | Non-Auto mode of Auto-Reclosure in 400KV | 01-01-2017 | 09:00 | 31-01-2017 | 17:00 | ODB | ER-II/ODISHA | For attending PID testing of LILO-2 Line | |
| 50 | A/R OF 400KV KAHALGAON - MAITHAN CKT. # I & | 01-01-2017 | 09:00 | 31-01-2017 | 18:00 | ODB | ER-I | PID WORK IN THE SAID LINE | |
| 51 | 400kV NSLG-Rangpo Ckt-II | 01-01-2017 | 9.00 hrs | 01-01-2017 | 17.00 hrs | ODB | ER-II/KOL | PG clamp removal | |
| 52 | 400kV BINAGURI-Tala-I | 01-01-2017 | 9.00 hrs | 01-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Repeat tan delta of 400kV R Phase Bushing & Neutral Bushing Replacement / oil leakage arrest/RELAY RETROFITTING. | |
| 53 | 400kV NSLG-Bangaigaon Ckt-1 | 01-01-2017 | 07.00 hrs | 05-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | NLDC/ may be done within 27 to 29th Dec. |
| 54 | 400kV NSLG-Tala Ckt-4 | 01-01-2017 | 07.00 hrs | 01-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | NLDC |
| 55 | Purnea-1 Main bay CB (422) AT BINAGURI | 01-01-2017 | 9.30 hrs | 01-01-2017 | 17.30 hrs | ODB | ER-II/KOL | CB Ovrhauling | |
| 56 | 315 MVA ICT-I AT SUBHASGRAM | 02-01-2017 | 08:30 | 02-01-2017 | 17:00 | ODB | ER-II/KOL | 220KV Bph LA inspection | WEST BENGAL |
| 57 | 765kV Angul Sundergarh Line-1 | 02-01-2017 | 07:00 | 02-01-2017 | 18:00 | ODB | ER-II/ODISHA | Improvement & strengthening of line jumpers to prevent swing during high speed wind to avoid tripping in future & improvement of line availability&reliability & Polymer anchoring in substation. | NLDC |
| 58 | 220 KV SIDE OF 315 MVA ICT-I, BAY-208 | 02-01-2017 | 09:00 | 05-01-2017 | 18:00 | OCB | ER-II/ODISHA | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM | ODISHA |
| 59 | ICT-I Tie Bay(408) at Jeypore | 02-01-2017 | 09:30 | 02-01-2017 | 17:30 | ODB | ER-II/ODISHA | For AMP works | ODISHA |
| 60 | 132 KV PURNEA - PURNEA BSPTCL#3 LINE | 02-01-2017 | 09:00 | 02-01-2017 | 17:00 | ODB | ER-I | | BIHAR |
| 61 | 160 MVA ICT-2 AT PURNEA | 02-01-2017 | 10:00 | 02-01-2017 | 17:00 | ODB | ER-I | AMP & GIS WORK | BIHAR |
| 62 | 400 KV BUS-4 AT BSF | 02-01-2017 | 09:00 | 06.01.2017 | 18:00 | OCB | ER-I | FOR DISCONNECTION OF CT CORE-1 FROM OLD BUS BAR PANNEL AND TERMINATION OF CT CORE-1 & 2 IN NEW BUS | |
| 63 | 220KV BUS-I AT GAYA S/S | 02-01-2017 | 10:00 | 02-01-2017 | 18:00 | ODB | ER-I | FOR KHIJARSARAI BAY COMMISSIONING WORK | BIHAR |
| 64 | 765KV B/R -2 AT NEW RANCHI | 02-01-2017 | 08:00 | 02-01-2017 | 18:00 | ODB | ER-I | RTV COATING OF TRENCH MAKE BUSHING & AMP | NLDC |
| 65 | WBSETCL Bus Section-1 AT BINAGURI | 02-01-2017 | 9.00 hrs | 02-01-2017 | 17.00 hrs | ODB | ER-II/KOL | AMP | WEST BENGAL |
| 66 | 220kV ICT#1 Bay AT BINAGURI | 02-01-2017 | 9.30 hrs | 04-01-2017 | 17.30 hrs | OCB | ER-II/KOL | CB Ovrhauling | |
| 67 | 220 KV BRP- CHP-I and II | 02-01-2017 | 07:00 Hrs | 11-01-2017 | 17:00 Hrs | OCB | ER-II/KOL | Dismantling of Loc-107,erection of new Tower and Stringing in | NLDC |
| 68 | 765kV Angul Sundergarh Line-2 | 03-01-2017 | 07:00 | 03-01-2017 | 18:00 | ODB | ER-II/ODISHA | Improvement & strengthening of line jumpers to prevent | NLDC |
| 69 | 125 MVAR Main Bay(409) at Jeypore | 03-01-2017 | 09:30 | 03-01-2017 | 17:30 | ODB | ER-II/ODISHA | For AMP works | |
| 70 | 400 KV Rourkela - Ranchi #2 | 03-01-2017 | 09:00 | 03-01-2017 | 18:00 | ODB | ER-II/ODISHA | AMP Work. | |
| 71 | 765KV Sundergarh-Angul Line#II at Sundergarh | 03-01-2017 | 09:00 | 03-01-2017 | 18:00 | ODB | ER-II/ODISHA | Polymer anchoring in Yphase Line Isolator | NLDC |
| 72 | 400KV Sundargarh-Raigarh#2 | 03-01-2017 | 09:00 | 03-01-2017 | 17:30 | ODB | ER-II/ODISHA | Replacement of Flash glass insulators at Loc. 372, 373 & 374 at Middle phase | NLDC |
| 73 | 132 KV PURNEA KISHANGANJ LINE | 03-01-2017 | 11:00 | 03-01-2017 | 13:00 | ODB | ER-I | GIS WORK | BIHAR |
| 74 | 50 MVAR BR-I AT JAMSHEDPUR | 03-01-2017 | 09:30 | 03-01-2017 | 17:30 | ODB | ER-I | BAY CONSTRUCTION WORK | |
| 75 | ICT-I MAIN BAY (400 KV) AT RANCHI | 03-01-2017 | 10:00 | 03-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 76 | MAIN BAY OF 400KV SSRM-NABINAGAR # I, BAY NO. 419 AT SASARAM | 03-01-2017 | 10:00 | 03-01-2017 | 18:00 | ODB | ER-I | FOR AMP WORK | |
| 77 | 400KV MUZ- -GKP-I | 03-01-2017 | 10:00 | 03-01-2017 | 16:00 | ODB | ER-I | FOR LINE BAY AMP WORK AT MUZ | NLDC |
| 78 | Main Bay BSF-1 (401) AT LAKHISARAI | 03-01-2017 | 10:00 | 03-01-2017 | 14:00 | ODB | ER-I | AMP | |
| 79 | 220kV NSLG-SLG Ckt-II | 03-01-2017 | 9.00 hrs | 03-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Relay retrofitting | |

| | | | | | | | | | |
|-----|--|------------|-----------|------------|-----------|-----|--------------|---|-------------|
| 80 | 400KV BONGAIGAON - NEW SILIGURI CIRCUIT # 3 and 4 (ENICL Line) | 03-01-2017 | 07:00 | 06.01.2017 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE OUT-AP 7/0 -AP 8/0 . | NLDC |
| 81 | 315 MVA ICT#I at Durgapur | 03-01-2017 | 11:00 | 03-01-2017 | 12:00 | ODB | ER-II/KOL | CB Retrofitting-trasfer load to transfer bus & protection testing | DVC |
| 82 | At DGP: 50 MVAR Bus Reactor | 03-01-2017 | 09:00 | 03-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 83 | 220kv S'gram-CESC-2 | 04-01-2017 | 08:30 | 04-01-2017 | 17:00 | ODB | ER-II/KOL | AMP | WEST BENGAL |
| 84 | 400KV KANIHA-ROURKELA-II | 04-01-2017 | 09:00 | 06-01-2017 | 17:00 | OCB | NTPC/KANIHA | MAINTENANACE ACTIVITIES OF BAY EQUIPMENT | |
| 85 | 400kv Angul Bolangir Line | 04-01-2017 | 07:00 | 04-01-2017 | 18:00 | ODB | ER-II/ODISHA | Improvement & strenghthening of line jumpers including replacement of conventional insulator with polymer insulator to prevent swing during high speed wind to avoid tripping in future & improvement of line availability&reliability. | NLDC |
| 86 | 63 MVAR BR Main Bay(416) at Jeypore | 04-01-2017 | 09:30 | 04-01-2017 | 17:30 | ODB | ER-II/ODISHA | For AMP works | |
| 87 | 315MVA ICT-II | 04-01-2017 | 09:00 | 04-01-2017 | 18:00 | ODB | ER-II/ODISHA | For AMP Works | ODISHA |
| 88 | 400/220kv 315MVA ICT-I at Rengali | 04-01-2017 | 08:00Hrs: | 13-01-2017 | 17:00Hrs: | OCB | ER-II/ODISHA | Complete overhauling of ICT-I at Rengali S/s. | |
| 89 | 400 KV Rourkela-Talcher #2 | 04-01-2017 | 09:00 | 04-01-2017 | 18:00 | ODB | ER-II/ODISHA | AMP Work. | |
| 90 | 765KV Sundergarh-Dharamjaygarh Line#I at | 04-01-2017 | 09:00 | 04-01-2017 | 18:00 | ODB | ER-II/ODISHA | Polymer anchoring in Yphase Line Isolator | NLDC |
| 91 | 50 MVAR BR-II AT JAMSHEDPUR | 04-01-2017 | 09:30 | 04-01-2017 | 17:30 | ODB | ER-I | BAY CONSTRUCTION WORK | |
| 92 | ICT-2 MAIN BAY (400 KV) AT RANCHI | 04-01-2017 | 10:00 | 04-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 93 | MAIN BAY OF 400KV SSRM-VARANASI (NR), BAY | 04-01-2017 | 10:00 | 04-01-2017 | 18:00 | ODB | ER-I | FOR AMP WORK | |
| 94 | 400KV MUZ- -GKP-II | 04-01-2017 | 10:00 | 04-01-2017 | 16:00 | ODB | ER-I | FOR LINE BAY AMP WORK AT MUZ | NLDC |
| 95 | 400kv Tala-IV L/R AT BINAGURI | 04-01-2017 | 9.00 hrs | 04-01-2017 | 17.00 hrs | ODB | ER-II/KOL | CSD Commissioning | |
| 96 | Bong -4 Main bay CB (427) AT BINAGURI | 04-01-2017 | 9.30 hrs | 04-01-2017 | 17.30 hrs | ODB | ER-II/KOL | CB Ovrhauling | |
| 97 | 220 KV Farakka- Lalmatia TL | 04-01-2017 | 08:00 | 12-01-2017 | 18:00 | OCB | ER-II/KOL | Erection of tower at Loc. No- 7/0 (DD+25 mtr with 4 m RC) and stringing between loc. No. 6/0 to 7/0 of LILO of 400 KV | JHARKHAND |
| 98 | 400 KV New Siliguri-New Purnea # I | 04-01-2017 | 09:00 Hrs | 04-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 99 | 400 KV DGP- Arambag line | 04-01-2017 | 09:00 | 05-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 100 | 400kv Angul- Meramundali Line-1 | 05-01-2017 | 07:00 | 05-01-2017 | 18:00 | ODB | ER-II/ODISHA | Improvement & strenghthening of line jumpers to prevent swing during high speed wind to avoid tripping in future & | |
| 101 | Indravati Line Tie Bay(411) at Jeypore | 05-01-2017 | 09:30 | 05-01-2017 | 17:30 | ODB | ER-II/ODISHA | For AMP works | |
| 102 | 220 KV Rourkela-Takera #1 | 05-01-2017 | 09:00 | 05-01-2017 | 18:00 | ODB | ER-II/ODISHA | AMP Work. | ODISHA |
| 103 | 765KV Sundergarh-Dharamjaygarh Line#II at Sundergarh | 05-01-2017 | 09:00 | 05-01-2017 | 18:00 | ODB | ER-II/ODISHA | Polymer anchoring in Yphase Line Isolator | NLDC |
| 104 | 50 MVAR L/R OF 400 KV BANKA - BIHARSHARIF -1 AT BANKA | 05-01-2017 | 10:00 | 05-01-2017 | 18:00 | ODB | ER-I | AMP WORK | |
| 105 | 400KV TATA -BARIPADA AT JAMSHEDPUR | 05-01-2017 | 09:00 | 05-01-2017 | 17:00 | ODB | ER-I | REPLACEMENT OF DEFECTIVE INSULATOR DAMAGED BY MISCREANTS | |
| 106 | 220 KV RNC -HATIA-II | 05-01-2017 | 10:00 | 05-01-2017 | 17:30 | ODB | ER-I | FOR REPLACEMENT OF LA AT RANCHI END. | JHARKHAND |
| 107 | 220KV TRANSFER BUS COUPLER BAY, (BAY NO. | 05-01-2017 | 10:00 | 05-01-2017 | 18:00 | ODB | ER-I | FOR AMP WORK | |
| 108 | 400KV MUZ- NPRN-I | 05-01-2017 | 10:00 | 05-01-2017 | 16:00 | ODB | ER-I | FOR LINE BAY AMP WORK AT MUZ | NLDC |
| 109 | 765/400 KV ICT-I AT NEW RANCHI S/S | 05-01-2017 | 09:00 | 07-01-2017 | 18:00 | ODB | ER-I | RTV COATING OF TRENCH MAKE BUSHING | NLDC |
| 110 | MAIN BAY OF 765 KV RNC-DMJ LINE-1 (704) AT | 05-01-2017 | 08:00 | 06.01.2017 | 18:00 | ODB | ER-I | BAY AMP | |

| | | | | | | | | | |
|-----|---|------------|-----------|------------|-----------|-----|--------------|--|-------------------------------------|
| 111 | TIE BAY OF 400 KV BSF-1 & ICT-1 (402) AT LAKHISARAI | 05-01-2017 | 10:00 | 05-01-2017 | 14:00 | ODB | ER-I | AMP | |
| 112 | BALIA -2 MAIN BAY AT PATNA | 05-01-2017 | 09:00 | 05-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |
| 113 | 400 KV BINAGURI-BONGAIGAON-IV L/R | 05-01-2017 | 9.00 hrs | 05-01-2017 | 17.00 hrs | ODB | ER-II/KOL | AMP | NLDC |
| 114 | 220kv NSLG-BRP Ckt-II | 05-01-2017 | 9.00 hrs | 05-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Relay retrofitting | |
| 115 | 400kv NSLG-Tala Ckt-1 | 05-01-2017 | 07.00 hrs | 05-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | NLDC |
| 116 | 220kv ICT#2 Bay AT BINAGURI | 05-01-2017 | 09:30 HRS | 07-01-2017 | 17:30 HRS | OCB | ER-II/KOL | CB Ovrhauling | |
| 117 | 400 KV New Siliguri-New Purnea # I | 05-01-2017 | 09:00 Hrs | 05-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 118 | 400 KV Kh- Barh#1 line | 05-01-2017 | 09:30hrs | 05-01-2017 | 17:30 hrs | OCB | NTPC | PM works & relay testing | |
| 119 | 400 KV Subhasgram- Jeerat Line | 06-01-2017 | 08:30 | 06-01-2017 | 17:00 | ODB | ER-II/KOL | LA & Jumper replacemnet at jeerat end. | WEST BENGAL |
| 120 | 400kv GMR Line#1 & Jindal Line#2 TIE Bay (426) | 06-01-2017 | 09:00 | 06-01-2017 | 15:00 | ODB | ER-II/ODISHA | AMP WORK | |
| 121 | 220 KV SIDE OF 160 MVA ICT-1, BAY-209 | 06-01-2017 | 09:00 | 09-01-2017 | 18:00 | OCB | ER-II/ODISHA | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC | ODISHA |
| 122 | 80 MVAR Bus Reactor | 06.01.2017 | 09:00 | 06-01-2017 | 18:00 | ODB | ER-II/ODISHA | For AMP Works | |
| 123 | 220 KV Rourkela-Takera #2 | 06-01-2017 | 09:00 | 06-01-2017 | 18:00 | ODB | ER-II/ODISHA | AMP Work. | ODISHA |
| 124 | 765/400KV, 1500MVA ICT-1 at Sundergarh | 06-01-2017 | 09:00 | 06-01-2017 | 18:00 | ODB | ER-II/ODISHA | For Charging of 33KV auxiliary Transformer | NLDC |
| 125 | 400KV Sterlite-Raigarh#2 | 06-01-2017 | 09:00 | 06-01-2017 | 17:30 | ODB | ER-II/ODISHA | Replacement of Flash glass insulators at Loc. 372, 373 & 374 | NLDC |
| 126 | 220 KV NEW PURNEA -PURNEA #1 | 06.01.2017 | 09:00 | 06.01.2017 | 17:00 | ODB | ER-I | AMP WORK OF SWITCH YARD BAY EQUIPMENTS | |
| 127 | 315 MVA ICT-1 AT JAMSHEDPUR | 06.01.2017 | 09:30 | 06.01.2017 | 17:30 | ODB | ER-I | BAY CONSTRUCTION WORK | JHARKHAND |
| 128 | 400 KV BUS -2 AT BIHARSHARIF | 06.01.2017 | 09:00 | 06.01.2017 | 18:00 | ODB | ER-I | STABILITY TEST AND COMMISSIONING OF BUS BAR PANNEL | |
| 129 | 400KV MUZ- NPRN-II | 06.01.2017 | 10:00 | 06.01.2017 | 16:00 | ODB | ER-I | FOR LINE BAY AMP WORK AT MUZ | NLDC |
| 130 | BARH -1 MAIN BAY AT PATNA | 06.01.2017 | 09:00 | 06.01.2017 | 17:00 | ODB | ER-I | AMP WORK | |
| 131 | 400kv NSLG-Bangaigaon Ckt-2 | 06.01.2017 | 07.00 hrs | 10-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | NLDC/ may be done within 27 to 29th |
| 132 | 400 KV New Siliguri-New Purnea # II | 06.01.2017 | 09:00 Hrs | 06.01.2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 133 | 400 kv DGP- Parulia line 2 | 06-01-2017 | 09:00 | 07-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 134 | 400kv Angul-Jindal Line#1 Main Bay (428) | 07-01-2017 | 09:00 | 07-01-2017 | 15:00 | ODB | ER-II/ODISHA | AMP WORK | |
| 135 | 400 KV Rourkela -Raigarh #2 | 07-01-2017 | 09:00 | 07-01-2017 | 18:00 | ODB | ER-II/ODISHA | For AMP work of Line & Line Reactor Bay | NLDC |
| 136 | 220 KV NEW PURNEA -PURNEA #1 | 07-01-2017 | 09:00 | 07-01-2017 | 17:00 | ODB | ER-I | AMP WORK OF SWITCH YARD BAY EQUIPMENTS | |
| 137 | TIE BAY OF765KV RNC-DMJ LINE-1 & 765/400 KV | 07-01-2017 | 08:00 | 07-01-2017 | 18:00 | ODB | ER-I | BAY AMP | |
| 138 | Main Bay OF ICT-1 (403) AT LAKHISARAI | 07-01-2017 | 10:00 | 07-01-2017 | 14:00 | ODB | ER-I | AMP | |
| 139 | 125 MVAR B/R - 2 AT PATNA | 07-01-2017 | 09:00 | 07-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |
| 140 | 220kv NSLG-BRP Ckt-I | 07-01-2017 | 9.00 hrs | 07-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Relay retrofitting | |
| 141 | 400kv NSLG-Tala Ckt-2 | 07-01-2017 | 07.00 hrs | 07-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | NLDC |
| 142 | 400 KV New Siliguri-New Purnea # II | 07-01-2017 | 09:00 Hrs | 07-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 143 | Non-Auto mode of Auto-Reclosure in 400KV Indravati(PG)-Indravati(OHPC) Line | 08-01-2017 | 08:00 | 15-01-2017 | 17:00 | ODB | ER-II/ODISHA | Live line OPGW stringing works | |
| 144 | 220kv Siliguri Line#1 Bay AT BINAGURI | 08-01-2017 | 09:30 HRS | 10-01-2017 | 17:30 HRS | OCB | ER-II/KOL | CB Ovrhauling | WEST BENGAL |
| 145 | 400 kv DGP- Parulia line 1 | 08-01-2017 | 09:00 | 09-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 146 | 315 MVA ICT-V AT SUBHASGRAM | 09-01-2017 | 08:30 | 09-01-2017 | 17:00 | ODB | ER-II/KOL | AMP & PSD commissioning | WEST BENGAL |
| 147 | 220kv PGCIL-OPTCL -I Bay (Bay no- 208)at Rengali | 09-01-2017 | 08:00Hrs: | 12-01-2017 | 17:00Hrs: | OCB | ER-II/ODISHA | Mechanism Overhauling of Breaker. | ODISHA |
| 148 | 400 KV Talcher #1 Tie Bay (Bay No.- 405) | 09-01-2017 | 09:00 | 09-01-2017 | 13:00 | ODB | ER-II/ODISHA | Overhauling of Air Compressor of 40552 CB. | |
| 149 | 400KV Sundergarh-Raigarh Line#II at Sundergarh | 09-01-2017 | 08:00 | 10-01-2017 | 18:00 | ODB | ER-II/ODISHA | to attend mechanical interlock problem (constructional | NLDC |
| 150 | 765KV Sundargarh-Dharmajoygarh Ckt-1 | 09-01-2017 | 10:00 | 09-01-2017 | 13:00 | ODB | ER-II/ODISHA | Refixing of Repair sleeves in the span of 86-87 | NLDC |

| | | | | | | | | | |
|-----|---|------------|-----------|------------|-----------|-----|--------------|---|-----------|
| 151 | 220 KV MAIN BUS-1 AT PURNEA | 09-01-2017 | 09:00 | 09-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 152 | SIPAT-I TIE BAY-420 AT RANCHI | 09-01-2017 | 10:00 | 09-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 153 | 400 KV BIHARSHARIF - MUZAFFARPUR -1 | 09-01-2017 | 09:00 | 09-01-2017 | 18:00 | ODB | ER-I | REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS. | NLDC |
| 154 | 220KV MUZ - KANTI -I | 09-01-2017 | 10:00 | 09-01-2017 | 16:00 | ODB | ER-I | FOR LINE BAY AMP WORK AT MUZ | BIHAR |
| 155 | 765 KV GAYA-VARANASI-I | 09-01-2017 | 10:00 | 09-01-2017 | 18:00 | OCB | ER-I | FOR HV BUSHING REPLACEMENT WORK IN Y-PHASE LINE | NLDC |
| 156 | 765/400 KV ICT-II AT NEW RANCHI S/S | 09-01-2017 | 09:00 | 11-01-2017 | 18:00 | ODB | ER-I | RTV COATING OF TRENCH MAKE BUSHING & AMP | NLDC |
| 157 | BALIA -1 AND BARH -2 TIE BAY AT PATNA | 09-01-2017 | 09:00 | 09-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |
| 158 | 400 KV PATNA - BARH - III | 09-01-2017 | 08:00 | 12-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF PORCELAIN INSULATOR WITH POLYMER INSULATOR | |
| 159 | 220kv NSLG-SLG Ckt-I | 09-01-2017 | 9.00 hrs | 09-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Relay retrofitting | |
| 160 | 400KV NSLG-Tala Ckt-3 | 09-01-2017 | 07.00 hrs | 09-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | NLDC |
| 161 | 400 KV BUS-I with Bay no-08 of NTPC Farakka | 09-01-2017 | 10:00 | 10-01-2017 | 17:00 | ODB | ER-II/KOL | BUS bar-I stability test has to also carried out. To charge Bay no-09, jumper of Bay no-08 is to be opened and to be connected with isolator of Bay no-09. <i>Then only, Bus reactor#1 with Bay no-09 will come into service. Moreover, dismantelling of strung BUS over bay- 09 has to also carried out.</i> | |
| 162 | 220KV Siliguri-Kishanganj # I | 09-01-2017 | 09:00 Hrs | 09-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | Loose span rectification | |
| 163 | 400kv Bus-I | 10-01-2017 | 07:00 | 10-01-2017 | 19:00 | ODB | ER-II/ODISHA | AMP WORK | |
| 164 | 400KV KANIHA-ROURKELA-I | 10-01-2017 | 09:00 | 12-01-2017 | 17:00 | OCB | NTPC/KANIHA | MAINTENANACE ACTIVITIES OF BAY EQUIPMENT | |
| 165 | 400 KV Indravati-Rengali line | 10-01-2017 | 09:00 | 10-01-2017 | 13:00 | ODB | ER-II/ODISHA | For removal of 50MVAR LR of Rengali-Indravati Line from service for replacement of insulating oil. And Testing of 50MVAR L/R in Rengali Line before replacement of Oil. | NLDC |
| 166 | 50MVAR L/R of 400KV Indravati-Rengali Line | 10-01-2017 | 13:00 | 17-01-2017 | 10:00 | OCB | ER-II/ODISHA | Replacement of insulating Oil. During this period, only 50MVAR LR will be out of service but the 400KV Indravati- | |
| 167 | Bolangir Line Main Bay (415) at Jeypore | 10-01-2017 | 09:30 | 10-01-2017 | 17:30 | ODB | ER-II/ODISHA | For AMP works | |
| 168 | 400KV ICT-I Main bay | 10-01-2017 | 09:00 | 10-01-2017 | 18:00 | ODB | ER-II/ODISHA | For AMP Works | |
| 169 | 400 KV Talcher #1 Main Bay (Bay No. - 406) | 10-01-2017 | 09:00 | 10-01-2017 | 13:00 | ODB | ER-II/ODISHA | Overhauling of Air Compressor of 40652 CB. | |
| 170 | 765KV Sundargarh-Dharmajoygargh Ckt-2 | 10-01-2017 | 10:00 | 10-01-2017 | 13:00 | ODB | ER-II/ODISHA | Refixing of Repair sleeves in the span of 40-41 | NLDC |
| 171 | 220 KV MAIN BUS-2 AT PURNEA | 10-01-2017 | 09:00 | 10-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 172 | 400 KV BUS-1 AT CHAIBASA | 10-01-2017 | 09:00 | 10-01-2017 | 17:00 | ODB | ER-I | FOR RECTIFICATION OF ISOLATOR ALIGNMENT PROBLEM | |
| 173 | 220KV BUS-1 AT NEW PURNEA | 10-01-2017 | 10:00 | 10-01-2017 | 16:00 | ODB | ER-I | AMP | |
| 174 | 400 KV JSR-ANDAL-2 | 10-01-2017 | 09:30 | 10-01-2017 | 17:30 | ODB | ER-I | BAY AMP WORK | |
| 175 | 315 MVA ICT-I AT RANCHI | 10-01-2017 | 10:00 | 10-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK. | JHARKHAND |
| 176 | 400 KV BUS -2 AT BIHARSHARIF | 10-01-2017 | 10:00 | 10-01-2017 | 13:00 | ODB | ER-I | OPENING OF JUMPER NEAR (BAY NO.-16 FUTURE) FOR 400KV TENUGHAT BAY EXTENSION WORK | |
| 177 | 400 KV TIE BAY OF LAKHISARAI -2 & FUTURE (BAY NO 17) AT BIHARSHARIF | 10-01-2017 | 10:00 | 25-01-2017 | 18:00 | OCB | ER-I | BAY WILL BE UNDER S/D TILL COMMISSIONING OF MAIN BAY OF 400KV TENUGHAT DUE TO OPENING OF JUMPERS. | |
| 178 | TIE BAY OF SSRM-BIHARSHARIFF # II, BAY NO. | 10-01-2017 | 10:00 | 10-01-2017 | 18:00 | ODB | ER-I | FOR AMP WORK | |
| 179 | 220KV MUZ - KANTI -II | 10-01-2017 | 10:00 | 10-01-2017 | 16:00 | ODB | ER-I | FOR LINE BAY AMP WORK AT MUZ | BIHAR |
| 180 | 765KV GAYA-VARANASI-2 | 10-01-2017 | 09:00 | 10-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS | NLDC |
| 181 | 200 MVA ICT-2 AT LAKHISARAI | 10-01-2017 | 08:00 | 14-01-2017 | 18:00 | ODB | ER-I | HVWS WORK AND CONSTRUCTION OF FIREWALL | BIHAR |
| 182 | BALIA -3 MAIN BAY AT PATNA | 10-01-2017 | 09:00 | 10-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |

| | | | | | | | | | |
|-----|--|------------|-----------|------------|-----------|-----|--------------|--|-------------|
| 183 | 400kV Tala-II L/R AT BINAGURI | 10-01-2017 | 07.00 hrs | 10-01-2017 | 17.00 hrs | ODB | ER-II/KOL | CSD Commissioning / Tan Delta in Variable Frequency | |
| 184 | 400 KV BONG- NEW SLG-1&2- LINE | 10-01-2017 | 07:00 | 13-01-2017 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE OUT-AP 17/0 -AP 18/0 | NLDC |
| 185 | 220KV Siliguri-Kishanganj # II | 10-01-2017 | 09:00 Hrs | 10-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | Loose span rectification | |
| 186 | 400 kv DGP- PPSP II | 10-01-2017 | 09:00 | 10-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 187 | 765 kv Ballia-Varanasi | 11-01-2017 | 08:00 | 11-01-2017 | 18:00 | ODB | NRLDC | For taking the 80MVAR SpareReactor in service at Varanasi | |
| 188 | 220kV S'gram-CESC-1 | 11-01-2017 | 08:30 | 11-01-2017 | 17:00 | ODB | ER-II/KOL | AMP | WEST BENGAL |
| 189 | 400kV Bus-2 | 11-01-2017 | 07:00 | 11-01-2017 | 19:00 | ODB | ER-II/ODISHA | AMP WORK | |
| 190 | 400 KV Talcher #2 Main Bay (Bay No.- 407) | 11-01-2017 | 09:00 | 11-01-2017 | 13:00 | ODB | ER-II/ODISHA | Overhauling of Air Compressor of 40752 CB. | |
| 191 | 400KV 125MVAR Bus Reactor-I at Sundergarh | 11-01-2017 | 08:00 | 11-01-2017 | 18:00 | ODB | ER-II/ODISHA | to attend mechanical interlock problem (constructional defect) of 400KV Siemens make Isolators | |
| 192 | 220 KV DALKHOLA-1 BAY CB AT PURNEA | 11-01-2017 | 10:00 | 11-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 193 | 400 KV BUS-2 AT CHAIBASA | 11-01-2017 | 09:00 | 11-01-2017 | 17:00 | ODB | ER-I | FOR RECTIFICATION OF ISOLATOR ALIGNMENT PROBLEM | |
| 194 | LR OF 400 KV RNC - SIPAT -1 AT RANCHI | 11-01-2017 | 10:00 | 11-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK, FOR ISOLATION OF L/R, LINE WILL OUT OF | |
| 195 | 400 KV BIHARSHARIF - MUZAFFARPUR -2 | 11-01-2017 | 09:00 | 11-01-2017 | 18:00 | ODB | ER-I | REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS. | NLDC |
| 196 | SSRM-ALLAHABAD LINE REACTOR BAY, BAY NO. | 11-01-2017 | 10:00 | 11-01-2017 | 18:00 | ODB | ER-I | FOR AMP WORK | |
| 197 | 220KV BUS-I AT MUZAFFARPUR | 11-01-2017 | 10:00 | 11-01-2017 | 16:00 | ODB | ER-I | COMMISSIONING OF GIS BAY | |
| 198 | MAIN BAY OF 125 MVAR B/R - 2 AT PATNA | 11-01-2017 | 09:00 | 11-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |
| 199 | 400 KV BINAGURI-BONGAIGAON-III L/R | 11-01-2017 | 07.00 hrs | 11-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Tan Delta in Variable Frequency | NLDC |
| 200 | 220kV Siliguri Line#2 Bay AT BINAGURI | 11-01-2017 | 09:30 HRS | 11-01-2017 | 17:30 HRS | OCB | ER-II/KOL | CB Ovrhauling | WEST BENGAL |
| 201 | 400 KV Farakka- Kahalgaon 1 & 2 | 11-01-2017 | 08:00 | 11-01-2017 | 18:00 | ODB | ER-II/KOL | Stringing between Loc. No. 5A/0 to 6/Q of LILO of 400 KV Rajarhat- Purnea D/c at Farakka . | |
| 202 | 220 KV Rangpo-New Melli line/Bay-207(CKT-I) | 11-01-2017 | 10:00 | 11-01-2017 | 18:00 | OCC | ER-II/KOL | BAY maintenance(AMP) | |
| 203 | 220 KV Rangpo-New Melli line/Bay-207(CKT-I) | 11-01-2017 | 09:00 | 11-01-2017 | 16:00 | ODB | ER-II/KOL | BAY maintenance(AMP) | |
| 204 | 220 KV Rangpo-New Melli line/Bay-212(CKT-II) | 11-01-2017 | 09:00 | 11-01-2017 | 16:00 | ODB | ER-II/KOL | BAY maintenance(AMP) | |
| 205 | 220KV Dalkhola-Kishanganj # I | 11-01-2017 | 09:00 Hrs | 11-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | Loose span rectification & Bay Amp work | |
| 206 | 400 kv DGP- PPSP I | 11-01-2017 | 09:00 | 11-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 207 | 400kV Bus Reactor-3 Main Bay (404) | 12-01-2017 | 09:00 | 12-01-2017 | 15:00 | ODB | ER-II/ODISHA | AMP WORK | |
| 208 | 400 kv Jeypore-Gazuwaka-1 | 12-01-2017 | 09:00 | 12-01-2017 | 13:00 | ODB | SRLCD | AMP | NLDC |
| 209 | 400KV KEONJHAR LINE MAIN BAY (401) AT | 12-01-2017 | 09:00 | 13-01-2017 | 18:00 | OCB | ER-II/ODISHA | SF6 GAS LEAKAGE RECTIFICATION WORK IN 40152CB | |
| 210 | 50 MVAR Bus Reactor Main Bay (Bay No.- 422) | 12-01-2017 | 09:00 | 12-01-2017 | 13:00 | ODB | ER-II/ODISHA | Overhauling of Air Compressor of 42252 CB. | |
| 211 | Main Bay-403 of 765/400KV ICT-I at Sundergarh | 12-01-2017 | 09:00 | 12-01-2017 | 18:00 | ODB | ER-II/ODISHA | FOR AMP WORK | |
| 212 | 220 KV DALKHOLA-2 BAY CB AT PURNEA | 12-01-2017 | 10:00 | 12-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 213 | 400 KV CHAIBASA-ROURKELA CKT-2 | 12-01-2017 | 09:00 | 12-01-2017 | 17:00 | ODB | ER-I | ISOLATOR RECTIFICATION WORK. | |
| 214 | MAIN BAY OF 400 KV NPRN -NSLG-1 (BAY NO 401) AT NEW PURNEA | 12-01-2017 | 10:00 | 12-01-2017 | 16:00 | ODB | ER-I | AMP | |
| 215 | 50 MVAR L/R OF 400 KV BIHARSHARIF - VARANASI -1 AT BIHARSHARIF | 12-01-2017 | 10:00 | 12-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |
| 216 | 400 KV BSF - VARANASI-1 | 12-01-2017 | 09:00 | 14-01-2017 | 18:00 | ODB | ER-I | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS | NLDC |
| 217 | 220KV BUS-II AT MUZAFFARPUR | 12-01-2017 | 10:00 | 12-01-2017 | 16:00 | ODB | ER-I | COMMISSIONING OF GIS BAY | |
| 218 | 400KV MAITHON GAYA-I AND 400KV KODERMA- | 12-01-2017 | 09:00 | 12-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF INSULATORS DAMAGED BY | |
| 219 | 765KV B/R -1 AT NEW RANCHI | 12-01-2017 | 08:00 | 14-01-2017 | 18:00 | ODB | ER-I | RTV COATING OF TRENCH MAKE BUSHING & AMP | NLDC |
| 220 | 400 kv KAHALGAON - BARH - I | 12-01-2017 | 08:00 | 12-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF BROKEN INSULATORS INSULATORS DAMAGED DUE T DENSED FOG | |

| | | | | | | | | | |
|-----|--|------------|-----------|------------|-----------|-----|--------------|--|-------------|
| 221 | 125 MVAR Bus Reactor-I AT BINAGURI | 12-01-2017 | 07.00 hrs | 12-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Tan Delta in Variable Frequency | |
| 222 | 400 KV Farakka- Kahalgaon 3 & 4 | 12-01-2017 | 08:00 | 20-01-2017 | 18:00 | OCB | ER-II/KOL | Erection of tower at Loc no. 5/0 & 5A/0 of LILO of 400 KV Rajarhat- Purnea D/c at Farakka and stringing between them (5/0 to 5A/0). Special Remarks : Span between 5/0 to 5A/0 is 80 mtrs. So, Distance between tower 5/0 & 5A/0 to 400 KV Farakka - Kahalgaon line is even less. Tower height of 5/0 and 5A/0 is approx 80 mtrs (DD+25 Mtrs with 4 m RC). So, during erection also, shutdown is required for passing stay / guy wires /ropes. | |
| 223 | 220 KV Rangpo-New Melli line/Bay-212(CKT-II) | 12-01-2017 | 10:00 | 12-01-2017 | 18:00 | OCC | ER-II/KOL | BAY maintenance(AMP) | |
| 224 | 400 KV DURGAPUR-Jamshedpur | 12-01-2017 | 09:00 | 12-01-2017 | 18:00 | ODB | ER-II/KOL | LA/CVT Jumper correction | |
| 225 | 400kv Malda-Farakka Line-CKT-I | 12-01-2017 | 09:00 | 12-01-2017 | 16:00 | OBD | ER-II/KOL | To attend Punch point of M/s Sterlite | NLDC |
| 226 | 220KV Dalkhola-Kishanganj # II | 12-01-2017 | 09:00 Hrs | 12-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | Loose span rectification & Bay AMP work | |
| 227 | At BKTPP: 315 MVA IBT 1 | 12-01-2017 | 08:00 | 14-01-2017 | 08:00 | ODB | WBSETCL | Winter Maintenance | |
| 228 | 132 KV Kh-Lalmtia line | 12-01-2017 | 09:30hrs | 12-01-2017 | 17:30 hrs | ODB | NTPC | PM works & relay testing | JHARKHAND |
| 229 | 220kv S'gram-WBSETCL Line #2 | 13-01-2017 | 08:30 | 13-01-2017 | 17:00 | ODB | ER-II/KOL | AMP | WEST BENGAL |
| 230 | 400 kv Jeypore-Gazuwaka-2 | 13-01-2017 | 09:00 | 13-Jan-17 | 13:00 | ODB | SRILDC | AMP | NLDC |
| 231 | 400kv Bus Reactor-3 & Meramundali Line-1 TIE Bay (405) | 13-01-2017 | 09:00 | 13-01-2017 | 15:00 | ODB | ER-II/ODISHA | AMP WORK | |
| 232 | Tie Bay-408 of 400KV Ind-Barat Line at Sundergarh | 13-01-2017 | 09:00 | 13-01-2017 | 18:00 | ODB | ER-II/ODISHA | FOR AMP WORK | |
| 233 | 220 KV NEW PURNEA-PURNEA#1 BAY CB AT PURNEA | 13-01-2017 | 10:00 | 13-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 234 | 400 KV CHAIBASA-JAMSHEDPUR CKT-2 | 13-01-2017 | 09:00 | 13-01-2017 | 17:00 | ODB | ER-I | ISOLATOR RECTIFICATION WORK. | |
| 235 | 315 MVA ICT-2 AT JAMSHEDPUR | 13-01-2017 | 09:30 | 13-01-2017 | 17:30 | ODB | ER-I | BAY CONSTRUCTION WORK | JHARKHAND |
| 236 | 400KV BUS-II AT MUZAFFARPUR | 13-01-2017 | 10:00 | 13-01-2017 | 16:00 | ODB | ER-I | TESTING OF LBB RELAY OF DARBHANGA BAY | |
| 237 | 400KV MAITHON GAYA-II AND 400KV KODERMA- | 13-01-2017 | 09:00 | 13-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF INSULATORS DAMAGED BY | |
| 238 | 400 KV KAHALGAON - BARH - II | 13-01-2017 | 08:00 | 13-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF BROKEN INSULATORS INSULATORS DAMAGED DUE T DENSED FOG | |
| 239 | 400kv NSLG-Kishanganj-2 Line | 13-01-2017 | 07.00 hrs | 13-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Hot spot rectification | |
| 240 | 400kv Bus-I AT BINAGURI | 13-01-2017 | 07.00 hrs | 18-01-2017 | 17.00 hrs | ODB | ER-II/KOL | To facilitate hot spot rectification in Purnea-3 & 4 Line | |
| 241 | 125 MVAR Bus Reactor-II AT BINAGURI | 13-01-2017 | 07.00 hrs | 13-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Tan Delta in Variable Frequency | |
| 242 | 220 KV BRP-Malbase | 13-01-2017 | 08:00 Hrs | 18-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | CLR Insulator Replacement | NLDC |
| 243 | 315 MVA ICT#I at Durgapur | 13-01-2017 | 15:00 | 13-01-2017 | 16:00 | ODB | ER-II/KOL | Final commissioning of CB | DVC |
| 244 | 400kv Malda-Farakka Line-CKT-I | 13-01-2017 | 09:00 | 13-01-2017 | 16:00 | OBD | ER-II/KOL | To attend Punch point of M/s Sterlite | NLDC |
| 245 | 400KV Malda-New purnea # I | 13-01-2017 | 09:00 Hrs | 13-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 246 | At DGP: 3*105 MVA ICT 2 | 13-01-2017 | 09:00 | 14-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 247 | 400 KV Farakka - Sagardighi | 13-01-2017 | 09:30hrs | 13-01-2017 | 14:00 hrs | ODB | NTPC | Main bay CT testing (Line may remain in service) | |
| 248 | 315 MVA ICT-II AT SUBHASGRAM | 14-01-2017 | 08:30 | 14-01-2017 | 17:00 | ODB | ER-II/KOL | AMP | WEST BENGAL |
| 249 | 400kv Meramundali Line-1 Main Bay (406) | 14-01-2017 | 09:00 | 14-01-2017 | 15:00 | ODB | ER-II/ODISHA | AMP WORK | |
| 250 | 400 KV KEONJHAR LINE | 14-01-2017 | 09:00 | 14-01-2017 | 18:00 | ODB | ER-II/ODISHA | MAIN 2 RELAY RETROFICATION WORK | NLDC |
| 251 | Tie Bay-417 of 400KV Bus Reactor-II at Sundergarh | 14-01-2017 | 09:00 | 14-01-2017 | 18:00 | ODB | ER-II/ODISHA | FOR AMP WORK | |
| 252 | 220 KV NEW PURNEA-PURNEA#2 BAY CB AT | 14-01-2017 | 10:00 | 14-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 253 | BALIA -4 MAIN BAY AT PATNA | 14-01-2017 | 09:00 | 02-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |

| | | | | | | | | | |
|-----|---|------------|-----------|------------|-----------|-----|--------------|--|-------------|
| 254 | 400kV NSLG-Kishanganj-1 Line | 14-01-2017 | 07.00 hrs | 14-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Hot spot rectification | |
| 255 | 315MVA ICT#1 AT BINAGURI | 14-01-2017 | 07.00 hrs | 14-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Tan Delta in Variable Frequency | |
| 256 | 220 KV DURGAPUR-DVCH#1 | 14-01-2017 | 11:00 | 14-01-2017 | 12:00 | ODB | ER-II/KOL | CB Overhauling-trasfer load to transfer bus & protection | DVC |
| 257 | 400KV Malda-New purnea # I | 14-01-2017 | 09:00 Hrs | 14-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 258 | At BKTPP: 400 KV Main Bus 1 | 14-01-2017 | 08:00 | 16-01-2017 | 08:00 | ODB | WBSETCL | Winter Maintenance | |
| 259 | 400 KV Farakka - Bus Reactor 2 | 14-01-2017 | 09:30hrs | 14-01-2017 | 14:00 hrs | ODB | NTPC | Main bay CT testing (Reactor may remain in service) | |
| 260 | 400 KV BSF - VARANASI - 2 | 15-01-2017 | 09:00 | 17-01-2017 | 18:00 | ODB | ER-I | FOR REPLACEMENT OF INSULATORS DAMAGED BY | NLDC |
| 261 | 400 KV PATNA - BARH - IV | 15-01-2017 | 08:00 | 20-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF PORCELAIN INSULATOR WITH POLYMER INSULATOR | |
| 262 | 220kV Bus-I AT BINAGURI | 15-01-2017 | 07.00 hrs | 15-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Bus isolator hot spot rectification / CVT replacement | |
| 263 | 400kV NSLG-Rangpo Ckt-1 | 15-01-2017 | 07.00 hrs | 16-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | |
| 264 | 315MVA ICT#2 AT BINAGURI | 15-01-2017 | 07.00 hrs | 15-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Tan Delta in Variable Frequency | |
| 265 | 220kV S'gram-KLC Line | 16-01-2017 | 08:30 | 16-01-2017 | 17:00 | ODB | ER-II/KOL | AMP | WEST BENGAL |
| 266 | 220 KV SIDE OF 160 MVA ICT-II, BAY-210 | 16-01-2017 | 09:00 | 16-01-2017 | 18:00 | ODB | ER-II/ODISHA | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. AMP OF BAY | ODISHA |
| 267 | 400kV Indravati Tie Bay(Bay no- 411) at Rengali | 16-01-2017 | 09:00Hrs: | 19-01-2017 | 17:00Hrs: | OCB | ER-II/ODISHA | Erection of Breaker for Bay extension work. | |
| 268 | Main Bay-718 of 765KV Sundergarh-Dharamjaygarh Line# II at Sundergarh | 16-01-2017 | 09:00 | 23-01-2017 | 18:00 | ODB | ER-II/ODISHA | REFURBISHMENT OF 765KV CB FOR DCRM PROBLEM(CONSTRUCTIONAL DEFECT) | |
| 269 | 220 KV BUS COUPLER BAY CB AT PURNEA | 16-01-2017 | 10:00 | 16-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. BUT 220 KV BUS -1 AND BUS-2 WILL REMAIN ISOLATED AT PRN.. | |
| 270 | 400 KV BUS-I AT JAMSHEDPUR | 16-01-2017 | 09:30 | 16-01-2017 | 17:30 | ODB | ER-I | BAY CONSTRUCTION WORK | |
| 271 | SIPAT-I MAIN BAY-421 BAY AT RANCHI | 16-01-2017 | 10:00 | 16-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK | |
| 272 | 400 KV RANCHI -CHANDWA CIRCUIT-1 | 16-01-2017 | 10:00 | 16-01-2017 | 16:00 | ODB | ER-I | REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS IN FOREST AREA | NLDC |
| 273 | 765 KV NEW RANCHI DHARAMJAYGARH -1 AT AT | 16-01-2017 | 08:00 | 19-01-2017 | 18:00 | ODB | ER-I | FOR REPLACEMENT OF QUAD DROPPER INTO TWIN FOR | NLDC |
| 274 | 80 MVAR B/R AT LAKHISARAI | 16-01-2017 | 08:00 | 19-01-2017 | 18:00 | ODB | ER-I | HVWS WORK AND CONSTRUCTION OF FIREWALL | |
| 275 | 400kV Malda-Farakka Line-CKT-II | 16-01-2017 | 09:00 | 16-01-2017 | 16:00 | ODB | ER-II/KOL | To attend Punch point of M/s Sterlite | NLDC |
| 276 | 400KV Malda-New purnea # II | 16-01-2017 | 09:00 Hrs | 16-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 277 | At DGP: 315 MVA ICT 1 | 16-01-2017 | 09:00 | 16-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 278 | At BKTPP: 315 MVA IBT 2 | 16-01-2017 | 08:00 | 18-01-2017 | 08:00 | ODB | WBSETCL | Winter Maintenance | |
| 279 | 400KV BUS-I AT TSTPP | 17-01-2017 | 09:00 | 17-01-2017 | 17:00 | ODB | NTPC/KANIHA | MAINTENANACE ACTIVITIES OF BAY EQUIPMENT | |
| 280 | 220kV S'gram-Newtown Line #2 | 17-01-2017 | 08:30 | 17-01-2017 | 17:00 | ODB | ER-II/KOL | AMP | WEST BENGAL |
| 281 | 765kV ICT-4 Main Bay(713) | 17-01-2017 | 09:00 | 17-01-2017 | 17:00 | ODB | ER-II/ODISHA | AMP WORK | NLDC |
| 282 | Non-Auto mode of Auto-Reclousure in 765KV Angul | 17-01-2017 | 09:00 | 31-01-2017 | 17:00 | ODB | ER-II/ODISHA | Rectification works of OPGW works | |
| 283 | 400 KV Indravati-Rengali line | 17-01-2017 | 10:00 | 17-01-2017 | 15:00 | ODB | ER-II/ODISHA | Testing of 50MVAR L/R in Rengali Line before charging. And | NLDC |
| 284 | 400KV Keonjhar-Rengali Line at Keonjhar | 17-01-2017 | 09:00 | 19-01-2017 | 18:00 | OCB | ER-II/ODISHA | For OPGW Stringing Work | |
| 285 | 220 KV TRANSFER BUS COUPLER BAY CB AT PURNEA | 17-01-2017 | 10:00 | 17-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 286 | MAIN BAY NEW SILIGURI -2 (BAY NO 404) AT NEW | 17-01-2017 | 10:00 | 17-01-2017 | 18:00 | ODB | ER-I | AMP | |

| | | | | | | | | | |
|-----|--|------------|-----------|------------|-----------|-----|--------------|--|-------------|
| 287 | BAY NO. 423 (TIE BAY OF SIPAT-II & FUTURE LINE-) AT RANCHI | 17-01-2017 | 10:00 | 17-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK | |
| 288 | 400 KV RANCHI - CHANDWA CIRCUIT-2 | 17-01-2017 | 10:00 | 17-01-2017 | 16:00 | ODB | ER-I | REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS IN | NLDC |
| 289 | 400KV FARAKKA - KAHALGAON CKT. # III & IV | 17-01-2017 | 09:00 | 20-01-2017 | 18:00 | OCB | ER-I | FOR POWER LINE CROSSING OF EXISTING 400 KV | |
| 290 | 500MVA ICT-3 AT MUZAFFARPUR | 17-01-2017 | 10:00 | 21-01-2017 | 16:00 | OCB | ER-I | REPLACEMENT OF BUSHING AND TURRET GASKETS. | BIHAR |
| 291 | TIE BAY OF 765KV B/R-2 & FUTURE (708) AT NEW | 17-01-2017 | 08:00 | 18-01-2017 | 18:00 | ODB | ER-I | BAY AMP | |
| 292 | SIPARA -2 BAY AT PATNA | 17-01-2017 | 09:00 | 17-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERUPPTION. LINE WILL BE | |
| 293 | 220kv Bus-II AT BINAGURI | 17-01-2017 | 07.00 hrs | 17-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Bus isolator hot spot rectification | |
| 294 | 400kv NSLG-Rangpo Ckt-2 | 17-01-2017 | 07.00 hrs | 18-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | |
| 295 | 220 KV BINAGURI-Birpara-1 | 17-01-2017 | 09:30 HRS | 17-01-2017 | 17:30 HRS | ODB | ER-II/KOL | CB Ovrhauling | |
| 296 | 400 KV BONG- NEW SLG-1&2- LINE | 17-01-2017 | 07:00 | 20-01-2017 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE IN-AP 10/0 -AP 11/0 | NLDC |
| 297 | 400kv Malda-Farakka Line-CKT-II | 17-01-2017 | 09:00 | 17-01-2017 | 16:00 | OBD | ER-II/KOL | To attend Punch point of M/s Sterlite | NLDC |
| 298 | 400KV Malda-New purnea # II | 17-01-2017 | 09:00 Hrs | 17-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | New Hardware fitting fixing | |
| 299 | 315 MVA ICT-V AND 400 KV BUS-2 AT MALDA | 17-01-2017 | 09:00 Hrs | 17-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | CT Change for R & Y Phase | WEST BENGAL |
| 300 | At DGP: 400 KV TBC Bay | 17-01-2017 | 09:00 | 17-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 301 | 765kv ICT-4 and BR-2 TIE Bay (714) | 18-01-2017 | 09:00 | 18-01-2017 | 17:00 | ODB | ER-II/ODISHA | AMP WORK | NLDC |
| 302 | 400 kv Bus-I at Jeypore | 18-01-2017 | 09:30 | 18-01-2017 | 13:30 | ODB | ER-II/ODISHA | For Relay Testing after Retrofitting of BusBar Protection System | |
| 303 | 400 kv Bus-II at Jeypore | 18-01-2017 | 14:00 | 18-01-2017 | 18:00 | ODB | ER-II/ODISHA | For Relay Testing after Retrofitting of BusBar Protection System | |
| 304 | 220 KV SIDE OF 160 MVA ICT-1 BAY CB AT PURNEA | 18-01-2017 | 10:00 | 18-01-2017 | 11:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 305 | 400 KV BUS-II AT JAMSHEDPUR | 18-01-2017 | 09:30 | 18-01-2017 | 17:30 | ODB | ER-I | BAY CONSTRUCTION WORK | |
| 306 | 400 KV CHANDWA-GAYA CIRCUIT-1 | 18-01-2017 | 10:00 | 18-01-2017 | 16:00 | ODB | ER-I | REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS IN FOREST AREA | NLDC |
| 307 | 400 KV KHG - LAKHISARAI- CKT. I | 18-01-2017 | 09:00 | 18-01-2017 | 18:00 | ODB | ER-I | FOR INSULATOR REPLACEMENT FOUND DEFECTIVE AFTER PID | |
| 308 | 220 KV BUS-I with Bus Coupler | 18-01-2017 | 09:00 Hrs | 18-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | Jumper Change | |
| 309 | At DGP: 400 KV Bus Coupler Bay | 18-01-2017 | 09:00 | 18-01-2017 | 09:00 | ODB | WBSETCL | Winter Maintenance | |
| 310 | At BKTPP: 400 KV Main Bus 2 | 18-01-2017 | 08:00 | 20-01-2017 | 08:00 | ODB | WBSETCL | Winter Maintenance | |
| 311 | 315 MVA ICT-III AT SUBHASGRAM | 19-01-2017 | 08:30 | 19-01-2017 | 17:00 | ODB | ER-II/KOL | AMP & Overcurrent Relay Relay retrofit | WEST BENGAL |
| 312 | 765 KV Fathepur-Varanasi | 19-01-2017 | 09:00 | 19-Jan-17 | 18:00 | ODB | NRLDC | RTV Coating of Bushing , NGR Bypassing of reactor , AMP | |
| 313 | 765kv Bus Reactor-2 main bay (715) | 19-01-2017 | 09:00 | 19-01-2017 | 17:00 | ODB | ER-II/ODISHA | AMP WORK | NLDC |
| 314 | 220 kv Bus-I at Jeypore | 19-01-2017 | 09:30 | 19-01-2017 | 13:30 | ODB | ER-II/ODISHA | For Relay Testing after Retrofitting of BusBar Protection System | ODISHA |
| 315 | 220 kv Bus-II at Jeypore | 19-01-2017 | 14:00 | 19-01-2017 | 18:00 | ODB | ER-II/ODISHA | For Relay Testing after Retrofitting of BusBar Protection System | ODISHA |
| 316 | 220 KV SIDE OF 160 MVA ICT-2 BAY CB AT PURNEA | 19-01-2017 | 10:00 | 19-01-2017 | 11:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 317 | 400KV BUS-1 AT NEW PURNEA | 19-01-2017 | 10:00 | 19-01-2017 | 18:00 | ODB | ER-I | AMP | |
| 318 | 400 KV JSR-DURGAPUR | 19-01-2017 | 09:30 | 19-01-2017 | 17:30 | ODB | ER-I | BAY CONSTRUCTION WORK | |
| 319 | 400 KV CHANDWA-GAYA CIRCUIT-2 | 19-01-2017 | 10:00 | 19-01-2017 | 16:00 | ODB | ER-I | REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS IN | NLDC |
| 320 | 400 KV KHG - LAKHISARAI- CKT. II | 19-01-2017 | 09:00 | 19-01-2017 | 18:00 | ODB | ER-I | FOR INSULATOR REPLACEMENT FOUND DEFECTIVE AFTER PID | |
| 321 | TIE BAY OF 765KV B/R-1 & FUTURE (711) AT | 19-01-2017 | 08:00 | 20-01-2017 | 18:00 | ODB | ER-I | BAY AMP | |
| 322 | SIPARA -1 BAY AT PATNA | 19-01-2017 | 09:00 | 19-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERUPPTION. LINE WILL BE | |
| 323 | 220 KV DURGAPUR-DVC#2 | 19-01-2017 | 11:00 | 19-01-2017 | 12:00 | ODB | ER-II/KOL | Final commissioning of CB | DVC |
| 324 | 400 KV Kahalgaon - Barh#2 | 19-01-2017 | 09:30hrs | 19-01-2017 | 17:30 hrs | OCB | NTPC | PM works & relay testing | |
| 325 | 400 KV Farakka - Bus Reactor 1 | 19-01-2017 | 09:30hrs | 19-01-2017 | 17:30 hrs | ODB | NTPC | Relay testing | |
| 326 | 765kv, 3*100 MVAR Bus Reactor-2 | 20-01-2017 | 09:00 | 20-01-2017 | 15:00 | ODB | ER-II/ODISHA | AMP WORK | NLDC |
| 327 | ICT-I (3x 105 MVA) at Jeypore | 20-01-2017 | 10:30 | 20-01-2017 | 11:30 | ODB | ER-II/ODISHA | For changing ICT-I combination form Unit-I,III, IV to Unit-I,II and III for charging Unit-II after Overhauling works | ODISHA |

| | | | | | | | | | |
|-----|---|------------|-----------|------------|-----------|-----|--------------|---|-------------|
| 328 | 400KV Keonjhar-Baripada Line at Keonjhar | 20-01-2017 | 09:00 | 20-01-2017 | 18:00 | ODB | ER-II/ODISHA | For jointing & splicing works of OPGW Stringing. | |
| 329 | 220 KV SIDE OF 160 MVA ICT-3 BAY CB AT PURNEA | 20-01-2017 | 10:00 | 20-01-2017 | 11:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION. | |
| 330 | 400KV BUS-II AT RANCHI | 20-01-2017 | 08:00 | 20-01-2017 | 18:00 | ODB | ER-I | CVT REPLACEMENT OF BUS-II. DURING S/D BUS-II 400 KV RNC-NRNC-I & 2 WILL ALSO REMAIN OUT OF SERVICE. | |
| 331 | 400 KV BUS REACTOR-1 AT CHANDWA | 20-01-2017 | 10:00 | 20-01-2017 | 16:00 | ODB | ER-I | FOR CHECKING AND REPLACING OF THE RELIEF VALVES OF ALL THE HYDRAULIC CIRCUIT BREAKERS AT GIS CHANDWA BY | |
| 332 | 400 KV LAKHISARAI - BSF CKT. I | 20-01-2017 | 09:00 | 20-01-2017 | 18:00 | ODB | ER-I | FOR INSULATOR REPLACEMENT FOUND DEFECTIVE AFTER PID | |
| 333 | 400 KV LAKHISARAI- KAHALGAON-1 | 20-01-2017 | 08:00 | 20-01-2017 | 08:10 | ODB | ER-I | FOR TAKING LINE REACTOR OUT OF SERVICE | |
| 334 | 50 MVAR L/R OF 400 kV LKR-KHG Line-1 AT | 20-01-2017 | 08:00 | 23-01-2017 | 18:00 | OCB | ER-I | HVWS WORK AND CONSTRUCTION OF FIREWALL | |
| 335 | 220 KV BUS COUPLER AT PATNA | 20-01-2017 | 09:00 | 20-01-2017 | 17:00 | ODB | ER-I | AMP WORK. NO POWER INTERRUPTION BUT 220 KV BUS -1 AND 2 AT PATNA WILL REMAN IN ISOLATED CONDITION. | BIHAR |
| 336 | 220kv NSLG-BRP Ckt-I & II | 20-01-2017 | 9.00 hrs | 30-12-2016 | 17.00 hrs | OCB | ER-II/KOL | PG clamp removal / Tower shifting at loc 178 by N F Railway | NLDC |
| 337 | 400kv NSLG-Purnea Ckt-1 | 20-01-2017 | 07.00 hrs | 22-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | |
| 338 | 220 KV BINAGURI-Siliguri-2 | 20-01-2017 | 09:30 HRS | 20-01-2017 | 17:30 HRS | ODB | ER-II/KOL | CB Ovrhauling | |
| 339 | 220 KV ICT#2 MAIN CB at Durgapur | 20-01-2017 | 11:00 | 20-01-2017 | 12:00 | ODB | ER-II/KOL | CB Overhauling-trasfer load to transfer bus & protection testing | DVC |
| 340 | At BKTPP: 315 MVA IBT 1 | 20-01-2017 | 08:00 | 22-01-2017 | 08:00 | ODB | WBSETCL | Winter Maintenance | |
| 341 | 400 KV Farakka - Malda 2 | 20-01-2017 | 09:30hrs | 20-01-2017 | 14:00 hrs | ODB | NTPC | Main bay CT testing (Line may remain in service) | |
| 342 | 400 KV Jsr-Mejia | 21.01.2017 | 09:30 | 21.01.2017 | 17:30 | ODB | ER-I | LA REPLACEMENT WORK | |
| 343 | 220 KV BUS # 1 AT SUBHASGRAM | 21-01-2017 | 08:30 | 21-01-2017 | 17:00 | ODB | ER-II/KOL | Line Isolator Bph Moving Arm replacement | |
| 344 | 400 KV MAIN BUS-COUPLER AT CHANDWA | 21-01-2017 | 10:00 | 21-01-2017 | 16:00 | ODB | ER-I | FOR CHECKING AND REPLACING OF THE RELIEF VALVES OF | |
| 345 | 400 KV LAKHISARAI - BSF CKT. II | 21-01-2017 | 09:00 | 21-01-2017 | 18:00 | ODB | ER-I | FOR INSULATOR REPLACEMENT FOUND DEFECTIVE AFTER PID | |
| 346 | 220 KV BINAGURI- Siliguri-1 | 21-01-2017 | 09:30 HRS | 21-01-2017 | 17:30 HRS | ODB | ER-II/KOL | CB Ovrhauling | |
| 347 | 160 MVA ICT-II (BHEL MAKE) AT BIRPARA | 21-01-2017 | 07:00 Hrs | 21-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | AMP of the Bay,ICT,220 KV Main Bus -II Replacement. During the said S/D period 220 KV BRP- NSLG- I is proposed to be charged through 220 KV TBC . | WEST BENGAL |
| 348 | 220 KV BRP- NSLG-II | 21-01-2017 | 07:00 Hrs | 21-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | AMP of the Bay,ICT,220 KV Main Bus -II Replacement. During | |
| 349 | 400 KV Farakka - Kahalgaon 3 | 21-01-2017 | 09:30hrs | 21-01-2017 | 14:00 hrs | ODB | NTPC | Main bay CT testing (Line may remain in service) | |
| 350 | 220KV BUS-II AT GAYA S/S | 22-01-2017 | 08:00 | 22-01-2017 | 18:00 | ODB | ER-I | FOR KHIJARSARAI BAY COMMISIONING WORK | BIHAR |
| 351 | 400 KV PATNA - BALIA - III | 22-01-2017 | 08:00 | 30-01-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF PORCELAIN INSULATOR WITH POLYMER INSULATOR | NLDC |
| 352 | 220 KV BINAGURI- Siliguri-1 | 22-01-2017 | 09:30 HRS | 22-01-2017 | 17:30 HRS | ODB | ER-II/KOL | CB Ovrhauling | |
| 353 | 160 MVA ICT-I (ALSTOM Make) AT BIRPARA | 22-01-2017 | 07:00 Hrs | 22-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | AMP of the Bay,ICT,220 KV Main Bus -II Replacement. During the above S/D period 220 KV BRP- NSLG-II and 220 KV BRP- | WEST BENGAL |

| | | | | | | | | | |
|-----|--|------------|-----------|------------|-----------|-----|--------------|---|--------------|
| 354 | 220 KV BRP- NSLG-I | 22-01-2017 | 07:00 Hrs | 22-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | AMP of the Bay,ICT,220 KV Main Bus -II Replacement.During | |
| 355 | 400 KV Farakka- Sagardighi S/c | 22-01-2017 | 09:00 | 22-01-2017 | 17:00 | ODB | ER-II/KOL | AMP for 2016-17 | WEST BENGAL |
| 356 | MAITHON-DURGAPUR LINE I&II (Both Circuit) | 22-01-2017 | 09:00 | 10-02-2017 | 18:00 | OCB | ER-II/KOL | Errection, Dismantalling, of tower at loc no 35 & Stringing and destringing of conductor from loc no 33 to 36. for Diversion of Maithon-Durgapur line. | NLDC |
| 357 | 132 KV Main Bus AT MALDA | 22-01-2017 | 09:00 Hrs | 22-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | Jumper Change | WEST BENGAL |
| 358 | 765KV 240MVAR Bus Reactor-I at Sundergarh | 23-01-2017 | 09:00 | 24-01-2017 | 18:00 | ODB | ER-II/ODISHA | FOR RTV COATING OF 765KV BUSHING | NLDC |
| 359 | SIPAT-II MAIN BAY-424 AT RANCHI | 23-01-2017 | 10:00 | 23-01-2017 | 17:30 | ODB | ER-I | FOR AMP WORK. | |
| 360 | 400KV KAHALGAON - MAITHAN CKT. # I & II | 23-01-2017 | 09:00 | 25-01-2017 | 18:00 | OCB | ER-I | FOR POWER LINE CROSSING OF EXISTING 400 KV KAHALGAON - MAITHAN (LOC. NO.: 17 TO 18) LINE, 400 KV MAINTENANACE ACTIVITIES OF BAY EQUIPMENT | |
| 361 | 400KV KANIHA-MEERAMUNDALI-I | 23-01-2017 | 09:00 | 25-01-2017 | 17:00 | OCB | NTPC/KANIHA | | |
| 362 | 765KV L/R OF 765 KV NEW RANCHI DHARAMJAYGARH -2 AT AT NEW RANCHI | 23-01-2017 | 09:00 | 25-01-2017 | 18:00 | ODB | ER-I | RTV COATING OF TRENCH MAKE BUSHING | NLDC |
| 363 | MAIN BAY OF 765KV/400 KV ICT-2 (706) AT NEW RANCHI | 23-01-2017 | 08:00 | 23-01-2017 | 18:00 | ODB | ER-I | BAY AMP | |
| 364 | 400 KV LAKHISARAI- KAHALGAON-1 | 23-01-2017 | 18:00 | 23-01-2017 | 18:10 | ODB | ER-I | FOR TAKING LINE REACTOR IN SERVICE | |
| 365 | 400kv NSLG-Purnea Ckt-2 | 23-01-2017 | 07.00 hrs | 25-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | |
| 366 | 400 kv New Siliguri- Bongaigaon -I and II | 23-01-2017 | 08:00 Hrs | 31-01-2017 | 17:00 Hrs | OCB | ER-II/KOL | Erection, Stringing in Span of 466-467, and 467-468.(Railway | NLDC |
| 367 | 315MVA ICT# IV and 400 KVHaldia Line #1 | 24-01-2017 | 08:30 | 24-01-2017 | 17:00 | ODB | ER-II/KOL | Protection checking of ICT#4 , Haldia Lin #1 and ICT#4 S/d is | WEST BENGAL |
| 368 | 400kv Jsr Maithon | 24.01.2017 | 09:30 | 24.01.2017 | 17:30 | ODB | ER-I | LA REPLACEMENT WORK | |
| 369 | Tie Bay-711 of 765KV Sundergarh-Angul Line# I at | 24-01-2017 | 09:00 | 30-01-2017 | 18:00 | ODB | ER-II/ODISHA | REFURBISHMENT OF 765KV CB FOR DCRM | |
| 370 | 400KV BUS-I AT RANCHI | 24-01-2017 | 08:00 | 24-01-2017 | 18:00 | ODB | ER-I | CVT REPLACEMENT OF BUS-I. | |
| 371 | 765KV BUS-I AT GAYA S/S | 24-01-2017 | 10:00 | 25-01-2017 | 18:00 | ODB | ER-I | FOR ISOLATOR RECTIFICATION WORK | NLDC |
| 372 | MAIN BAY OF 765KV B/R-2 (707) AT NEW RANCHI | 24-01-2017 | 08:00 | 24-01-2017 | 18:00 | ODB | ER-I | BAY AMP | |
| 373 | 400 kv LAKHISARAI- KAHALGAON-2 | 24-01-2017 | 18:00 | 24-01-2017 | 18:10 | ODB | ER-I | FOR TAKING LINE REACTOR IN SERVICE | |
| 374 | 400 KV BUS -2 AT PATNA | 24-01-2017 | 09:00 | 25-01-2017 | 17:00 | ODB | ER-I | AMP WORK | |
| 375 | 400KV BONGAIGAON - NEW SILIGURI CIRCUIT # 3 | 24-01-2017 | 07:00 | 27-01-2017 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE IN-AP10/0 -AP11/0 | NLDC |
| 376 | 220 KV ICT#2 MAIN CB at Durgapur | 24-01-2017 | 11:00 | 24-01-2017 | 12:00 | ODB | ER-II/KOL | Final commissioning of CB | |
| 377 | 765KV 240MVAR Bus Reactor-II at Sundergarh | 25-01-2017 | 09:00 | 26-01-2017 | 18:00 | ODB | ER-II/ODISHA | FOR RTV COATING OF 765KV BUSHING | NLDC |
| 378 | 765KV BUS-II AT GAYA S/S | 25-01-2017 | 10:00 | 25-01-2017 | 18:00 | ODB | ER-I | FOR ISOLATOR RECTIFICATION WORK | NLDC |
| 379 | MAIN BAY OF 765KV B/R-1 (710) AT NEW RANCHI | 25-01-2017 | 08:00 | 25-01-2017 | 18:00 | ODB | ER-I | BAY AMP | |
| 380 | 220kv SLG-Kishanganj Ckt-1 | 26-01-2017 | 07.00 hrs | 26-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | |
| 381 | 400kv Jsr Chaibasa-I | 26.01.2017 | 09:30 | 26.01.2017 | 17:30 | ODB | ER-I | LA REPLACEMENT WORK | |
| 382 | 400 KVHaldia Line #2 | 27-01-2017 | 08:30 | 27-01-2017 | 17:00 | ODB | ER-II/KOL | Attending Hotspot of line Isolator | WEST BENGAL |
| 383 | 765KV 240MVAR Angul Line Reactor-I at Sundergarh | 27-01-2017 | 09:00 | 28-01-2017 | 18:00 | ODB | ER-II/ODISHA | FOR RTV COATING OF 765KV BUSHING | NLDC |
| 384 | 400 KV BUS-I of NTPC Farakka | 27-01-2017 | 09:00 | 28-01-2017 | 17:00 | ODB | ER-II/KOL | Bus-I connection for newly constrctued 400 KV Farakka-Rajarhat bay and 400 KV Farakka- Purnea bay (under ERSS-V). BUS bar-I stability test has to also carried out. | NTPC FARAKKA |
| 385 | 220 KV BUS-II with Bus Coupler | 27-01-2017 | 09:00 Hrs | 27-01-2017 | 17:00 Hrs | ODB | ER-II/KOL | Jumper Change | |
| 386 | At BKTPP: 315 MVA IBT 2 | 27-01-2017 | 08:00 | 29-01-2017 | 08:00 | ODB | WBSETCL | Winter Maintenance | |
| 387 | 400 KV Farakka - Durgapur 2 | 27-01-2017 | 09:30hrs | 27-01-2017 | 17:30 hrs | ODB | NTPC | Relay testing | |
| 388 | 400kv Jsr-chaibasa-2 | 28.01.2017 | 09:30 | 28.01.2017 | 13:30 | ODB | ER-I | ISOLATOR BLADE REPLACEMENT WORK | |
| 389 | 220kv Bus Coupler Bay AT SUBHASGRAM | 28-01-2017 | 08:30 | 28-01-2017 | 17:00 | ODB | ER-II/KOL | AMP | |
| 390 | 220kv SLG-Kishanganj Ckt-2 | 28-01-2017 | 07.00 hrs | 28-01-2017 | 17.00 hrs | ODB | ER-II/KOL | Insulator replacement in crossings | |
| 391 | 400 KV Farakka - Kahalgaon 4 | 28-01-2017 | 09:30hrs | 28-01-2017 | 14:00 hrs | ODB | NTPC | Tie bay CT testing (Line may remain in service) | |

| | | | | | | | | | |
|-----|--|------------|----------|------------|-----------|-------|--------------|---|-------------|
| 392 | 400 KV BUS-II of NTPC Farakka | 29-01-2017 | 09:00 | 30-01-2017 | 17:00 | ODB | ER-II/KOL | Bus-II connection for newly constructed 400 KV Farakka-Rajarhat bay and 400 KV Farakka- Purnea bay (under ERSS-V). BUS bar-II stability test has to also carried out. | |
| 393 | 400KV BARH PATNA LINE 4 MAIN BAY, BAY NO- | 29-01-2017 | 09:30hrs | 30-01-2017 | 18:00 hrs | OCB | NTPC | PM Job of Bay & Relay test. | |
| 394 | 400KV BARH PATNA LINE 4 TIE BAY, BAY NO-11 | 29-01-2017 | 09:30hrs | 30-01-2017 | 18:00 hrs | OCB | NTPC | PM Job of Bay & Relay test. | |
| 395 | 400kV Jeerat-Baharampur | 30-01-2017 | 08:30 | 30-01-2017 | 17:00 | ODB | ER-II/KOL | AMP (Bay + Protection System) | WEST BENGAL |
| 396 | 765KV 240MVAR Angul Line Reactor-II at | 30-01-2017 | 09:00 | 31-01-2017 | 18:00 | ODB | ER-II/ODISHA | FOR RTV COATING OF 765KV BUSHING | NLDC |
| 397 | 400 KV BONG- NEW SLG-1&2- LINE | 31-01-2017 | 07:00 | 02-02-2017 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE IN-AP18/0 -AP19/0 | NLDC |
| 398 | 400 kV PATNA - BALIA - IV | 02-02-2017 | 08:00 | 10-02-2017 | 17:00 | ODB | ER-I | FOR REPLACEMENT OF PORCELAIN INSULATOR WITH | NLDC |
| 399 | 400 KV BONG- NEW SLG-1&2- LINE | 07-02-2017 | 07:00 | 10-02-2017 | 16:00 | ODB | ER-II/KOL | 800KV LILO work- Crossing at LINE IN-AP12/0 -AP13/0 | NLDC |
| 400 | 400KV KANIHA-MEERAMUNDALI-I | 31-01-2017 | 09:00 | 02-02-2017 | 17:00 | OCB | NTPC/KANIHA | MAINTENANACE ACTIVITIES OF BAY EQUIPMENT | |
| 401 | At BKTPP: Jerat bay | 31-12-2016 | 09:00 | 11-01-2017 | 09:00 | OCB | WBSETCL | Winter Maintenance | |
| 402 | 400 kV Jeypore-Gazuwaka-1 | 12-01-2017 | 09:00 | 12-01-2017 | 13:00 | Daily | PGCIL | AMP | SRPC |
| 403 | 400 kV Jeypore-Gazuwaka-2 | 13-01-2017 | 09:00 | 13-01-2017 | 13:00 | Daily | PGCIL | AMP | SRPC |
| 404 | 765 kV Fathepur-Varanasi | 19-01-2017 | 09:00 | 19-01-2017 | 18:00 | Daily | PGCIL | RTV Coating of Bushing , NGR Bypassing of reactor , AMP | NRPC |
| 405 | 765 kV Ballia-Varanasi | 11-01-2017 | 08:00 | 11-01-2017 | 18:00 | Daily | PGCIL | For taking the 80MVAR Spare Reactor in service at Varanasi | NRPC |