

**EASTERN REGIONAL LOAD DESPATCH CENTRE  
KOLKATA**

**TRANSMISSION ELEMENTS OUTAGE APPROVED IN 129TH OCC MEETING OF ERPC**

| Sr. No | NAME OF THE ELEMENTS                                   | DATE       | TIME      | DATE       | TIME      | REMARKS | S/D availed BY | Reason   | SUBJECT TO CONSENT FROM AGENCY  |
|--------|--|------------|-----------|------------|-----------|---------|----------------|--|---|
| 1      | 401 KV RENGALI - INDRAVATI S/C                         | 18-01-2017 | 07:00     | 31-01-2017 | 17:00     | ODB     | ER-II/Odisha   | For carrying out PID Test  | Will be allowed after restoration of tie bay of reactor and Indravati line. |
| 2      | 400KV PATNA-BARH-1 & 400KV KHLG-BARH-2                 | 18-01-2017 | 08:00     | 19-01-2017 | 17:00     | ODB     | ER-I           | FOR INSULATOR REPLACEMENT WITH POLYMER IN THE MULTI CKT PORTION AT BARH  |   |
| 3      | 400kv MAITHON-MEJIA-II                                 | 18-01-2017 | 10:00     | 18-01-2017 | 17:00     | ODB     | ER-II/ KOLKATA | INSULATOR DISC BROKEN LOC 12   | DVC   |
| 4      | 400 KV TALCHER - ROURKELA CKT-II                       | 19-01-2017 | 07:00     | 20-01-2017 | 17:00     | ODB     | ER-II/Odisha   | For replacement of porcelain Insulator with polymer Long rod in in major crossings like National High way, powerline crossings.  | NLDC  |
| 5      | 400KV PATNA-BARH-2 & 400KV KHLG-BARH-1                 | 20-01-2017 | 08:00     | 21-01-2017 | 17:00     | ODB     | ER-I           | FOR INSULATOR REPLACEMENT WITH POLYMER IN THE MULTI CKT PORTION AT BARH  |   |
| 6      | 315MVA ICT#2 at Baripada                               | 20-01-2017 | 09:00     | 27-01-2017 | 18:00     | OCB     | ER-II/Odisha   | REPLACEMENT OF 03NOS 400KV HV BUSHING  | OPTCL   |
| 7      | A/R of 400kv Rengali- Indravati line at Bolangir       | 20-01-2017 | 08.00     | 10-02-2017 | 18.00     | ODB     | ER-II/Odisha   | For Online PID testing for Rengali-Indravati line under Bolangir TLO   |   |
| 8      | 220kV Bus Coupler Bay ( Bay no- 204) at Rengali        | 20-01-2017 | 08.00Hrs. | 20-01-2017 | 17.00Hrs. | ODB     | ER-II/Odisha   | AMP work   |   |
| 9      | 400KV PATNA-BARH-3                                     | 20-01-2017 | 08:00     | 24-01-2017 | 17:00     | ODB     | ER-I           | FOR INSULATOR REPLACEMENT WITH POLYMER   |   |
| 10     | 400 KV BUS-II of NTPC Farakka                          | 20-01-2017 | 10:00     | 20-01-2017 | 16:00     | OCB     | ER-II/ KOLKATA | For conducting Bus bar-II stability test for integration of bay-12 after upgradation of bay-12 from 2000A to 3150A rating under ERSS-XIII projects.  |   |
| 11     | 220KV TBC Bay ( Bay- 203) at Rengali                   | 21-01-2017 | 10.00Hrs. | 21-01-2017 | 17.00Hrs. | ODB     | ER-II/Odisha   | AMP work   |   |
| 12     | 400 KV TALCHER - ROURKELA CKT-I                        | 21-01-2017 | 07:00     | 30-01-2017 | 17:00     | ODB     | ER-II/Odisha   | For carrying out PID Test  | NLDC  |
| 13     | 400 KV Talcher- Angul at Talcher                       | 21-01-2017 | 08:00     | 21-01-2017 | 17:00     | ODB     | ER-II/Odisha   | Replacement of polymer pilot with glass insulator to strengthen line jumpers to prevent swing during high speed wind to avoid tripping in future.  |   |
| 14     | 400 KV TALCHER - ROURKELA CKT-II                       | 22-01-2017 | 07:00     | 27-01-2017 | 17:00     | ODB     | ER-II/Odisha   | For carrying out PID Test  | NLDC  |
| 15     | 400KV Bay 401 02 at Bolangir                           | 22-01-2017 | 09.00     | 05-02-2017 | 18.00     | ODB     | ER-II/Odisha   | For Construction works of Bay extension & Reactor package  |   |
| 16     | 220KV Kalayaneswari line-2                             | 22-01-2017 | 10:00     | 22-01-2017 | 17:30     | ODB     | ER-II/ KOLKATA | Replacement of Hivelm isolator Arm of Line isolator  | DVC   |
| 17     | 400KV Talcher-Tie Bay ( Bay- 406) at Rengali           | 23-01-2017 | 08.00Hrs. | 23-01-2017 | 17.00Hrs. | ODB     | ER-II/Odisha   | AMP work   |   |
| 18     | Bay-08 at NTPC Farakka                                 | 23-01-2017 | 10:00     | 24-01-2017 | 18:00     | ODB     | ER-II/ KOLKATA | Testing and commissioning of CSD of CB of Bay-08   |   |
| 19     | 220KV Kalayaneswari line-1                             | 23-01-2017 | 10:00     | 23-01-2017 | 17:30     | ODB     | ER-II/ KOLKATA | Replacement of Hivelm isolator Arm of Line isolator  | DVC   |
| 20     | 400/220kv 315MVA ICT-I at Rengali                      | 24-01-2017 | 08.00Hrs. | 07-02-2017 | 17.00Hrs. | OCB     | ER-II/Odisha   | Complete overhauling of ICT-I at Rengali S/s.  |   |
| 21     | 400 KV BARH-GORAKHPUR-I                                | 24-01-2017 | 08:00     | 26-01-2017 | 18:00     | ODB     | ER-I           | JUMPER TIGHTINF,REPLACEMENT OF SPACER DAMPER AND AMP WORK  | NLDC  |
| 22     | 220KV SLG-Kishanganj Ckt-II                            | 24-01-2017 | 9.00 hrs  | 24-01-2017 | 17.00 hrs | ODB     | ER-II/ KOLKATA | PG clamp removal   |   |
| 23     | (220KV Bus Coupler )204 Bay at Bolangir                | 25-01-2017 | 09.00     | 25-01-2017 | 18.00     | ODB     | ER-II/Odisha   | AMP Work   |   |
| 24     | 400 KV Chaibasa #2 Main Bay at Rourkela (Bay No.- 409) | 25-01-2017 | 09:00     | 25-01-2017 | 18:00     | ODB     | ER-II/Odisha   | AMP Work.  |   |
| 25     | 400KV PATNA-BARH-4                                     | 25-01-2017 | 08:00     | 29-01-2017 | 17:00     | ODB     | ER-I           | FOR INSULATOR REPLACEMENT WITH POLYMER   |   |
| 26     | 400KV Mejia-III line                                   | 25-01-2017 | 10:00     | 25-01-2017 | 18:00     | ODB     | ER-II/ KOLKATA | Replacement of Hivelm isolator Arm of Tie bay isolator of Mejia-III side   | DVC   |
| 27     | 400kV Angul- Bolangir Line                             | 26-01-2017 | 07:00     | 26-01-2017 | 18:00     | ODB     | ER-II/Odisha   | Improvement & strengthening of line jumpers including replacement of conventional insulator with polymer insulator to prevent swing during high speed wind to avoid tripping in future & improvement of line availability&reliability. |   |
| 28     | 132kv Kurseong - Rangit                                | 26-01-2017 | 9.00 hrs  | 27-01-2017 | 17.00 hrs | ODB     | ER-II/ KOLKATA | Insulator fitting  | WBSETCL   |
| 29     | 132KV Siliguri - Meli                                  | 26-01-2017 | 9.00 hrs  | 27-01-2017 | 17.00 hrs | ODB     | ER-II/ KOLKATA | Insulator fitting  |   |
| 30     | 315MVA ICT-II at Bolangir                              | 27-01-2017 | 09.00     | 27-01-2017 | 18.00     | ODB     | ER-II/Odisha   | AMP Work   | OPTCL   |
| 31     | 400kV Indravati Tie Bay(Bay no- 411) at Rengali        | 27-01-2017 | 09.00Hrs. | 28-01-2017 | 17.00Hrs. | OCB     | ER-II/Odisha   | Erection of Breaker for Bay extension work.  |   |
| 32     | 400 KV Chaibasa #1 Main Bay at Rourkela (Bay No.- 416) | 27-01-2017 | 09:00     | 27-01-2017 | 18:00     | ODB     | ER-II/Odisha   | AMP Work.  |   |
| 33     | 200 MVA ICT-1 AT LAKHISARAI                            | 27-01-2017 | 08:00     | 30-01-2017 | 18:00     | ODB     | ER-I           | CONSTRUCTION OF FIREWALL   | BIHAR   |

|    |  |            |           |            |           |           |                |  |         |
|----|--|------------|-----------|------------|-----------|-----------|----------------|--|---------|
| 34 | 400 KV NRNC-CHANDWA CKT-1  | 27-01-2017 | 09:00     | 28-01-2017 | 17:00     | ODB       | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS  | NLDC    |
| 35 | 400 KV BARH-GORAKHPUR-II   | 27-01-2017 | 08:00     | 29-01-2017 | 18:00     | ODB       | ER-I           | JUMPER TIGHTINF,REPLACEMENT OF SPACER DAMPER AND AMP WORK  | NLDC    |
| 36 | 220 kV GAYA-DEHRI-I  | 27-01-2017 | 08:00     | 29-01-2017 | 18:00     | ODB       | ER-I           | FOR KHIJARSARAI BAY COMMISSIONING WORK   | BIHAR   |
| 37 | 400KV BUS-II AT PATNA  | 27-01-2017 | 09:00     | 28-01-2017 | 17:00     | ODB       | ER-I           | Construction works: for commissioning of 405 bay   |         |
| 38 | 315 MVA ICT-I (Muzaffarpur S/S)  | 27-01-2017 | 10:00     | 27-01-2017 | 16:00     | ODB       | ER-I           | AMP  | BIHAR   |
| 39 | 220 KV Bus Coupler CB  | 27-01-2017 | 9.00 hrs  | 30-01-2017 | 17.00 hrs | ODB       | ER-II/ KOLKATA | CB Overhauling   |         |
| 40 | 400 KV BUS-I with Bay no-08 of NTPC Farakka  | 27-01-2017 | 10:00     | 28-01-2017 | 17:00     | ODB       | ER-II/ KOLKATA | BUS bar-I stability test has to also carried out. To charge Bay no-09, jumper of Bay no-08 is to be opened and to be connected with isolator of Bay no-09. <b>Then only, Bus reactor#1 with Bay no-09 will come into service. Moreover, de-stringing of strung BUS over bay- 09 is also to be carried out.</b> |         |
| 41 | 220 Kv Ranchi - Hatia - I  | 27-01-2017 | 09:00     | 28-01-2017 | 17:00     | ODB       | JHARKHAND      | Repalcement of damaged conductor   |         |
| 42 | 220 Kv Ranchi - Hatia - I  | 29-01-2017 | 09:00     | 30-01-2017 | 17:00     | ODB       | JHARKHAND      | Repalcement of damaged conductor   |         |
| 43 | 500MVA ICT # 3 at Baripada   | 28-01-2017 | 09:00     | 28-01-2017 | 18:00     | ODB       | ER-II/Odisha   | ON LINE OPERATION OF CSD   |         |
| 44 | 400KV Pandiabili-Mendhasal # 1 & 400KV Baripada-Pandiabili (Both lines together) at Pandiabili | 28-01-2017 | 07:00     | 28-01-2017 | 18:00     | ODB       | ER-II/Odisha   | <b>Improvement &amp; strengthening of line jumpers to prevent swing during high speed wind to avoid tripping in future &amp; improvement of line availability&amp;reliability.</b>   | OPTCL   |
| 45 | 400KV Bay 402 at Bolangir  | 28-01-2017 | 09:00     | 28-01-2017 | 18.00     | ODB       | ER-II/Odisha   | AMP Work   |         |
| 46 | 132 KV TRANSFER BUS AT PURNEA  | 28-01-2017 | 09:00     | _____      |           | PERMANENT | ER-I           | PERMANENT REMOVAL OF TRANSFER BUS IS REQUIRED FOR GIS BUILDING AND ASSOCIATED CIVIL THE 132 KV TRANSFER BUS AND 132 KV TBC BAY WILL BE UNDER PERMANENT S/D FOR CONSTRUCTION WORK OF AIS TO GIS CONVERSION OF ALL LINE AND ICT 132 KV BAYS  | BIHAR   |
| 47 | 132 KV PURNEA - PURNEA BSPTCL#3 OF BSPTCL  | 28-01-2017 | 09:00     | 30-01-2017 | 17:00     | ODB       | ER-I           | TO FACILITATE WORK OF DISMANTLING OF LM TOWER TO FACILITATE CONSTRUCTION OF GIS BUS DUCT AND SF6 TO AIR BUSHING FOUNDATIONS.   | BIHAR   |
| 48 | 132KV Siliguri - Kurseong  | 28-01-2017 | 9.00 hrs  | 28-01-2017 | 17.00 hrs | ODB       | ER-II/ KOLKATA | Jumper Cone Repairing / Insulator fitting  | WBSETCL |
| 49 | 400 KV Talcher- Meramundali at Talcher   | 29-01-2017 | 08:00     | 29-01-2017 | 17:00     | ODB       | ER-II/Odisha   | <b>Replacement of polymer pilot with glass insulator to strengthen line jumpers to prevent swing during high speed wind to avoid tripping in future.</b>   | OPTCL   |
| 50 | 125MVAR BUS REACTOR at Baripada  | 29-01-2017 | 09:00     | 29-01-2017 | 18:00     | ODB       | ER-II/Odisha   | ON LINE OPERATION OF CSD   |         |
| 51 | 400KV Pandiabili-Mendhasal # 2 & 400KV Pandiabili-Duburi (Both lines together) at Pandiabili   | 29-01-2017 | 07:00     | 29-01-2017 | 18:00     | ODB       | ER-II/Odisha   | <b>Improvement &amp; strengthening of line jumpers to prevent swing during high speed wind to avoid tripping in future &amp; improvement of line availability&amp;reliability.</b>   | OPTCL   |
| 52 | 400kv Maithon-JAMSHEDPUR   | 29-01-2017 | 10:00     | 29-01-2017 | 13:00     | ODB       | ER-II/ KOLKATA | AMP work for line Bay.   |         |
| 53 | 400 KV Meramundali- Angul-II at Talcher  | 30-01-2017 | 08:00     | 30-01-2017 | 17:00     | ODB       | ER-II/Odisha   | <b>Replacement of polymer pilot with glass insulator to strengthen line jumpers to prevent swing during high speed wind to avoid tripping in future.</b>   | OPTCL   |
| 54 | 400KV Keonjhar Liine Main Bay(401) at Baripada   | 30-01-2017 | 09:00     | 01-02-2017 | 18:00     | OCB       | ER-II/Odisha   | SF6 GAS LEAKAGE RECTIFICATION WORK IN 40152CB  |         |
| 55 | 400KV Baripada-Duburi at Pandiabili  | 30-01-2017 | 07:00     | 30-01-2017 | 18:00     | ODB       | ER-II/Odisha   | <b>Improvement &amp; strengthening of line jumpers to prevent swing during high speed wind to avoid tripping in future &amp; improvement of line availability&amp;reliability.</b>   | OPTCL   |
| 56 | 765KV side of ICT#2 Main Bay (707) at Angul  | 30-01-2017 | 09:00     | 01-02-2017 | 18:00     | OCB       | ER-II/Odisha   | FOR DCRM REFURBISHMENT OF CB.  | NLDC    |
| 57 | 400kV Rengali-Talcher-I Line at Rengali  | 30-01-2017 | 11.00Hrs. | 30-01-2017 | 15.00Hrs. | ODB       | ER-II/Odisha   | Retrofitting of DP Relay   |         |
| 58 | 400 KV Chaibasa #1 & Sundargarh #1 Tie Bay at Rourkela (Bay No.- 417)                          | 30-01-2017 | 09:00     | 30-01-2017 | 18:00     | ODB       | ER-II/Odisha   | AMP Work.  |         |
| 59 | 400 KV NRNC-CHANDWA CKT-2  | 30-01-2017 | 09:00     | 31-01-2017 | 17:00     | ODB       | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS  | NLDC    |
| 60 | 400 KV BIHARSHARIF-MUZAFFARPUR -II   | 30-01-2017 | 08:00     | 31-01-2017 | 18:00     | ODB       | ER-I           | JUMPER TIGHTINF,REPLACEMENT OF SPACER DAMPER AND AMP WORK  | NLDC    |
| 61 | 400 KV CHAIBASA-KHARAGPUR CKT -1   | 30-01-2017 | 09:00     | 30-01-2017 | 17:00     | ODB       | ER-I           | FOR COMMISSIONING OF CSD IN TIE CB   |         |
| 62 | 765 kV GAYA-VARANASI-I   | 30-01-2017 | 10:00     | 30-01-2017 | 18:00     | ODB       | ER-I           | FOR HV BUSHING REPLACEMENT WORK IN Y-PHASE LINE REACTOR  | NLDC    |
| 63 | 400KV BUS-1 AT JAMSHEDPUR  | 30-01-2017 | 09:30     | 30-01-2017 | 17:30     | ODB       | ER-I           | BAY CONSTRUCTION WORK FOR 3rd ICT  |         |
| 64 | 400KV NPRN-MALDA-2   | 30-01-2017 | 10:00     | 30-01-2017 | 18:00     | ODB       | ER-I           | REPLACEMENT OF Y PH CVT AT NPRN  | NLDC    |
| 65 | 315 MVA ICT-II (Muzaffarpur S/S)   | 30-01-2017 | 10:00     | 30-01-2017 | 16:00     | ODB       | ER-I           | AMP  | BIHAR   |
| 66 | 401 RANCHI MAITHON-I MAIN BAY AT RANCHI  | 30-01-2017 | 10:00     | 30-01-2017 | 17:30     | ODB       | ER-I           | AMP Work   |         |

|     |   |            |           |            |           |     |                |   |           |
|-----|---|------------|-----------|------------|-----------|-----|----------------|---|-----------|
| 67  | TIE BAY OF 315 MVA ICT-II AND FUTURE BAY AT PATNA                   | 30-01-2017 | 09:30     | 30-01-2017 | 17:30     | ODB | ER-I           | AMP work  |           |
| 68  | 400KV Angul- Meramundali Line-1                                     | 31-01-2017 | 07:00     | 31-01-2017 | 18:00     | ODB | ER-II/Odisha   | Improvement & strengthening of line jumpers to prevent swing during high speed wind to avoid tripping in future & improvement of line availability&reliability.   | OPTCL     |
| 69  | Tie Bay-708 of 765KV Sundergarh-Angul Line#III at Sundergarh        | 31-01-2017 | 08:00     | 03-02-2017 | 18:00     | OCB | ER-II/Odisha   | REFURBISHMENT OF 765KV CB FOR DCRM PROBLEM(CONSTRUCTIONAL DEFECT)   |           |
| 70  | 400KV Rengali-Talcher-II Line at Rengali                            | 31-01-2017 | 11.00Hrs. | 31-01-2017 | 15.00Hrs. | ODB | ER-II/Odisha   | Retrofitting of DP Relay  |           |
| 71  | 400 KV Rourkela - Sundargarh #2 Main Bay at Rourkela (Bay No.- 430) | 31-01-2017 | 09:00     | 31-01-2017 | 18:00     | ODB | ER-II/Odisha   | Checking of DC Earth Fault in TC-2 Circuit.   |           |
| 72  | 315 MVA ICT -3 AT BSF   | 31-01-2017 | 10:00     | 31-01-2017 | 18:00     | ODB | ER-I           | FOR AMP WORK OF ICT-3 & ASSOCIATED 220KV LINE BAY   | BIHAR     |
| 73  | 315 MVA ICT-II AT RANCHI  | 31-01-2017 | 10:00     | 31-01-2017 | 17:30     | ODB | ER-I           | AMP work  | Jharkhand |
| 74  | 400KV BUS-2 AT JAMSHEDPUR   | 31-01-2017 | 09:30     | 31-01-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK FOR 3rd ICT   |           |
| 75  | Main Bay BSF-1 AT LAKHISARAI  | 31-01-2017 | 10:00     | 31-01-2017 | 14:00     | ODB | ER-I           | AMP WORK  |           |
| 76  | MAIN BAY OF 500 MVA ICT-I AT PATNA                                  | 31-01-2017 | 09:30     | 31-01-2017 | 17:30     | ODB | ER-I           | AMP work  |           |
| 77  | 315 MVA ICT-I at Subhasgram   | 01-02-2017 | 08:30     | 01-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | 220KV Bph LA replacement  | WBSETCL   |
| 78  | 765 KV Bus-I AT NEW RANCHI  | 01-02-2017 | 08:00     | 01-02-2017 | 18:00     | ODB | ER-I           | AMP WOK   | NLDC      |
| 79  | 400 KV CHAIBASA-KHARAGPUR CKT -2                                    | 01-02-2017 | 09:00     | 01-02-2017 | 17:00     | ODB | ER-I           | FOR COMMISSIONING OF CSD IN TIE CB  |           |
| 80  | 220 KV ARA-KHAGAUL-I  | 01-02-2017 | 10:00     | 04-02-2017 | 18:00     | OCB | ER-I           | CB Overhauling AT BSPTCL KHAGAUL END(LINE OUTAGE REQUIRED DUE TO NON COMMISSIONING OF TBC AT KHAGAUL END)   | BIHAR     |
| 81  | 400 KV D/C Muzaffarpur-Gorakhpur Ckt-I                              | 01-02-2017 | 10:00     | 01-02-2017 | 16:00     | ODB | ER-I           | AMP   | NLDC      |
| 82  | MAIN BAY OF ICT-1 (CWD60-Q52) AT SSRM                               | 01-02-2017 | 10:00     | 01-02-2017 | 18:00     | ODB | ER-I           | AMP WORK  |           |
| 83  | Tie BAY OF MTN-I & ICT-I AT RANCHI                                  | 01-02-2017 | 10:00     | 01-02-2017 | 17:00     | ODB | ER-I           | AMP Work  |           |
| 84  | 400KV Berhampore Bheramara Ckt-I Line(404 bay)                      | 01-02-2017 | 09:00     | 01-02-2017 | 18.00Hrs  | ODB | ER-II/ KOLKATA | Replacement of Line isolator PAD (89L), AMP   | NLDC      |
| 85  | 220KV NSLG-BRP Ckt-I & II   | 01-02-2017 | 9.00 hrs  | 10-02-2017 | 17.00 hrs | OCC | ER-II/ KOLKATA | PG clamp removal / Tower shifting at loc 178 by N F Railway   | NLDC      |
| 86  | 400KV NSLG-Rangpo Ckt-II  | 01-02-2017 | 9.00 hrs  | 01-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Hot spot rectification  |           |
| 87  | 400kV Bus-I   | 01-02-2017 | 07.00 hrs | 04-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | To facilitate hot spot rectification in Purnea-3 & 4 Line and Rangpo-1 & 2 Line   |           |
| 88  | 400 KV Maithon Line1  | 01-02-2017 | 10:00     | 01-02-2017 | 13:00     | ODB | ER-II/ KOLKATA | Wave trap jumper rectification  |           |
| 89  | 400kv MEJIA-JAMSHEDPUR  | 01-02-2017 | 10:30     | 01-02-2017 | 16:00     | ODB | ER-II/ KOLKATA | CONDUCTOR STRAND DAMAGE LOC 15-16 (LILO SIDE)   | DVC       |
| 90  | 220kV S'gram-CESC-2   | 02-02-2017 | 08:30     | 02-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP   | WBSETCL   |
| 91  | 220KV BALASORE LINE-I BAY-201 AT BARIPADA                           | 02-02-2017 | 09:00     | 02-02-2017 | 18:00     | OCB | ER-II/Odisha   | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM   |           |
| 92  | 765KV Bus Reactor-1 Main Bay (712) at Angul                         | 02-02-2017 | 09:00     | 04-02-2017 | 18:00     | OCB | ER-II/Odisha   | FOR DCRM REFURBISHMENT OF CB.   | NLDC      |
| 93  | ICT-I (3x 105 MVA) at Jeypore                                       | 02-02-2017 | 10:30:00  | 02-02-2017 | 11:30:00  | ODB | ER-II/Odisha   | For changing ICT-I combination form Unit-I,III, IV to Unit-I,II and III for charging Unit-II after Overhauling works  | OPTCL     |
| 94  | 125 MVAR Bus Reactor at Rourkela                                    | 02-02-2017 | 09:00     | 02-02-2017 | 18:00     | ODB | ER-II/Odisha   | Removal of Control & Power Cable for testing at third party Lab by M/s Siemens.   |           |
| 95  | 132 KV PURNEA - PURNEA BSPTCL#3 LINE                                | 02-02-2017 | 09:00     | 02-02-2017 | 17:00     | ODB | ER-I           | TO FACILITATE WORK OF DISMANTLING OF LM TOWER TO FACILITATE CONSTRUCTION OF GIS BUS DUCT AND SF6 TO AIR BUSHING FOUNDATIONS.  | BIHAR     |
| 96  | 160 MVA ICT-2 AT PURNEA   | 02-02-2017 | 10:00     | 02-02-2017 | 17:00     | ODB | ER-I           | To facilitate Construction of GIS bus duct & SF6 to air bushing foundation.<br>Dismantling of 132 kv Transfer Bus section which is above KISHANGANJ & ICT #2 bay<br>1.Removing of jumpers of each phase from Transfer Bus to tandem isolator.<br>2.Dismantling of Transfer bus Conductors of that particular section. | BIHAR     |
| 97  | 400 KV VNS - BSF -. I   | 02-02-2017 | 09:00     | 02-02-2017 | 18:00     | ODB | ER-I           | FOR BALANCE BUS SPLIT WORK AT BSF   | NLDC      |
| 98  | 400KV KHALGAON - MAITHAN CKT. # I & II                              | 02-02-2017 | 09:00     | 04-02-2017 | 18:00     | OCB | ER-I           | FOR POWER LINE CROSSING OF EXISTING 400 KV KHALGAON - MAITHAN D/C LINE, 400 KV FARAKKA - KHALGAON LINE( CKT.1,2, 3 & 4 ) AND 400 KV KHLG - BARH -1 & 2 BY CONSTRUCTION OF NEW LINE FOR SHIFTING OF 400KV KHALGAON - BANKA LINE UNDER BUS SPLIT SCHEME AT NTPC SWITCHYARD, KHALGAON.                                   | NLDC      |
| 99  | 220KV BUS-I AT GAYA   | 02-02-2017 | 10:00     | 02-02-2017 | 18:00     | ODB | ER-I           | FOR KHIJARSARAI BAY COMMISSIONING WORK  |           |
| 100 | 400KV JAMSHEDPUR-TISCO  | 02-02-2017 | 09:30     | 02-02-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK FOR 3rd ICT   |           |

|     |   |            |           |            |           |     |                |   |           |
|-----|---|------------|-----------|------------|-----------|-----|----------------|---|-----------|
| 101 | 400 KV D/C Muzaffarpur-Gorakhpur Ckt-II                       | 02-02-2017 | 10:00     | 02-02-2017 | 16:00     | ODB | ER-I           | AMP   | NLDC      |
| 102 | TIE BAY OF BSF-1 & ICT-1 AT LAKHISARAI                        | 02-02-2017 | 10:00     | 02-02-2017 | 14:00     | ODB | ER-I           | AMP WORK  |           |
| 103 | MAIN BAY OF 400KV BSF-LAKHISARAI-1(413 BAY) AT BSF            | 02-02-2017 | 10:00     | 08-02-2017 | 18:00     | OCB | ER-I           | OVERHAULING OF PNEUMATIC DRIVE MECHANISM OF CKT BREAKER   |           |
| 104 | 400KV NSLG-Rangpo Ckt-I                                       | 02-02-2017 | 9.00 hrs  | 02-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Hot spot rectification  |           |
| 105 | 400KV Tala-I L/R along with Line                              | 02-02-2017 | 9.00 hrs  | 02-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Repeat tan delta of 400KV R Phase Bushing & Neutral Bushing Replacement / oil leakage arrest.   | NLDC      |
| 106 | WBSETCL 220kV Bus Section-1                                   | 02-02-2017 | 9.00 hrs  | 04-02-2017 | 17.00 hrs | OCC | ER-II/ KOLKATA | CB Overhauling  | WBSETCL   |
| 107 | 400KV Tala Ckt-I  | 02-02-2017 | 9.00 hrs  | 02-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Relay retrofitting  | NLDC      |
| 108 | 400KV NSLG-Bangaigaon Ckt-1                                   | 02-02-2017 | 07.00 hrs | 05-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings  | NLDC      |
| 109 | 400KV NSLG-Tala Ckt-4   | 02-02-2017 | 07.00 hrs | 02-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings  | NLDC      |
| 110 | 220 KV DVC#1  | 02-02-2017 | 11:00     | 02-02-2017 | 12:00     | ODB | ER-II/ KOLKATA | CB Overhauling-trasfer load to transfer bus & protection testing  |           |
| 111 | 400KV MTN Mejia-I Line  | 02-02-2017 | 10:00     | 02-02-2017 | 13:00     | ODB | ER-II/ KOLKATA | AMP Work  | DVC       |
| 112 | 400 KV Subhasgram- Jeerat Line                                | 03-02-2017 | 08:30     | 03-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | LA & Jumper replacemnet at jeerat end.  | WBSETCL   |
| 113 | 220KV BALASORE LINE-II BAY-202 AT BARIPADA                    | 03-02-2017 | 09:00     | 03-02-2017 | 18:00     | OCB | ER-II/Odisha   | <b>NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM</b>  |           |
| 114 | ICT-II at Jeypore   | 03-02-2017 | 09:30:00  | 03-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For Replacement of 390 kv LAs with 336 kv LAs   | OPTCL     |
| 115 | 400 KV Rourkela - Raigarh #2 at Rourkela                      | 03-02-2017 | 09:00     | 03-02-2017 | 09:30     | ODB | ER-II/Odisha   | For isolating Line Reactor for AMP Work.  | NLDC      |
| 116 | 400 KV Rourkela - Raigarh #2 Line Reactor (419LR) at Rourkela | 03-02-2017 | 09:30     | 03-02-2017 | 17:30     | ODB | ER-II/Odisha   | Line Reactor AMP Work.  | NLDC      |
| 117 | 400 KV Rourkela - Raigarh #2                                  | 03-02-2017 | 17:30     | 03-02-2017 | 18:00     | ODB | ER-II/Odisha   | For connecting Line Reactor after its AMP Work.   | NLDC      |
| 118 | 132 KV PURNEA KISHANGANJ LINE                                 | 03-02-2017 | 11:00     | 03-02-2017 | 13:00     | ODB | ER-I           | To facilitate Construction of GIS bus duct & SF6 to air bushing foundation.<br>Dismantling of 132 kv Transfer Bus section which is above KISHANGANJ & ICT #2 bay<br>1.Removing of jumpers of each phase from Transfer Bus to tandem isolator.<br>2.Dismantling of Transfer bus Conductors of that particular section. | BIHAR     |
| 119 | 765 KV Bus-II AT NEW RANCHI                                   | 03-02-2017 | 08:00     | 03-02-2017 | 18:00     | ODB | ER-I           | AMP WOK   | NLDC      |
| 120 | 400 KV VNS - BSF -- 2   | 03-02-2017 | 09:00     | 03-02-2017 | 18:00     | ODB | ER-I           | FOR BALANCE BUS SPLIT WORK AT BSF   | NLDC      |
| 121 | 220KV BUS-II AT GAYA  | 03-02-2017 | 08:00     | 03-02-2017 | 18:00     | ODB | ER-I           | FOR KHIJARSARAI BAY COMMISSIONING WORK  |           |
| 122 | 315MVA ICT-2 AT JAMSHEDPUR                                    | 03-02-2017 | 09:30     | 03-02-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK FOR 3rd ICT   | Jharkhand |
| 123 | 400 KV D/C Muzaffarpur-Purnea Ckt-I                           | 03-02-2017 | 10:00     | 03-02-2017 | 16:00     | ODB | ER-I           | AMP   | NLDC      |
| 124 | MAIN BAY OF ICT-2 (CWD70-Q52) AT SSRM                         | 03-02-2017 | 10:00     | 03-02-2017 | 18:00     | ODB | ER-I           | AMP WORK  |           |
| 125 | 400KV Berhampore Sagardighi Ckt-I Line(407 bay)               | 03-02-2017 | 09:00     | 03-02-2017 | 16.00Hrs  | ODB | ER-II/ KOLKATA | Fixing Alingment of isolator (89A) and AMP  | NLDC      |
| 126 | 220KV NSLG-SLG Ckt-II   | 03-02-2017 | 9.00 hrs  | 03-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Relay retrofitting / AMP  |           |
| 127 | 400KV NSLG-Kishanganj-2 Line                                  | 03-02-2017 | 07.00 hrs | 03-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Hot spot rectification  |           |
| 128 | 400 KV Subhasgram- Jeerat Line                                | 04-02-2017 | 08:30     | 04-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP at Jeerat End.  | WBSETCL   |
| 129 | 220 KV BUS COUPLER BAY-203 AT BARIPADA                        | 04-02-2017 | 09:00     | 04-02-2017 | 18:00     | OCB | ER-II/Odisha   | <b>NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM</b>  |           |
| 130 | Tie Bay-705 of 765KV B/R-II & 765KV ICT-II at Sundergarh      | 04-02-2017 | 08:00     | 08-02-2017 | 18:00     | OCB | ER-II/Odisha   | REFURBISHMENT OF 765KV CB FOR DCRM PROBLEM(CONSTRUCTIONAL DEFECT)   |           |
| 131 | 765/400 kv ICT-I AT GAYA                                      | 04-02-2017 | 10:00     | 04-02-2017 | 18:00     | ODB | ER-I           | AMP WORK  | NLDC      |
| 132 | MAIN BAY OF ICT-1 AT LAKHISARAI                               | 04-02-2017 | 10:00     | 04-02-2017 | 14:00     | ODB | ER-I           | AMP WORK  |           |
| 133 | 400KV NSLG-Kishanganj-1 Line                                  | 04-02-2017 | 07.00 hrs | 04-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Hot spot rectification  |           |
| 134 | 220 KV DVC#1  | 04-02-2017 | 11:00     | 04-02-2017 | 12:00     | ODB | ER-II/ KOLKATA | Final commissioning of CB   |           |
| 135 | BNG-IV L/R at New Siliguri                                    | 05-02-2017 | 9.00 hrs  | 05-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | AMP   |           |
| 136 | WBSETCL 220kV Bus Section-2                                   | 05-02-2017 | 9.00 hrs  | 07-02-2017 | 17.00 hrs | OCC | ER-II/ KOLKATA | CB Overhauling  | WBSETCL   |
| 137 | 220KV NSLG-BRP Ckt-II   | 05-02-2017 | 9.00 hrs  | 05-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Relay retrofitting / AMP  |           |
| 138 | 400KV NSLG-Tala Ckt-1   | 05-02-2017 | 07.00 hrs | 05-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings  | NLDC      |

|     |   |            |           |            |           |     |                |  |         |
|-----|---|------------|-----------|------------|-----------|-----|----------------|--|---------|
| 139 | 400 KV Farakka- Kahalgaon 3 & 4                       | 05-02-2017 | 09:00     | 22-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | Erection of tower at Loc no. 3/0, 5/0 & 5A/0 of LILO of 400 KV Rajarhat- Purnea D/c at Farakka and stringing between Loc 2/0-3/0-4/0 & (5/0 to 5A/0).<br><b>Special Remarks :</b><br>Distance between 3/0 to 400 KV FKK-Kahalgaon -3&4 line is very less. Span between 5/0 to 5A/0 is 80 mtrs,so distance between tower 5/0 & 5A/0 to 400 KV Farakka - Kahalgaon line is even less. Tower height of 3/0 is 75 mtrs (DD+25) while those of 5/0 and 5A/0 is approx 80 mtrs (DD+25 Mtrs with 4 m RC). So, during erection of 3/0, 5/0, 5A/0 , shutdown is required for passing stay / guy wires /ropes etc. | NLDC    |
| 140 | 400kv MAITHON-RIGHTBANK-I                             | 05-02-2017 | 10:30     | 05-02-2017 | 16:00     | ODB | ER-II/ KOLKATA | INSULATOR DISC BROKEN LOC 14   |         |
| 141 | 220KV SLG-KISHANGANJ-I                                | 05-02-2017 | 9000      | 05-02-2017 | 16:00 Hrs | ODB | ER-II/ KOLKATA | AMP WORK & ISOLATOR REMOTE OPERATION CHECKING FROM NTAMC   |         |
| 142 | 315 MVA ICT-V at Subhasgram                           | 06-02-2017 | 08:30     | 06-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP & PSD commissioning  | WBSETCL |
| 143 | 220 KV SIDE OF 315 MVA ICT-II, BAY-204 at Baripada    | 06-02-2017 | 09:00     | 06-02-2017 | 18:00     | OCB | ER-II/Odisha   | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM  |         |
| 144 | 400KV side of ICT#1 Main Bay (401) at Angul           | 06-02-2017 | 09:00     | 06-02-2017 | 15:00     | ODB | ER-II/Odisha   | AMP WORK   |         |
| 145 | 765/400KV, 1500MVA ICT-II at Sundergarh               | 06-02-2017 | 08:00     | 06-02-2017 | 18:00     | ODB | ER-II/Odisha   | Commissioning of CSD in 400KV side of ICT-II   | NLDC    |
| 146 | 400 KV Talcher #1 Tie Bay (Bay No.- 405) at Rourkela  | 06-02-2017 | 09:00     | 06-02-2017 | 14:00     | ODB | ER-II/Odisha   | Overhauling of Air Compressor of 40552 CB.   |         |
| 147 | 220 kv NEW PURNEA -PURNEA #1                          | 06-02-2017 | 09:00     | 06-02-2017 | 17:00     | ODB | ER-I           | AMP WORK OF BAY EQUIPMENTS   |         |
| 148 | 765KV B/R -2 AT NEW RANCHI                            | 06-02-2017 | 08:00     | 08-02-2017 | 18:00     | ODB | ER-I           | RTV COATING OF TRENCH MAKE BUSHING RECOMMENDED BY MANUFACTURER DUE TO DESIGN DEFICIENCY  | NLDC    |
| 149 | 765/400 kv ICT-II AT GAYA                             | 06-02-2017 | 10:00     | 06-02-2017 | 18:00     | ODB | ER-I           | AMP WORK   | NLDC    |
| 150 | 220 kv ARA-KHAGAU-LI                                  | 06-02-2017 | 10:00     | 09-02-2017 | 18:00     | OCB | ER-I           | CB Overhauling AT BSPTCL KHAGAU END(LINE OUTAGE REQUIRED DUE TO NON COMMISSIONING OF TBC AT KHAGAU END)  | BIHAR   |
| 151 | 400KV JAMSHEDPUR-MAITHON                              | 06-02-2017 | 09:30     | 06-02-2017 | 17:30     | ODB | ER-I           | AMP work   |         |
| 152 | 400 KV D/C Muzaffarpur-Purnea Ckt-II                  | 06-02-2017 | 10:00     | 06-02-2017 | 16:00     | ODB | ER-I           | AMP  | NLDC    |
| 153 | Main Bay KHG-2 AT LAKHISARAI                          | 06-02-2017 | 10:00     | 06-02-2017 | 14:00     | ODB | ER-I           | AMP WORK   |         |
| 154 | 400 KV RANCHI-RGP-I MAIN BAY AT RANCHI                | 06-02-2017 | 10:00     | 06-02-2017 | 17:30     | ODB | ER-I           | AMP Work   |         |
| 155 | MAIN BAY OF 125MVAR B/R-2(BAY 418) AT NPRN            | 06-02-2017 | 10:00     | 06-02-2017 | 18:00     | ODB | ER-I           | AMP WORK   |         |
| 156 | Main Bay (403 bay) of Berhampore -Jeerat Line         | 06-02-2017 | 09:00     | 06-02-2017 | 16:00Hrs  | ODB | ER-II/ KOLKATA | Checking of wiring and operation of Breaker (52CB) from SCADA and AMP  |         |
| 157 | 400KV NSLG-Bangaigaon Ckt-2                           | 06-02-2017 | 07.00 hrs | 10-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings   | NLDC    |
| 158 | 220 KV BRP-Malbase S/C                                | 06-02-2017 | 08:00 Hrs | 11-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | CLR Insulator Replacement  | NLDC    |
| 159 | 400 KV New Siliguri-New Purnea # I                    | 06-02-2017 | 09:00 Hrs | 06-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing  |         |
| 160 | 500MVA ICT-I at Maithon                               | 06-02-2017 | 09:30     | 06-02-2017 | 17:30     | ODB | ER-II/ KOLKATA | Leakage arresting work   | DVC     |
| 161 | 220 KV BUS-I with Bus Coupler                         | 06-02-2017 | 09:00     | 06-02-2017 | 14:00     | ODB | ER-II/ KOLKATA | Jumper Change  |         |
| 162 | 220KV SLG-KISHANGANJ-II                               | 06-02-2017 | 9000      | 06-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | CB COMPRESSOR REPLACEMENT &AMP WORK, ISOLATOR REMOTE OPERATION CHECKING FROM NTAMC   |         |
| 163 | 132KV RANGIT-KURSEAONG & Rangit-Rangpo Line           | 06-02-2017 | 08:00     | 06-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | For repairing of STUB at Leg C of Tower no. 24/DC+0 and replacement of buckled/bend leg members and sag correction of both circuits  | WBSETCL |
| 164 | 400kv SgTPP-Parulia #2                                | 06-02-2017 | 07:00     | 06-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance   |         |
| 165 | 220 KV SIDE OF 315 MVA ICT-I, BAY-208 at Baripada     | 07-02-2017 | 09:00     | 07-02-2017 | 18:00     | OCB | ER-II/Odisha   | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY. FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM  |         |
| 166 | 400kv Bolangir Line & ICT#1 TIE Bay (402) at Angul    | 07-02-2017 | 09:00     | 07-02-2017 | 15:00     | ODB | ER-II/Odisha   | AMP WORK   |         |
| 167 | 765/400KV, 1500MVA ICT-I at Sundergarh                | 07-02-2017 | 08:00     | 07-02-2017 | 18:00     | ODB | ER-II/Odisha   | Charging of 33KV auxiliary Transformer and commissioning of CSD in 400KV side of ICT-I   | NLDC    |
| 168 | ICT-II Main Bay (418) at Jeypore                      | 07-02-2017 | 09:30:00  | 07-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For AMP works  | OPTCL   |
| 169 | 400KV ICT-II Tie Bay at Keonjhar                      | 07-02-2017 | 09:00     | 07-02-2017 | 18:00     | ODB | ER-II/Odisha   | For AMP Works  |         |
| 170 | 400 KV Talcher #1 Main Bay (Bay No.- 406) at Rourkela | 07-02-2017 | 09:00     | 07-02-2017 | 14:00     | ODB | ER-II/Odisha   | Overhauling of Air Compressor of 40652 CB.   |         |
| 171 | 220 kv NEW PURNEA -PURNEA # 2                         | 07-02-2017 | 09:00     | 07-02-2017 | 17:00     | ODB | ER-I           | AMP WORK OF BAY EQUIPMENTS   |         |
| 172 | 400 KV KHG - LAKHISARAI - I                           | 07-02-2017 | 09:00     | 07-02-2017 | 18:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATOR WITH POLYMER.   |         |
| 173 | 315 MVA , 400/220 KV ICT-2 AT SSRM                    | 07-02-2017 | 10:00     | 07-02-2017 | 18:00     | ODB | ER-I           | for AMP of ICT-2 & 220 KV side bay   | BIHAR   |
| 174 | 400KV FARAKKA - KAHALGAON CKT. # III & IV             | 07-02-2017 | 09:00     | 09-02-2017 | 18:00     | OCB | ER-I           | FOR POWER LINE CROSSING OF EXISTING 400 KV KAHALGAON - MAITHAN D/C LINE, 400 KV FARAKKA - KAHALGAON LINE( CKT.1,2, 3 & 4 ) AND 400 KV KHLG - BARH -1 & 2 BY CONSTRUCTION OF NEW LINE FOR SHIFTING OF 400KV KAHALGAON - BANKA LINE UNDER BUS SPLIT SCHEME AT NTPC SWITCHYARD, KAHALGAON.  |         |

|     |   |            |           |            |           |     |                |  |         |
|-----|---|------------|-----------|------------|-----------|-----|----------------|--|---------|
| 175 | 132 KV BANKA(PG) - BANKA (BSPTCL)-I                         | 07-02-2017 | 11:00     | 07-02-2017 | 14:00     | ODB | ER-I           | AMP WORK   | BIHAR   |
| 176 | 765KV GAYA-BALLIA LINE                                      | 07-02-2017 | 09:00     | 07-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS  | NLDC    |
| 177 | 80 MVAR B/R AT RANCHI                                       | 07-02-2017 | 10:00     | 07-02-2017 | 17:30     | ODB | ER-I           | AMP work   |         |
| 178 | 400 KV BUS-II (Muzaffarpur S/S)                             | 07-02-2017 | 10:00     | 09-02-2017 | 16:00     | ODB | ER-I           | AMP  |         |
| 179 | TIE BAY OF KHG-2 & Bus Reactor AT LAKHISARAI                | 07-02-2017 | 10:00     | 07-02-2017 | 14:00     | ODB | ER-I           | AMP WORK   |         |
| 180 | MAIN BAY OF 400KV NPRN-MALDA-2(BAY 413) AT NPRN             | 07-02-2017 | 10:00     | 07-02-2017 | 16:00     | ODB | ER-I           | REPLACEMENT OF R & Y PH CT AT NPRN   |         |
| 181 | Maintenance work for 400KV ICT # 1 Barh                     | 07-02-2017 | 09:30hrs  | 11-02-2017 | 18:00 hrs | OCB | BARH           | PM Job of ICT # 1<br>Annual testing  |         |
| 182 | Maintenance work for 400KV Bay of ICT # 1, BAY No:04,05,06  | 07-02-2017 | 09:30hrs  | 11-02-2017 | 18:00 hrs | OCB | BARH           | PM Job of Bay & Relay test   |         |
| 183 | 220KV NSLG-BRP Ckt-I  | 07-02-2017 | 9:00 hrs  | 07-02-2017 | 17:00 hrs | ODB | ER-II/ KOLKATA | Relay retrofitting / AMP   |         |
| 184 | 400KV NSLG-Tala Ckt-2                                       | 07-02-2017 | 07:00 hrs | 07-02-2017 | 17:00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings   | NLDC    |
| 185 | 400 KV New Siliguri-New Purnea # I                          | 07-02-2017 | 09:00 Hrs | 07-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing  |         |
| 186 | 220 KV ICT#2 incommer                                       | 07-02-2017 | 11:00     | 07-02-2017 | 12:00     | ODB | ER-II/ KOLKATA | CB Overhauling-trasfer load to transfer bus & protection testing , Fixing of insulation sleeve                 |         |
| 187 | SgTPP:400kv bay of 315MVA ICT#1                             | 07-02-2017 | 07:00     | 07-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance   |         |
| 188 | 220KV S'gram-CESC-1   | 08-02-2017 | 08:30     | 08-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP  | WBSETCL |
| 189 | 220 KV SIDE OF 160 MVA ICT-I, BAY-209 at Baripada           | 08-02-2017 | 09:00     | 08-02-2017 | 18:00     | OCB | ER-II/Odisha   | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY.<br>FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM |         |
| 190 | 765KV side of ICT#1 Main Bay (704) at Angul                 | 08-02-2017 | 09:00     | 08-02-2017 | 17:00     | ODB | ER-II/Odisha   | AMP WORK   | NLDC    |
| 191 | 400 KV Talcher #2 Main Bay (Bay No.- 407) at Rourkela       | 08-02-2017 | 09:00     | 08-02-2017 | 14:00     | ODB | ER-II/Odisha   | Overhauling of Air Compressor of 40752 CB.   |         |
| 192 | 400 KV KHG - LAKHISARAI - 2                                 | 08-02-2017 | 09:00     | 08-02-2017 | 18:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATOR WITH POLYMER.   |         |
| 193 | 132 KV BANKA(PG) - BANKA (BSPTCL)-2                         | 08-02-2017 | 11:00     | 08-02-2017 | 14:00     | ODB | ER-I           | AMP WORK   | BIHAR   |
| 194 | 765KV GAYA-VARANASI-LINE                                    | 08-02-2017 | 09:00     | 09-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS  | NLDC    |
| 195 | 400KV JAMSHEDPUR-CHAIBASA-1                                 | 08-02-2017 | 09:30     | 08-02-2017 | 17:30     | ODB | ER-I           | AMP work   |         |
| 196 | TIE BAY OF 400 KV RNC-RAGHUNTHPUR-I AND ICT-II AT RANCHI    | 08-02-2017 | 10:00     | 08-02-2017 | 13:00     | ODB | ER-I           | AMP Work   |         |
| 197 | MAIN BAY OF 400KV NPRN-MALDA-2(BAY 413) AT NPRN             | 08-02-2017 | 10:00     | 08-02-2017 | 16:00     | ODB | ER-I           | REPLACEMENT OF B PH CT AT NPRN   |         |
| 198 | 400 KV New Siliguri-New Purnea # II                         | 08-02-2017 | 09:00 Hrs | 08-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing  |         |
| 199 | 400kv SgTPP-Baharampur #1                                   | 08-02-2017 | 07:00     | 08-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance   |         |
| 200 | 220KV S'gram-WBSETCL Line #2                                | 09-02-2017 | 08:30     | 09-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP  | WBSETCL |
| 201 | 220 KV SIDE OF 160 MVA ICT-II, BAY-210 at Baripada          | 09-02-2017 | 09:00     | 09-02-2017 | 18:00     | OCB | ER-II/Odisha   | NO OUTAGE LINE WILL REMAIN IN SERVICE THROUGH TBC BAY.<br>FOR OVERHAULING OF 220 KV CGL CB OPERATING MECHANISM |         |
| 202 | 765KV Sundargarh Line-2 & ICT#1 TIE Bay (705) at Angul      | 09-02-2017 | 09:00     | 09-02-2017 | 17:00     | ODB | ER-II/Odisha   | AMP WORK   | NLDC    |
| 203 | Tie Bay-702 of 765KV B/R-I & 765KV ICT-I at Sundergarh      | 09-02-2017 | 08:00     | 13-02-2017 | 18:00     | OCB | ER-II/Odisha   | REFURBISHMENT OF 765KV CB FOR DCRM PROBLEM(CONSTRUCTIONAL DEFECT)  |         |
| 204 | Gajuwaka-II Main Bay (413) at Jeypore                       | 09-02-2017 | 09:30:00  | 09-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For AMP works  | NLDC    |
| 205 | 400KV Baripada-BR Tie Bay at Keonjhar                       | 09-02-2017 | 09:00     | 09-02-2017 | 18:00     | ODB | ER-II/Odisha   | For AMP Works  |         |
| 206 | 50 MVAR Bus Reactor Main Bay (Bay No.- 422) at Rourkela     | 09-02-2017 | 09:00     | 09-02-2017 | 14:00     | ODB | ER-II/Odisha   | Overhauling of Air Compressor of 42252 CB.   |         |
| 207 | 220 KV MAIN BUS-1 AT PURNEA                                 | 09-02-2017 | 09:00     | 09-02-2017 | 17:00     | ODB | ER-I           | AMP WORK of 220 KV BUS -1 . NO POWER INTERRUPTION  |         |
| 208 | 765/400 KV ICT-I at New Ranchi S/S                          | 09-02-2017 | 09:00     | 11-02-2017 | 18:00     | ODB | ER-I           | RTV COATING OF TRENCH MAKE BUSHING RECOMMENDED BY MANUFACTURER DUE TO DESIGN DEFICIENCY                        | NLDC    |
| 209 | 400 KV LAKHISARAI - BSF -. I                                | 09-02-2017 | 09:00     | 09-02-2017 | 18:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATOR WITH POLYMER.   |         |
| 210 | 132 KV BANKA - SABAOUR CKT-I                                | 09-02-2017 | 11:00     | 09-02-2017 | 14:00     | ODB | ER-I           | AMP WORK   | BIHAR   |
| 211 | Main Bay OF Bus Reactor AT LAKHISARAI                       | 09-02-2017 | 10:00     | 09-02-2017 | 14:00     | ODB | ER-I           | AMP WORK   |         |
| 212 | MAIN BAY OF 400KV BSF-SASARAM-2(409 BAY) AT BSF             | 09-02-2017 | 10:00     | 16-02-2017 | 18:00     | OCB | ER-I           | OVERHAULING OF PNEUMATIC DRIVE MECHANISM OF CKT BREAKER  |         |
| 213 | Tie bay of ICT-1 & Future Daltonganj Line CWD60-Q50 AT SSRM | 09-02-2017 | 10:00     | 09-02-2017 | 18:00     | ODB | ER-I           | AMP WORK   |         |
| 214 | TIE BAY OF 400KV NPRN-MALDA-2(BAY 414) AT NPRN              | 09-02-2017 | 10:00     | 09-02-2017 | 16:00     | ODB | ER-I           | REPLACEMENT OF R & Y PH CT AT NPRN   |         |
| 215 | 220KV NSLG-SLG Ckt-I  | 09-02-2017 | 9:00 hrs  | 09-02-2017 | 17:00 hrs | ODB | ER-II/ KOLKATA | Relay retrofitting / AMP   |         |
| 216 | 400KV NSLG-Tala Ckt-3                                       | 09-02-2017 | 07:00 hrs | 09-02-2017 | 17:00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings   | NLDC    |
| 217 | 400 KV New Siliguri-New Purnea # II                         | 09-02-2017 | 09:00 Hrs | 09-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing  |         |
| 218 | 125MVAR Bus Reactor-1 at Maithon                            | 09-02-2017 | 09:30     | 11-02-2017 | 17:30     | OCB | ER-II/ KOLKATA | Leakage arresting work   |         |
| 219 | 220KV SLG-NSLG-I  | 09-02-2017 | 9000      | 09-02-2017 | 16:00 Hrs | ODB | ER-II/ KOLKATA | AMP WORK & ISOLATOR REMOTE OPERATION CHECKING FROM NTAMC   |         |

|     |  |            |           |            |           |     |                |  |         |
|-----|--|------------|-----------|------------|-----------|-----|----------------|--|---------|
| 220 | 400kv SgTPP-Baharampur #2                                    | 09-02-2017 | 07:00     | 09-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance   |         |
| 221 | 400KV 315MVA ICT#1 MAIN BAY (403) AT BARIPADA                | 10-02-2017 | 09:00     | 10-02-2017 | 18:00     | ODB | ER-II/Odisha   | AMP OF MAIN BAY  |         |
| 222 | 765KV Angul-Sundargarh Line-2 Main Bay (706) at Angul        | 10-02-2017 | 09:00     | 10-02-2017 | 17:00     | ODB | ER-II/Odisha   | AMP WORK   | NLDC    |
| 223 | Gajuwaka-I Main Bay(412) at Jeypore                          | 10-02-2017 | 09:30:00  | 10-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For AMP works  | NLDC    |
| 224 | 200 MVA ICT-2 AT LAKHISARAI                                  | 10-02-2017 | 08:00     | 14-02-2017 | 18:00     | ODB | ER-I           | CONSTRUCTION OF FIREWALL   | BIHAR   |
| 225 | 400 KV LAKHISARAI - BSF -. 2                                 | 10-02-2017 | 09:00     | 10-02-2017 | 18:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATOR WITH POLYMER.   |         |
| 226 | 132 KV BANKA - SABAOUR CKT-2                                 | 10-02-2017 | 11:00     | 10-02-2017 | 14:00     | ODB | ER-I           | AMP WORK   | BIHAR   |
| 227 | 400 KV GAYA-MAITHON-II & 400 KV GAYA-KODERMA-I               | 10-02-2017 | 09:00     | 11-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS  |         |
| 228 | 400KV JAMSHEDPUR-MEJIA                                       | 10-02-2017 | 09:30     | 10-02-2017 | 17:30     | ODB | ER-I           | AMP work   |         |
| 229 | 400 KV BUS-I (Muzaffarpur S/S)                               | 10-02-2017 | 10:00     | 11-02-2017 | 16:00     | ODB | ER-I           | AMP  |         |
| 230 | TIE BAY OF 400KV NPRN-MALDA-2(BAY 414) AT NPRN               | 10-02-2017 | 10:00     | 10-02-2017 | 16:00     | ODB | ER-I           | REPLACEMENT OF B PH CT AT NPRN   |         |
| 231 | Tala-2 L/R at New Siliguri                                   | 10-02-2017 | 07.00 hrs | 10-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | CSD Commissioning / Tan Delta in Variable Frequency  |         |
| 232 | 220KV Siliguri-Kishanganj # I                                | 10-02-2017 | 09:00 Hrs | 10-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | Loose span rectification   |         |
| 233 | 220 KV ICT#2 incommer  | 10-02-2017 | 11:00     | 10-02-2017 | 12:00     | ODB | ER-II/ KOLKATA | Final commissioning of CB  |         |
| 234 | 220KV SLG-NSLG-II  | 10-02-2017 | 9000      | 10-02-2017 | 16:00 Hrs | ODB | ER-II/ KOLKATA | <b>AMP WORK &amp; ISOLATOR REMOTE OPERATION CHECKING FROM NTAMC</b>  |         |
| 235 | 315 MVA ICT-II at Subhasgram                                 | 11-02-2017 | 08:30     | 11-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP  | WBSETCL |
| 236 | 400KV KHARAGPUR MAIN BAY (404) AT BARIPADA                   | 11-02-2017 | 09:00     | 11-02-2017 | 18:00     | ODB | ER-II/Odisha   | AMP OF MAIN BAY  |         |
| 237 | 400KV 125 MVAR Bus Reactor - 2 Main bay, Bay 416 AT SSRM     | 11-02-2017 | 10:00     | 11-02-2017 | 18:00     | ODB | ER-I           | AMP WORK   |         |
| 238 | Bangaigaon-III L/R at New Siliguri                           | 11-02-2017 | 07.00 hrs | 11-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Tan Delta in Variable Frequency  |         |
| 239 | 220KV Siliguri-Kishanganj # II                               | 11-02-2017 | 09:00 Hrs | 11-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | Loose span rectification   |         |
| 240 | 400kv SgTPP-Subhasgram line and line Reactor                 | 11-02-2017 | 07:00     | 11-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance   |         |
| 241 | 400kv Rengali- Indravati line at Bolangir                    | 12-02-2017 | 07.00     | 14-02-2017 | 18.00     | ODB | ER-II/Odisha   | For insulator replacement works for major crossing for 400KV Rengali-Indravati line under Bolangir TLO   |         |
| 242 | 125 MVAR Bus Reactor-I at New Siliguri                       | 12-02-2017 | 07.00 hrs | 12-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Tan Delta in Variable Frequency  |         |
| 243 | 160 MVA ICT-II (BHEL MAKE) at Birpara                        | 12-02-2017 | 07:00 Hrs | 12-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | AMP of the ICT,220 KV Main Bus -II conductor Replacement. During the said S/D period 220 KV BRP- NSLG- I is proposed to be charged through 220 KV TBC .                                      | WBSETCL |
| 244 | 220 KV BRP- NSLG-II  | 12-02-2017 | 07:00 Hrs | 12-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | AMP of the Bay,220 KV Main Bus -II conductor Replacement. During the said S/D period 220 KV BRP- NSLG- I is proposed to be charged through 220 KV TBC .                                      |         |
| 245 | 220kv S'gram-KLC Line  | 13-02-2017 | 08:30     | 13-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP  | WBSETCL |
| 246 | 765kv, 3x100MVAR Bus Reactor-1 at Angul                      | 13-02-2017 | 09:00     | 13-02-2017 | 17:00     | ODB | ER-II/Odisha   | AMP WORK   | NLDC    |
| 247 | 765/400 KV ICT-II at New Ranchi S/S                          | 13-02-2017 | 09:00     | 15-02-2017 | 18:00     | ODB | ER-I           | RTV COATING OF TRENCH MAKE BUSHING RECOMMENDED BY MANUFACTURER DUE TO DESIGN DEFICIENCY  | NLDC    |
| 248 | 400 KV CHANDWA-GAYA CKT-1                                    | 13-02-2017 | 09:00     | 14-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS  | NLDC    |
| 249 | 765/400 kv ICT-III AT GAYA                                   | 13-02-2017 | 10:00     | 13-02-2017 | 18:00     | ODB | ER-I           | AMP WORK   | NLDC    |
| 250 | 315 MVA ICT-II AT PATNA                                      | 13-02-2017 | 10:00     | 13-02-2017 | 18:00     | ODB | ER-I           | AMP work   | BIHAR   |
| 251 | 50MVAR B/R-1 AT JAMSHEDPUR                                   | 13-02-2017 | 09:30     | 13-02-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK  |         |
| 252 | 400 KV BUS-I (Muzaffarpur S/S)                               | 13-02-2017 | 10:00     | 13-02-2017 | 16:00     | ODB | ER-I           | AMP  |         |
| 253 | 80MVAR B/R MAIN BAY AT RANCHI                                | 13-02-2017 | 10:00     | 13-02-2017 | 17:30     | ODB | ER-I           | AMP work   |         |
| 254 | 125 MVAR Bus Reactor-II at New Siliguri                      | 13-02-2017 | 07.00 hrs | 13-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Tan Delta in Variable Frequency  |         |
| 255 | 160 MVA ICT-I (ALSTOM Make) at Birpara.                      | 13-02-2017 | 07:00 Hrs | 13-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | 220 KV Main Bus -II conductor Replacement. During the above S/D period 220 KV BRP- NSLG-II and 220 KV BRP- CHP-II will be alternately charged through TBC as per requirement.                | WBSETCL |
| 256 | 220 KV BRP- NSLG-I   | 13-02-2017 | 07:00 Hrs | 13-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | AMP of the Bay, 220 KV Main Bus -II Conductor Replacement.During the above S/D period 220 KV BRP- NSLG-II and 220 KV BRP- CHP-II will be alternately charged through TBC as per requirement. |         |
| 257 | 220KV Dalkhola-Kishanganj # I                                | 13-02-2017 | 09:00 Hrs | 13-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | Loose span rectification & Bay AMP work  |         |
| 258 | 220 KV BUS-II with Bus Coupler                               | 13-02-2017 | 09:00     | 13-02-2017 | 14:00     | ODB | ER-II/ KOLKATA | Jumper Change  |         |
| 259 | 160 MVA ICT-I at Siliguri                                    | 13-02-2017 | 9000      | 13-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | <b>NIFS Valve replacement work</b>   | WBSETCL |
| 260 | 220kv S'gram-Newtown Line                                    | 14-02-2017 | 08:30     | 14-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP & LA Replacement   | WBSETCL |
| 261 | 400kv Angul-GMR Line-1 Main Bay (427) at Angul               | 14-02-2017 | 09:00     | 14-02-2017 | 15:00     | ODB | ER-II/Odisha   | AMP WORK   |         |
| 262 | Main Bay-707 of 765KV Sundergarh-Angul Line#II at Sundergarh | 14-02-2017 | 08:00     | 17-02-2017 | 18:00     | OCB | ER-II/Odisha   | REFURBISHMENT OF 765KV CB FOR DCRM PROBLEM(CONSTRUCTIONAL DEFFECT)   |         |

|     |  |            |           |            |           |     |                |   |           |
|-----|--|------------|-----------|------------|-----------|-----|----------------|---|-----------|
| 263 | Indravati Line Main Bay(410) at Jeypore                            | 14-02-2017 | 09:30:00  | 14-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For AMP works   |           |
| 264 | 400KV RENGALI MAINBAY (403) at Indravati                           | 14-02-2017 | 09:00     | 14-02-2017 | 18:00     | ODB | ER-II/Odisha   | AMP work  |           |
| 265 | 400 KV BSF - BALIA - . I   | 14-02-2017 | 09:00     | 15-02-2017 | 18:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS   | NLDC      |
| 266 | 400 KV GAYA-MAITHON-I & 400 KV GAYA-KODERMA-II                     | 14-02-2017 | 09:00     | 15-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS   |           |
| 267 | 765KV BR-I AT GAYA   | 14-02-2017 | 10:00     | 14-02-2017 | 18:00     | ODB | ER-I           | AMP WORK  | NLDC      |
| 268 | 400 KV TIE BAY OF ICT-1 & 400KV CHAIBASA-JSR Ckt-1 AT CHAIBASA     | 14-02-2017 | 09:00     | 14-02-2017 | 17:00     | ODB | ER-I           | AMP WORK  |           |
| 269 | MAIN BAY OF 400 KV RANCHI-Maithan RB-II AT RANCHI                  | 14-02-2017 | 10:00     | 14-02-2017 | 17:30     | ODB | ER-I           | AMP Work  |           |
| 270 | MAIN BAY OF 400 KV PATNA-BALLIA-II AT PATNA                        | 14-02-2017 | 10:00     | 14-02-2017 | 18:00     | ODB | ER-I           | AMP work  |           |
| 271 | 315MVA ICT#1 at New Siliguri                                       | 14-02-2017 | 07.00 hrs | 14-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Tan Delta in Variable Frequency / 220kv Bay AMP   | WBSETCL   |
| 272 | 220 KV BRP- CHP-I and II   | 14-02-2017 | 07:00 Hrs | 14-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | Main Bus -II Conductor Replacement  | NLDC      |
| 273 | 220KV Dalkhola-Kishanganj # II                                     | 14-02-2017 | 09:00 Hrs | 14-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | Loose span rectification & Bay AMP work   |           |
| 274 | 125MVAR Bus Reactor-2 at Maithon                                   | 14-02-2017 | 09:30     | 14-02-2017 | 17:30     | ODB | ER-II/ KOLKATA | Leakage arresting work  |           |
| 275 | 400kv SgTTP-Farakka line   | 14-02-2017 | 07:00     | 14-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance  |           |
| 276 | 400KV Keonjhar Line at Baripada                                    | 15-02-2017 | 09:00     | 17-02-2017 | 18:00     | OCB | ER-II/Odisha   | Main 2 Relay Replacement work   |           |
| 277 | 400KV GMR Line-2 & Jindal Line-1 Tie Bay (429) at Angul            | 15-02-2017 | 09:00     | 15-02-2017 | 15:00     | ODB | ER-II/Odisha   | AMP WORK  |           |
| 278 | 400 KV CHANDWA-GAYA CKT-2  | 15-02-2017 | 09:00     | 16-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS   | NLDC      |
| 279 | 765 KV SASARAM-FATEHPUR LINE                                       | 15-02-2017 | 10:00     | 15-02-2017 | 18:00     | ODB | ER-I           | FOR MODIFICATION FROM QUAD CONDUCTOR ARRANGEMENT TO TWIN CONDUCTOR ARRANGEMENT OF JUMPER  | NLDC      |
| 280 | 400KV KAHALGAON BARH - 1 AND 2                                     | 15-02-2017 | 09:00     | 17-02-2017 | 18:00     | OCB | ER-I           | FOR POWER LINE CROSSING OF EXISTING 400 KV KAHALGAON - MAITHAN D/C LINE, 400 KV FARAKKA - KAHALGAON LINE( CKT.1,2, 3 & 4 ) AND 400 KV KHLG - BARH -1 & 2 BY CONSTRUCTION OF NEW LINE FOR SHIFTING OF 400KV KAHALGAON - BANKA LINE UNDER BUS SPLIT SCHEME AT NTPC SWITCHYARD, KAHALGAON. | NLDC      |
| 281 | 765KV BR - II AT GAYA  | 15-02-2017 | 10:00     | 15-02-2017 | 18:00     | ODB | ER-I           | AMP WORK  | NLDC      |
| 282 | 315MVA ICT-1 AT JAMSHEDPUR   | 15-02-2017 | 09:30     | 15-02-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK   | Jharkhand |
| 283 | 220KV BUS-2 AT NPRN  | 15-02-2017 | 10:00     | 15-02-2017 | 18:00     | ODB | ER-I           | AMP WORK  |           |
| 284 | TIE BAY OF 80MVAR BR & Future Line AT RANCHI                       | 15-02-2017 | 10:00     | 15-02-2017 | 18:00     | ODB | ER-I           | AMP Work  |           |
| 285 | 400 KV Bus Reactor # 1   | 15-02-2017 | 09:30hrs  | 15-02-2017 | 17:30 hrs | ODB | KAHALGAON      | CT replacement  |           |
| 286 | 220kv Bus-I  | 15-02-2017 | 07.00 hrs | 15-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Bus isolator hot spot rectification / CVT replacement   |           |
| 287 | 400KV NSLG-Rangpo Ckt-1  | 15-02-2017 | 07.00 hrs | 16-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings  |           |
| 288 | 315MVA ICT#2 at New Siliguri                                       | 15-02-2017 | 07.00 hrs | 15-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Tan Delta in Variable Frequency / 220kv Bay AMP   | WBSETCL   |
| 289 | 400kv NSLG-Rangpo Ckt-I  | 15-02-2017 | 9.00 hrs  | 16-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Sag adjustment  |           |
| 290 | 400KV Malda-New purnea # I   | 15-02-2017 | 09:00 Hrs | 15-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing   | NLDC      |
| 291 | 160 MVA ICT-II at Siliguri   | 15-02-2017 | 9000      | 15-02-2017 | 16:00 Hrs | ODB | ER-II/ KOLKATA | ICT-II & BAY AMP WORK   | WBSETCL   |
| 292 | SgTTP:400kv Main Bus#1   | 15-02-2017 | 07:00     | 15-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance  |           |
| 293 | 315 MVA ICT-III at Subhasgram                                      | 16-02-2017 | 08:30     | 16-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP & Overcurrent Relay Relay retrofit  | WBSETCL   |
| 294 | 400KV Angul-GMR Line-2 Main Bay (430) at Angul                     | 16-02-2017 | 09:00     | 16-02-2017 | 15:00     | ODB | ER-II/Odisha   | AMP WORK  |           |
| 295 | 765KV Sundergarh-Dharamjaygarh Line#I at Sundergarh                | 16-02-2017 | 08:00     | 16-02-2017 | 18:00     | ODB | ER-II/Odisha   | Polymer anchoring in Yphase Line Isolator   | NLDC      |
| 296 | Gazuwaka-I FSC   | 16-02-2017 | 09:30:00  | 16-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For AMP works   | NLDC      |
| 297 | 125 Mvar BUS RAEACTOR MAIN BAY (410) at Indravati                  | 16-02-2017 | 09:00     | 16-02-2017 | 18:00     | ODB | ER-II/Odisha   | AMP work  |           |
| 298 | 400kv Bus-I at Rengali   | 16-02-2017 | 09.00Hrs. | 16-02-2017 | 17.00Hrs. | ODB | ER-II/Odisha   | For erection of Beam structure of New Bay extension work at Rengali.  |           |
| 299 | 80 MVAR Bus Reactor AT LAKHISARAI                                  | 16-02-2017 | 08:00     | 19-02-2017 | 18:00     | ODB | ER-I           | CONSTRUCTION OF FIREWALL  |           |
| 300 | 765KV B/R -1 AT NEW RANCHI   | 16-02-2017 | 08:00     | 18-02-2017 | 18:00     | ODB | ER-I           | RTV COATING OF TRENCH MAKE BUSHING RECOMMENDED BY MANUFACTURER DUE TO DESIGN DEFICIENCY   | NLDC      |
| 301 | 400 KV BSF - BALIA - . 2   | 16-02-2017 | 09:00     | 17-02-2017 | 18:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS   | NLDC      |
| 302 | 220KV BUS-1 AT RAMCHANDRAPUR(JUSNL)                                | 16-02-2017 | 09:30     | 16-02-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK   |           |
| 303 | 400 KV TIE BAY OF ICT-2 & 400KV CBSA- RKL Ckt-1 AT CHAIBASA        | 16-02-2017 | 09:00     | 16-02-2017 | 17:00     | ODB | ER-I           | AMP WORK  |           |
| 304 | TIE BAY OF 400 KV PATNA-BARH-I AND 400 KV PATNA-BALLIA-II AT PATNA | 16-02-2017 | 10:00     | 16-02-2017 | 17:30     | ODB | ER-I           | AMP work  |           |
| 305 | 400 KV Fkk - Behrampore line                                       | 16-02-2017 | 09:30hrs  | 17-02-2017 | 17:30 hrs | ODB | FARAKKA        | Relay and Breaker testing.  |           |
| 306 | 400KV Malda-New purnea # I   | 16-02-2017 | 09:00 Hrs | 16-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing   | NLDC      |
| 307 | 765kv Bus Reactor-1 Main Bay (712) at Angul                        | 17-02-2017 | 09:00     | 17-02-2017 | 17:00     | ODB | ER-II/Odisha   | AMP WORK  | NLDC      |
| 308 | 765KV Sundergarh-Dharamjaygarh Line#II at Sundergarh               | 17-02-2017 | 08:00     | 17-02-2017 | 18:00     | ODB | ER-II/Odisha   | Polymer anchoring in Yphase Line Isolator   | NLDC      |



|     |  |            |           |            |           |     |                |   |           |
|-----|--|------------|-----------|------------|-----------|-----|----------------|---|-----------|
| 309 | ICT-I Main Bay(407) at Jeypore                                   | 17-02-2017 | 09:30:00  | 17-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For AMP works   | OPTCL     |
| 310 | 220KV BUS-2 AT RAMCHANDRAPUR(JUSNL)                              | 17-02-2017 | 09:30     | 17-02-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK   |           |
| 311 | TIE BAY OF 400KV BSF-SSRM-2 & BALIA-1(408 BAY) AT BSF            | 17-02-2017 | 10:00     | 24-02-2017 | 18:00     | OCB | ER-I           | OVERHAULING OF PNEUMATIC DRIVE MECHANISM OF CKT BREAKER   |           |
| 312 | 220KV Bus-II   | 17-02-2017 | 07.00 hrs | 17-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Bus isolator hot spot rectification   |           |
| 313 | 400KV NSLG-Rangpo Ckt-2  | 17-02-2017 | 07.00 hrs | 18-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings  |           |
| 314 | 400KV NSLG-Rangpo Ckt-II   | 17-02-2017 | 9.00 hrs  | 18-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Sag adjustment  |           |
| 315 | 400KV Malda-New purnea # II                                      | 17-02-2017 | 09:00 Hrs | 17-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing   | NLDC      |
| 316 | 400kv D/C Malda-Farakka Line-CKT-I                               | 17-02-2017 | 9000      | 17-02-2017 | 1600      | ODB | ER-II/ KOLKATA | To attend Punch point of M/s Sterlite   | NLDC      |
| 317 | 400 KV (Quad) Kishanganj-New Purnea # II                         | 17-02-2017 | 09:00     | 27-02-2017 | 17:00     | ODB | POWERLINK      | For changing 160KN Porcelain Insulator Strings by 160KN Polymer Insulator Strings at 54 Nos Tension/Angle towers between Tower no 300 Kishanganj (BR) and Purnea Tower no 449 Section in Ckt-2. |           |
| 318 | SgTTP:400kv Main Bus#2   | 17-02-2017 | 07:00     | 17-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance  |           |
| 319 | 220 KV BUS # 1   | 18-02-2017 | 08:30     | 18-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP   |           |
| 320 | Main Bay-715 of 765KV Sundergarh-Angul Line#II at Sundergarh     | 18-02-2017 | 08:00     | 22-02-2017 | 18:00     | OCB | ER-II/Odisha   | REFURBISHMENT OF 765KV CB FOR DCRM PROBLEM(CONSTRUCTIONAL DEFECT)   |           |
| 321 | 400KV Bus-II at Rengali  | 18-02-2017 | 09.00Hrs. | 18-02-2017 | 17.00Hrs. | ODB | ER-II/Odisha   | For erection of Beam structure of New Bay extension work at Rengali.  |           |
| 322 | 220KV TRANSFER BUS AT RAMCHANDRAPUR (JUSNL)                      | 18-02-2017 | 09:30     | 18-02-2017 | 17:30     | ODB | ER-I           | BAY CONSTRUCTION WORK   | Jharkhand |
| 323 | MAIN BAY OF 400 KV PATNA-BARH-I AT PATNA                         | 18-02-2017 | 10:00     | 18-02-2017 | 18:00     | ODB | ER-I           | AMP work  |           |
| 324 | 400KV Malda-New purnea # II                                      | 18-02-2017 | 09:00 Hrs | 18-02-2017 | 17:00 Hrs | ODB | ER-II/ KOLKATA | New Hardware fitting fixing   | NLDC      |
| 325 | 400kv D/C Malda-Farakka Line-CKT-I                               | 18-02-2017 | 9000      | 18-02-2017 | 1600      | ODB | ER-II/ KOLKATA | To attend Punch point of M/s Sterlite   | NLDC      |
| 326 | 400 KV Maithon-Meja  | 18-02-2017 | 09:00     | 18-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | For insulator replacement work.   | DVC       |
| 327 | 315MVA ICT# IV and 400 KV Haldia Line #1                         | 20-02-2017 | 08:30     | 20-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | Protection checking of ICT#4 , Haldia Lin #1 and ICT#4 S/d is required  | WBSETCL   |
| 328 | 765kv Line Reacto-1 Bay (706R) at Angul                          | 20-02-2017 | 09:00     | 20-02-2017 | 17:00     | ODB | ER-II/Odisha   | AMP WORK  | NLDC      |
| 329 | 400 kv Bus-I at Jeypore  | 20-02-2017 | 09:30:00  | 20-02-2017 | 13:30:00  | ODB | ER-II/Odisha   | For Relay Testing after Retrofitting of BusBar Protection System  |           |
| 330 | 400 kv Bus-II at Jeypore   | 20-02-2017 | 14:00:00  | 20-02-2017 | 18:00:00  | ODB | ER-II/Odisha   | For Relay Testing after Retrofitting of BusBar Protection System  |           |
| 331 | 400KV UHIEP-INDRAVATI MAIN BAY (412) at Indravati                | 20-02-2017 | 09:00     | 20-02-2017 | 18:00     | ODB | ER-II/Odisha   | AMP work ( During this S/D period there will be no power flow between PG-UIHEP line due to non availability of PG-UIHEP Tie Bay CB)   | OPTCL     |
| 332 | 400 kv LAKHISARAI-KHG CKT-1                                      | 20-02-2017 | 08:00     | 20-02-2017 | 08:10     | ODB | ER-I           | FOR TAKING L/R OUT OF SERVICE   |           |
| 333 | 50 MVAR L/R OF 400 kv LKR-KHG Line-1 AT LAKHISARAI               | 20-02-2017 | 08:00     | 23-02-2017 | 18:00     | OCB | ER-I           | CONSTRUCTION OF FIREWALL  |           |
| 334 | 160 MVA ICT-1 AT PURNEA  | 20-02-2017 | 10:00     | 20-02-2017 | 17:00     | ODB | ER-I           | For GIS Construction work   | BIHAR     |
| 335 | 765KV L/R OF 765 KV NEW RANCHI DHARAMJAYGARH -1 AT AT NEW RANCHI | 20-02-2017 | 08:00     | 22-02-2017 | 18:00     | ODB | ER-I           | RTV COATING OF TRENCH MAKE BUSHING RECOMMENDED BY MANUFACTURER DUE TO DESIGN DEFICIENCY   | NLDC      |
| 336 | 765 kv NRNC-DMG CKT-1  | 20-02-2017 | 09:00     | 21-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS AND FOR REPLACEMENT OF QUAD DROPPER INTO TWIN FOR CVT/LA AT NRNC  | NLDC      |
| 337 | 765KV GAYA-VARANASI-II LINE                                      | 20-02-2017 | 09:00     | 20-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS   | NLDC      |
| 338 | 500 MVA ICT-III (Muzaffarpur S/S)                                | 20-02-2017 | 10:00     | 24-02-2017 | 16:00     | OCB | ER-I           | For replacement of design defect of bushing during warranty period by manufacturer.   |           |
| 339 | 220KV SIDE ICT-II BAY AT RANCHI                                  | 20-02-2017 | 10:00     | 20-02-2017 | 17:30     | ODB | ER-I           | AMP work  | Jharkhand |
| 340 | 211 bay (220 KV side ICT-2 Main bay) AT PATNA                    | 20-02-2017 | 10:00     | 20-02-2017 | 15:00     | ODB | ER-I           | AMP work  |           |
| 341 | 400KV NSLG-Purnea Ckt-1  | 20-02-2017 | 07.00 hrs | 22-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings  |           |
| 342 | 400kv SgTTP-Parulia #1   | 20-02-2017 | 07:00     | 20-02-2017 | 16:00     | ODB | WBSETCL        | Winter Maintenance  |           |
| 343 | 765/400kv, 3*500MVA ICT#4 at Angul                               | 21-02-2017 | 09:00     | 21-02-2017 | 17:00     | ODB | ER-II/Odisha   | AMP WORK  | NLDC      |
| 344 | 220 kv Bus-I at Jeypore  | 21-02-2017 | 09:30:00  | 21-02-2017 | 13:30:00  | ODB | ER-II/Odisha   | For Relay Testing after Retrofitting of BusBar Protection System  | OPTCL     |
| 345 | 220 kv Bus-II at Jeypore   | 21-02-2017 | 14:00:00  | 21-02-2017 | 18:00:00  | ODB | ER-II/Odisha   | For Relay Testing after Retrofitting of BusBar Protection System  | OPTCL     |
| 346 | 400 KV BUS-I AT BANKA  | 21-02-2017 | 09:30     | 21-02-2017 | 17:30     | ODB | ER-I           | AMP WORK  |           |
| 347 | 80MVAR SIPAT L/R-II AT RANCHI                                    | 21-02-2017 | 10:00     | 21-02-2017 | 17:30     | ODB | ER-I           | AMP work  |           |
| 348 | 400 KV /132KV ICT # 1  | 21-02-2017 | 09:30hrs  | 24-02-2017 | 17:30 hrs | OCB | KAHALGAON      | CT replacement  |           |
| 349 | 220 KV MLD-DLK LINE-II at Malda                                  | 21-02-2017 | 09:00     | 21-02-2017 | 14:00     | ODB | ER-II/ KOLKATA | CT & CVT AMP  |           |
| 350 | 220kv Bus Coupler Bay  | 22-02-2017 | 08:30     | 22-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP   |           |

|     |   |            |           |            |           |     |                |  |           |
|-----|---|------------|-----------|------------|-----------|-----|----------------|--|-----------|
| 351 | 765kV Angul- Sundergarh Line-1                                    | 22-02-2017 | 07:00     | 23-02-2017 | 18:00     | ODB | ER-II/Odisha   | 1. Improvement & strengthening of line jumpers to prevent swing during high speed wind to avoid tripping in future & improvement of line availability&reliability.<br>2. Polymer anchoring at Angul and Sundargarh end.<br>3. Commissioning of NGR bypassing scheme at Angul and Sundargarh end. | NLDC      |
| 352 | 400KV JEYPORE-RENGALI TIE BAY (402) at Indravati                  | 22-02-2017 | 09:00     | 22-02-2017 | 18:00     | ODB | ER-II/Odisha   | AMP work (During this S/D period, there will be no power flow in Indravati- Jeypora line due to non availability of PG-UIHEP Tie Bay CB)   |           |
| 353 | 160 MVA ICT-3 AT PURNEA   | 22-02-2017 | 10:00     | 22-02-2017 | 17:00     | ODB | ER-I           | For GIS Construction work  | BIHAR     |
| 354 | 765 KV NRNC-DMG CKT-2   | 22-02-2017 | 09:00     | 23-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF INSULATORS DAMAGED BY MISCREANTS AND FOR REPLACEMENT OF QUAD DROPPER INTO TWIN FOR CVT/LA AT NRNC   | NLDC      |
| 355 | 400 KV BUS-II AT BANKA  | 22-02-2017 | 09:30     | 22-02-2017 | 17:30     | ODB | ER-I           | AMP WORK   |           |
| 356 | 220KV RANCHI-HATIA-I Line AT RANCHI                               | 22-02-2017 | 10:00     | 22-02-2017 | 17:30     | ODB | ER-I           | AMP & Hot spot of 20689L   | Jharkhand |
| 357 | Main Bay-701 of 765KV Bus Reactor-I at Sundergarh                 | 23-02-2017 | 08:00     | 26-02-2017 | 18:00     | OCB | ER-II/Odisha   | REFURBISHMENT OF 765KV CB FOR DCRM PROBLEM(CONSTRUCTIONAL DEFECT)  |           |
| 358 | 400 KV LAKHISARAI-KHG CKT-1                                       | 23-02-2017 | 18:00     | 23-02-2017 | 18:10     | ODB | ER-I           | FOR TAKING L/R INTO SERVICE AT LKR   |           |
| 359 | 765KV L/R OF 765 KV NEW RANCHI DHARAMJAYGARH - 2 AT AT NEW RANCHI | 23-02-2017 | 09:00     | 25-02-2017 | 18:00     | ODB | ER-I           | RTV COATING OF TRENCH MAKE BUSHING RECOMMENDED BY MANUFACTURER DUE TO DESIGN DEFICIENCY  | NLDC      |
| 360 | 400KV FKK - KAHALGAON CKT. # I & II                               | 23-02-2017 | 09:00     | 26-02-2017 | 18:00     | OCB | ER-I           | FOR POWER LINE CROSSING OF EXISTING 400 KV KAHALGAON - MAITHAN D/C LINE, 400 KV FARAKKA - KAHALGAON LINE( CKT.1,2, 3 & 4 ) AND 400 KV KHLG - BARH -1 & 2 BY CONSTRUCTION OF NEW LINE FOR SHIFTING OF 400KV KAHALGAON - BANKA LINE UNDER BUS SPLIT SCHEME AT NTPC SWITCHYARD, KAHALGAON.          |           |
| 361 | 125 MVAR BUS-REACTOR-I AT PATNA                                   | 23-02-2017 | 10:00     | 23-02-2017 | 18:00     | ODB | ER-I           | AMP work   |           |
| 362 | 400 KV MAIN BAY OF 80 MVAR BR-1 AT CHAIBASA                       | 23-02-2017 | 09:00     | 23-02-2017 | 17:00     | ODB | ER-I           | FOR REPLACEMENT OF DEFECTIVE CSD CARD  |           |
| 363 | 400 KV Fkk - Kahaalgaon Line#3                                    | 23-02-2017 | 09:30hrs  | 24-02-2017 | 17:30 hrs | ODB | FARAKKA        | Relay and Breaker testing.   |           |
| 364 | 400KV NSLG-Purnea Ckt-2   | 23-02-2017 | 07.00 hrs | 25-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings   |           |
| 365 | 400kv D/C Malda-Farakka Line-CKT-II                               | 23-02-2017 | 9000      | 23-02-2017 | 1600      | ODB | ER-II/ KOLKATA | To attend Punch point of M/s Sterlite  | NLDC      |
| 366 | 765kV Angul -Sundergarh Line-2                                    | 24-02-2017 | 07:00     | 25-02-2017 | 18:00     | ODB | ER-II/Odisha   | 1. Improvement & strengthening of line jumpers to prevent swing during high speed wind to avoid tripping in future & improvement of line availability&reliability.<br>2. Polymer anchoring at Angul and Sundargarh end.<br>3. Commissioning of NGR bypassing scheme at Angul and Sundargarh end. | NLDC      |
| 367 | 63 MVAR Bus Reactor Tie (417) Bay at Jeypore                      | 24-02-2017 | 09:30:00  | 24-02-2017 | 17:30:00  | ODB | ER-II/Odisha   | For AMP works  |           |
| 368 | 400 KV LAKHISARAI-KHG CKT-2                                       | 24-02-2017 | 18:00     | 24-02-2017 | 18:10     | ODB | ER-I           | FOR TAKING L/R OUT OF SERVICE AT LKR   |           |
| 369 | 400 KV Farakka- Kahaalgaon 1 & 2                                  | 24-02-2017 | 08:00     | 24-02-2017 | 18:00     | ODB | ER-II/ KOLKATA | Stringing between Loc. No. 5A/0 to 6/Q of LILO of 400 KV Rajarhat-Purnea D/c at Farakka .  |           |
| 370 | 220 KV MLD-DLK LINE-I at Malda                                    | 24-02-2017 | 09:00     | 24-02-2017 | 14:00     | ODB | ER-II/ KOLKATA | CT & CVT AMP   |           |
| 371 | 400kv D/C Malda-Farakka Line-CKT-II                               | 24-02-2017 | 9000      | 24-02-2017 | 1600      | ODB | ER-II/ KOLKATA | To attend Punch point of M/s Sterlite  | NLDC      |
| 372 | 400 KV Subhasgram- Sagardighi Line                                | 24-02-2017 | 08:30     | 24-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | AMP  | WBSETCL   |
| 373 | 400 KV BUS-II of NTPC Farakka                                     | 25-02-2017 | 09:00     | 26-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | Bus-I connection for newly constructed 400 KV Farakka- Rajarhat bay and 400 KV Farakka- Purnea bay (under ERSS-V) & BUS Bar-I stability test .   |           |
| 374 | 220KV SLG-Kishanganj Ckt-1  | 26-02-2017 | 07.00 hrs | 26-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings   |           |
| 375 | 220 KV Farakka- Lalmatia TL                                       | 26-02-2017 | 08:00     | 26-02-2017 | 18:00     | ODB | ER-II/ KOLKATA | Stringing between loc. No. 6/Q to 7/Q of LILO of 400 KV Rajarhat-Purnea D/c at Farakka.  |           |
| 376 | 400 KV BUS-I of NTPC Farakka                                      | 27-02-2017 | 09:00     | 28-02-2017 | 17:00     | ODB | ER-II/ KOLKATA | Bus-II connection for newly constructed 400 KV Farakka- Rajarhat bay and 400 KV Farakka- Purnea bay (under ERSS-V)& BUS Bar-II stability test .  |           |
| 377 | 132 KV Kh -Sabour Line  | 28-02-2017 | 09:30hrs  | 28-02-2017 | 17:30 hrs | ODB | KAHALGAON      | PM works & Relay testing   |           |
| 378 | 220KV SLG-Kishanganj Ckt-2  | 28-02-2017 | 07.00 hrs | 28-02-2017 | 17.00 hrs | ODB | ER-II/ KOLKATA | Insulator replacement in crossings   |           |
| 379 | 400 KV (Quad) Kishanganj-New Purnea # II                          | 01-03-2017 | 09:00     | 10-03-2017 | 17:00     | ODB | POWERLINK      | For changing 160KN Porcelain Insulator Strings by 160KN Polymer Insulator Strings at 46 Nos Tension/Angle towers between Tower no 01 Siliguri(W.B.) and Bidhannagar(W.B.) Tower no 01 TO Tower no. 95 in Ckt-2.  |           |

