



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

Tel No.:033-24235199, 24235016 FAX No.:033-24221802, 24221358 Web: www.erpc.gov.in

NO. ERPC/MS/OPERATION/2017-18/

DATE: 27.04.2017

FAX MESSAGE NO. 237

To,

As per list.

Sub: Corrigendum for minutes of Special meeting to review the limit of maximum power flow through 400kV Rangpo – Siliguri D/c line held on 29.03.2017.

Sir,

Please refer to the minutes of the above meeting held on 29.03.2017 at ERPC, Kolkata which was issued vide fax message No. 210 dated 06.04.2017. Subsequently, CTU vide letter dated 24.04.2017 has requested for modification in the minutes. Therefore, in view of request of CTU a corrigendum is hereby issued for the minutes of the above meeting and **para 3 & 7 under point No. 3**- "Review of limit on maximum power flow through 400 kV D/C Rangpo-Siliguri line for Rangpo SPS" will get substituted as follows:

1) Para 3 of Point no 3 shall be replaced with:

"It was informed that in India till date none of such type of line was loaded upto 1500 MW. Further, Powergrid added that this line passes through highly hilly train and the line may be loaded judiciously."

2) Para 7 of Point no 3 shall be replaced with:

"It was also emerged that till date the said line or any D/C Twin moose line has not been loaded upto the maximum limit of 1500 MW."

Yours faithfully,

(A. K. Bandyopadhyaya)

Member Secretary

Copy to:

1. Chief Engineer, PSP&A-II division, CEA, Sewa Bhawan, R.K.Puram, New Delhi- 110066.
2. Executive Director, NLDC, POSOCO, B-9, Qutab Institutional Area, Katwaria Sarai, N. Delhi- 110016 (Fax No.- 011-26524525, 26536901)
3. COO (CTU-Planning), PGCIL, Saudamini, Plot No-2, Sector-29, Gurgaon- 122001
4. GENERAL MANAGER, ERLDC, KOLKATA, (FAX NO. 033-2423-5809)
5. GENERAL MANAGER, TEESTA-V POWER STATION, NHPC, SINGTAM, EAST SIKKIM (FAX 03592 - 247377)

List of addressee:

1. Sr. Vice President (O&M), Teesta Urja Ltd, 2nd Floor, Vijaya Building, 17, Barakhamba Road, Cannaught Place, N. Delhi- 110001 (Fax- 011-46529744/75)
2. Director, Shiga Energy Pvt. Ltd., 5th Floor, DLF Building No. 8, Tower-C, DLF Cyber City, Phase-II, Gurgaon – 122002
3. CEO, Sneha Kinetic Power Projects Pvt.Ltd. #31 -A, National Highway, Behind SNOD building,. Deorali, Gangtok, Sikkim-73710
4. President, Dans Energy Pvt. Ltd, 5th Floor, DLF Building No. 8, Tower-C, DLF Cyber City, Phase-II, Gurgaon – 122002
5. Sr. General Manager, Gati Infrastructure Private Limited, 268 Udyug Vihar, Pahse-IV, Gurgaon-122016, Haryana
6. GENERAL MANAGER (OS), POWERGRID, ER-II, KOLKATA(Fax no: 033-23572827)
7. Sr. Vice President, Teestavalley Power Transmission Ltd. 2nd Floor, Vijaya Building, 17, Barakhamba Road, New Delhi-110001