



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: [www.erpcc.gov.in](http://www.erpcc.gov.in)

NO: ERPC/COM-II/VARH/2017/Feb01

Date: 06.04.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 06.03.2017-12.03.2017**

Sir,

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(A.K.BANDYOPADHYAY)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 06/03/17 to 12/03/17**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5902403

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 06/03/17 to 12/03/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE
<b>BSPHCL</b>	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-2582.8	335764	0	0	335764
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-3233.8	420394	0	0	420394
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-2140.9	278317	0	0	278317
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	386.6	-50258	0	0	-50258
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	579.5	-75335	0	0	-75335
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	151.5	-19695	-1.6	-208	-19903
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3044.4	395772	0	0	395772
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1412.8	183664	-7.1	-923	182741
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-1015.7	132041	-9.8	-1274	130767
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-981.5	127595	-57.2	-7436	120159
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-931.9	121147	-60.3	-7839	113308
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	821.9	-106847	0	0	-106847
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-50.4	6552	-186	-24180	-17628
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-3046.8	396084	-0.8	-104	395980
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-3304	429520	0	0	429520
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	683.9	-88907	0	0	-88907
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	693.4	-90142	0	0	-90142
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-420.2	54626	-3.1	-403	54223
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1373.6	178568	0	0	178568
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	137.4	-17862	0	0	-17862
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	136.6	-17758	0	0	-17758
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1355.4	176202	0	0	176202
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	0	0	0	0	0
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-595.6	77428	0	0	77428
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-594.7	77311	0	0	77311
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	-340.7	44291	0	0	44291
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	-319.2	41496	0	0	41496
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	307.9	-40027	0	0	-40027
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	93.1	-12103	148	19240	7137
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	289.1	-37583	0	0	-37583
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-708	92040	0	0	92040
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-2355.6	306228	0	0	306228
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-2281	296530	0	0	296530
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	-15	1950	0	0	1950
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	-12.3	1599	0	0	1599
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	-3.9	507	0	0	507
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-27.4	3562	0	0	3562
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	NP5233A	-250.8	32604	0	0	32604
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	NP5234A	-354.8	46124	0	0	46124
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	NP7828A	139.2	-18096	0	0	-18096
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	NP7829A	360.2	-46826	0	0	-46826
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2372.5	308425	0	0	308425
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3084.5	400985	0	0	400985
		<b>TOTAL</b>			<b>4345887</b>		<b>-23127</b>	<b>4322760</b>
					0			
<b>JUVNL</b>	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-12483.7	1622881	0	0	1622881
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-2504.3	325559	0	0	325559
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	3622.1	-470873	0	0	-470873
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3787.8	-492414	0	0	-492414
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-2041.5	265395	0	0	265395
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-847.4	110162	0	0	110162
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-814.6	105898	0	0	105898
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7881A	-2877.7	374101	0	0	374101
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	57.7	-7501	0	0	-7501
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8869A	-554.4	72072	0	0	72072
		<b>TOTAL</b>			<b>1905280</b>		<b>0</b>	<b>1905280</b>
<b>DVC</b>	1	220 KV DURGA PUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) -II	NP6458A	-7095	922350	0	0	922350
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	302.4	-39312	0	0	-39312
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	NP6451A	404.4	-52572	0	0	-52572
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	1262.4	-164112	0	0	-164112
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	1327.6	-172588	0	0	-172588
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-3133.7	407381	0	0	407381
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	958	-124540	0	0	-124540
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1622.2	210886	0	0	210886
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	536.8	-69784	0	0	-69784
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	357.7	-46501	0	0	-46501
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-9160.9	1190917	0	0	1190917
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-8406.1	1092793	0	0	1092793
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	5294	-688220	0	0	-688220
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	4892	-635960	0	0	-635960
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-9239.7	1201161	0	0	1201161
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-9268.9	1204957	0	0	1204957
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7711.6	1002508	0	0	1002508
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	5932.7	-771251	0	0	-771251
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-10667.2	1386736	0	0	1386736
		<b>TOTAL</b>			<b>5854849</b>		<b>0</b>	<b>5854849</b>

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

<b>GRIDCO</b>	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1222.8	-158834	0	0	-158834
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	1157.6	-150488	0	0	-150488
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	1337.5	-173875	0	0	-173875
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	1402.3	-182299	0	0	-182299
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	NP5957A	-3923.5	510055	0	0	510055
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	NP5958A	-4036.6	524758	0	0	524758
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	420.3	-54639	48.6	6318	-48321
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-987.3	128349	0	0	128349
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	333.6	-43368	0	0	-43368
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-390.4	50752	0	0	50752
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2748	357240	0	0	357240
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3946.4	513032	0	0	513032
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3918.8	509444	0	0	509444
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1686	219180	0	0	219180
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1599.8	207974	0	0	207974
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	NP7916A	-8371.2	1088256	0	0	1088256
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	1451.8	-188734	0.7	91	-188643
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	14796.4	-1923532	0	0	-1923532
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	3206.3	-416819	0	0	-416819
	21	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	NP5980A	-184.4	23972	0	0	23972
	22	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	NP7498A	-275.8	35854	0	0	35854
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-2316.1	301093	0	0	301093
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0	0	0
	25	220 KV BOLANGIR(PG)-SADEPALI(GRIDCO)	NP8789A	18.8	-2444	-38.6	-5018	-7462
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-7.7	1001	0	0	1001
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-60.4	7852	0	0	7852
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-78.6	10218	0	0	10218
		<b>TOTAL</b>		<b>1193998</b>		<b>1391</b>	<b>1195389</b>	
<b>SIKKIM</b>	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-73.60	9568	0	0	9568
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-186.30	24219	0	0	24219
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.8	-104	-104
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	102.20	-13286	0	0	-13286
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	100.60	-13078	0	0	-13078
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	0.00	0	0	0	0
		<b>TOTAL</b>		<b>7423</b>		<b>-104</b>	<b>7319</b>	
<b>WBSETCL</b>	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	-2302.3	299299	-163.1	-21203	278096
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	-706.1	91793	-780.5	-101465	-9672
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	867.2	-112736	-6	-780	-113516
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	1097	-142610	-0.6	-78	-142688
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	NP7555A	-115.1	14963	0	0	14963
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	NP6478A	-30.1	3913	-37.1	-4823	-910
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	NP5946A	-1673.1	217503	0	0	217503
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1463.8	190294	0	0	190294
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	NP5892A	-1618.9	210457	0	0	210457
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-1132.4	147212	0	0	147212
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	4208.2	-547066	0	0	-547066
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	5145.4	-668902	0	0	-668902
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-61.7	8021	0	0	8021
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	14803.9	-1924507	0	0	-1924507
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	13621	-1770730	0	0	-1770730
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-2307.8	300014	0	0	300014
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-2423.6	315068	0	0	315068
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-231.5	30095	0	0	30095
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	125.1	-16263	0	0	-16263
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	173.1	-22503	0	0	-22503
	21	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-I	NP6548A	6427.6	-835588	0	0	-835588
	22	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-II	NP7557A	6705.8	-871754	0	0	-871754
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	NP5068A	-410.6	53378	0	0	53378
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	NP7969A	-368.8	47944	0	0	47944
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	NP7935A	263.1	-34203	-16.5	-2145	-36348
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	233.5	-30355	-39.9	-5187	-35542
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	1816.1	-236093	-8.8	-1144	-23737
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	3768.4	-489892	0	0	-489892
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	NP7938A	2053.5	-266955	0	0	-266955
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	2003.5	-260455	0	0	-260455
	31	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	2962.5	-385125	0	0	-385125
	32	402 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	2828.7	-367731	0	0	-367731
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-4400.3	572039	0	0	572039
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8731A	-4254.9	553137	0	0	553137
	35	400 KV ARAMBAGH(WB)-RANCHI NEW(PG)	ER1136A	-10335.2	1343576	0	0	1343576
	36	400 KV PPS(PG)-RANCHI NEW(PG)	ER1139A	9083.2	-1180816	0	0	-1180816
		<b>TOTAL</b>		<b>-5765578</b>		<b>-136825</b>	<b>-5902403</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.