



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: www.erpcc.gov.in

NO: ERPC/COM-II/VARH/2017

Date: 29.05.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 08.05.2017-14.05.2017

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(A.K.BANDYOPADHYAY)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 08/05/17 to 14/05/17**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	6213213

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 08/05/17 to 14/05/17

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-1760	237600	0	0	237600
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-1810.6	244431	0	0	244431
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-900.4	121554	0	0	121554
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	122.3	-16511	-62.2	-8397	-24908
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	226.1	-30524	-21.4	-2889	-33413
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	103	-13905	-112.2	-15147	-29052
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3939.3	531806	0	0	531806
	8	132 KV ARAH (PG) - ARAH (BSPHCL)	NP6051A	-1369.9	184937	-10.1	-1363.5	183573
	9	132 KV ARAH (PG) - DUMRAO (BSPHCL)	NP6054A	-839.7	113360	-6.6	-891	112469
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-112.9	15242	-3.6	-486	14756
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-93.8	12663	-4.4	-594	12069
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	292.2	-39447	20.3	2740.5	-36707
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	95.2	-12852	21.9	2956.5	-9896
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-3168.3	427721	-0.2	-27	427694
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-3530.9	476672	0	0	476672
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	542.2	-73197	0	0	-73197
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	543.2	-73332	0	0	-73332
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-538.6	727111	-4	-540	72171
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-348.8	47088	0	0	47088
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	22.7	-3065	0	0	-3065
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	22.7	-3065	0	0	-3065
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2989.4	403569	0	0	403569
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-120.6	16281	0	0	16281
	24	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-I	NP7888A	-59.1	7979	0	0	7979
	25	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-II	NP7431A	-62.5	8438	0	0	8438
	26	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-I	NP7887A	-18.2	2457	0	0	2457
	27	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-II	NP7430A	-13.8	1863	0	0	1863
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	258.9	-34952	0	0	-34952
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-145.1	19589	-7.3	-985.5	18603
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	645.2	-87102	0	0	-87102
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-463.4	62559	0	0	62559
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1110.3	149891	0	0	149891
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-1252.2	169047	-0.1	-13.5	169034
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	-1.4	189	0	0	189
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	-1.1	149	0	0	149
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	5.4	-729	-1.2	-162	-891
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	5.7	-770	0	0	-770
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	NP5233A	-792.5	106988	0	0	106988
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	NP5234A	-825.6	111456	0	0	111456
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	NP7828A	281.6	-38016	-0.1	-13.5	-38030
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	NP7829A	679	-91665	0	0	-91665
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1472	198720	-552.7	-74614.5	124106
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1822	245970	-285	-38475	207495
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-1	ER1284A	880.5	-118868	-0.3	-40.5	-118908
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-2	ER1289A	1030.3	-139091	-0.2	-27	-139118
		TOTAL			3471795		-138902	3332894
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-13506.7	1823405	0	0	1823405
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-2937.6	396576	0	0	396576
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	613.2	-82782	0.1	14	-82769
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3943	-532305	0	0	-532305
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1761.7	237830	0	0	237830
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-436.4	58914	0	0	58914
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-394.2	53217	0	0	53217
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7466A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	39	-5265	0	0	-5265
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8869A	-423.2	57132	0	0	57132
		TOTAL			2006721	14	2006735	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-4904.8	662148	0	0	662148
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-20.6	2781	0	0	2781
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-105.4	14229	0	0	14229
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	656.6	-88641	0	0	-88641
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	383.4	-51759	0	0	-51759
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-2715.1	366539	0	0	366538.5
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1103.1	-148919	0	0	-148918.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1192.3	160961	0	0	160960.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	1080.3	-145841	0	0	-145840.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	960.4	-129654	0	0	-129654
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4745.1	640589	0	0	640588.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3625.9	489497	0	0	489496.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1237.7	-167090	0	0	-167089.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	1062.3	-143411	0	0	-143410.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-7951.5	1073453	0	0	1073452.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-7905	1067175	0	0	1067175
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-8120.2	1096227	0	0	1096227
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	5686.9	-767732	0	0	-767731.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-8949.5	1208183	0	0	1208182.5
		TOTAL			5138735	0	5138735	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-665.8	89883	0	0	89883
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	-658.2	88857	0	0	88857
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-976.1	131773.5	0	0	131773.5
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-1459.3	197005.5	0	0	197005.5
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	NP5957A	-243.1	32818.5	0	0	32818.5
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	NP5958A	-238.9	32251.5	0	0	32251.5
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	423.1	-57118.5	159	21465	-35653.5
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-280.1	37813.5	0	0	37813.5
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	131.2	-17712	0	0	-17712
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-481	64935	0	0	64935
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5222.4	705024	0	0	705024
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-5858.2	790857	0	0	790857
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-5794	782190	0	0	782190
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2339.4	315819	0	0	315819
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1956	264060	0	0	264060
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-1610.9	217471.5	0	0	217471.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	716.7	-96754.5	0	0	-96754.5
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	2187.3	-295285.5	0	0	-295285.5
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	267.4	-36099	0	0	-36099
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	-38.1	-5143.5	-5143.5
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	-55.1	-7438.5	-7438.5
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-433.8	58563	0	0	58563
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	63.9	8626.5	8626.5
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-181.7	-24529.5	-24529.5
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	-17.6	-2376	-2376
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-181.2	24462	0	0	24462
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-188.9	25501.5	0	0	25501.5
		TOTAL		3356316		-9396	3346920	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-35.00	4725	0	0	4725
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-58.40	7884	0	0	7884
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-2	-270	-270
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	11.40	-1539	0	0	-1539
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	10.10	-1364	0	0	-1364
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	1.10	-149	0	0	-149
		TOTAL		9558		-270	9288	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	-249.2	33642	-1624.8	-219348	-185706
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	0	0	-6063.4	-818559	-818559
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	-913.3	123296	-702.8	-94878	28418
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	-952.2	128547	-465.4	-62829	65718
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-513	-69255	-69255
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	-1.2	162	-990.5	-133718	-133556
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-71.8	9693	0	0	9693
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-162.2	21897	0	0	21897
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-1004.2	135567	0	0	135567
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-558	75330	0	0	75330
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	825.6	-111456	0	0	-111456
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	1037.6	-140076	0	0	-140076
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-5.8	783	0	0	783
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	9688.5	-1307948	0	0	-1307948
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	7653.5	-1033223	0	0	-1033223
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	1320.6	-178281	0	0	-178281
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-2613.6	352836	0	0	352836
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-53.1	7169	0	0	7169
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	16	-2160	0	0	-2160
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	-196.4	26514	0	0	26514
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	4727.5	-638213	0	0	-638213
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	5803.8	-783513	0	0	-783513
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-66	8910	-42	-5670	3240
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1071A	-46	6210	-46.2	-6237	-27
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	48.5	-6548	-190.4	-25704	-32252
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	-75.4	10179	-319.5	-43133	-32954
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	242	-32670	-150.5	-20318	-52988
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	1105.2	-149202	51.4	6939	-142263
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	2069.6	-279396	0	0	-279396
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	2726.5	-368078	0	0	-368078
	31	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	4230.9	-571172	0	0	-571172
	32	402 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	3851.3	-519926	0	0	-519926
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-2692.1	363434	0	0	363434
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8731A	-2751.7	371480	0	0	371480
	35	400 KV ARAMBAGH(WB)-RANCHI NEW(PG)	ER1136A	-4096.5	553028	0	0	553028
	36	400 KV PPS(PG)-RANCHI NEW(PG)	ER1139A	6128.3	-827321	0	0	-827321
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-705.6	95256	0	0	95256
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-659.8	89073	0	0	89073
		TOTAL		-4720505		-1492709	-6213213	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArh,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) *NA* means meter reading not available.