



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: [www.erpcc.gov.in](http://www.erpcc.gov.in)

NO: ERPC/COM-II/VARH/2017

Date: 19.05.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 24.04.2017-30.04.2017**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(A.K.BANDYOPADHYAY)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 24/04/17 to 30/04/17**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5447993

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

*for the period 24/04/17 to 30/04/17*

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAh_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAh_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE
<b>BSPHCL</b>	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-2667.1	360059	0	0	360059
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2640.5	356468	0	0	356468
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1556	210060	-10.8	-1458	208602
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	139.7	-18860	-18.1	-2443.5	-21303
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	366.6	-49491	-4.3	-580.5	-50072
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	73.1	-9869	-39.6	-5346	-15215
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2711	365985	0	0	365985
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1278.8	172638	-14.4	-1944	170694
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-649.2	87642	-13.9	-1876.5	85766
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-266.4	35964	0	0	35964
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-229.2	30942	0	0	30942
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	204.5	-27608	6.7	904.5	-26703
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	108.5	-14648	12.1	1633.5	-13014
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-3366.5	454478	0	0	454478
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-3409.8	460323	0	0	460323
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	784.2	-105867	0	0	-105867
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	775.6	-104706	0	0	-104706
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-462.5	62438	-7.2	-972	61466
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1151.4	155439	0	0	155439
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	55	-7425	0	0	-7425
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	55.1	-7439	0	0	-7439
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3096.9	418082	0	0	418082
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-226.1	30524	0	0	30524
	24	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-I	NP7888A	-117.7	15890	-0.1	-13.5	15876
	25	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-II	NP7431A	-123.4	16659	0	0	16659
	26	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-I	NP7887A	-58.9	7952	-0.1	-13.5	7938
	27	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-II	NP7430A	-55.4	7479	-0.6	-81	7398
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	264.2	-35667	0	0	-35667
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-184.1	24854	-2.7	-364.5	24489
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	219.2	-29592	0	0	-29592
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-868.6	117261	0	0	117261
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1798.7	242825	0	0	242825
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-1930.6	260631	0	0	260631
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	-13.5	1823	0	0	1823
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	-11.7	1580	0	0	1580
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	-9	1215	0	0	1215
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-16.8	2268	0	0	2268
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	NP5233A	-335.3	45266	0	0	45266
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	NP5234A	-405.2	54702	0	0	54702
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	NP7828A	672.1	-90734	0	0	-90734
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	NP7829A	671.3	-90626	0	0	-90626
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1631.2	220212	-428.3	-57820.5	162392
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1940	261900	-164.7	-22234.5	239666
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-1	ER1284A	854.8	-115398	-10.5	-1417.5	-116816
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-2	ER1289A	845.1	-114089	-14.3	-1930.5	-116019
		<b>TOTAL</b>			<b>3891024</b>		<b>-92610</b>	<b>3798414</b>
<b>JUVNL</b>	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-13359.3	1803506	0	0	1803506
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-1849	249615	-0.3	-41	249575
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	797.2	-107622	0.6	81	-107541
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3735.6	-504306	0	0	-504306
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1808.8	244188	0	0	244188
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-312	42120	0	0	42120
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-584.2	78867	0	0	78867
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7466A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	25.6	-3456	0	0	-3456
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8869A	-587.5	79313	0	0	79313
		<b>TOTAL</b>			<b>1882224</b>		<b>41</b>	<b>1882265</b>
<b>DVC</b>	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-4792	646920	0	0	646920
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-42.8	5778	0	0	5778
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-26	3510	0	0	3510
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	1236.2	-166887	0	0	-166887
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	712.4	-96174	0	0	-96174
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	NP7408A	-1473.8	198963	0	0	198963
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1003.2	-135432	0	0	-135432
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-2178.5	294098	0	0	294097.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	-298.9	40352	0	0	40351.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	-496.8	67068	0	0	67068
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4811.3	649526	0	0	649525.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4354.4	587844	0	0	587844
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	2398.1	-323744	0	0	-323743.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	2132	-287820	0	0	-287820
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-7433.7	1003550	0	0	1003549.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-7457.8	1006803	0	0	1006803
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6425.1	867389	0	0	867388.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	5517.5	-744863	0	0	-744862.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-7745.2	1045602	0	0	1045602
		<b>TOTAL</b>			<b>4662482</b>		<b>0</b>	<b>4662482</b>

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-434.8	58698	0	0	58698
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	-543.6	73386	0	0	73386
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	27.1	-3658.5	0	0	-3658.5
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	128.4	-17334	0	0	-17334
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	NP5957A	-1157.1	156208.5	0	0	156208.5
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	NP5958A	-1142.6	154251	0	0	154251
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	556.8	-75168	0	0	-75168
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-91.8	12393	0	0	12393
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	18.2	-2457	0	0	-2457
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-888	119880	0	0	119880
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4140.4	558954	0	0	558954
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4177.2	563922	0	0	563922
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3851.6	519966	0	0	519966
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-3124.7	421834.5	0	0	421834.5
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-2380.7	321394.5	0	0	321394.5
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-132.1	17833.5	0	0	17833.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	1	-135	0	0	-135
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	73	-9855	0	0	-9855
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	-18.5	-2497.5	-2497.5
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	-27.6	-3726	-3726
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-36.6	4941	0	0	4941
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	55.5	7492.5	7492.5
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-240.2	-32427	-32427
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-102.9	13891.5	0	0	13891.5
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-98.8	13338	0	0	13338
		<b>TOTAL</b>		<b>2902284</b>		<b>-31158</b>	<b>2871126</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-57.90	7817	0	0	7817
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-74.50	10058	0	0	10058
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.1	-13.5	-14
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	2.90	-392	0	0	-392
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	2.20	-297	0	0	-297
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	23.80	-3213	0	0	-3213
		<b>TOTAL</b>		<b>13973</b>		<b>-14</b>	<b>13959</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	-605.4	81729	-3305.5	-446243	-364514
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	-0.3	41	-7062.6	-953451	-953411
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	-814	109890	-2299.9	-310487	-200597
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	-805.4	108729	-1783.7	-240800	-132071
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-893.8	-120663	-120663
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0	0	-1407.4	-189999	-189999
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	NP5946A	-140.7	18995	0	0	18995
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-247.8	33453	0	0	33453
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-1366.4	184464	0	0	184464
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-826.6	111591	0	0	111591
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	323	-43605	0	0	-43605
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	873.7	-117950	0	0	-117950
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-7.9	1067	0	0	1067
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	6764.1	-913154	0	0	-913154
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	5189.8	-700623	0	0	-700623
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1359.1	183479	0	0	183479
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-5081.9	686057	0	0	686057
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-71.8	9693	0	0	9693
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	0.5	-68	0	0	-68
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	171.8	-23193	0	0	-23193
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	4876.3	-658301	0	0	-658301
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	5523.6	-745686	0	0	-745686
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-395.8	53433	-26.5	-3578	49856
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-368.5	49748	-36.7	-4955	44793
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	-26.3	3551	-380.6	-51381	-47831
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	52.1	-7034	-629.5	-84983	-92016
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	173.7	-23450	-695.6	-93906	-117356
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	828.2	-111807	12.3	1661	-110147
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	1024	-138240	653.2	88182	-50058
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	1613.4	-217809	567.1	76559	-141251
	31	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	3377	-455895	0	0	-455895
	32	402 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	3164	-427140	0	0	-427140
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-2449	330615	0	0	330615
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-2490.5	336218	0	0	336218
	35	400 KV ARAMBAGH(WB)-RANCHI NEW(PG)	ER1136A	-1991.9	268907	0	0	268907
	36	400 KV PPS(PG)-RANCHI NEW(PG)	ER1139A	8160.4	-1101654	0	0	-1101654
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-2021.1	272849	0	0	272849
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-1745.2	235602	0	0	235602
		<b>TOTAL</b>		<b>-3113951</b>		<b>-2334042</b>	<b>-5447993</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) \*NA\* means meter reading not available.