



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: [www.erpcc.gov.in](http://www.erpcc.gov.in)

NO: ERPC/COM-II/VARH/2017

Date: 22.06.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 29.05.2017-04.06.2017**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(A.K.BANDYOPADHYAY)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 29/05//17 to 04/06/17**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5728220

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 29/05/17 to 04/06/17

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArH (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-1799.4	242919	0	0	242919
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-1782.9	240692	0	0	240692
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1198.9	161852	-0.4	-54	161798
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	15.8	-2133	-166.2	-22437	-24570
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	37.7	-5090	-54.2	-7317	-12407
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	0	0	-357.1	-48208.5	-48209
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3774.1	509504	2.7	364.5	509868
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1291.1	174299	-12.3	-1660.5	172638
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-862.5	116438	-6.4	-864	115574
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-249.7	33710	-44.6	-6021	27689
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-93.7	12650	-81.9	-11056.5	1593
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	50.3	-6791	11.5	1552.5	-5238
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	12.6	-1701	202.9	27391.5	25691
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-3412.7	460715	0	0	460715
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-3542.1	478184	0	0	478184
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	-59.7	8060	0	0	8060
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	-48.7	6575	0	0	6575
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-625.6	84456	-5.4	-729	83727
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1594.1	215204	0	0	215204
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	79.1	-10679	0	0	-10679
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	78.3	-10571	0	0	-10571
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-4198.3	566771	18.4	2484	569255
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	222.3	-30011	-17.6	-2376	-32387
	24	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-I	NP7888A	-188	25380	0	0	25380
	25	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-II	NP7431A	-196.6	26541	0	0	26541
	26	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-I	NP7887A	-22.1	2984	0	0	2984
	27	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-II	NP7430A	-15.6	2106	0	0	2106
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	251.9	-34007	0	0	-34007
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-16.7	2255	-99.6	-13446	-11192
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	939.7	-126860	1.3	175.5	-126684
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-369.5	49883	-8.7	-1174.5	48708
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-806.7	108905	-12.3	-1660.5	107244
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-961.7	129830	-7.3	-985.5	128844
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	-3.4	459	0	0	459
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	-3.1	419	0	0	419
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	-9.3	1256	0	0	1256
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-0.1	14	0	0	14
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-168.9	22802	-26.4	-3564	19238
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-178.1	24044	-25.1	-3388.5	20655
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	NP7828A	928.8	-125388	0	0	-125388
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	NP7829A	935.5	-126293	0	0	-126293
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1058.6	142911	-1723.3	-232645.5	-89735
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1207.4	162999	-1256	-169560	-6561
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-1	ER1284A	525.8	-70983	-44	-5940	-76923
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-2	ER1289A	524.2	-70767	-18.7	-2524.5	-73292
		<b>TOTAL</b>			<b>3393536</b>		<b>-503645</b>	<b>2889891</b>
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-12759.6	1722546	0	0	1722546
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-2373.1	320369	0	0	320369
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	1443	-194805	0	0	-194805
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	4455.4	-601479	0	0	-601479
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1459	196965	0	0	196965
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-194.8	26298	0	0	26298
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-181.2	24462	0	0	24462
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7466A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	0	0	0	0	0
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8869A	-717.4	96849	0	0	96849
		<b>TOTAL</b>			<b>1591205</b>		<b>0</b>	<b>1591205</b>
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-4897.4	661149	0	0	661149
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-89.6	12096	0	0	12096
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-57.7	7790	0	0	7789.5
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	487.8	-65853	0	0	-65853
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	551.4	-74439	0	0	-74439
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	NP7408A	-2506.8	338418	0	0	338418
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	395.5	-53393	0	0	-53392.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1039.6	140346	0	0	140346
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	1308.8	-176688	0	0	-176688
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	1106.6	-149391	0	0	-149391
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-2961.7	399830	0	0	399829.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2671	360585	0	0	360585
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	205.5	-27743	0	0	-27742.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-26.3	3551	0	0	3550.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-8115.2	1095552	0	0	1095552
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-8130.6	1097631	0	0	1097631
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7480.2	1009827	0	0	1009827
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	4287.7	-578840	0	0	-578839.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-9097.1	1228109	0	0	1228108.5
		<b>TOTAL</b>			<b>5228537</b>		<b>0</b>	<b>5228537</b>

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

<b>GRIDCO</b>	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	978.8	-132138	0	0	-132138	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	942.4	-127224	0	0	-127224	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-1138.8	153738	0	0	153738	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-782.8	105678	0	0	105678	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	245.1	-33088.5	0	0	-33088.5	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	279.7	-37759.5	0	0	-37759.5	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	561.2	-75762	0	0	-75762	
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-124.8	16848	0	0	16848	
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	20.1	-2713.5	0	0	-2713.5	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	503	-67905	0	0	-67905	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5865	791775	0	0	791775	
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-6560.2	885627	0	0	885627	
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-6489	876015	0	0	876015	
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-3394.4	458244	0	0	458244	
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-2357.7	318289.5	0	0	318289.5	
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-1662.8	224478	0	0	224478	
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	1128.5	-152347.5	0	0	-152347.5	
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	3849	-519615	0	0	-519615	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	483.5	-65272.5	0	0	-65272.5	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	-13	-1755	-1755	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	-25	-3375	-3375	
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-391.2	52812	0	0	52812	
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0	0	0	
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	0	0	0	
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	-1148.8	-155088	-155088	
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	0	0	0	0	0	
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0	
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-0.4	54	0	0	54	
	30	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	0	0	0	0	0	
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	0	0	-14.4	-1944	-1944	
			<b>TOTAL</b>		<b>2669733</b>		<b>-162162</b>	<b>2507571</b>	
	<b>SIKKIM</b>	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-45.70	6170	-0.1	-13.5	6156
		2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-56.80	7668	-0.1	-13.5	7655
3		66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.6	-81	-81	
4		132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0	
5		132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0	
6		132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	-3.60	486	0	0	486	
		<b>TOTAL</b>		<b>14324</b>		<b>-108</b>	<b>14216</b>		
<b>WBSETCL</b>	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	-1.7	230	-1473.5	-198923	-198693	
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	0	0	-6775.5	-914693	-914693	
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	-732.5	98888	-1148.3	-155021	-56133	
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	-726.1	98024	-831.5	-112253	-14229	
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-517.6	-69876	-69876	
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0	0	-1615.4	-218079	-218079	
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	47.3	-6386	0	0	-6386	
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	24.3	-3281	0	0	-3281	
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-558.4	75384	0	0	75384	
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-695	93825	0	0	93825	
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-1900.5	256568	0	0	256568	
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	-778.5	105098	0	0	105098	
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	3.5	-473	0	0	-473	
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	9158.8	-1236438	0	0	-1236438	
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	8023.9	-1083227	0	0	-1083227	
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	1868.9	-252302	0	0	-252302	
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	468.3	-63221	0	0	-63221	
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-37.2	5022	0	0	5022	
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	6	-810	0	0	-810	
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	-491.2	66312	0	0	66312	
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	3407.2	-459972	0	0	-459972	
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	9918.7	-1339025	0	0	-1339025	
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-119.6	16146	0	0	16146	
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1071A	-96.7	13055	0	0	13055	
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	-95.4	12879	-180.96	-24430	-11551	
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	-75.5	10193	-422.4	-57024	-46832	
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	101.6	-13716	-254.4	-34344	-48060	
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	889.3	-120056	-0.4	-54	-120110	
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	1819.4	-245619	191.6	25866	-219753	
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	2493.5	-336623	170.9	23072	-313551	
	31	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	1875.3	-253166	0	0	-253166	
	32	402 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	1582.9	-213692	0	0	-213692	
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-3153.7	425750	0	0	425750	
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8731A	-3188.8	430488	0	0	430488	
	35	400 KV ARAMBAGH(WB)-RANCHI NEW(PG)	ER1136A	-3900.6	526581	0	0	526581	
	36	400 KV PPS(PG)-RANCHI NEW(PG)	ER1139A	5739.6	-774846	0	0	-774846	
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-676.2	91287	0	0	91287	
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-627.1	84659	0	0	84659	
		<b>TOTAL</b>		<b>-3992463</b>		<b>-1735757</b>	<b>-5728220</b>		

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH, w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with IISTS.

5) \*NA\* means meter reading not available.