



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/2017

Date: 14.07.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 26.06.2017-02.07.2017**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

**(A.K.BANDYOPADHYAY)**  
**MEMBER SECRETARY**

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 26/06//17 to 02/07/17**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	3261492

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 26/06/17 to 02/07/17

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-3078.3	415571	0	0	415571
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-3106	419310	0	0	419310
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-2081.4	280989	0	0	280989
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	0	0	-285.3	-38515.5	-38515.5
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-9.9	1337	-29.6	-3996	-2660
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	0	0	-467.4	-63099	-63099
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-4017.4	542349	0	0	542349
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1413.1	190769	-0.3	-40.5	190728
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-911.5	123053	-0.2	-27	123026
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-126.6	17091	-1.7	-229.5	16862
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-125.8	16983	-10.8	-1458	15525
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	6	-810	27.1	3658.5	2849
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	19.9	-2687	25.1	-34843.5	-37530
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-4154.2	560817	0	0	560817
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-3890.8	525258	-14.1	-1903.5	523355
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	473.7	-63950	0	0	-63950
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	466.8	-63018	0	0	-63018
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-558.8	75438	0	0	75438
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2185.5	295043	0	0	295043
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	56.2	-7587	0	0	-7587
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	56.1	-7574	0	0	-7574
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-4366.2	589437	0	0	589437
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	637.5	-86063	-2	-270	-86333
	24	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-I	NP7888A	-213	28755	0	0	28755
	25	132 KV LAKHISARA(PG)-LAKHISARA(BSPHCL)-II	NP7431A	-220.7	29795	0	0	29795
	26	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-I	NP7887A	-134.9	18212	0	0	18212
	27	132 KV LAKHISARA(PG)-JAMUI(BSPHCL)-II	NP7430A	-112.7	15215	0	0	15215
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	244.7	-33035	0	0	-33035
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	24.8	-3348	264.9	35761.5	32414
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	1070.4	-144504	0	0	-144504
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-1085.3	146516	0	0	146516
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-2023.6	273186	0	0	273186
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-2247.1	303359	0	0	303359
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	-2	270	0	0	270
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	-1.9	257	0	0	257
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	-6.1	824	0	0	824
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-8.1	1094	0	0	1094
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-491.9	66407	-13.2	-1782	64625
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-414.9	56012	-30.8	-4158	51854
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	NP7828A	1196.6	-161541	0	0	-161541
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	NP7829A	1207.2	-162972	0	0	-162972
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-943.1	127319	-2578.9	-348151.5	-220833
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1283.7	173300	-2072.4	-279774	-106475
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-1	ER1284A	163.4	-22059	-50.8	-6858	-28917
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-2	ER1289A	160.2	-21627	-51.9	-7006.5	-28634
		<b>TOTAL</b>			<b>4513185</b>		<b>-752693</b>	<b>3760493</b>
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-13652.9	1843142	0	0	1843142
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-3540.1	477914	0	0	477914
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	2616.5	-353228	0	0	-353228
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3752	-506520	0	0	-506520
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1762.6	237951	0	0	237951
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-204.4	27594	0	0	27594
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-222.8	30078	0	0	30078
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7466A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	45.8	-6183	0	0	-6183
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8869A	-830.5	112118	0	0	112118
		<b>TOTAL</b>			<b>1862865</b>	<b>0</b>	<b>1862865</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-5796.4	782514	0	0	782514
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-122.8	16578	0	0	16578
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-380.6	51381	0	0	51381
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	11.2	-1512	0	0	-1512
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	45	-6075	0	0	-6075
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	NP7408A	-3693.8	498663	0	0	498663
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	258.7	-34925	0	0	-34924.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1943.6	262386	0	0	262386
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	-58.1	7844	0	0	7843.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	-239.9	32387	0	0	32386.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4731.3	638726	0	0	638725.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4215.6	569106	0	0	569106
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	267	-36045	0	0	-36045
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-173.8	23463	0	0	23463
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-10521.8	1420443	0	0	1420443
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-10548	1423980	0	0	1423980
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-9057	1222695	0	0	1222695
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	4177.7	-563990	0	0	-563989.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-10808.4	1459134	0	0	1459134
		<b>TOTAL</b>			<b>7766753</b>	<b>0</b>	<b>7766753</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

<b>GRIDCO</b>	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1442	-194670	0	0	-194670
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	1390.6	-187731	0	0	-187731
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-940.8	127008	0	0	127008
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-594.6	80271	0	0	80271
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1016.4	-137214	0	0	-137214
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	1242.4	-167724	0	0	-167724
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	4801.6	-648216	0	0	-648216
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-981.9	132556.5	0	0	132556.5
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	30.5	-4117.5	0	0	-4117.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	494.4	-66744	0	0	-66744
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5906.6	797391	0	0	797391
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-6111	824985	0	0	824985
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-6048.6	816561	0	0	816561
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-3206.8	432918	0	0	432918
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-3060	413100	0	0	413100
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-8607.3	1161985.5	0	0	1161985.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	7929.4	-1070469	0	0	-1070469
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	16719.9	-2257186.5	0	0	-2257186.5
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4385.5	-592042.5	0	0	-592042.5
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-160.4	21654	0	0	21654
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-190.3	25690.5	0	0	25690.5
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3348	451980	0	0	451980
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0	0	0
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-60.4	8154	0	0	8154
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-12745.1	1720588.5	0	0	1720588.5
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	564.3	-76180.5	0	0	-76180.5
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	956.5	-129127.5	0	0	-129127.5
		<b>TOTAL</b>		<b>1483421</b>		<b>0</b>	<b>1483421</b>	
<b>SIKKIM</b>	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-30.10	4064	0	0	4064
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-11.70	1580	0	0	1580
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.1	-13.5	-14
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	3.30	-446	0	0	-446
		<b>TOTAL</b>		<b>5198</b>		<b>-14</b>	<b>5184</b>	
<b>WBSETCL</b>	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	-25.8	3483	-465.9	-62897	-59414
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	0	0	-5412.8	-730728	-730728
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	-1154.6	155871	-125.7	-16970	138902
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	-1197.8	161703	-68	-9180	152523
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-905.9	-122297	-122297
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0	0	-983.8	-132813	-132813
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	0	0	0	0	0
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	110.6	-14931	0	0	-14931
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-778.8	105138	0	0	105138
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-541.6	73116	0	0	73116
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-1645.4	222129	0	0	222129
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	-909.8	122823	0	0	122823
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGA PUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	9292.1	-1254434	0	0	-1254434
	15	400 KV DURGA PUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	7743.4	-1045359	0	0	-1045359
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-575	77625	0	0	77625
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	962.2	-129897	0	0	-129897
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	0	0	0	0	0
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	0	0	0	0	0
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	-1593	215055	0	0	215055
	21	400 KV DURGA PUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	5357.5	-723263	0	0	-723263
	22	400 KV DURGA PUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	5868.8	-792288	0	0	-792288
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-310.2	41877	-161.3	-21776	20102
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1071A	-308.2	41607	-187.5	-25313	16295
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	-66.4	8964	-22	-2970	5994
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	-82.9	11192	9.6	1296	12488
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	306.2	-41337	-6.6	-891	-42228
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	1253.5	-169223	8.9	1202	-168021
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	3180.1	-429314	0	0	-429314
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	4014.2	-541917	0	0	-541917
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	2054.9	-277412	0	0	-277412
	32	402 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	1991.6	-268866	0	0	-268866
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-5404	729540	0	0	729540
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8731A	-5428.1	732794	0	0	732794
	35	400 KV ARAMBAGH(WB)-RANCHI NEW(PG)	ER1136A	-8921.8	1204443	0	0	1204443
	36	400 KV PPS(PG)-RANCHI NEW(PG)	ER1139A	7233.2	-976482	0	0	-976482
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-2278.7	307625	0	0	307625
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-2308	311580	0	0	311580
		<b>TOTAL</b>		<b>-2138157</b>		<b>-1123335</b>	<b>-3261492</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVARh,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) \*NA\* means meter reading not available.