

EASTERN REGIONAL POWER COMMITTEE
14 GOLF CLUB ROAD, TOLLYGUNGE, KOLKATA-700 033

Phone: 033-24239650 # Fax : 033-24239652/24239653 # Web : www.erpc.gov.in

No-ERPC/COM-I/GEN/2017/1885

dated-17.08.2017

FAX Msg No:

To: As per List

Subject: Minutes of 35th Commercial Sub Committee Meeting of ERPC-Reg

Sir,

Minutes of the 35th Commercial Sub Committee Meeting of ERPC held on 02.08.2017 have been issued with the approval of Member Secretary and available for download at www.erpc.gov.in.

Encl-as above

Yours faithfully,

Sd/-

Executive Engineer

Distribution List-CC Members:

- 1) Director (Projects), BSPTCL, Patna (Fax:0612 250455).
- 2) Executive Director (Comml.), DVC, Kolkata (Fax: 033 2355 2129)
- 3) Director (Projects), JUVNL, Ranchi (Fax : 0651 2400799 / 2490486).
- 4) Executive Director (RT), WBSEDCL, Kolkata (Fax : 033 2359 8398/2337 3002)
- 5) Chief Engineer (Commercial), WBSETCL, Bidyut Bhavan, Block DJ, Sector-II, Bidhannagar,Kolkata-700091 (033-23591952)
- 6) Chief Engineer, SLDC, WBSETCL, Howrah (033 2688 6232)
- 7) Chief Engineer (Trans), Deptt. Of Power, Govt. Of Sikkim, Gangtok (Fax:03592 228186)
- 8) General Manager (Comml.-ER), NTPC, Corporate Centre, New Delhi (Fax : 011 2436 8417)
- 9) AGM(Comml.), ER-I, Powergrid, Patna (Fax: 0612 2227630)
- 10) AGM(Comml.), ER-II, Powergrid, Kolkata (Fax NO. 033 2357 2827)
- 11) Chief Engineer (Commercial), NHPC, Faridabad (Fax:0129 2278358)
- 12) GM, ERLDC, Kolkata (Fax: 033 2423 5029)
- 13) Asst. General Manager (F&A), Finance Wing, Ohpc, Bhubaneswar(Fax:0674 2542102)
- 14) General Manager (SO), CESC Ltd., Kolkata (Fax : 033 2212 9871)
- 15) General Manager (Commercial & Operations), WBPDC, Kolkata (Fax:23350582 / 23393286)
- 16) Sr. General Manager(Finance), OPGC, Odisha (Fax: 06645 222225)
- 17) Director Of Accounts, TVNL, Ranchi (Fax : 0651 2251296 / 2253181)
- 18) General Manager (R&T), OPTCL, Bhubaneswar (Fax: 0674 2542120)
- 19) Sr.General Manager (PP), Gridco, Bhubaneswar (Fax : 0674 2547180 / 2547261)
- 20) Vice President(Commercial), PTC, New Delhi (Fax: 011 4165 9504)
- 21) DGM (ALDC), DPL, Durgapur (Fax : 0343 255- 6786/6251)
- 22) Vice-President (OPN-ER), Tata Power Co. Ltd., Jamshedpur (Fax :0657 2277298)
- 23) Director (GM), CEA, New-Delhi (FAX: 011 2610 9750)
- 24) Member Secretary, NERPC, Shillong (Fax : 0364 2520030) .
- 25) Member Secretary, NRPC, New Delhi (Fax : 011 2686 5206).
- 26) Member Secretary, SRPC, Bangalore (Fax : 080 22259343).
- 27) Member Secretary, WRPC, Mumbai (Fax : 022 2837 0193).
- 28) Head (Commercial), MPL, MA-5 Gogna Colony, P.O- Maithon Dam, Jharkhand-828207, Fax-8860075658
- 29) President (Commercial), APNRL, Crescent Tower, 3rd Floor, Kolkata-700020, Fax-033-3091-5344
- 30) Associate Vice President (CC), GMR Kamalanga Energy Ltd. (GKEL), Bhubaneswar (Fax : 0674 2303994)
- 31) GM (BD&PS), NVVN Ltd, Scope Complex, Core-3, 7th Floor, Lodhi Road, New Delhi-110003
- 32) GM (Power Sales), JITPL, Plot-12, Local Shopping Complex, Sector B-1, Vasant Kunj, New Delhi-110070 (Fax:011 26121734)



MINUTES OF THE 35th COMMERCIAL SUB COMMITTEE MEETING OF ERPC

DATE: 02.08.2017

TIME: 1100 HRS

VENUE: ERPC CONFERENCE HALL, KOLKATA

**MINUTES OF THE 35th COMMERCIAL SUB-COMMITTEE MEETING OF ERPC
SCHEDULED HELD ON 02.08.2017 (WEDNESDAY) AT 11:00 HRS AT ERPC,
KOLKATA**

**ITEM NO. 1 Confirmation of the minutes of the 34th Commercial Sub-Committee meeting
held on 06.02.17**

The minutes of the 34th Commercial Sub Committee meeting were intimated vide ERPC letter No-ERPC/COM-I/GEN/2016/1857 dated 13.02.2017

No request for amendment has been received by ERPC Secretariat.

Members may confirm the minutes of the 34th Commercial Sub Committee Meeting.

Deliberation in the meeting

Members confirmed the minutes of the 35th Commercial Sub Committee meeting.

ITEM NO. 2 Payment/Receipt Status from various pool accounts in ER

a) Payment of Deviation Charge – Present Status.

As informed by ERLDC, The status of Deviation Charge payment as on 20.07.2017 is enclosed at **Annexure – I**. The current principal outstanding Deviation Charge of BSPHCL & JUVNL is **Rs. 24.40 Cr & Rs. 10.79 Cr** respectively considering bill up to 09.07.2017. Moreover, an interest amount of **Rs. 50.14 Lacs and Rs. 30.56 Lacs** (as on 20.07.2017) is also payable by BSPHCL & JUVNL respectively due to delay payment of DSM charges. ERLDC has also given reminders to BSPHCL on 28.06.17 & 20.07.2017 requesting to liquidate the entire Deviation charges.

SIKKIM, APNRL and IBEUL are not paying deviation charges amount to the Pool and waiting for adjustment with the receivable amount.

JUVNL, BSPHCL, APNRL, SIKKIM & IBEUL may confirm the program for payment of outstanding dues.

Deliberation in the meeting

ERLDC updated that BSPHCL had partially liquidated their dues and the present outstanding is around Rs. 16.89 Cr. The outstanding against JUVNL has increased to 11.74 Cr. The interest amount outstanding is around Rs.54 Lacs and 32 Lacs against BSPCHCL and JUVNL respectively.

BSPHCL representative informed that the outstanding would be liquidated by the end of this month. JUVNL representative was absent.

ERLDC requested BSPHCL to clear the dues before the ensuing TCC/ERPC meetings scheduled on 25-26.08.2017.

b) Disbursement of Interest due to delayed payment of deviation charges

As intimated, ERLDC had received/recovered interest amount from JUVNL, BSPHCL and APNRL towards interest due to delayed payment of deviation charges in FY 2016-17. Same amount was paid towards deviation interest payment to the receiving constituents and Ancillary services. Details of Interest disbursement are mentioned in **Annexure-II**. With this, outstanding deviation charges including interest for all the ER constituents (*except APNRL which has Rs. 28,476 & Vedanta has Rs. 3, 51,637 towards interest*) along with Inter-regional Pool during FY 2016-17 are fully settled.

This is for information to the members.

Deliberation in the meeting

ERLDC requested intervention of GRIDCO for resolution of issues related to Vedanta as they have ceased to be a member of ER Pool. GRIDCO representative requested ERLDC to write to Vedanta with a copy to GRIDCO so that the issue could be taken up with appropriate authorities.

c) Reactive Energy Charges – Present Status.

The updated position of Receipt/Payment of Reactive Energy Charges in the pool as on 25.07.2017 (considering bill up to 09.07.2017) is indicated in **Annexure – III**. The total outstanding receivable on account of Reactive charges from WBSETCL/WBSEDCL is **Rs. 2.41 Cr** & from **BSPHCL** is **Rs. 0.94 Lac**.

Out of the above amount of **Rs. 2.41 Cr**, reactive amount receivable from WBSEDCL prior to 04.01.2016 is **Rs. 1.82 Cr** (prior to Suo-moto order dated 21.07.2016 of the Hon'ble WBERC in the matter of case no: SM-14/16-17)

In response to a request by ERPC, a letter has been received from Hon'ble WBERC recently (at **Annexure-L**) in which the state Commission has advised to settle bills prior to 04.01.2016 as per practice being followed at that time.

WBSETCL/WBSEDCL & BSPHCL may confirm the program for payment of outstanding dues.

Deliberation in the meeting

BSPHCL informed that they have liquidated their outstanding amount. WBSETCL informed that they have paid an amount of Rs. 60 Lakhs towards reactive energy charges.

WBSETCL informed that for some bills raised by ERLDC clarifications were required. For the period prior to 04.01.2016 for settlement of reactive bills for the state of West Bengal, it was informed that a clarification had been received from Hon'ble WBSERC in which the state Commission has advised to settle bills prior to 04.01.2016 as per practice being followed at that time. WBSETCL and WBSEDCL representatives informed that they would take action as per the directions of the Commission.

d) RRAS Account ----Present Status

The updated position of Payments to the RRAS Provider(s) from the DSM pool and Payments by the RRAS Provider(s) to the DSM pool as on 20.07.2017 (considering bill up to 09.07.2017) is indicated in **Annexure – IV**. So far **Rs. 53.3 Cr** have been settled under RRAS in ER during FY 2017-18.

This is for information to the members.

Deliberation in the meeting

Members noted.

GRIDCO representative informed that initially there had been some delay in receiving reimbursement of capacity charges from NTPC. NTPC informed that there were some teething troubles initially which have been streamlined. GRIDCO representative opined that there should be provision for interest payment in case of delay of Generators in reimbursement of capacity charges.

GRIDCO representative stated while they are making payment to ERLDC on behalf of their open access customers on time, some of their open access customers were delaying payment to GRIDCO. ERLDC opined that GRIDCO should take up with the state regulatory commission for dealing with such situations.

e) Congestion account - Present Status

ERLDC have informed that the status of congestion charge payment after full settlement is enclosed at **Annexure – V**

Members may note.

Deliberation in the meeting

Members noted.

f) Status of PSDF

As intimated, an amount of **Rs. 21.34 Cr** from Reactive account have been transferred to PSDF after 34th Commercial sub-committee meeting held on 06.02.17. With this the total amount of **Rs. 921.7 Cr** has been transferred to PSDF so far. *No amount from Deviation pool has been transferred to PSDF A/c since 29.06.16 and surplus amount in deviation pool is being utilized for settlement of RRAS Bill.* The break up details of fund transferred to PSDF (till 25.07.17) is enclosed in **Annexure VI**.

This is for information to the members.

Deliberation in the meeting

Members noted.

ITEM NO. 3 Reconciliation of Commercial Accounts

i. Deviation Account

At the end of 1st quarter of 2017-18, the reconciliation statement (Period: 01.04.17 to 30.06.17) has been issued by ERLDC on 04.07.17 and statements had been sent to the respective constituents and also uploaded the same at ERLDC website (www.erldc.org). The constituents were requested to verify /check the same & comments if any on the same were to be reported to ERLDC by 21.07.2017. The status of reconciliation is enclosed in **Annexure-VII**.

BSPHCL, JUVNL, DVC, WBSETCL, SIKKIM, MPL, APNRL, JITPL, IBEUL, TPTCL, JLHEP (DANS Energy), TUL & DICKCHU have not signed reconciliation statement for 1st quarter of 2017-18. Further JUVNL, SIKKIM, MPL, APNRL, JITPL & TPTCL have not signed reconciliation statement for previous Quarter of 2016-17.

JLHEP (DANS Energy) & IBEUL have not yet signed any reconciliation statement since becoming regional entity.

Above constituents are once again requested to submit the signed reconciliation statement at the earliest.

If the confirmation is not received within 2 weeks from the date of issuance of letter the statements issued by ERLDC have been deemed to be reconciled.

Deliberation in the meeting

It was updated that WBSETCL and BSPHCL had reconciled. DVC committed to get the statement reconciled within 10.08.2017. MPL representative informed that they would reconcile at the earliest. JLHEP and Dikchu HPS have got deviation statements reconciled.

Beneficiaries yet to reconcile were requested to get their

ii. Reactive Account

At the end of 1st quarter of 2017-18, the reconciliation statement (Period: 01.04.17 to 30.06.17) has been issued by ERLDC on 04.07.17 and statements had been sent to respective constituents and also uploaded the same at ERLDC website (www.erldc.org). Constituents were requested to verify /check the same & comments if any on the same were to be reported to ERLDC.

WBSETCL may reconcile the Reactive account.

Deliberation in the meeting

It was informed that WBSETCL have reconciled the Reactive Account.

iii. RRAS Account

At the end of 1st quarter of 2017-18, the reconciliation statement (Period: 01.04.17 to 30.06.17) has been issued by ERLDC on 04.07.17 and statement had been sent to

RRAS Provides and also uploaded the same at ERLDC website (www.erldc.org). RRAS Provider i.e NTPC has already reconciled the RRAS Account.

This is for information to the members.

Deliberation in the meeting

Members noted.

iv. Short Term Open Access

a. For STOA payments made to SLDC / STU:

The reconciliation statements of STOA payments for the period Apr'17 to Jun'17 have been sent to the DVC, OPTCL and WBSETCL for checking at their end and confirmation.

WBSETCL has confirmed for the entire period. DVC is yet to confirm for the month Apr-17 & Jun-17. OPTCL is yet to confirm only for Jun-17.

As per clause 15.1 of CERC approved STOA bilateral procedure since the confirmations have not been received within 2 weeks from the date of issuance of the letters the statement issued by ERLDC have been deemed to be reconciled.

Members may note.

Deliberation in the meeting

OPTCL informed that they have reconciled the STOA payments. DVC informed that they will complete the reconciliation at the earliest.

b. For payments made to STOA applicants:

The reconciliation statements of STOA payments for the period of Apr'16-Mar'17 have been sent to the CESC, DVC, GMRKEL, JITPL, JUVNL, SAIL-RSP, TATA Steel(Discom),TSFAP Bamnival,TSFAP Joda,TSL Kalinganagar and WBSEDCL for checking at their end and confirmation.

CESC, GMRKEL, TSL (Discom),TSL Kalinganagar,TSFAP Joda has confirmed for the entire period. JITPL,JUVNL, WBSEDCL and TSFAP Bamnival are yet to confirm for the period of Jan-17 to Mar-17. SAIL-RSP is yet to confirm for the period of Jul-16 to Mar-17.

The reconciliation statements of STOA payments for the period of Apr'17-Jun'17 have also been issued.

As per clause 15.1 of CERC approved STOA bilateral procedure since the confirmations have not been received within 2 weeks from the date of issuance of the letters the statement issued by ERLDC have been deemed to be reconciled.

The details is attached in the **Annexure-VIII**

Since there is a serious audit objection on non-signing of DSM, Congestion and STOA reconciliation statement it is once again requested that all regional pool members may check and sign the statement sent by ERLDC.

Members may take necessary action for signing the statements at the earliest.

Deliberation in the meeting

WBSEDCL informed that they would get reconciliation completed at the earliest.

JUVNL, JITPL representatives were not present.

All beneficiaries were requested to get the statements reconciled so that audit issues could be avoided.

ITEM NO. 4 State Transmission Utility Charges and Losses applicable for STOA for FY 2016-17

As available with ERLDC the STU charges and losses to be considered for STOA for FY 2017-18 is as follows:

Name of STU	Intra-State Transmission Charges	TRANSMISSION LOSS (For Embedded entities)
WBSETCL	*	3.10%
DVC	Rs. 80 / MWh	3.04%
OPTCL	Rs. 62.5 / MWh	3.70%
JUSNL	*	#
BSPTCL	*	#
SIKKIM	*	#

N.B:* Indicates rates yet to be furnished by concerned State Utilities. Transmission Charges for use of

state network shall be Payable @ Rs.80 per MWh as per subsequent Amendment regulation 2009-

dated 20.05.2009.

Not yet intimated by the State Utility.

State Load Despatch Centre Operating Charges for STOA for FY 2017-18

Name of SLDC	SLDC Operating Charge
West Bengal	**
DVC	**
Odisha	Rs. 2000
Jharkhand	**
Bihar	**
SIKKIM	**

N.B:

** Indicates rates yet to be furnished by concerned State Utilities.

Operating charges at the rate of Rs 1000/-, per day or part of the day for each bilatera

1 transaction for each of the Regional Load Despatch Centre involved and at the rate of Rs 1000/- per day or part of the day for each State Load Despatch Centre involved shall be payable by the applicant as per subsequent Amendment regulation 2009-dated 20.05.2009.

This is for information to the members.

Deliberation in the meeting

DVC informed that their transmission loss figures have been revised to 2.68 % for 2017-18. OPTCL informed that their rate has been revised to 3.5 % for 2017-18.

ERLDC requested constituents to inform immediately upon revision of transmission loss, Intra state transmission charges, Operating charges of SLDC, etc through letter/e-mail. The change would be effected on receipt of the intimation. Retrospective revision would not be carried out.

ITEM NO. 5 Information of Deviation/reactive payment in ER pool account

Constituents of Eastern region are making payment of Deviation charge and Reactive Charge in ER Pool Accounts. However ERLDC is not getting details of payment made in ER pool account. In 31st and subsequent CCM, all the ER pool members were requested to send the details of payment in the format (given below) to ERLDC in the email account at erldcomml@posoco.in.

S.No	Name of Utility	Amount	DSM/Reactive Account Week No	Date	Cheque No	Mode of Payment

APNRL, DANS Energy, JLHEP, TPTCL and MPL are sending the details.

DVC and WBSETCL are sending through Hard Copy.

Other constituents may furnish the details of payment made in ER Pool.

Deliberation in the meeting

Members were requested to inform ERLDC as per format so that payment reconciliations could be done at the earliest.

Members noted.

ITEM NO.6 Opening of LC by ER constituents for DSM payments

The details of LC amount required to be opened in 2017-18 by ER constituents is given in **Annexure - IX**. Letters to this effect has already been issued by ERLDC to the defaulting entities viz, BSPHCL, GMR, GATI, JITPL, IBEUL, BRBCL, JLHEP (DANS Energy), TPTCL, NVVN (Nepal) and TUL. At present JUVNL, Sikkim, APNRL & BRBCL have valid LC. Rest of the constituents which were required to open/recoup the LC, have not opened/recoup the LC.

BSPHCL, GMR, GATI, JITPL, IBEUL, JLHEP(DANS Energy), TPTCL, NVVN(Nepal) and TUL may please intimate the latest status.

Deliberation in the meeting

BSPHCL representative informed that opening of LC was under process and it would be opened shortly.

GMR, GATI, JITPL, IBEUL, JLHEP(DANS Energy), TPTCL, NVVN(Nepal) and TUL were once again advised to get the LC opened as per regulatory requirement.

Member Secretary opined that STOA to defaulting entities may be denied as per decision of ERPC.

It was decided that ERLDC would write letter to all defaulting constituents for opening of LC within a specified time frame with the condition that if they fail to open the LC, STOA would be denied. The outcome would be placed before the ensuing TCC/ERPC meetings.

ITEM NO.7 Updation of CT/PT Ratio

The meter details along with the CT/PT ratio are uploaded at ERLDC website (www.erlhc.org). The constituents are requested to check CT/PT ratios being used. Comments/discrepancies, if any, on the same may please be communicated to ERLDC at the earliest. So far no discrepancy has been reported to ERLDC.

Members may please update.

Deliberation in the meeting

NHPC representative informed that the meter serial number needed to be checked for Teesta-Rangpo line 1 at Teesta end. ERLDC assured that it would be checked and corrected if required.

ITEM NO.8 Meter readings related issues

i. Dehri (BSPTCL)

Dehri (BSPHCL) end meter NP-6097-A installed for 220 KV Pusauli (PG) line is recording 2/3rd reading as compared to Pusauli end meter data since 03.07.17. The above problem was informed to BSPTCL, Gaya (PG) and Pusauli (PG) through email with request to check CT and PT connection along with PT Fuse at Dehri. Meter data validation of the aforesaid line is not possible until meter data at Dehri end is correct.

BSPTCL / PGCIL may please update.

Deliberation in the meeting

Powergrid requested BSPTCL to check the CT/PT connections. BSPTCL representatives informed that they would check and inform to Powergrid.

ii. Chandil (JUVNL)

Chandil (JUVNL) end meter NP-7436-A installed for 220 KV Santaldih (WB) line is recording 1/4th reading as compared to Santaldih end meter data since 07:45 Hrs of 19.07.17. The above problem was informed to SLDC Ranchi & PGCIL through email with request to check Healthiness of meter as well as CT and PT connection along with PT Fuse at Chandil. Meter data validation of the aforesaid line is affected since 19.07.17.

JUVNL may respond.

Deliberation in the meeting

As JUVNL/JUSNL representative was absent it was decided to bring it to the notice of TCC.

ITEM NO.9 Non Receipt of SEM data from Various Locations

i. Kurseong, Kalimpong & Rammam (WBSETCL)

SEM data of all 132kV and 66 kV tie lines from Kurseong, Rammam & Kalimpong end respectively are not being sent to ERLDC since 19.06.17 due to on-going protests in North Bengal area. These metres are also not reporting to AMR since 16.06.17 due to communication failure. Due to non-receipt of SEM data from the above mentioned locations, standby meter is used for WBSETCL energy calculation. WBSETCL is requested to advise its vendor M/s Squarem Tech to collect the SEM data from the above locations and send the same to ERLDC by every Tuesday after normalisation of the North Bengal situation.

WBSETCL may please respond.

Deliberation in the meeting

WBSETCL representative informed that due to political unrest in the concerned areas sending of data to ERLDC had become difficult. However, when opportunity presents, data will be collected and send.

ii. Samastipur (BSPTCL)

220kV Samastipur (BSPTCL) – Darbhanga (DMTCL) line has already been charged and line is loaded since 16.04.17. Interface meter has been installed at Samastipur end of the aforesaid Line. As this line is a Tie Line of BSPHCL and SEM data is not received since the charging of line. Data validation of Darbhanga (DMTCL) end meter is not possible due to unavailability of meter data from Samastipur.

The matter of non-availability of Samastipur data was last discussed in 135th OCC meeting held on 24.07.17 where BSPTCL agreed to send the SEM data by arranging

laptop at their end. However Samastipur end data is still not being sent from BSPTCL end.

BSPTCL may please respond.

Deliberation in the meeting

It was informed that the data from Samastipur is now available.

iii. Nabinagar Power Generation Company (NPGC), BSPTCL

132kV Rihand-Sonenagar Line is made LILO at NPGC (BSPTCL) almost two months back. Now, 132kV Rihand-NPGC is the new tie line of NR-ER corridor. Meter is installed at NPGC end for both 132kV Rihand (NR)-NPGC and 132kV Sonenagar (BSPTCL)-NPGC feeders. SEM details are available with ERLDC but data is not yet been received by ERLDC since the installation of meter.

BSPTCL may please respond.

Deliberation in the meeting

It was informed from BSPHCL side that there was some cable issue for downloading data which is expected to be resolved by 04.08.17.

ITEM NO.10 Defective SEM at Rangpo (PGCIL)

Meter data of 5(five) nos of SEM installed at Rangpo (PG) is not being sent to ERLDC since last one & half month. Rangpo (PG) was asked via e-mail and telephonically to send the SEM data to ERLDC. It was informed by Rangpo (PG) that meters are not working and the problem started after time correction of respective meters. The meter details are as below:

NP-7623-A 220 KV SIDE OF RANGPO 100 MVA 220/132 ICT-3
NP-7622-A 400 KV SIDE OF RANGPO 315 MVA 400/220 ICT-2
NP-7621-A 400 KV SIDE OF RANGPO 315 MVA 400/220 ICT-1
NP-7619-A 400 KV RANGPO (PG)-TEESTA (NHPC) LINE-2
NP-7620-A 400 KV RANGPO (PG)-BINAGURI (PG) LINE-2

The matter was informed to ERTS-II, Powergrid for replacement of defective meters. The meter is yet to be replaced at Rangpo end. Due to non-receipt of meter data of so many meters at a time, data validation and energy accounting is very difficult.

PGCIL may please update the status.

Deliberation in the meeting

Powergrid representative informed that meter had reached Rangpo S/S and would be replaced shortly.

ITEM NO.11 Installation of Check & Standby Meters at Tie Lines

i. New Town & Bantala (WBSETCL)

Two nos of 220kV feeders are feeding power to Bantala and Newtown from Subhasgram (PG). SEM is placed only at Subhasgram (PG) end for the above lines whereas no standby meters has been installed at Bantala as well as Newtown end. In absence of Subhashgram(PG) end data, no back up meter available for the above lines for accounting of the power flow through these Tie lines. *As per CEA Metering regulation, meter is required to be installed at both end of the line between substations of two different Licensees.*

PGCIL/WBSETCL is requested to coordinate action for installation of meter.

Deliberation in the meeting

Powergrid representative informed that meters are available. Meters would be handed over to WBSETCL for installation.

ii. EM Bypass (WBSETCL)

SEM are placed at Subhasgram (PG) end only for 220kV Subhasgram (PG)- EM Bypass D/C. No standby meters has been installed at EM Bypass (WBSETCL) end. In absence of Subhashgram (PG) end data; there is no back up meter available for accounting of the power flow through these Tie lines. *As per CEA Metering regulation, meter is required to be installed at both end of the line between substations of two different Licences.*

PGCIL/WBSETCL is requested to coordinate action for installation of meter.

Deliberation in the meeting

CESC representative informed that they already have SECURE make ABT compliant meters installed. CESC representative also opined that there may be difference in burden of different make of meters.

It was clarified that as per CEA metering regulations for inter-state meters, the SEMs are to be procured and handed over to constituents by Powergrid. As per the recent purchase, Genus make meters have been procured and the same would be handed over to WBSETCL/CESC. Powergrid representative informed that nowadays all meters have similar burden.

iii. Subhasgram (WBSETCL)

SEM are placed at Subhasgram (PG) end only for 220kV Subhasgram (PG)-Subhasgram D/C. No standby meters has been installed at Subhasgram (WBSETCL) end. In absence of Subhashgram (PG) end data, there is no back up meter available for accounting of the power flow through these Tie lines. *As per CEA Metering regulation, meter is required to be installed at both end of the line between substations of two different Licences*

PGCIL/WBSETCL is requested to coordinate for installation of meter

Deliberation in the meeting

Powergrid representative informed that meters would be handed over to WBSETCL for installation.

iv. Barh (NTPC)

As per clause 7(1) of Central Electricity Authority (Installation and Operation of Meters) Regulations 2006 & subsequent amendments, Main & Check Meters are to be installed on all outgoing feeders of Generating Stations. Main and Check meters are already installed at all outgoing feeders at Barh except 400 KV Kahalgaon (NTPC) Line-1 and 400 KV Patna (PG) Line-1 where Check meter is yet to be installed. Earlier Check meter was not installed due to scarcity of meters in the region. Since Genus make meter under new procurement is already delivered, 02 nos of check meters are to be installed at Barh for the above feeders.

PGCIL/NTPC may please respond.

Deliberation in the meeting

Powergrid representative confirmed that meters were available. It was informed that NTPC had not yet placed requirement of meters. NTPC representative informed that they will place requirement immediately.

ITEM NO. 12 Implementation of Automatic Meter Reading in Eastern Region

The implementation of AMR 3rd phase was last discussed in 35th TCC/ERPC meeting held on 25.02.17 and it was informed by PGCIL that all 37 locations has been integrated to AMR. There are few locations Like Balimela, Lakisarai (PG), Darbhanga, Gyalesing (Sikkim), Rangpo, Sagbari, TUL, Alipurduar, Atri, Samangara and Sundergarh wherein AMR is yet to be integrated.

The list of meter and location of 3rd phase is in **Annexure-X**.

Presently we are receiving data from 124 locations out of total 153 locations through AMR. The status of data receipt from the locations as below:

- Number of meters for which AMR has been commissioned-820/153 DCUs
- Number of Meter & locations as per LOA/Phase-I 458 meters/97 locations.
- Number of Meter & locations as per LOA/Phase-II 198 meters/19 locations.
- Number of Meter & locations as per LOA/Phase-III 249 meters/37 locations.

- Number of meters for which data is received: 620
- Number of locations for which data is received: 124 locations
- Number of DCUs online-124 DCU
- Number of DCUs offline-29 DCU

After the phase-wise completion of AMR for the locations commissioned, some of the utilities have been asked to discontinue the sending of the weekly SEM data through mail. However, in case of an emergency or communication failure, as the case may be, the utilities may download the data through DCD/Laptop and send it by mail. As such DCD is required to be kept in charged condition. Of late, there have been issues with the GPRS communication/DCU for around 15 locations.

Powergrid may take up the issue on priority basis with the vendor and update the status of implementation for remaining locations.

Deliberation in the meeting

ERLDC expressed concern that the Genus make meters have not yet been ~~in~~ integrated in the AMR system due to one issue or the other. Powergrid informed that as multiple agencies were involved, there had been some coordination issue in the beginning. Much progress has been made in the meanwhile and data capture from Genus meters is now possible. The only pending issue was relating to the data format which would be settled shortly.

ERLDC observed that in future tenders Powergrid need to incorporate the learnings from the present case into tender process so that this type of delay in integration of meters with AMR could be avoided.

Powergrid representative agreed to bring the issues to the notice of concerned department.

ITEM NO.13 Time correction of SEMs in Eastern Region

The issue was discussed in 35th TCC/ERPC meetings and it was felt that the meters with severe drift greater than 10 min need to be replaced first and if replacement is done with Genus then readings are to be collected manually using Laptop till interfacing with AMR is completed. 35th ERPC advised Powergrid to replace the 10% of the heavily drifted SEMs with new Genus make meters in Phase-I. Subsequently drifted meter replacement work of Phase –I for 24 meters have been completed.

As per decision taken in 134th OCC meeting, another 10% heavily drifted meter list was prepared by ERLDC and given to Powergrid for replacement. However meter replacement work for 2nd phase is yet to be done. Same is enclosed in **Annexure-XI**.

POWERGRID may please further update the status.

Deliberation in the meeting

Powergrid representatives confirmed that all the drifted meters in Phase-II would be replaced before the ensuing TCC/ERPC meetings.

ITEM NO.14 Non-submission of weekly SEM readings by Tuesday noon from non- AMR Locations/ faulty AMR locations

As per IEGC (effective from 3.5.2010) Sub-clause-22 of Clause-6.4 (demarcation of responsibilities), all concerned utilities in whose premises SEMs are installed shall take weekly meter readings and transmit the same to RLDC by Tuesday noon for timely issuance of Deviation account Bill. Significant improvement in timely receipt of SEM data has been seen after AMR implementation at various locations and most of the meter data is being received by Tuesday. Recently Genus meters are installed at few locations in Eastern Region and integration of Genus meter in AMR is under progress, data of those Genus meters are being sent manually. However general trend of receipt of readings is as below:

By Wednesday or later: Birpara, Ranchi New, Pusauli, Rangpo, WBSETCL (North Bengal) & SIKKIM

Constituents are requested to send data on time.

Deliberation in the meeting

Constituents where readings were getting delayed were requested to send the data on time.

ERLDC informed that due to non-integration of Genus meters in AMR some of the streamlined stations were also going in default mode.

GM, ERLDC informed that introduction of 5 minutes scheduling and dispatch were being actively discussed by the policy makers and may become a reality in near future. In such a scenario, current SEM's need to be either retrofitted or replaced by 5 minute meters. Powergrid may discuss with the vendors of existing meters for options available.

ITEM NO.15. Procurement of new SEM's and DCD/Laptops

In 30th ERPC meeting procurement of 965 no of SEM's and 110 nos of Laptop/DCD (in 111th OCC meeting) was approved. Further 31st TCC/ERPC approved the cost sharing mechanism of expenditure on SEM's and DCD/Laptops along with POWERGRID overhead charges @ 15% to be shared by the beneficiaries constituents of Eastern Region in proportional to the share allocation for the month in which the proposal was approved in the ERPC meeting.

In 33rd TCC/ERPC, PGCIL informed that delivery is expected in six phases starting August'16. In 34th CCM held on 06.02.17 and 35th TCC/ERPC meeting held on 24.02.17 & 25.02.17, Powergrid informed that receipt of Genus make meters have already started and had been installed in some locations and their integration with AMR was under process by M/s TCS.

Powergrid may further update the status of meter procurement.

Deliberation in the meeting

Powergrid updated that 300 meters and 40 laptops with software had been supplied by M/s Genus so far.

Members noted.

ITEM NO.16. Integration of Genus Make meter in AMR

In Eastern Region, order for procurement of 965 no of SEM's was placed with M/s Genus Power. First Lot of the meters have already been delivered by Genus and 24 meters of Genus make meter has been installed in different substation in ER. Issue of Integration of Genus make meters in AMR system was discussed in meeting held with PGCIL, ERLDC, M/s Genus, & M/s TCS on 02.03.17 at ERLDC. In 133rd OCC, Powergrid informed that it will take some more time and asserted it will be done by June, 2017.

In 134th OCC, Powergrid informed that communication of meter in AMR system is established and DCU able to read the Genus make meter data however there are some issues related to baud rate of communication and testing is in progress at Subashgram (PG). It is expected to be completed by July, 2017.

Powergrid may please further update.

Deliberation in the meeting

The issue was already discussed in Item 12

ITEM NO.17 Accounting of Tertiary Loading Arrangement at PGCIL s/station in ER

Auxiliary consumption of PGCIL EHV AC sub stations are usually met from HT feeders of the State Discom. In few substations of PGCIL, auxiliary consumption is met through tertiary winding (as alternate supply for reliability). At present State net drawl through Powergrid substation in ER is being computed considering meter installed at feeders after LV side of Transformer. Those sub stations where auxiliary requirement is met through tertiary, States net drawl need to be computed by adding drawl through feeders after LV side of Transformer and auxiliary consumption through tertiary.

In NR, WR & SR, auxiliary power through tertiary is already being accounted in States net drawl.

In order to account for the drawl through tertiary for Auxiliary consumption, PGCIL is requested to:

1. Provide list of substations in ER where auxiliary supply is met through tertiary.
2. Install SEM on 33 KV tertiary side of transformers used for auxiliary supply.

133rd OCC advised Powergrid to send the readings of SEMs connected to tertiary windings to ERLDC regularly for accounting purpose. Further OCC decided that after getting the SEMs details of all tertiary loadings, ERPC/ERLDC will devise a mechanism for accounting of the tertiary loading arrangement.

In 134th & 135th OCC, Powergrid was advised to submit the details of pending SEM details connected to tertiary windings and also the SEM readings on regular basis to ERLDC and ERPC for accounting of the tertiary loading arrangement.

Status of meter details and receipt of their data at ERLDC from Powergrid ER-I, ER-II and Odisha project is at **Annexure-XII**

Powergrid may update the status.

Members may discuss.

Deliberation in the meeting

It was decided that the drawal of auxiliary power from tertiary winding by Powergrid substations would be treated as state drawl for inter-regional accounting. Powergrid and the states would make back to back commercial arrangements for this power.

ERLDC requested Powergrid to submit the requisite information such as meter no, CTR, PTR, etc in respect of those meters and also make meter readings available on time.

Powergrid agreed to make the necessary data available before the ensuing TCC/ERPC meetings.

ITEM NO.18 Nomination of Nodal Officers by Regional Entities to ERLDC

All Regional entities is requested to intimate the contact details of the Nodal Officer who could coordinate with their sites and ERLDC to ensure the following:

- Under - recording of SEM data due to reasons such as CT/PT input problems
- Polarity reversal
- Change in CT/PT ratio
- Meter replacements
- Completeness w.r.t no of meters and no of days
- Checking of time drift in meters: correction and reporting to RLDC
- Data non-availability due to reasons such as outage of Feeder etc.

It was requested to furnish the details like Name, designation, Mailing address, Landline No, Fax No, Email Id, Mobile No etc. to ERLDC for smooth transaction of SEM data.

So far details of Nodal person only from BSPHCL, GATI, DVC, Teesta-V, NTPC ER-I(HQ), Talcher NTPC, GMR, BRBCL and GRIDCO have been received by ERLDC.

In the last CC meeting, PGCIL nominated Shri Partho Ghosh & Shri Rajesh as Nodal Officers for ERTS-I.

All remaining constituents are once again requested to send the details of Nodal person from their end.

Deliberation in the meeting

ERLDC informed that inspite of communicating with the nodal person difficulties had been faced by them for coordination. DVC representative requested ERLDC to contact him directly in case there were coordination issues. Rangit representative provided the details of nodal officer.

Powergrid informed that they were facing access issues while sending personnel to constituent's premises for replacement of meters, testing, etc. GM, ERLDC felt that in general the SLDC Chief in case of states and Station Head in case of generating station may be taken to be nodal officers for coordinating meter related issues. Members agreed.

ITEM NO.19 Despatch of power from Farakka-III under RRAS-ERLDC agenda

The Eligibility for participation for Reserves Regulation Ancillary Services under clause 5.1 of Ancillary Services Operations regulation states that:

Quote:

“5.1. All Generating Stations that are regional entities and whose tariff is determined or adopted by the Commission for their full capacity shall provide RRAS.”

Unquote

As per CERC order 280 GT 2014 dated 03.03.17 Hon'ble commission has determined tariff for 500 MW i.e. for full capacity for Farakka Stage-III. Therefore Farakka Stage-III should come under the ambit of RRAS and shall provide necessary formats such as AS-1, AS-2.

ERLDC may elaborate.

Members may discuss.

Deliberation in the meeting

ERLDC informed that as the tariff for Farakka Stage-III had been decided by the Hon'ble commission for full capacity, the station should participate in RRAS. Further it was informed that participation in RRAS would help in getting a higher schedule for the station.

NTPC representative informed that as there was 15 % merchant capacity in FSTPS-III which needs to be considered. ERLDC opined that FSTPS-III would be scheduled under RRAS keeping in view its merchant nature.

NTPC sought some time to sort out the commercial implications with their Corporate office.

ITEM NO.20. Agenda items submitted by Powergrid

a) Non Opening of LC requisite amount of LC :

Following constituents are required to enhance/ extend LC towards Payment Security Mechanism, as per CERC Regulations:

Beneficiary	Present Value of LC	Amount (in Cr.)
		Value of LC Required
North Bihar Power Distribution Company Limited(NBPDCL)	3.85	29.00
South Bihar Power Distribution Company Limited(SBPDCL)	15.27	40.00
Ind-Bharat Energy (Utkal) Limited	14.38	20.68

Non-availability of LC for requisite value and validity as per CERC Regulations is causing serious problem for POWERGRID to comply with the provisions of CERC Regulations and Loan Covenants.

Members are requested to utilize their good office and resolve the matter.

Deliberation in the meeting

BSPTCL representatives informed that as per their knowledge the fund requirement had been placed before the Holding company (BSPHCL) which is responsible for coordination of commercial accounts.

IBUEL representative was not present.

MS, ERPC felt that Powergrid may put their appeal for payment before the TCC/ERPC members.

b) Payment of Outstanding dues more than 60 days :

Beneficiary	Amount (in Cr.)	
	Total Outstanding dues	Outstanding due more than 60 days
South Bihar Power Distribution Company Limited(SBPDCL)	152.54	69.46
Bhartiya Rail Bijlee Company (BRBCL)	17.82	11.95
Ind-Bharat Energy (Utkal) Limited	114.92	95.61

Members are requested to kindly intervene in the matter.

Deliberation in the meeting

c) Issue related to non-payment of Transmission charges & non-renewal of LC by Ind-Bharat(Utkal) Limited :

A special meeting was convened on 22.05.17 at ERPC Kolkata issues on Commencement of Commercial Power transaction from Unit # 1 of Ind Barath. In the said meeting Ind Barath has agreed to follow the direction CERC vide Petition no 127/MP/2016 along-with IA 2/2017. After giving the assurance till date Ind Barath has neither pay **Rs 10.0 Cr** nor starting balance amount including surcharge in 12 monthly instalments. However Ind Barath has opened an LC of **Rs 14.28 Cr** which is not sufficient & not in line with our terms & conditions. As on date the total outstanding towards our transmission charges comes to **Rs 114.92 Cr.** out of which **Rs 95.61 Cr** has already cross the limit of **60 days**.

Members are requested to kindly intervene in the matter.

Deliberation in the meeting

IBUEL representative was not present.

Powergrid representative informed that M/s IBUEL had not complied with the directions of CERC also. ERLDC informed that M/s IBUEL had not engaged in any commercial transaction.

d) List of new Assets commissioned

List of Assets commissioned by POWERGRID is enclosed as **Annexure-XIII**.

Members may note

Deliberation in the meeting

Members noted.

e) Drawal of Power by JUSNL from Daltonganj 400/220/132kV S/s(PG):

JUSNL has finalised their downstream of 220Kv & 132Kv TL to evacuate the power from Daltonganj (PG) S/S. 400/220Kv Daltonganj (PG) S/S under ERSS III & 220/132Kv Daltonganj (PG) S/S under ERSS XVII are to be scheduled in October'17. The following downstream work would be constructed by JUSNL to match for drawl of power from 220Kv & 132Kv level from Daltonganj (PG) :

Eastern Region System Strengthening Scheme III :

- Daltonganj (POWERGRID) – Latehar 220Kv D/C
- Daltonganj (POWERGRID) – Garhwa 220kV D/c

Eastern Region System Strengthening Scheme XVII:

- Daltonganj (POWERGRID) – Daltonganj (JUSNL) 132kV D/C
- Daltonganj (POWERGRID) – Chatarpur/Lesliganj 132kV D/c

Contingent plan:

The contingent arrangement for the evacuation of power from Daltonganj Substation shall be connecting through existing 220kV D/C Daltonganj-Latehar (presently charged at 132 kV) line passes through Daltonganj SS (PG), which require the diversion, at a distance of about 1km from Daltonganj(PG) only & It is to be disconnected when the original 132kV line from Daltonganj(PG) to Daltonganj(JUSNL) become ready by M/s R S Infra Private Limited.

JUSNL requested to expedite the transmission line of 220 kV & 132 kV for normalization of the system as required.

*Powergrid may elaborate.
Members are requested to discuss*

Deliberation in the meeting

Members felt that Commercial Sub-Committee meeting may not be the correct forum for discussions on transmission planning.

It was decided to refer the issue to TCC.

f) Diversion of spare transformer from Gaya(765kV) to New Ranchi(765kV) :

One number 500 MVA 765/400Kv Transformer was approved in 24th ERPC meeting dated 26.04.13 for Gaya S/s as regional spare, Now this Spare we are keeping at Ranchi 765/400Kv substation.

This is for information to the members.

Deliberation in the meeting

Members agreed.

ITEM NO. 21 Agenda items submitted by NHPC

1) Signing of reconciliation statement.

Reconciliation statements are pending for IVth quarter for the F.Y 2016-17 in respect of GRIDCO, NBPDCCL & SBPDCL whereas reconciliation statements for 1st quarter of 2017-18 have also been sent to all the beneficiaries which also need to be signed on priority.

NHPC may elaborate.

Deliberation in the meeting

BSPTCL requested NHPC to send their representatives preferably on 09.08.2017 for getting the statements reconciled. NHPC agreed.

2) Payment of Late Payment Surcharge by WBSEDCL.

A late payment surcharge of Rs. 1.14 Crs is pending against WBSEDCL since long in respect of Rangit and Teesta-V Power Stations despite many reminders from NHPC. WBSEDCL may be requested to release the said amount on priority.

NHPC may elaborate.

Deliberation in the meeting

WBSSEDCL representative informed that a decision would soon be taken by their management and accordingly the issue would be resolved.

3) Non-Opening of LC of requisite value.

NBPDCL, SBPDCL and JBVNL have not provided the LC of requisite amount NBPDCL, SBPDCL & JBVNL be requested to open L.C amounting to Rs. 6.41 Crs, Rs.9.23 Crs and Rs. 8.34 Crs respectively at the earliest being a statutory requirement as per PPA .

NHPC may elaborate.

Deliberation in the meeting

Representatives from Jharkhand were not present. It was decided that issues related to Bihar could be taken up during the visit of NHPC representatives on 09.08.2017 to Bihar.

4) Extension of PPA in r/o TLDP-III & IV Power Stations.

WBSSEDCL at present has valid PPAs for TLDP-III & IV projects for 05 years period only which are expiring on 31.03.2018 and 10.03.2021 respectively. WBSSEDCL be again requested to extend the PPA for a period of 35 years from COD of power stations.

NHPC may elaborate.

Deliberation in the meeting

WBSSEDCL representative informed that the issue of cost overrun was subjudice and therefore decision could not be taken.

NHPC requested to get the agreement signed which would be subject to the outcome of the judicial process.

5) Signing of PPA in respect of Tawang H.E.Project, Stage-I & II.

Signing of Power Purchase Agreement is pending with GRIDCO, JBVNL & WBSSEDCL. All the three beneficiaries may be again requested to sign the long pending Power purchase agreement at the earliest.

NHPC may elaborate.

Deliberation in the meeting

GRIDCO representative informed that they were still examining the issue.

WBSSEDCL representative informed that there was an in principle agreement however, they would send the revised PPA for comments to NHPC before finalizing.

ITEM NO. 22 Agenda items submitted by WBSEDCL

During real time sudden contingency, to mitigate shortfall, WBSEDCL avails URS power from the NTPC power stations from which WBSEDCL has GOI allocation & thereafter from Bundle power allocation, in case of non availability normal urs power.

While placing requisition to NTPC , WBSEDCL has a practice of strictly mentioning URS allocation only from the NTPC power stations from which WBSEDCL has GOI allocation, maintaining the Merit order dispatch principle. The main reason for not mentioning the bundle source is to avoid allocation from Bundle power head , as additional 7 paisa/unit cost is incurred by the beneficiary as trading margin to NVVNL being Nodal authority of Bundle power.

But despite of the above fact, during billing it is observed that NVVNL has been billing a proportionate energy of URS power with additional cost burden of 7 paisa /unit which violates the basic philosophy of merit order dispatch principle and also poses additional financial burden to WBSEDCL.

WBSEDCL may elaborate. NTPC may respond.

Deliberation in the meeting

WBSEDCL representative explained that billing for URS from power stations in which WBSEDCL had both solar and non-solar shares NTPC/NVVN were getting the URS power also apportioned among solar and non-solar. Due to this WBSEDCL had to bear 7 paisa excess charges for the URS apportioned solar power as NVVN commission. This was violating the merit order.

GM, ERLDC responded that the issue would be looked at in detail by ERLDC and ERPC and informed to WBSEDCL and NTPC/NVVN.

ITEM NO. 23 Higher Variable Cost of Farakka-I,II &III & Kahakgaon-I, II-Agenda items submitted by GRIDCO

The detailed agenda note of GRIDCO is at **Annexure-XIV**

GRIDCO may elaborate.

Deliberation in the meeting

GRIDCO representatives informed that the variable cost of NTPC power had risen sharply in the past few months. Comparing with the other IPPs the cost appears to be much higher. They requested NTPC for clarifying the issues so that they may be able to explain to state regulator during filing of tariff.

NTPC responded that the energy charges of their generators are determined as per the guidelines of CERC. He further informed that now third party sampling is done for determination of calorific value of the coal. Therefore, the energy price/charge of NTPC is fair and transparent.

NTPC informed that submergence of Rajmahal mines due to rains led to procurement of coal from Raniganj and other mines which increased the cost of coal. He added that the NTPC energy charges indicated by GRIDCO in their energy note are provisional and would get reduced based on third party sampling received for the period.

GRIDCO requested NTPC to share the details. NTPC agreed.

ITEM NO. 24 Financial loss to Maithon Power Limited (MPL) due to load curtailment on 1st August 2016 and post facto revision of schedule—MPL agenda

- a. There was a load curtailment on 1st August 2016 due to tripping of 765 KV Raichur Solapur Feeder-2.
- b. ERLDC had not intimated MPL about the above curtailment due to which MPL has injected the schedule (122 MW) vide the MTOA approval No M_15_06 for Kerala State Electricity Board Limited (KSEBL) to the grid.
- c. This 122 MW was reflecting in ERLDC schedule and subsequently in ERPC bilateral REA for August 2016.
- d. Upon protest by KSEBL, ERLDC has revised its schedule subsequently for 1st August 2016 and ERPC also revised the bilateral REA on February 2017.
- e. No revisions were made in DSM statement for the period, subsequent to this incident.
- f. Due to this nearly 1.3 MUs power went unaccounted which has injected by MPL to the grid.
- g. This has caused financial loss to MPL to the tune of nearly Rs 30 lacs.

MPL requests this forum to help in getting back this amount.

Deliberation in the meeting

MS, ERPC stated that the issues related to the event of load curtailment on 1st August 2016 and post facto revision of schedule resulting in financial loss of MPL has been understood. ERLDC and ERPC would together study the issue and remedial measures would be taken.

SUMMARY OF DEVIATION CHARGE RECEIPT AND PAYMENT STATUS

BILL UPTO 09.07.17 (Week -14 of 2017 - 18)

Last Payment Disbursement Date - 24.07.17

Figures in Rs. Lakhs

CONSTITUENTS	Receivable	Received	Payable	Paid	Outstanding
WR	5.27659	0.00000	43665.49512	34094.49098	-9565.72755
SR	16067.86336	13458.99527	43.57998	43.57998	2608.86809
NER	14047.55241	6170.19529	4167.45508	1603.42877	5313.33081
NR	9712.49883	8616.16113	720.62661	718.97790	1094.68899
BSPHCL	4571.29056	2096.48231	34.08173	0.00000	2440.72652
JUVNL	2986.86387	1887.87093	19.67150	0.00000	1079.32144
DVC	122.76189	121.12494	1742.35864	1654.34426	-86.37743
GRIDCO	293.05575	202.24314	399.47557	350.50642	41.84346
WBSETCL	6305.59655	6008.46425	19.19944	19.19944	297.13230
SIKKIM	172.04725	0.00000	289.16270	87.11407	-30.00138
NTPC	3327.47038	3099.90996	0.00071	0.00000	227.55971
NHPC	21.58420	0.00000	662.36096	607.32796	-33.44880
MPL	10.12507	10.12102	181.68643	153.60181	-28.08057
APNRL	77.63765	0.00000	77.44552	0.00000	0.19213
CHUZACHEN (GATI)	12.21274	12.21048	174.40967	169.98045	-4.42696
NVVN(IND-BNG)	40.70515	37.49305	97.44659	97.44659	3.21210
JIITPL	134.13547	134.13547	322.40934	283.10501	-39.30433
GMR	54.74858	30.95567	365.18596	365.15336	23.76031
IND BARATH	40.10005	0.00000	0.00000	0.00000	40.10005
TPTCL(DAGACHU)	691.96393	576.07293	0.16235	0.16235	115.89100
JLHEP(DANS ENERGY)	171.27110	171.26047	40.31883	30.69707	-9.61113
BRBCL(Nabinagar)	126.64580	103.07079	0.00000	0.00000	23.57501
NVVN (IND-NEPAL)	39.13145	0.03446	319.63469	310.21307	29.67537
HVDC SASARAM	2.33430	1.80110	3.46343	3.17655	0.24632
TEESTA-III	830.30027	830.28027	260.23242	242.66771	-17.54471
DIKCHU	0.00000	0.00000	341.64727	322.18967	-19.45760
Pool Balance	0.00000	392.77755	-1655.77197	0.00000	1262.99442
Addl Deviation charge	3439.35753	5373.80435	0.00000	0.00000	-1934.44682
IRE	0.00000	0.00000	149.80549	0.00000	-149.80549
VAE	0.00000	0.00000	3974.83498	0.00000	-3974.83498
TOTAL	59865.17320	43568.88293	56416.37905	41157.36342	

Receivable:	% Realization	72.77834608	As on	24.07.17
Received	Receivable by ER POOL		Payable	Payable by ER POOL
"- ve" Payable by ER pool	Received by ER POOL		Paid	Paid by ER POOL
	"- ve" Payable by ER pool			
	"- ve" Payable by ER pool			

Interest Disbursement-I

Date: 11/04/17

Int. Amt. received by ER Pool on 06.04.17 (₹ in Lacs) from JUVNL	Constituents' Name	Amt paid	Remarks
		(₹ in Lacs)	
326.68053	DVC	0.47887	Interest for FY 16-17
	GRIDCO	0.3993	Interest for FY 16-17
	WBSETCL	0.27612	Interest for FY 16-17
	SIKKIM	3.8917	Interest for FY 16-17
	NHPC	0.43765	Interest for FY 16-17
	MPL	0.15311	Interest for FY 16-17
	BRBCL	1.49138	Interest for FY 16-17
	WR POOL	6.62404	Interest for FY 16-17
	NR POOL	8.93238	Interest for FY 16-17
	SR POOL	39.8788	Interest for FY 16-17
	NER POOL	26.8909	Interest for FY 16-17
	NTPC(RRAS Provider)	237.22628	Payment for Wk-50(Part)
	Total	326.68053	

Interest Disbursement-II

Date: 03/05/17

Int. Amt. received by ER Pool on 29.04.17 (₹ in Lacs) from BSPHCL	Constituents	Amt paid	Remarks
		(₹ in Lacs)	
61.95308	NVVN(BD)	0.00386	Interest for FY 16-17
	GRIDCO	0.00065	Balance Interest for FY 16-17
	WR POOL	0.26482	Balance Interest for FY 16-17
	NR POOL	42.55948	Balance Interest for FY 16-17
	RRAS Provider	19.12427	For payment of RRAS Bill
	Total	61.95308	

Interest Disbursement-III

Date: 01/06/17

Int. Amt. received by ER Pool on 29.04.17 (₹ in Lacs)	Constituents	Amt paid	Remarks
		(₹ in Lacs)	
37.45106 (JUVNL)	WR POOL	20.22855	Balance Interest for FY 16-17(Till 31/01/17)
5.6533 (APNRL)	RRAS Provider	22.87581	For payment of RRAS Bill
43.10436		43.10436	

STATUS OF REACTIVE CHARGES

**RECEIVABLE IN ER POOL AS PER PUBLISHED A/C UPTO 09.07.17 (2017 -18)
AS ON 25.07.2017**

CONSTITUENT	AMOUNT RECEIVABLE IN THE POOL (Rs.)	AMOUNT RECEIVED IN THE POOL (Rs.)	OUTSTANDING (Rs.)
BSPHCL	378537	284950	93587
JSEB	1137688	1137688	0
DVC	357122	357122	0
GRIDCO	175949692	175949692	0
WBSETCL	423116147	399021530	24094617
SIKKIM	326155	325817	338
TOTAL	601265341	577076799	24188542

Note: (+ve) means payable by utility & (-ve) means receivable by utility

Annexure - IV

SUMMARY OF RRAS CHARGE RECEIPT AND PAYMENT STATUS

BILL from 03.04.17 to 09.07.17 (upto Week - 14 of 2017 - 18)

Last Payment Disbursement Date -18.07.17

Figures in Rs. Lakhs

CONSTITUENTS	Receivable	Received	Payable	Paid	Outstanding
FSTPP STG-I & II	221.64809	220.77345	1726.02283	1586.13805	-139.01015
KhSTPP STG-I	137.22977	129.54275	828.71076	708.85357	-112.17018
KhSTPP STG-II	61.30545	55.93926	2569.83346	2227.78744	-336.67983
TSTPP STG-I	119.23301	110.64437	147.36165	129.40784	-9.36517
BARH STG-II	297.08899	278.75077	1598.88682	1478.43793	-102.11067
TOTAL	836.50529	795.65060	6870.81552	6130.62483	-699.33599

Annexure - V

SUMMARY OF CONGESTION CHARGE RECEIPT AND PAYMENT STATUS

**Bill upto 07.01.2013
Last Payment Disbursement Date - 13.05.2013**

Figures in Rs. Lakhs

CONSTITUENTS	Receivable	Received	Payable	Paid	Outstanding
BSEB	0.67823	0.67823	0.39118	0.39118	0.00000
JSEB	16.37889	16.37889	2.61323	2.61323	0.00000
DVC	0.00000	0.00000	6.24040	6.24040	0.00000
GRIDCO	5.34488	5.34488	0.00000	0.00000	0.00000
WBSETCL	0.00000	7.42249	4.32834	11.75083	0.00000
SIKKIM	0.65609	6.20909	0.00000	5.55300	0.00000
NTPC	6.93152	6.93152	7.42249	7.42249	0.00000
NHPC	0.70445	0.70445	0.05875	0.05875	0.00000
MPL	4.81694	4.81694	0.85169	0.85169	0.00000
STERLITE	7.70504	7.70504	0.00000	0.00000	0.00000
Pool Balance	0.00000	0.00000	21.30996	21.30996	0.00000
TOTAL	43.21604	56.19153	43.21604	56.19153	0.00000

% Realization

Receivable: Receivable by ER POOL

Received Received by ER POOL

"- ve" Payable by ER pool

As on 31.05.2015

Payable Payable by ER POOL

Paid Paid by ER POOL

"+ ve" Receivable by ER pool

DETAILS OF DISBURSEMENT TO POWER SYSTEM DEVELOPMENT FUND

Sl No	Nature of Amount	Amount transferred to PSDF (Rs in Lac)	Date of Disbursement	Cheque No	Remarks
1	Opening Balance (upto 31.03.16)	86464.58111			
2	Addl. Dev	83.33978	01.04.16		Addl Dev Charge 15-16
3	Addl. Dev	43.77416	05.04.16		Addl Dev Charge 15-16
4	Addl. Dev	31.83984	07.04.16		Addl Dev Charge 15-16
5	Addl. Dev	52.08622	11.04.16		Addl Dev Charge 15-16
6	Addl. Dev	107.23773	13.04.16		Addl Dev Charge 15-16
7	Addl. Dev	220.15330	19.04.16		Addl Dev Charge 15-16
8	Addl. Dev	76.84824	21.04.16		Addl Dev Charge 15-16
9	Addl. Dev	20.84026	26.04.16		DSM Interest 2014-15(Paid by APNRL)
10	Addl. Dev	10.01920	26.04.16		Addl Dev Charge 16-17
16	Addl. Dev	432.25696	28.04.16		Addl Dev Charge 16-17
17	Addl. Dev	117.08707	02.05.16		Addl Dev Charge 16-17
18	Addl. Dev	41.65418	04.05.16		Addl Dev Charge 16-17
19	Addl. Dev	114.33049	06.05.16		Addl Dev Charge 15-16 & 16-17
20	Deviation Interest	38.50018	06.05.16		Deviation Interest
21	Addl. Dev	35.54178	10.05.16		Addl Dev Charge 16-17
22	Addl. Dev	448.87953	31.05.16		Addl Dev Charge 16-17
23	Addl. Dev	170.51274	29.06.16		Addl Dev Charge 16-17
24	Reactive Charges	530.57497	28.09.16		Reactive Charges_15-16
25	Reactive Charges	1000.00000	26.12.16		Reactive Charges_16-17
26	Reactive Charges	779.39811	14.02.17		Reactive Charges_16-17
27	Reactive Charges	500.00000	29.03.17		Reactive Charges_16-17
28	Reactive Charges	203.61904	26.04.17		Reactive Charges_16-17
29	Reactive Charges	394.80618	30.05.17		Reactive Charges_16-17
30	Reactive Charges	256.53944	28.06.17		Reactive Charges_16-17
	Total	92174.42051			

Status of Reconciliation of Deviation Pool Account

	2016-17				2017-18
Name of The Utility	Q1 (04.07.16)	Q2 (03.10.16)	Q3 (04.01.17)	Q4 (05.04.17)	Q1(04.07.17)
Inter Regional					
WR	NO	NO	YES	NO	YES
SR	YES	YES	NO	YES	YES
NER	NO	NO	YES	YES	NO
NR	NO	NO	NO	NO	NO
Intra Regional					
BSPHCL	YES	YES	YES	YES	NO
JUVNL	YES	YES	YES	NO	NO
DVC	YES	YES	YES	YES	NO
GRIDCO	YES	YES	YES	YES	YES
WBSETCL	YES	YES	YES	YES	YES
SIKKIM	YES	YES	YES	NO	NO
NTPC	YES	YES	YES	YES	YES
NHPC	YES	YES	YES	YES	YES
MPL	YES	YES	YES	NO	NO
VEDANTA	NO	NO	NO	NO	N/A
APNRL	YES	YES	NO	NO	NO
CHUZACHEN(GATI)	YES	NO	YES	YES	YES
NVVN(Ind-Bng)	YES	YES	YES	YES	YES
NVVN(Ind-Nep)	YES	YES	YES	YES	YES
GMR	YES	YES	YES	YES	YES
JITPL	YES	YES	YES	NO	NO
INBEUL	NO	NO	NO	NO	NO
TPTCL (DAGACHU)	YES	YES	YES	NO	NO
JLHEP(DANS ENERGY)	NO	NO	NO	NO	NO
BRBCL	NO	NO	NO	NO	YES
POWERGRID	N/A	N/A	YES	YES	YES
TUL (TEESTA-III)	N/A	N/A	N/A	NO	NO
DIKCHU	N/A	N/A	N/A	N/A	YES

Note:

- (1) The dates in the bracket indicates the date of sending the Reconciliation statements by ERLDC to utilities.
- (2) YES Indicates that signed reconciliation statement received by ERLDC
- (3) NO Indicates that signed reconciliation statement is not received by ERLDC

Annexure-VIII

Reconciliation Between Open Access department of ERLDC and SLDCs, STUs				
Sl. No.	STUs / SLDCs Name	Apr-17	May-17	Jun-17
	Date of Issuance	17-May-17	15-Jun-17	14-Jul-17
1	West Bengal - SLDC and STU	YES	YES	YES
2	DVC - SLDC	NO	YES	NO
3	OPTCL-SLDC and STU	YES	YES	NO

Reconciliation Between Open Access department of ERLDC and Applicants					
Sl. No.	Applicants Name	Quarter-I (Apr-16-June-16)	Quarter-II (Jul-16-Sep-16)	Quarter-III (Oct-16-Dec-16)	Quarter-IV (Jan-17-Mar-17)
	Date of Issuance	14/07/2016	18/10/2016	13.01.17	17.04.17
1	Calcutta Electric Supply Company	YES	YES	YES	YES
2	Damodar Valley Corporation	YES	NA	NA	NO
3	GMR Kamalanga Energy Limited	YES	YES	YES	YES
4	Jindal India Thermal Power Limited	YES	YES	YES	NO
5	Jharkhand State Electricity Board	YES	YES	YES	NO
6	SAIL Rourkela Steel Plant	YES	NO	NO	NO
7	TATA Steel - Discom	NA	YES	YES	YES
8	TATA Steel Ferro Alloy Plant Bamnibal	YES	YES	YES	NO
9	TATA Steel Ferro Alloy Plant Joda	NA	NA	YES	YES
10	Tata Steel Limited Kalinganagar	NA	YES	YES	YES
11	West Bengal State Distribution Company Ltd.	YES	NA	NA	NO

[illegible]

Current Status of Letter of Credit (LC) amount against UI charges for ER constituents*Figures in Lacs of Rupees*

SI No	ER Constituents	No. of weeks in which Deviation Charge payable	No of times payment was delayed during 2015-16	Total Deviation charges payable to pool during 2015-16	Average weekly Deviation Charge liability	LC Amount	Due date of expiry	Remarks
		(A)	(B)	(C)	(D)	(E)	(F)	(G)
1	BSPHCL	44	44	10288.28725	194.11863	213.53049	Expired on 03.01.17	Reminder letter issued on 30/05/17
2	JUVNL	45	45	12078.12053	227.88907	250.67797	31.01.2018	Opened for 85.89820 Lac
3	SIKKIM	6	6	43.59053	0.82246	0.90471	07.03.2018	Opened for 1.60277 Lacs
4	APNRL	31	31	514.12213	9.70042	10.67046	31.10.2017	Opened for ₹ 10.67046 Lacs
5	CHUZACHEN	6	5	24.43612	0.46106	0.50716	Not Opened	Letter issued on 02/05/17
6	JITPL	18	3	1304.7548	24.61802	27.07982	Not Opened	Letter issued on 02/05/17
7	GMR	12	4	367.39848	6.93205	7.62525	15.07.2017	Opened for 19.66436 Lacs
8	IND-BARATH	48	36	96.68933	1.82433	2.00676	Not Opened	Letter issued on 02/05/17
9	TPTCL	45	3	1287.684311	24.29593	26.72552	Not Opened	Letter issued on 02/05/17
10	JLHEP	27	24	346.25598	6.53313	7.18644	Not Opened	Letter issued on 02/05/17
11	BRBCL	48	3	343.15334	6.47459	7.12205	31.03.2018	Opened for ₹ 7.12205 Lacs
12	NVVN(IND-NEP)	36	5	419.02891	7.90621	8.69683	Not Opened	Letter issued on 02/05/17
13	TEESTA-III(TUL)	3	3	109.40403	2.06423	2.27065	Not Opened	Letter issued on 02/05/17

Annexure-X

3rd Phase : 33 Locations

			S.No	ERLDC_ID	OLD MTR	NEW MTR	LOCATION	S.No	ERLDC_ID	OLD MTR	NEW MTR	LOCATION
1	BALIMELA(BLM)	GRIDCO	1	AP-03	NP-7438-A	NP-8642-A	APNRL	109	EN-51		NP-7887-A	LAKHISARAI(PG)
2	BANGRIPOSHI(BGR)	GRIDCO	2	AP-02	NP-7462-A	NP-8643-A	APNRL	110	EN-52		NP-7430-A	LAKHISARAI(PG)
3	BANKA(BNK)	PG	3	EN-93		NP-8742-A	ARA(PG)	111	EN-89		NP-7887-A	LAKHISARAI(PG)
4	CHAIBASA(CHB)	PG	4	EN-94		NP-8743-A	ARA(PG)	112	EN-90		NP-7430-A	LAKHISARAI(PG)
5	CHAIBASA(CHA)	JUVNL	5	ES-02		NP-8860-A	ARA(PG)	113	EN-51		NP-7888-A	LAKHISARAI(PG)
6	DUMKA(DUM)	JUVNL	6	ES-22		NP-8790-A	BOLANGIR(PG)	114	EN-52		NP-7431-A	LAKHISARAI(PG)
7	DARBHANGA(DBG)	DMTCL	7	ES-23		NP-8789-A	BOLANGIR(PG)	115	OR-23		NP-7915-A	DUBURI(GRIDCO)
8	GYALSHING(GSH)	SIKKIM	8	EP-99		NP-7560-A	BOLANGIR(PG)	116	JS-09		NP-8695-A	DUMKA(JUVNL)
9	HALDIA(HAL)	WBSETCL	9	ES-27		NP-8775-A	MALDA(PG)	117	JS-10		NP-8774-A	DUMKA(JUVNL)
10	IND-BARATH (IBR)	IPPR	10	ES-28		NP-8776-A	MALDA(PG)	118	SM-07		NP-8730-A	GYALSHING(SIKKIM)
11	JAMUI(JMU)	BIHAR	11	EN-87		NP-8727-A	MAITHON(PG)	119	WB-60		LT-0307-A	HALDIA CESC(WB)
12	JLHEP(DANS ENERGY)	IPPR	12	EN-88		NP-8739-A	MAITHON(PG)	120	WB-61		LT-0311-A	HALDIA CESC(WB)
13	KISANGANJ (KSN)	PG	13	ES-42		NP-7401-A	MAITHON(PG)	121	OR-15		NP-7991-A	BALIMELA(GRIDCO)
14	KATAPALLI(KTP)	GRIDCO	14	ES-01		NP-8874-A	MUZAFFARPUR(PG)	122	OR-16		NP-7992-A	BALIMELA(GRIDCO)
15	KUDRA(KUD)	BIHAR	15	ES-07		NP-8871-A	MUZAFFARPUR(PG)	123	OR-62		NP-5907-A	BANGRIPOSHI(GRIDCO)
16	KISANGANJ (KIS)	BSPTCL	16	ES-08		NP-8873-A	MUZAFFARPUR(PG)	124	NB-01		NP-8700-A	NABINAGAR
17	LAKHISARAI(LKS)	PG	17	ES-09		NP-8872-A	MUZAFFARPUR(PG)	125	NB-02		NP-8701-A	NABINAGAR
18	LAKHISARAI(LKK)	BIHAR	18	ES-43		NP-6077-A	MUZAFFARPUR(PG)	126	NB-05		NP-8662-A	NABINAGAR
19	NABINAGAR(NBN)	NTPC	19	ES-44		NP-6078-A	MUZAFFARPUR(PG)	127	NB-07		NP-8892-A	NABINAGAR
20	NEW DUBRI (DBR)	GRIDCO	20	OR-20	NP-5983-A	NP-7498-A	MENDHASAL(GRIDCO)	128	NB-11		NP-8891-A	NABINAGAR
21	NEW PUSAULI (NPS)	BIHAR	21	BI-72		NP-8748-A	BANKA(BSPTCL)	129	BI-56		NP-7690-A	NALANDA(BSPTCL)
22	NALANDA(NLN)	BIHAR	22	ES-40		NP-8692-A	PUSAULI(PG)	130	OR-22		NP-7916-A	NEW DUBURI(GRIDCO)
23	NEW MELLI (NML)	PG	23	ES-41		NP-8693-A	PUSAULI(PG)	131	EN-85		NP-8647-A	NEW MELLI(PG)
24	PANDIABILPNB)	PG	24	EN-83		NP-8673-A	BANKA(PG)	132	EN-86		NP-8640-A	NEW MELLI(PG)
25	RANCHI NEW(RNC)	PG	25	EN-84		NP-8675-A	BANKA(PG)	133	ES-51		NR-4621-A	NEW MELLI(PG)
26	SADIEPALI(SDP)	GRIDCO	26	ES-03		NP-8694-A	BANKA(PG)	134	ES-52		NR-4620-A	NEW MELLI(PG)
27	RANGPO(RGP)	PG	27	ES-04		NP-8696-A	BANKA(PG)	135	BI-27		NP-8698-A	JAMUI(BSPHCL)
28	SAGBARI(SGB)	SIKKIM	28	BH-22		NP-7482-A	BARH(NTPC)	136	BI-26		NP-8669-A	JAMUI(BSPHCL)
29	TEEST-III(TST)	TUL	29	ES-45		NP-8074-A	BARIPADA(PG)	137	BI-27		NP-8668-A	JAMUI(BSPHCL)
30	TALCHER SOLAR (TLS)	NTPC	30	EN-68		NP-8721-A	BERHAMPORE(PG)	138	JL-01		NP-8737-A	JORETHANG(JLHEP)
31	DIKCHU(DIC)	DICKCHU	31	EN-69		NP-8726-A	BERHAMPORE(PG)	139	JL-02		NP-8766-A	JORETHANG(JLHEP)
32	SONNAGAR NEW(SONN)	BSPTCL	32	ES-10		NP-8655-A	PATNA(PG)	140	JL-03		NP-8762-A	JORETHANG(JLHEP)
33	ALIPURDUAR	PG	33	RG-12		NP-8734-A	RANGIT(NHPC)	141	JL-04		NP-8763-A	JORETHANG(JLHEP)
34	MTPS KANTI(NTPC)	NTPC	34	RG-13		NP-8733-A	RANGIT(NHPC)	142	JL-05		NP-8764-A	JORETHANG(JLHEP)
35	KEONJHAR(KEO)	GRIDCO	35	RG-14		NP-8732-A	RANGIT(NHPC)	143	JL-06		NP-8765-A	JORETHANG(JLHEP)
36	ATRI(ATR)	GRIDCO	36	RG-15		NP-8736-A	RANGIT(NHPC)	144	OR-17		NP-7561-A	KATAPALI(GRIDCO)
37	PURI(PUR)	GRIDCO	37	RG-16		NP-8735-A	RANGIT(NHPC)	145	BI-32		NP-8664-A	PUSAULI NEW(BSPHCL)
			38	OR-55	NP-0624-B	NP-5938-A	JODA(GRIDCO)	146	BI-33		NP-8665-A	PUSAULI NEW(BSPHCL)
			39	EN-29		NP-7950-A	ANGUL(PG)	147	EN-10		NP-7847-A	RANCHI NEW(PG)
			40	EN-30		NP-7558-A	ANGUL(PG)	148	EN-11		NP-7876-A	RANCHI NEW(PG)
			41	EN-31		NP-7987-A	ANGUL(PG)	149	EN-12		NP-7849-A	RANCHI NEW(PG)
			42	EN-32		NP-7988-A	ANGUL(PG)	150	EN-13		NP-7866-A	RANCHI NEW(PG)
			43	EN-43		NP-7629-A	ANGUL(PG)	151	EN-14		NP-7865-A	RANCHI NEW(PG)
			44	EN-44		NP-7949-A	ANGUL(PG)	152	EN-19		NP-7875-A	RANCHI NEW(PG)
			45	EN-32	NP-7988-A	NP-7908-A	ANGUL(PG)	153	EN-91		NP-8755-A	RANCHI NEW(PG)
			46	EN-63		NP-8780-A	ANGUL(PG)	154	EN-92		NP-8754-A	RANCHI NEW(PG)
			47	EN-64		NP-8781-A	ANGUL(PG)	155	EN-99		NP-8753-A	RANCHI NEW(PG)
			48	EN-65		NP-8785-A	ANGUL(PG)	156	ES-46		NP-7013-A	KISHANAGNJ(PG)
			49	EN-66		NP-8786-A	ANGUL(PG)	157	ES-47		NR-4614-A	KISHANAGNJ(PG)
			50	EN-77		NP-8778-A	ANGUL(PG)	158	ES-48		NR-4444-A	KISHANAGNJ(PG)
			51	EN-78		NP-8779-A	ANGUL(PG)	159	ES-49		NR-4436-A	KISHANAGNJ(PG)
			52	EN-82		NP-8777-A	ANGUL(PG)	160	ES-50		NR-4440-A	KISHANAGNJ(PG)
			53	ES-06		NP-8788-A	ANGUL(PG)	161	ES-11		NP-8887-A	KISHANAGNJ(PG)
			54	ES-05	NP-8787-A	NP-7995-A	ANGUL(PG)	162	ES-12		NP-8885-A	KISHANAGNJ(PG)
			55	ES-58		NP-8077-A	ANGUL(PG)	163	ES-13		NP-8856-A	KISHANAGNJ(PG)
			56	ES-59		NP-8076-A	ANGUL(PG)	164	ES-14		NP-8886-A	KISHANAGNJ(PG)
			57	EM-49		NP-7880-A	CHANDIL(JUVNL)	165	ES-15		NP-8858-A	KISHANAGNJ(PG)
			58	EP-18	NP-7471-A	NP-8660-A	GAYA(PG)	166	ES-16		NP-8889-A	KISHANAGNJ(PG)
			59	ES-26		NP-8659-A	GAYA(PG)	167	ES-17		NP-8859-A	KISHANAGNJ(PG)

60	EP-19	NP-7470-A	NP-8658-A	GAYA(PG)	168	ES-18		NP-8855-A	KISHANGANJ(PG)
61	WB-30		NP-7403-A	KHARAGPUR(WB)	169	ES-19		NP-8880-A	KISHANGANJ(PG)
62	BS-38		NR-4442-A	KISHANAGNJ(BSPTCL)	170	ES-20		NP-8888-A	KISHANGANJ(PG)
63	BS-39		NR-4445-A	KISHANAGNJ(BSPTCL)	171	ES-21		NP-8857-A	KISHANGANJ(PG)
64	BI-28		NP-8653-A	SULTANGANJ(BSPHCL)	172	EN-22		NP-7933-A	RANGPO(PG)
65	BI-29		NP-8672-A	SULTANGANJ(BSPHCL)	173	EN-23		NP-7955-A	RANGPO(PG)
66	BI-61	NP-6019-B	NP-7400-A	SULTANGANJ(BSPHCL)	174	EN-24		NP-7956-A	RANGPO(PG)
67	EN-40		NP-7906-A	SUNDERGARH(PG)	175	EN-25		NP-7957-A	RANGPO(PG)
68	EN-41		NP-7634-A	SUNDERGARH(PG)	176	EN-33		NP-7922-A	RANGPO(PG)
69	EN-42		NP-7638-A	SUNDERGARH(PG)	177	EN-34		NP-7923-A	RANGPO(PG)
70	EN-57		NP-7907-A	SUNDERGARH(PG)	178	EN-35		NP-7924-A	RANGPO(PG)
71	EN-79		NP-7636-A	SUNDERGARH(PG)	179	EN-36		NP-7623-A	RANGPO(PG)
72	EN-95		NP-7635-A	SUNDERGARH(PG)	180	EN-39		NP-7622-A	RANGPO(PG)
73	WB-23		LT-0194-A	SAGARDIGHI(WBSETCL)	181	EN-38		NP-7621-A	RANGPO(PG)
74	WB-24		LT-0191-A	SAGARDIGHI(WBSETCL)	182	EN-54		NP-7619-A	RANGPO(PG)
75	WB-25		NP-8724-A	SAGARDIGHI(WBSETCL)	183	EN-55		NP-7620-A	RANGPO(PG)
76	WB-26		NP-8725-A	SAGARDIGHI(WBSETCL)	184	EN-59		NP-8710-A	RANGPO(PG)
77	WB-27		NP-8723-A	SAGARDIGHI(WBSETCL)	185	EN-60		NP-8711-A	RANGPO(PG)
78	WB-28		NP-8722-A	SAGARDIGHI(WBSETCL)	186	EN-80		NP-8714-A	RANGPO(PG)
79	BI-07	NP-6074-A	NP-7825-A	SABOUR(BSPHCL)	187	EN-81		NP-8715-A	RANGPO(PG)
80	BI-73		NP-8749-A	SABOUR(BSPHCL)	188			NP-7940-A	RANGPO(PG)
81	ES-31		NP-7442-A	PANDIABILI(PG)	189			NP-7941-A	RANGPO(PG)
82	ES-32		NP-7427-A	PANDIABILI(PG)	190	ES-24		NP-8712-A	RANGPO(PG)
83	ES-33		NP-7454-A	PANDIABILI(PG)	191	ES-25		NP-8713-A	RANGPO(PG)
84	ES-34		NP-7554-A	PANDIABILI(PG)	192	OR-18		NP-7944-A	SADEIPALI(GRIDCO)
85	ES-35		NP-7438-A	PANDIABILI(PG)	193	JS-11		NP-8865-A	CHAIBASA(JUVNL)
86	ES-36		NP-7407-A	PANDIABILI(PG)	194	JS-12		NP-8866-A	CHAIBASA(JUVNL)
87	ES-37		NP-7462-A	PANDIABILI(PG)	195	JS-13		NP-8867-A	CHAIBASA(JUVNL)
88	JS-50		NP-8644-A	KENDIPOSI(JUVNL)	196	SM-05		NP-8797-A	SAGBARI(SIKKIM)
89	WB-29		NP-7381-A	KHARAGPUR(WB)	197	SM-06		NP-8798-A	SAGBARI(SIKKIM)
90	BI-50		NP-7869-A	KUDRA(BSPHCL)	198	BI-42		NP-7380-A	SONNAGAR NEW(BSPTCL)
91	BI-26		NP-8697-A	LAKHISARAI(BSPHCL)	199	BI-43		NP-7450-A	SONNAGAR NEW(BSPTCL)
92	BI-30		NP-8670-A	LAKHISARAI(BSPTCL)	200	IB-01		NP-8792-A	IBEUL
93	BI-31		NP-8671-A	LAKHISARAI(BSPTCL)	201	IB-02		NP-8793-A	IBEUL
94	EN-46		NP-7432-A	LAKHISARAI(PG)	202	IB-03		NP-8795-A	IBEUL
95	EN-27		NP-7433-A	LAKHISARAI(PG)	203	IB-04		NP-8794-A	IBEUL
96	EN-37		NP-7889-A	LAKHISARAI(PG)	204	IB-05		NP-8783-A	IBEUL
97	EN-26		NP-7885-A	LAKHISARAI(PG)	205	IB-06		NP-8782-A	IBEUL
98	EN-47		NP-7886-A	LAKHISARAI(PG)	206	IB-07		NP-8784-A	IBEUL
99	EN-50		NP-7429-A	LAKHISARAI(PG)	207	IB-08		NP-8796-A	IBEUL
100	EN-51		NP-7888-A	LAKHISARAI(PG)	208	TL-32		NP-7961-A	TALCHER SOLAR(NTPC)
101	EN-58		NP-8678-A	CHAIBASA(PG)	209	TL-33		NP-7626-A	TALCHER SOLAR(NTPC)
102	EN-67		NP-8637-A	CHAIBASA(PG)	210	TL-34		NP-7962-A	TALCHER SOLAR(NTPC)
103	EN-97		NP-8868-A	CHAIBASA(PG)	211	TL-35		NP-7628-A	TALCHER SOLAR(NTPC)
104	EN-98		NP-8869-A	CHAIBASA(PG)	212	TL-37		NP-7627-A	TALCHER SOLAR(NTPC)
105	ES-29		NP-7471-A	CHAIBASA(PG)	213	TL-38		NP-5968-A	TALCHER SOLAR(NTPC)
106	ES-30		NP-7467-A	CHAIBASA(PG)	214	TL-31		NP-7909-A	TALCHER SOLAR(NTPC)
107	DM-01		NP-8656-A	DARBHANGA(DMTCL)	215	TL-30		NP-5979-A	TALCHER SOLAR(NTPC)
108	DM-02		NP-8719-A	DARBHANGA(DMTCL)	216	TL-37	NP-7627-A	NP-7946-A	TALCHER SOLAR(NTPC)
					217	TL-40	NP-7618-A	NP-7945-A	TALCHER SOLAR(NTPC)
					218	TL-39	NP-7614-A	NP-7631-A	TALCHER SOLAR(NTPC)
					219	TL-41	NP-7615-A	NP-7633-A	TALCHER SOLAR(NTPC)
					220	TL-36	NP-7632-A	NP-7630-A	TALCHER SOLAR(NTPC)
					221			LT-0135-A	MTPS KANTI(NTPC)
					222			LT-0192-A	MTPS KANTI(NTPC)
					223			LT-0129-A	MTPS KANTI(NTPC)
					224			LT-0133-A	MTPS KANTI(NTPC)
					225			LT-0093-A	MTPS KANTI(NTPC)
					226			LT-0127-A	MTPS KANTI(NTPC)
					227			LT-0126-A	MTPS KANTI(NTPC)
					228			TP-0006-A	MTPS KANTI(NTPC)
					229			LT-0132-A	MTPS KANTI(NTPC)
					230			LT-0130-A	MTPS KANTI(NTPC)
					231			LT-0092-A	MTPS KANTI(NTPC)
					232			LT-0128-A	MTPS KANTI(NTPC)
					233			LT-0125-A	MTPS KANTI(NTPC)

234			LT-0140-A	MTPS KANTI(NTPC)
235			LT-0131-A	MTPS KANTI(NTPC)
236			TP-0008-A	MTPS KANTI(NTPC)
237			LT-0246-A	MTPS KANTI(NTPC)
238			LT-0219-A	MTPS KANTI(NTPC)
239			LT-0214-A	MTPS KANTI(NTPC)
240			LT-0242-A	MTPS KANTI(NTPC)
241			LT-0187-A	MTPS KANTI(NTPC)
242			LT-0215-A	MTPS KANTI(NTPC)
243	ES-54		NR-4451-A	ALIPURDUAR(PG)
244	ES-55		NR-4452-A	ALIPURDUAR(PG)
245	ES-56		NR-4457-A	ALIPURDUAR(PG)
246	ES-57		NR-4458-A	ALIPURDUAR(PG)

List of drifted meters to be replaced in Phase-II

SNO	LOCATION	METER SNO	FEEDER NAME	Region
1	MUZAFFARPUR(PG)	NP-5074-A	400 KV MUZAFARPUR (PG)-GORAKHPUR(NR)-1	ER-I
2	MUZAFFARPUR(PG)	NP-9981-A	400 KV MUZAFARPUR (PG)-GORAKHPUR(NR)-2	ER-I
3	RANCHI(PG)	NP-5835-A	400 KV RANCHI-SIPAT-1 (WR)	ER-I
4	RANCHI(PG)	NP-5836-A	400 KV RANCHI-SIPAT-2 (WR)	ER-I
5	RANCHI NEW(PG)	NP-7847-A	765 KV RANCHI NEW -DHARAMJAYGARH-1	ER-I
6	RANCHI NEW(PG)	NP-8753-A	765 KV RANCHI NEW -DHARAMJAYGARH-2	ER-I
7	MEJIA(DVC)	NP-5226-A	MEJIA END OF MAITHON(PG)-1	ER-II
8	MEJIA(DVC)	NP-5227-A	MEJIA END OF MAITHON(PG)-2	ER-II
9	BINAGURI(PG)	NP-5884-A	BINAGURI END OF BONGAIGAON (NER)-1	ER-II
10	BINAGURI(PG)	NP-5885-A	BINAGURI END OF BONGAIGAON (NER)-2	ER-II
11	ROURKELLA(PG)	NP-5933-A	ROURKELA END OF TARKERA (GRIDCO)-2	ER-II
12	KHARAGPUR(PG)	NP-7563-A	400 KV KHARAGPUR -BARIPADA(PG)	ER-II
13	MPL	NP-7970-A	MAITHON RB END OF RANCHI (PG)-1 (MAIN)	ER-II
14	MPL	NP-7971-A	MAITHON RB END OF RANCHI (PG)-2 (MAIN)	ER-II
15	MPL	NP-7564-A	MAITHON RB END OF MAITHON (PG)-1 (MAIN)	ER-II
16	MPL	NP-6518-A	MAITHON RB END OF MAITHON (PG)-2 (MAIN)	ER-II
17	STERLITE	NP-7572-A	400 KV STERLITE - RAIGARH(WR)-II(MAIN)	ER-II
18	STERLITE	NP-7372-A	400 KV STERLITE - ROURKELLA(PG)-II(MAIN)	ER-II
19	ROURKELLA(PG)	NP-5928-A	400 KV ROURKELLA(PG)-RAIGARH(WR)	ER-II
20	MIRAMUNDALI(OPTCL)	NP-5977-A	400 KV MIRAMUNDALI-ANGUL-1	ER-II
21	MIRAMUNDALI(OPTCL)	NP-5976-A	400 KV MIRAMUNDALI-ANGUL-2	ER-II
22	SUNDERGARH(PG)	NP-7634-A	765 KV SUNDERGARH-DHARAMJAYGARH-1	ER-II
23	SUNDERGARH(PG)	NP-7638-A	765 KV SUNDERGARH-DHARAMJAYGARH-2	ER-II

ER-I								
S. No	S/Station	Loc ID	Meter No	Make	CTR	PTR	Remarks	Data Receipt
1	Banka	ES-88	NP-7458-A	L&T	50	33000/110		Yes
2	Lakhisarai	ES-94	NP-8870-A	L&T	50	33000/110		Yes
3	New Ranchi(765)	ES-87	NP-8752-A	L&T	50	33000/110		Yes
4	Ara(220)	ES-99	NP-8893-A	L&T	50	33000/110		Yes
5	Muzaffarpur	ET-02	NP-5231-A	L&T	1000	415/110		Yes
6	New Purnea	ES-98	NP-5249-A	L&T	50	33000/110		Yes
7	Pusauli	ET-06	NP-8646-A	L&T	50	33000/110		Yes
8	Gaya(765)	EM-99	NP-7472-A	L&T	50	33000/110		No
9	Kishanganj	ES-90	NP-8876-A	L&T	50	33000/110		No
10	Patna	ES-89	ER-1285-A	Genus	50	33000/110		No
11	Biharshariff	ET-01	NP-2355-A	SECURE	1000	415/110		No
12	Chaibasa						Detail not rcvd	No
13	Jamshedpur						Detail not rcvd	No
14	Ranchi(400/220)						Detail not rcvd	No
ER-II & Odhisa Project								
1	Angul	ES-95	NP-5942-A	L&T	1000	415/110		Yes
3	Pandiabili	ES-39	NP-7462-A	L&T	1000	415/110		Yes
4	Rangpo (33 kv TRF)	ES-96	NP-7940-A	L&T	1000	415/110		Yes
5	Rangpo (11 KV AUX TRF)	ES-97	NP-7941-A	L&T	1000	415/110		Yes
8	Sundergarh	ES-93	ER-1019-A	Genus	50	33000/110		Yes
9	Baripada	EM-69	NP-5909-A	L&T	1200	400/110		Yes
2	Bolangir	ET-03	NP-7951-A	L&T	50	33000/110		No
6	Durgapur	ET-04	NP-6024-B	L&T	200	400/110		No
7	Rengali	ET-05	NP-0629-B	Secure	200	415/110		No
10	Jeypore		NP-5695-A	L&T			Detail not rcvd	No
11	Keonjhar		NP-7921-A	L&T			Detail not rcvd	No
12	Maithon						Detail not rcvd	No
13	Birpara						Detail not rcvd	No
14	Siliguri						Detail not rcvd	No
15	Subhashgram						Detail not rcvd	No

Date of Commercial Operation(DOCO) of the Asstes						
						Annexure-XIII
A	Eastern Region Strengthening Scheme-V	DOCO	Approved Cost	Standing Committee Reference	RPC Meeting Reference	Sharing of Charges
01	1 no 80 MVAR Bus Reactor and associated 400kV bay at Gokrana	30/04/17	Rs.1364.52 Cr.(including IDC of Rs.59.11 Cr.).	SCM meeting of ER on 20.09.10	16th TCC & ERPC Meeting on 17.12.10 & 18.12.2010	As per New Sharing methodology of PoC
02	1 no 80 MVAR Switchable line Reactor and associated 400kV bay at Farakka	30/04/17				
03	Gokarna-Farakka portion of 400kV D/C Rajarhat-Purnea TL including LILO of one ckt of Rajarhat-Purnea TL at Farakka and LILO of other ckt of Rajarhat-Purnea TL at Gokrana and associated line bays at Farakka and Gokrana	31/03/17				
B	Common System associated with East Coast Energy Pvt. Ltd. and NCC Power Projects Ltd. LTOA Generation Projects in Srikakulamarea-Part A & Part C	DOCO	Approved Cost	Standing Committee Reference	RPC Meeting Reference	Sharing of Charges
01	765kV Double Circuit Angul-Srikakulam Transmission Line	01/02/17	Rs.1909.24 Cr.(including IDC of Rs.115.94 Cr.).	30th SCM Meeting of SR on 13.04.2010, 35th SCM meeting of SR on 04.01.2013 & SCM of ER on 28.12.2010	Special meetin of SRPC ON 25.11.2010	As per New Sharing methodology of PoC
02	765/400kV Substation at Srikakulam	01/02/17				
03	765kV bay extension at Angul and Srikakulam Substation along-with 2x240 MVAR switchable line reactors each & Angul S/s & Srikakulam S/s	01/02/17				
04	1x330 MVAR 765kV Bus Reactor at Srikakulam Substation	01/02/17				
C	Transmission System assocaiated with Darlipali TPS	DOCO	Approved Cost	Standing Committee Reference	RPC Meeting Reference	Sharing of Charges
01	Darlipali TPS(NTPC)-Jharsuguda(Sundargarh) Pooling station 765kV Double Circuit Transmission Line along-with 02nos 765kV Bays at Jharsuguda9Sundragarh)Pooling station	26/04/17	Rs.187.04 Cr.(including IDC of Rs.11.58 Cr.).	31st Meeting of empower committee on Transmission held on 18.02.13 at CERC New Delhi	Connectivity & Long Term Access with constituents of Eastern Region held on 05.01.13and 24th ERPC meeting on 27.04.13	# Mention in Note
D	ULDC Microwave link & Wide Band Communication Network	DOCO	Approved Cost	Standing Committee Reference	RPC Meeting Reference	Sharing of Charges
01	7 nos. OPGW links under Central Sector assocaiated with expansion of wideband communication network in Eastern Region		-	-	-	-
a)	Baripada-Keonjhar	01/03/17				
b)	Birpara-Alipurduar	01/03/17				
c)	Angul-Bolangir	01/03/17				
d)	Gaya-Chandwa	01/03/17				
e)	Purnea 400kV- Purnea 220kV	01/03/17				
f)	Rengali-Keonjhar	01/03/17				
g)	Uttara(Pandiabilli)-Mendhasal	01/03/17				
E	Fibre Optic Communication system in lieu of existing Unified Load Despatch & Communoication(ULDC) Microwave links in Eastern Region	DOCO	Approved Cost	Standing Committee Reference	RPC Meeting Reference	Sharing of Charges
DVC	i) Kalyaneshwari-Kalipahari	01/07/17				
	ii) LILO at Raghunathpur	01/07/17				
	iii) Koderma TPS-Koderma 400/220 S/s	01/07/17				
	iv) BTPS A- BTPS B	01/07/17				
	v) Ramgarh 220 - Ramgarh 132	01/07/17				
	i) LILO at Liluah-Rishra	01/07/17				

WBSEDCL	ii) Saltlake S/s to Abhikshan Bhawan(UGFO)	01/07/17				
	iii) Vidyut Bhawan to Saltlake GIS(UGFO)	01/07/17				
	iv) Bidhannagar 400- Bidhannagar 220	01/07/17				
OPTCL	i) Mancheswar-Bhubaneswar SLOC	01/07/17				
	ii) Bhubaneshwar SLOC-Vidyut Bhawan(Last Mile)	01/07/17				
BSPTCL	i) Jakkampur-SLDC Patna(UGFO)	01/07/17				
Central	i) ERLDC-Kasba(UGFO)	01/07/17				
F	Expansion & Upgradation of SCADA/EMS System at SLDCs of ER	DOCO	Approved Cost	Standing Committee Reference	RPC Meeting Reference	Sharing of Charges
BSPTCL	(b) Integration of RTUs to Main & Backup Control Centre	01/07/17				
	(f) RTU	01/07/17				
DVC	(b) Integration of RTUs to Main & Backup Control Centre	01/07/17				
	(f) RTU	01/07/17				
JUSNL	(b) Integration of RTUs to Main & Backup Control Centre	01/07/17				
	(f) RTU	01/07/17				
Sikkim	(b) Integration of RTUs to Main & Backup Control Centre	01/07/17				
	(f) RTU	01/07/17				
# Note :	6th Amendment to CERC (Connectivity and LTA/MTOA in ISTS & Related matters) Regulation 2009 was notified on 17.02.17 As per the amendment of Clause (8) of Regulation 8 "The transmission charges for the dedicated transmission line shall be payable by Generator from date of COD of the dedicated line till operationalisation of LTA of the generating station of the generating company". Hence NTPC Darlipalli will bear the transmission charges of the line till operationalisation of LTA.					



WEST BENGAL ELECTRICITY REGULATORY COMMISSION



Ref. No. WBERC/B-7/1/0470

Dated, Kolkata, the 16th June, 2017

From
Dr. Jiban Chandra Chakraborty, I.A.S.(Retd.)
Secretary

To
The Member Secretary
Eastern Regional Power Committee,
Government of India, Ministry of Power,
14 Golf Club Road, Tollygunge
Kolkata - 700 033

Sub: Submission of Inter-state Commercial issues for kind
consideration of the Commission

Ref : Your letter no. ERPC/COM-1/GEN/2017/1621 dated 31.01.2017

Sir,

In inviting a reference to the above, I am directed to state you as follows:


Issue 1: State transmissions utility charges for WBSETCL System.

Commission has taken note of the issue and will do the needful in due course.

**Issue 2: Outstanding reactive energy charge for WBSEDCL/WBSETCL to the tune of
Rs. 1,81,54,128/-**

- It appears from the available documents maintained at the Commission's office that a practice used to be followed prior to 04.01.2016 with regard to settlement of ERPC's reactive energy bills.
- Energy bills prior to 04.01.2016 shall be settled as per the practice as above.

Yours faithfully,


Secretary

SCANNED

ERPC::KOLKATA

ATTENDANCE SHEET35th COMMERCIAL SUB-COMMITTEE MEETING (CCM)

DATE: 02.08.2017 (WEDNESDAY)

TIME: 11:00 HRS

VENUE: ERPC CONFERENCE HALL

Sl. No.	Organisation	Name & Designation	Contact Number	E-mail Id	Signature
1	ERPC	AK Bandopadhyay MS	9433068533	mserpc-power @nrc.in	A. Bandopadhyay
2	ERLDC	P. Mukhopadhyay GM	98894 38073	pmukhopadhyay@ posoco.in	P. Mukhopadhyay
3	ERLDC	G. MITRA	9831297392	gopalmitra@posoco.in	G. Mitra
4	POWERGRID-ERII	B. K. PRADHAN	94347420 21	bkpradhan@powergrid co.in	B. K. Pradhan
5	DVE	Subrata Ghosh	9432677043	subrata.ghosh@64 @gmail.com	Subrata Ghosh
6	NTPL	S. D. Jha	947004528	sdjha@ntpl.co.in	S. D. Jha
7	NTPL	R. K. Sood	9650990616	rsood@ntpl.co.in	R. K. Sood
8	NTPL	Kallol Sarma, AGM ER-IT Hq, BSR	9902498534	kallolsarma123@ gmail.com	Kallol Sarma
9	NHPC	R. RAINA	9800213734	r.raina@gmail.com	R. Raina
10	NHPC	Vijay Kumar	9818696821	Vijay.kumar23@ gmail.com	Vijay Kumar
11	MPL	Pankaj Mondal	77730 148 16	Pankaj.mondal@tatapo wer.com	Pankaj Mondal
12	MPL	Rajeev Kumar	9234500773	RajeevKumar@Tatapo wer.com	Rajeev Kumar
13	ERPC	Rintu Ghosh			R. Ghosh
14	ERLDC/ POSOCO	SUBHENDU MUKHERJEE	9433041874	subhendu@posoco. in	Subhendu Mukherjee
15	ERLDC POSOCO	Nadim Ahmad	9432351831	nadim@posoco.in	Nadim Ahmad
16	ERLDC, POSOCO	Pinki Debnath	9007079914	pinkidebnath@posoco.in	Pinki Debnath
17	ERLDC, POSOCO	Shabari Pramanick	9007058764	shabari.pramanick@posoco.in	Shabari Pramanick
18	ERLDC, POSOCO	Gaurav Mukherjee	990 3329547	gaurav.mukherjee@posoco.in	Gaurav Mukherjee
19	POWERGRID/ERII	PARTHA GHOSH	9434748263	partha.ghosh@ powergrid.co.in	Partha Ghosh
20	ERPC	Alikpantha De, AEE	9681932906	alikipantha@gmail.com	Alikpantha De
21	ERPC	S. P. Datta, AGM (MVR)	9433067022	spdatta@rediffmail. com	S. P. Datta
22	SBPDCL	Deepak Kumar ABEY	7033291929	acecomsbpdcl@gmail.com	Deepak Kumar ABEY
23	SBPDCL	Alok Chandra, AO	7763813960	astsbpdcl@gmail.com	Alok Chandra

Sl. No.	Organisation	Name & Designation	Contact Number	E-mail Id	Signature
24	SLDC WBSE TEL	C.K. Halder A.C.E.	9434910379	ckhalder@yahoo.co.in	
25	SLDC WBSE TEL	V. Srinivasan AM (F&D)	9434910415	wbsele.fia@gmail.com	
26	WBSE DCL	A. Chakrabarty, Sr. Mgfr	9836699161	eeptf@gmail.com	
27	WBSE DCL	P. Banerjee	9432140715	prabanta2@gmail.com	
28	CESE Ltd	Soma Basu	9903010746	soma.basu@rp-sg.in	
29	GRIDCO Ltd	U.N. Mishra Chm PL	9438907774	sgm.pp@gridco.co.in	
30	GRIDCO LTD.	U.K. Sahoo, DGM	9437185507	u.sahoo.puri@gmail.com	
31	OPTCL	Sadananda Patra	9438908096	ele.sdpatra.co.in	
32	OPTCL	Biplab K. Behera	9438907689	ele.bkbehera@optcl.co.in	
33	ERPC	S.K. Chatterjee	8420084901		
34	ERPC	P.P. Jena	9776198991	ppjena.erpc@gtv.in	
35	POWERGRID	M.K. AGARWAL	9431815668	mkag@powergrid.co.in	
36	NHPC Ltd	R. RAINA	9800213734	r.raina@gmail.com	
37	ERPC	D.K. Bauri	9883617236	eeop.erpc@govt.in	
38	ERPC	S. Paul	9051085892	eecon.erpc@govt.in	
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					