

भारत सरकार Govemment of India विद्युत मंत्रालय Ministry of Power **पूर्वी क्षेत्रीय विद्युत समिति**



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033 14 Golf Club Road, Tollygunj, Kolkata-700033

Tel No.:033-24235199, 24235005 FAX No.:033-24221802, 24221358 Web: www.erpc.gov.in

NO. ERPC/PROTECTION/2016-17/

DATE: 04.08.2017

FAX MESSAGE NO. - 414

To,

As per list enclosed.

Sub: Notice for 58th Protection Coordination sub-Committee (PCC) meeting of ERPC

Notice is hereby given that **58th PCC meeting** of ERPC will be held on **29th August 2017** (Tuesday) at 11: 00 hrs at ERPC Conference Room, Kolkata.

The tentative agenda items for discussion will be as follows:

- 1) Confirmation of the minutes of 57th Protection sub-Committee Meeting of ERPC
- 2) Follow-up action on decision of previous Protection sub-Committee Meetings
- 3) Analysis of following grid disturbances of July, 2017:
- Disturbance at 220 kV Lalmatia S/s on 03-07-17 at 18:32 hrs.
- > Disturbance at 400kV Patna on 03-07-17 at 18:53 hrs
- ➤ Disturbance at 400 kV Bokaro S/s on 13-07-17 at 20:18 hrs
- Disturbance at 220 kV Lalmatia S/s on 15-07-17 at 09:40 hrs
- ➤ Repeated disturbances at 400kV Teesta-III, Dikchu and Rangpo on at 00:30 hrs on 16-07-2017, 15:56 hrs & 19:11 hrs on 24-07-2017, 19:11 hrs and 10:08 hrs on 27-07-2017.
- Disturbance at 220 kV Tarkera S/s on 31-07-17 at 11:24 hrs.
- 4) Multiple elements tripping without load loss:
- ➤ Disturbance at 220 kV Dalkhola S/s on 19-07-17 at 10:50 hrs
- 5) Single line tripping incidences as per list enclosed at **Annexure-I**.

You are requested to kindly furnish the detail report along with all records (SLD, SOE, DR, Relay and schematic diagram of auxiliary supply, wherever applicable) related to above trippings for meaningful analysis during the meeting.

Your participation in the meeting is highly solicited. Please confirm your participation in the meeting along with name and designation of the participants.

Yours faithfully,

-sd(A. K. Bandyopadhyaya)
Member Secretary

LIST OF ADDRESSES:

Chief Engineer, Trans (O&M)	Electrical Superintending Engineer (CRITL)
Bihar State Electricity Board, Vidyut Bhawan,	Bihar State Electricity Board, Vidyut Bhawan,
Bailey Road, Patna-800021	Bailey Road, Patna-800021
Chief Engineer (SLDC)	Chief Engineer (CTC)
Damodar Valley Corporation, GOMD-I Premises,	Damodar Valley Corporation, P.O. Maithon Dam,
P.O Danesh Seikh Lane, Howrah-711109	Dist. Dhanbad, Jharkhand-828207
Chief Engineer, Trans (O&M)	Electrical Superintending Engineer (CLD)
Jharkhand State Electricity Board	Jharkhand State Electricity Board, Kusai Colony,
Kusai Colony, Doranda, Ranchi-834002	Doranda, Ranchi-834002
Chief General Manager (O&M),	Sr. General Manager (PPA), Technical Wing,
OPTCL, Janpath, Bhubaneswar,	OHPCL, Orissa State Police Housing & Welfare
	I
Odisha – 751 022. FAX: 0674-2542932	Corpn. Bldg. Vanivihar Chowk,
cgm.onm@optcl.co.in	Janpath, Bhubaneswar-752022
Chief Load Dispatcher, SLDC	Chief Engineer (Testing), WBSETCL
OPTCL, P.O. Mancheswar Rly. Colony	Central Testing Laboratory, Abhikshan, Salt Lake,
Bhubaneswar-751017	Kolkata-700091 (Fax no. 2367-3578/1235)
Chief Engineer (CLD)	Addl. Chief Engineer (ALDC)
WBSETCL, P.O. Danesh Sheikh Lane,	West Bengal Electricity Distribution Company Ltd
Andul Road, Howrah-711109	Vidyut Bhavan, 7 th Floor, Bidhannagar, Sector-I
	Salt Lake City, Kolkata-700091(Fax-033-2334-5862)
Dy. Chief Engineer (Testing)/ Sr. Manager (Testing)	General Manager (O&M)
CESC Ltd.,4, Sasi Sekhar Bose Road,	KhSTPS, NTPC Ltd., P.O. Deepti Nagar,
Kolkata-700025	Dist. Bhagalpur, Bihar-813203
General Manager(O&M)	Dy. General Manager (Engineering),
FSTPS, NTPC Ltd., P.O. Nabarun,	WBPDCL,OS Dept. Corporate Office, 3/C,L.A Block,
Dist. Murshidabad, West Bengal-742236	Salt Lake-III, Kolkata-700098 (Fax-033-23350516)
General Manager (O&M)	General Manager (OS), ERHQ-II, NTPC Ltd., 3 rd flr.
Barh STPS, NTPC Ltd., P.O. NTPC Barh,	OLIC Building, Plot no. N 17/2, Nayapalli, Unit-8
Dist. Patna, Bihar-803213	Bhubaneswar- 751012 (Fax No. 0674-2540919)
General Manager(O&M)	General Manager (O&M)
TSTPS, NTPC Ltd.	POWERGRID, Odisha Projects
P.O.Kaniha, Dist. Angul, Orissa-759117	Sahid Nagar, Bhubaneswar – 751 007
General Manager(OS), ERHQ-I, NTPC Ltd.,	Director (GM Division)
Loknayak Jaiprakash Bhawan, (2 nd Floor),	Central Electricity Authority
Dak Bunglow Chawk, Patna-800001	Sewa Bhawan, R. K. Puram, New Delhi-110066
Executive Director (O&M)	Electrical Superintending Engineer, TTPS,
NHPC Ltd., NHPC Office Complex, Sector-33,	Tenughat Vidyut Nigam Ltd.,
Faridabad, Haryana-121003 (Fax-01292272413)	Lalpania, Dist. Bokaro, Jharkhand-829149
Dy. General Manager (Electrical)	General Manager (OS), ER-I
IB Thermal Power Station, OPGCL	Power Grid Corporation of India Ltd.,
	Alankar Place, Boring Road, Patna-800001
Banhapalli, Dist. Jharsuguda-768234,Orissa	ĕ
Chief Engineer (Trans.)	Sr. Manager (CTMC)
Power Deptt., Govt. of Sikkim,	Durgapur Projects Limited,
Gangtok-731010	Durgapur-713201
General Manager,	Manager (Electrical), Adhunik Power & Natural
ERLDC, POSOCO	Resources Ltd. "Lansdowne Towers, Kolkata-700020
14, Golf Club Road, Tollygunge, Kolkata-700033	(Fax No. 033-2289 0285)
General Manager (OS), ER-II	Shri A.K.Nayak/Shri Sumit S Ghosh
Power Grid Corporation of India Ltd.,	Maithon Power Limited, Maithon Office, MA 5
J-I-15, Block-EP, Sector-V,Salt Lake,Kolkata-91	Gogna, Dist. Dhanbad, Jhankand State, PIN-828207
General Manager (P&O), PTC Ltd.,	Vice President, Vedanta Ltd.
Kanchanjunga Bldg.,18, Barakhamba Road,	1 st Floor, Module C/2, Fortune Tower, C S Pur,
New Delhi-110001	Bhubaneswar- 751023
Managing Director, Bhutan Power Corporation	Managing Director, Druk Green Power Corprn.
Post Box no. 580, Thimpu, Bhutan.	P.O. Box-1351, Thimpu, Bhutan.
Darbhanga(Bihar), Darbhanga Motihari Transmission	Head Construction, ENCIL, Siliguri-7340051
Company Limited (DMTCL)	

Annexure-I

LINE NAME	TRIP DATE	TRIP TIME	RESTORATIO N DATE	RESTORA TION TIME	Relay Indication LOCAL END	Relay Indication REMOTE END	Reason	
Fault Clearing time violating protection standard								
220KV FSTPP-LALMATIA-I	18/07/2017	9:50	18/07/2017	12:25	R_N,64.5km ,zone 1 from farakka		R-N FAULT	
220KV CHANDIL-RANCHI-I	21/07/2017	3:56	21/07/2017	4:44	R_N,81 km from ranchi,2.31 kA current	5.78 KA ,13.27 km from chandil,Zone 1	R-N FAULT	
20KV CHANDIL-STPS(WBSEB)-I	21/07/2017	3:56	21/07/2017	4:41	R_N		R-N FAULT	
No autoreclose operation observed in PMU data								
00KV FARAKKA - KAHALGAON-IV	01/07/2017	23:09	01/07/2017	23:43	Did not trip	Y-ph, z1	Y-N FAULT	
00KV RANCHI-ROURKELA-I	02/07/2017	16:32	02/07/2017	17:14	Ranchi: Y_N,F.D.26.7 KM, F.C. 8.6 kA	Rourkela: Y_N,F.D. 136 KM, F.C. 2.709 kA, A/R started but after 80 ms healthy phase breakers also opened	Y-N FAULT	
65KV NEW RANCHI- DHARAMJAIGARH-II	05/07/2017	15:41	05/07/2017	18:45	Y-N, 29.91 KM, F/C=1.5 KA, DT received		Y-N FAULT	
<u>00kv Biharsariff-</u> Muzaffarpur-i	06/07/2017	14:12	06/07/2017	15:12	Y-N, F/C 9.7 kA, 14.44 km from MZF	Y-N, F/C 3.07 kA, 101 km from BSF	Y-N FAULT	
20KV BARIPADA-BALASORE-II	07/07/2017	11:39	08/07/2017	19:52	R-N, Z-I, 9.2KM , 9.544KA From Baripada	R-N, 70KM from Balasore, 1.36KA	R-N FAULT	
20KV TSTPP-MEERAMUNDALI-II	08/07/2017	16:09	08/07/2017	19:46	R-N, Z-I, IR=14.39KA		R-N FAULT	
OOKV PATNA-BALIA-II	09/07/2017	15:08	09/07/2017	15:49	Y-N,7.9 km ,F/C 13 KA		Y-N FAULT	
OOKV PATNA-BALIA-III	09/07/2017	15:16	09/07/2017	17:14	R-N, F/C 10.47 kA, 13.9 km from Patna	125 KM,3.44 KA,R_N from Balia	R-N FAULT	
20KV DEHRI -GAYA-II	09/07/2017	15:33	09/07/2017	15:46	B-N, Z-I, 45.7 km from Dehri		B-N FAULT	
20KV ARRAH-PUSAULI-S/C	10/07/2017	9:13	10/07/2017	9:51	R_N,26.84 km from Arrah,2.839 KA		R-N FAULT	
OOKV LAKHISARAI-KhSTPP-II	11/07/2017	8:15	11/07/2017	9:01	y_n,92.1 KM FROM kAHALGAON	Y_N,64.7 KM FROM LAKHISARAI,7.2 KA	Y-N FAULT	
20KV BUDHIPADAR-RAIGARH-I	14/07/2017	12:40	14/07/2017	14:26	Y_B_N fault, Z1, 18KM From Budhipadar, Yph-11.04 KA, Bph-11.07 KA		Y-B-N FAULT	
20KV JORETHANG-NEW MELLI-I	15/07/2017	16:59	15/07/2017	19:01	Y-B FAULT, 2.5KM,		Y-B-N FAULT	
20KV BUDHIPADAR-KORBA-II	15/07/2017	21:31	15/07/2017	22:25	R_N,147.5 KM from Budhipadar, Zone II		R-N FAULT	
20KV GAYA-SONENAGAR-II	20/07/2017	14:24	20/07/2017	15:15	54.1KM From Gaya, B_N, 2.8KA	49KM from Sonenagar,B_N	B-N FAULT	
00KV KOLAGHAT-KHARAGPUR-II	28/07/2017	9:04	28/07/2017	9:16	Y_N, F.D. 61.71 KM, F.C. 3.56 kA (Kharagpur end)	Y_N, F.D. 30.52 KM, F.C.7.50 kA, A/R successful (Kolaghat end)	Y-N FAULT	
20KV CHANDIL-RANCHI-I	29/07/2017	20:16	29/07/2017	20:55	R_N, Z_1 lr=2.543KA	R_N, Ir=3.704KA, 40.14 KM From Ranchi	R-N FAULT	
00KV PPSP-BIDHANNAGAR-I	30/07/2017	5:33	30/07/2017	5:47	R_N,Z-1,1.1 KA,151 KM FROM BIDHANNAGAR		R-N FAULT	
Sasaram HVDC Tripping								
IVDC PUSAULI	17/07/2017	5:41	17/07/2017	6:38	SYSTEM FAIL ALARM		SYSTEM FAILURE ALARM A PUSAULI	

HVDC PUSAULI	17/07/2017	16:35	17/07/2017	17:34	SYSTEM FAIL ALARM	SYSTEM FAILURE ALARM AT PUSAULI
HVDC PUSAULI	20/07/2017	8:29	20/07/2017	9:25	SYSTEM FAIL ALARM	System alarm failure
HVDC PUSAULI	31/07/2017	18:34	31/07/2017	19:45	SYSTEM FAIL ALARM	System fail alarm

Miscellaneous: Tripping on DT, Spurious tripping, No reason furnished

			I I J	- ,	oparious tripping / ito		
400KV RANCHI-ROURKELA-I	05/07/2017	17:44	05/07/2017	18:05			SPURIOUS TRIPPING
400KV NEW PURNEA-KISHANGANJ-	10/07/2017	5:36	10/07/2017	6:17	DT received		OPERATION OF GIS GAS COMPARTMENT ZONE TRIP (GS-8) DUE TO HEAVY RAIN AT KISHANGANI
400KV NEW PURNEA-KISHANGANJ- L	10/07/2017	8:28	10/07/2017	10:33	DT received		OPERATION OF GIS GAS COMPARTMENT ZONE TRIP (GS-8) DUE TO HEAVY RAIN AT KISHANGANI
400KV BAHARAMPUR- BHERAMARA-II	11/07/2017	14:18	11/07/2017	15:38	Did not trip		SPURIOUS TRIPPING
400KV BINAGURI-BONGAIGAON-I	13/07/2017	10:21	13/07/2017	10:37	DT received	Did not trip	DT RECEIVED AT BINAGURI
765KV JHARSUGUDA-DARLIPALI-I	17/07/2017	11:20	17/07/2017	19:35	DT Received		DT RECEIVED AT JHARSUGUDA
400KV JAMSHEDPUR-ANDAL-I	17/07/2017	16:50	17/07/2017	17:12	DT Received	Did not trip	DT RECEIVED AT JAMSHEDPUR
400KV FSTPP-BAHARAMPUR-SC	18/07/2017	19:40	18/07/2017	20:07	-	DT Received	DT RECEIVED AT BAHARAMPUR
400KV FSTPP-BAHARAMPUR-SC	18/07/2017	20:09	18/07/2017	22:06		DT Received	DT RECEIVED AT BAHARAMPUR
400KV BARIPADA-KEONJHOR-I	19/07/2017	13:15	19/07/2017	13:31	Did not trip		DT RECEIVED AT KEONJHAR
1500MVA ICT-2 AT JHARSUGUDA	23/07/2017	14:17	23/07/2017	17:05	SPURIOUS TRIPPING		
400KV GAYA-KODERMA-I	26/07/2017	16:33	26/07/2017	16:45	DT received at Gaya end.		DT received at Gaya end.
400KV MEERAMUNDALI-ANGUL-I	28/07/2017	11:03	28/07/2017	11:39	Opened from Meramundali end only. DT received.		DT received at Meramundali
400KV TSTPP-RENGALI-I	28/07/2017	22:11	28/07/2017	22:23	INADVERTENT TRIPPING WHILE DOING S/D WORK AT RENGALI MAIN BUS II	DT SENT TO TALCHER	DT SENT TO TALCHER WHILE DOING S/D WORK AT RENGALI MAIN BUS II
765KV DHARAMJAIGARH- JHARSUGUDA-I	29/07/2017	10:56	29/07/2017	11:18	Opened from Dharmjaygarh end. DT received.		DT received at Dharamjaygarh