



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/2017

Date: 22.09.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 04.09.2017-10.09.2017**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

**(A.K.BANDYOPADHYAY)**  
**MEMBER SECRETARY**

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 04/09//17 to 10/09/17**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	3684906

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 04/09/17 to 10/09/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/L (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-1269.9	171437	0	0	171437
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-1064.6	143721	0	0	143721
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-503.3	67946	0	0	67946
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	0	0	-521.8	-70443	-70443
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-39.9	5387	-20.5	-2767.5	2619
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	0	0	-905	-122175	-122175
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-5535.5	747293	0	0	747293
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-741.2	100062	-501.3	-67675.5	32387
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-185.1	24989	-468.9	-63301.5	-38313
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-67.2	9072	-1	-135	8937
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-46.7	6305	-5	-675	5630
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	0	0	0.1	13.5	14
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0.6	-81	36	4860	4779
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-3445	465075	0	0	465075
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-3188.8	430488	-0.5	-67.5	430421
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	404.6	-54621	0	0	-54621
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	404.7	-54635	0	0	-54635
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-201.2	27162	-357.3	-48235.5	-21074
	19	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-2370.7	320045	0	0	320045
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	0	0	0	0	0
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	0	0	0	0	0
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2815	380025	0	0	380025
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-2547.5	343913	0	0	343913
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-10.6	1431	0	0	1431
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-10.7	1445	0	0	1445
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	-15.5	2093	0	0	2093
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	-9.3	1256	0	0	1256
	28	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	203.6	-27486	0	0	-27486
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	11.4	-1539	45.7	6169.5	4631
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	654.8	-88398	0	0	-88398
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-330	44550	-0.1	-13.5	44537
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-723.8	97713	-0.1	-13.5	97700
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-844.3	113981	0	0	113981
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	0	0	0
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	-6.9	-931.5	-932
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	0	0	0
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-603.3	81446	0	0	81446
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-542.3	73211	0	0	73211
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	734.5	-99158	0	0	-99158
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	754.5	-101858	0	0	-101858
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1155	155925	-14.6	-1971	153954
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1420.2	191727	-0.1	-13.5	191714
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-1	ER1284A	333.6	-45036	0	0	-45036
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-2	ER1289A	328.5	-44348	0	0	-44348
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-1	ER1171A	-5	675	-174.2	-23517	-22842
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-2	ER1177A	-5.6	756	-181.3	-24475.5	-23720
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-1	ER1256A	9.9	-1337	-39.5	-5332.5	-6669
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-2	ER1258A	-75.3	10166	-297.8	-40203	-30038
		<b>TOTAL</b>		<b>3490533</b>		<b>-367376</b>	<b>3123158</b>	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-13721	1852335	0	0	1852335
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-2964.6	400221	0	0	400221
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	465	-62775	0	0	-62775
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3423.8	-462213	0	0	-462213
	6	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1439.3	194306	0	0	194306
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-125.4	16929	11	1485	18414
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-119.4	16119	0	0	16119
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	39.7	-5360	0	0	-5360
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8869A	98	-13230	0	0	-13230
		<b>TOTAL</b>		<b>1936332</b>		<b>1485</b>	<b>1937817</b>	
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) -II	NP6458A	-4448.4	600534	0	0	600534
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-0.4	54	0	0	54
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-33.4	4509	0	0	4509
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	50.6	-6831	0	0	-6831
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	113	-15255	0	0	-15255
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-3745	505575	0	0	505575
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	164.8	-22248	0	0	-22248
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	73.2	-9882	0	0	-9882
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	2987.2	-403272	0	0	-403272
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	2688.9	-363002	0	0	-363001.5
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-3630.1	490064	0	0	490063.5
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-2410.5	325418	0	0	325417.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	632.4	-85374	0	0	-85374
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	710.9	-95972	0	0	-95971.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-9155.1	1235939	0	0	1235938.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-9180.8	1239408	0	0	1239408
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-8434.4	1138644	0	0	1138644
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	4873	-657855	0	0	-657855
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-8426.5	1137578	0	0	1137577.5
	21	400 KV RANCHI(PG)-RTPS(DVC)-2	NP7871A	9150.1	-1235264	0	0	-1235263.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-3	NP7853A	8329.7	-1124510	0	0	-1124509.5
		<b>TOTAL</b>		<b>5018031</b>		<b>0</b>	<b>5018031</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	16.8	-2268	0	0	-2268
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-231.1	31198.5	0	0	31198.5
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-495.3	66865.5	0	0	66865.5
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	3572.1	-482233.5	0	0	-482233.5
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	3761.9	-507856.5	0	0	-507856.5
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	-42.8	5778	0	0	5778
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-419.2	56592	0	0	56592
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	58.7	-7924.5	0	0	-7924.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1862.8	251478	0	0	251478
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4903	661905	0	0	661905
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4634.4	625644	0	0	625644
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4668.2	630207	0	0	630207
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2767.3	373585.5	0	0	373585.5
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-2505.3	338215.5	0	0	338215.5
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-5759.9	777586.5	0	0	777586.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	5940	-801900	0	0	-801900
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	9140.8	-1234008	0	0	-1234008
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	2274.5	-307057.5	0	0	-307057.5
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-12.9	1741.5	0	0	1741.5
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-14.5	1957.5	0	0	1957.5
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-1992.7	269014.5	0	0	269014.5
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0.3	40.5	40.5
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-3.5	-472.5	-472.5
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-1420	191700	0	0	191700
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	414.1	-55903.5	0	0	-55903.5
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	459	-61965	0	0	-61965
		<b>TOTAL</b>		<b>822353</b>		<b>-432</b>	<b>821921</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-33.50	4523	0	0	4523
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-0.30	41	0	0	41
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	8.30	-1121	0	0	-1121
		<b>TOTAL</b>		<b>3443</b>		<b>0</b>	<b>3443</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	0	0	-2399.6	-323946	-323946
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	0	0	-6513.1	-879269	-879269
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	-469.7	63410	-1339.9	-180887	-117477
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	-324.7	43835	-1144.8	-154548	-110714
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-1295.2	-174852	-174852
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0	0	-1850.1	-249764	-249764
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	56.1	-7574	0	0	-7574
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	70.4	-9504	0	0	-9504
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-929.4	125469	0	0	125469
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-455.2	61452	0	0	61452
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-1580	213300	0	0	213300
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	-840.4	113454	0	0	113454
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	5063.6	-683586	0	0	-683586
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	2812.4	-379674	0	0	-379674
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-489.8	66123	0	0	66123
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	405.2	-54702	0	0	-54702
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	41	-5535	0	0	-5535
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-54.5	7358	0	0	7358
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	-1058.7	142925	0	0	142925
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	1621.7	-218930	0	0	-218930
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	2638.2	-356157	0	0	-356157
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-365	49275	0	0	49275
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1071A	-283.5	38273	0	0	38273
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	60.6	-8181	-5.8	-783	-8964
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	35.1	-4739	-224.7	-30335	-35073
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	60.6	-8181	-258.3	-34871	-43052
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	622.7	-84065	83.7	11300	-72765
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	382.7	-51665	342	46170	-5495
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	981.8	-132543	206.4	27864	-104679
	31	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	430.4	-58104	0	0	-58104
	32	402 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	267.4	-36099	0	0	-36099
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-3159.5	426533	0	0	426533
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8731A	1492.5	-201488	0	0	-201488
	35	400 KV PPS NEW(WB)-RANCHI NEW(PG)-1	ER1040A	2984.4	-402894	0	0	-402894
	36	400 KV PPS NEW(WB)-RANCHI NEW(PG)-2	ER1130A	3018.2	-407457	0	0	-407457
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-109	14715	0	0	14715
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-29.4	3969	0	0	3969
		<b>TOTAL</b>		<b>-1740987</b>		<b>-1943919</b>	<b>-3684906</b>	

**Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/kVArh,w.e.f. 01/04/2017**

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTD.

5) "NA" means meter reading not available.