



सत्यमेव जयते

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/2017

Date: 20.11.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JBVNL, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)


**Sub: Provisional Reactive Energy (VARH) Charges for the week from 30.10.2017-05.11.2017**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

  
(J. BANDYOPADHYAY)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 30/10//17 to 05/11/17**

***REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL***

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	5226431
SIKKIM	POOL	0
WBSETCL	POOL	2675741

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

*for the period 30/10/17 to 05/11/17*

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE
<b>BSPHCL</b>	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-3459.6	467046	0	0	467046
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-4172.3	563261	0	0	563261
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-3300.9	445622	0	0	445622
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	-140.6	18981	0	0	18981
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-269.6	36396	0	0	36396
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	21.3	-2876	0	0	-2876
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1467.7	198140	0	0	198140
	8	132 KV ARAH (PG) - ARAH (BSPHCL)	NP6051A	-1767.8	238653	0	0	238653
	9	132 KV ARAH (PG) - DUMRAO (BSPHCL)	NP6054A	-1113.5	150323	0	0	150323
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-2374.3	320531	0	0	320531
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-1000.1	135014	0	0	135014
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	147.3	-19886	0	0	-19886
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	0	0	0
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2087.7	281840	0	0	281840
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-2151	290385	0	0	290385
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	594.7	-80285	0	0	-80285
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	661.7	-89330	0	0	-89330
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-737.8	99603	0	0	99603
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1726.3	233051	0	0	233051
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8675A	23.1	-3119	0	0	-3119
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	22.2	-2997	0	0	-2997
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2657.4	358749	0	0	358749
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-308.8	41688	0	0	41688
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-635.5	85793	0	0	85793
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-638.9	86252	0	0	86252
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	-224.2	30267	0	0	30267
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	-192.4	25974	0	0	25974
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	310.1	-41864	0	0	-41864
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	108.3	-14621	0.1	13.5	-14607
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	3301.9	-445757	0	0	-445757
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-1268.4	171234	-0.1	-13.5	171221
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-3558.7	480425	0	0	480425
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-3873.5	522923	-0.1	-13.5	522909
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	-1.3	176	0	0	176
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	0	0	0
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-0.5	68	0	0	68
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-471.7	63680	0	0	63680
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-577	77895	0	0	77895
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2394.2	-323217	0	0	-323217
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2399.1	-323879	0	0	-323879
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2779.7	375260	0	0	375260
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2915	393525	0	0	393525
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-1	ER1284A	2496.8	-337068	0	0	-337068
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-2	ER1289A	2835.7	-382820	0	0	-382820
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPTCL)-1	ER1171A	315.2	-42552	-4.9	-661.5	-43214
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPTCL)-2	ER1177A	307.8	-41553	-5.2	-702	-42255
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-1	ER1256A	-336.8	45468	-9	-1215	44253
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-2	ER1258A	194.7	-26285	-0.2	-27	-26312
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPTCL)-1	ER1172A	39.1	39.1	39.1	39.1	39.1
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPTCL)-2	ER1229A	41.5	41.5	41.5	41.5	41.5
		<b>TOTAL</b>		<b>4060192</b>	<b>0</b>	<b>-2538</b>	<b>4057654</b>	
<b>JUVNL</b>	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-12763.3	1723046	0	0	1723046
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-3183.6	429786	0	0	429786
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	8554.3	-1154831	0	0	-1154831
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2418.6	-326511	0	0	-326511
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1725	232875	0	0	232875
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-901.8	121743	0	0	121743
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-889.6	120096	0	0	120096
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8868A	51	-6885	0	0	-6885
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	287.8	-38853	0	0	-38853
		<b>TOTAL</b>		<b>1100466</b>	<b>0</b>	<b>0</b>	<b>1100466</b>	
<b>DVC</b>	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-5515.2	744552	0	0	744552
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-1230.6	166131	0	0	166131
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-1413.4	190809	0	0	190809
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	1312.2	-177147	0	0	-177147
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	1240.2	-167427	0	0	-167427
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIAPADA(PG)	NP7408A	-5955.1	803939	0	0	803938.5
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1415.4	-191079	0	0	-191079
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1481.7	200030	0	0	200029.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	614.1	-82904	0	0	-82903.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	582.2	-78597	0	0	-78597
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-8883.3	1199246	0	0	1199245.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-8606.2	1161837	0	0	1161837
	14	400 KV KODERMA(DVC) - Gayni(PG)-I	NP7891A	1797.4	-242649	0	0	-242649
	15	400 KV KODERMA(DVC) - Gayni(PG)-II	NP7890A	1347.2	-181872	0	0	-181872
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-14161.8	1911843	0	0	1911843
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-14193.8	1916163	0	0	1916163
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4667.6	632826	0	0	632826
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-1916	258660	0	0	258660
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-12316.6	1662741	0	0	1662741
	21	400 KV RANCHI(PG)-RTPS(DVC)-2	NP7871A	2310.2	-311877	0	0	-311877
	22	400 KV RANCHI(PG)-RTPS(DVC)-3	NP7853A	4685.5	-632543	0	0	-632542.5
		<b>TOTAL</b>		<b>8782682</b>	<b>0</b>	<b>0</b>	<b>8782682</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	385	-51975	0	0	-51975
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	620.4	-83754	0	0	-83754
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	718.4	-96984	0	0	-96984
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	2858.8	-385938	0	0	-385938
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	2860.3	-386140.5	0	0	-386140.5
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	686.8	-92718	0	0	-92718
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1511.3	204025.5	0	0	204025.5
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	260.5	-35167.5	0	0	-35167.5
	10	220 KV TSTPP (NTFC) - RENGALI HPS (GRIDCO)	NP5102A	-1077.2	145422	0	0	145422
	11	220 KV TSTPP (NTFC) - TTPS (GRIDCO)	NP5103A	-5373	725355	0	0	725355
	12	220 KV TSTPP (NTFC) - MMUNDALI (GRIDCO)-I	NP5112A	-4314.6	582471	0	0	582471
	13	220 KV TSTPP (NTFC) - MMUNDALI (GRIDCO)-II	NP5101A	-4288.2	576207	0	0	576207
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1329.4	179469	0	0	179469
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-637.1	86008.5	0	0	86008.5
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	NP7916A	-12605	1701675	0	0	1701675
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	28755.7	-3882019.5	0	0	-3882019.5
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	27734.2	-3744117	0	0	-3744117
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTFC)	NP7932A	10494.9	-1416811.5	0	0	-1416811.5
	21	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	NP5980A	-1518.9	205051.5	0	0	205051.5
	22	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	NP7498A	-1899.2	256392	0	0	256392
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4273	578855	0	0	578855
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	34.8	-4698	0.3	40.5	-4657.5
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-5.1	688.5	0	0	688.5
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-2406.9	324931.5	0	0	324931.5
	28	400 KV STERLITE - ROURKELA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	1980.7	-267394.5	0	0	-267394.5
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2177.6	-293976	0	0	-293976
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	6.8	-918	0	0	-918
	33	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	358.6	-48411	0	0	-48411
		<b>TOTAL</b>		<b>-5226471</b>		<b>41</b>	<b>-5226431</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-184.50	24908	0	0	24908
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-73.00	9855	0	0	9855
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	66.40	-8964	0	0	-8964
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	63.40	-8559	0	0	-8559
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.20	-1647	0	0	-1647
		<b>TOTAL</b>		<b>15593</b>		<b>0</b>	<b>15593</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	-4116.3	555701	0	0	555701
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	-1470.6	198531	-305.9	-41297	157235
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	1199.3	-161906	-0.3	-41	-161946
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	1463	-197505	0	0	-197505
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	-89.3	12056	0	0	12056
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	-1.5	203	0	0	203
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-152.9	20642	0	0	20642
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-797	107595	0	0	107595
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-1297.1	175109	0	0	175109
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-894.8	120798	0	0	120798
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	2578	-348030	0	0	-348030
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	3548.3	-479021	0	0	-479021
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	8.6	-1161	0	0	-1161
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	9095.6	-1227906	0	0	-1227906
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	8569.4	-1156869	0	0	-1156869
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	255.2	-34452	0	0	-34452
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-1556.7	210155	0	0	210155
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-2.9	392	0	0	392
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-86.7	11705	0	0	11705
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	810.2	-108377	0	0	-108377
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	7683.6	-1037286	0	0	-1037286
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	7841.5	-1058603	0	0	-1058603
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-673.3	90896	0	0	90896
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-349.4	47169	0	0	47169
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	413	-55755	-0.3	-41	-55796
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	311.2	-42012	-3.8	-513	-42525
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	2266.9	-306032	0	0	-306032
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	4954.1	-668804	0	0	-668804
	29	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-3530.1	476564	0	0	476564
	30	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-3548.6	479061	0	0	479061
	31	400 KV SAGARDIGHI(WB)-BEHRAMPUR(PG) LINE-I	NP8723A	-682.6	92151	0	0	92151
	32	400 KV SAGARDIGHI(WB)-BEHRAMPUR(PG) LINE-II	NP8724A	-656.4	88614	0	0	88614
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-4395.3	593366	0	0	593366
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8731A	-4424.3	597281	0	0	597281
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-1	ER1040A	4564.1	-616154	0	0	-616154
	36	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-2	ER1130A	4653.5	-628223	0	0	-628223
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-6217.8	839403	0	0	839403
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-5761.9	777857	0	0	777857
		<b>TOTAL</b>		<b>-2633850</b>		<b>-41891</b>	<b>-2675741</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArh, w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.