



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/2017

Date: 07.12.2017

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JBVNL, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 13.11.2017-19.11.2017**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

**(J. BANDYOPADHYAY)**  
**MEMBER SECRETARY**

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 13/11/17 to 19/11/17**

***REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL***

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	7652165
SIKKIM	POOL	41013
WBSETCL	POOL	3532235

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

*for the period 13/11/17 to 19/11/17*

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-2006.2	270837	0	0	270837
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2980.4	402354	0	0	402354
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1964	265140	0	0	265140
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	-257.8	34803	0	0	34803
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-352.4	47574	0	0	47574
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	-209.2	28242	0	0	28242
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	344.2	-46467	0	0	-46467
	8	132 KV ARAH (PG) - ARAH (BSPHCL)	NP6051A	-1756.4	237114	0	0	237114
	9	132 KV ARAH (PG) - DUMRAO (BSPHCL)	NP6054A	-864.8	116748	0	0	116748
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-1440.9	194522	0	0	194522
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-1023.8	138213	0	0	138213
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	152.7	-20615	0	0	-20615
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	0	0	0
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2951.8	398493	0	0	398493
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-3033	409455	0	0	409455
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	382.1	-51584	0	0	-51584
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	376.6	-50841	0	0	-50841
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-658.6	88911	0	0	88911
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1621.6	218916	0	0	218916
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8675A	46.8	-6318	0	0	-6318
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	44.1	-5954	0	0	-5954
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1681.5	227003	0	0	227003
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-436.9	58982	0	0	58982
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-628.4	84834	0	0	84834
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-583.4	78759	0	0	78759
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	-252.5	34088	0	0	34088
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	-240.1	32414	0	0	32414
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	310.4	-41904	0	0	-41904
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	NP4614A	0	0	0	0	0
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	NP4444A	0	0	0	0	0
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	NP4436A	0	0	0	0	0
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	NP4440A	0	0	0	0	0
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	123.6	-16686	0	0	-16686
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	0	0	0	0	0
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-1359	183465	0	0	183465
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-3566.1	481424	0	0	481424
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-3886.8	524718	0	0	524718
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	-6.3	851	0	0	851
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	-0.9	122	0	0	122
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	-0.3	41	0	0	41
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-3.1	419	0	0	419
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-156.9	21182	0	0	21182
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-254.1	34304	0	0	34304
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2031.1	-274199	0	0	-274199
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2644.4	-356994	0	0	-356994
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2549.5	344183	0	0	344183
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2700.7	364595	0	0	364595
	48	220 KV DARBHANGA(DMTCL)-MOTIPURI(BSPTCL)-1	ER1284A	356.3	-480101	0	0	-480101
	49	220 KV DARBHANGA(DMTCL)-MOTIPURI(BSPTCL)-2	ER1289A	3519.8	-475173	0	0	-475173
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPTCL)-1	ER1171A	254.3	-34331	0	0	-34331
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPTCL)-2	ER1177A	242.1	-32684	0	0	-32684
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-1	ER1256A	-374.9	50612	0	0	50612
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-2	ER1258A	175	-23625	0	0	-23625
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPTCL)-1	ER1172A	46.8	46.8	46.8	46.8	46.8
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPTCL)-2	ER1229A	53.3	53.3	53.3	53.3	53.3
		<b>TOTAL</b>		<b>3455938</b>	<b>0</b>	<b>100</b>	<b>3456038</b>	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-12101.2	1633662	0	0	1633662
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	-0.2	-27	-27
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-2033.1	274469	0	0	274469
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	8059.2	-1087992	0	0	-1087992
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	4159.9	-561587	0	0	-561587
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1592.4	214974	0	0	214974
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-720.6	97281	0	0	97281
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-713.8	96363	0	0	96363
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8868A	51.3	-6926	0	0	-6926
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	336.8	-45468	0	0	-45468
		<b>TOTAL</b>		<b>614777</b>	<b>0</b>	<b>-27</b>	<b>614750</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-5419.8	731673	0	0	731673
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-1180.2	159327	0	0	159327
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-1255.4	169479	0	0	169479
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	960.6	-129681	0	0	-129681
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	978.6	-132111	0	0	-132111
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIAPADA(PG)	NP7408A	-6244.4	842994	0	0	842994
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	5885.3	-794516	0	0	-794516
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-2692.7	363515	0	0	363515
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	NP5226A	-1071.8	144693	0	0	144693
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	NP5227A	-1106.7	149405	0	0	149405
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-9172	1238220	0	0	1238220
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-8898.4	1201284	0	0	1201284
	14	400 KV KODERMA(DVC) - Gayni(PG)-I	NP7891A	1777.9	-240017	0	0	-240017
	15	400 KV KODERMA(DVC) - Gayni(PG)-II	NP7890A	1382.8	-186678	0	0	-186678
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-12830.9	1732172	0	0	1732172
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-12874.5	1738058	0	0	1738058
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-889.1	120029	0	0	120029
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-884.1	119354	0	0	119354
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-11693.5	1578623	0	0	1578623
	21	400 KV RANCHI(PG)-RTPS(DVC)-2	NP7871A	5737	-774495	0	0	-774495
	22	400 KV RANCHI(PG)-RTPS(DVC)-3	NP7853A	3852.8	-520128	0	0	-520128
		<b>TOTAL</b>		<b>7511198</b>	<b>0</b>	<b>0</b>	<b>7511198</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	198.6	-26811	0	0	-26811
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	803.7	-108499.5	0	0	-108499.5
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	972.2	-131247	0	0	-131247
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	3959.2	-534492	0	0	-534492
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	3963.7	-535099.5	0	0	-535099.5
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	66.7	-9004.5	0	0	-9004.5
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1454.3	196330.5	0	0	196330.5
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	257.5	-34762.5	0	0	-34762.5
	10	220 KV TSTPP (NTFC) - RENGALI HPS (GRIDCO)	NP5102A	-1157.8	156303	0	0	156303
	11	220 KV TSTPP (NTFC) - TTPS (GRIDCO)	NP5103A	-4947.2	667872	0	0	667872
	12	220 KV TSTPP (NTFC) - MMUNDALI (GRIDCO)-I	NP5112A	-3479.8	469773	0	0	469773
	13	220 KV TSTPP (NTFC) - MMUNDALI (GRIDCO)-II	NP5101A	-3767.8	508653	0	0	508653
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-394	53190	0	0	53190
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-343.1	46318.5	0	0	46318.5
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	NP7916A	-12753.1	1721668.5	0	0	1721668.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	37198.4	-5021784	0	0	-5021784
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	29439.3	-3974305.5	0	0	-3974305.5
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTFC)	NP7932A	10873.1	-1467868.5	0	0	-1467868.5
	21	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	NP5980A	-2054.6	277371	0	0	277371
	22	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	NP7498A	-2434.2	328617	0	0	328617
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5734.4	774144	0	0	774144
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	711.7	-96079.5	0	0	-96079.5
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	2.8	-378	0	0	-378
	26	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	3102.7	-418864.5	0	0	-418864.5
	27	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2964.6	-400221	0	0	-400221
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	138.8	-18738	0	0	-18738
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	464.7	-62734.5	0	0	-62734.5
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	NP6538A	44	-5940	0	0	-5940
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	NP6539A	41.3	-5575.5	0	0	-5575.5
		<b>TOTAL</b>		<b>-7652165</b>	<b>0</b>	<b>0</b>	<b>-7652165</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-181.70	24530	0	0	24530
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-113.90	15377	-224.6	-30321	-14945
	3	86 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	-0.10	14	-3	-405	-392
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	182.40	-24624	0	0	-24624
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	178.90	-24152	0	0	-24152
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	10.60	-1431	0	0	-1431
		<b>TOTAL</b>		<b>-10287</b>		<b>-30726</b>	<b>-41013</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	NP6445A	-4240	572400	0	0	572400
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	-1694.6	228771	-125.4	-16929	21842
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	2264.3	-305681	0	0	-305681
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	2583.7	-348800	0	0	-348800
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	136.9	-18482	0	0	-18482
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	62.4	-8424	0	0	-8424
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1036.8	139968	0	0	139968
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1392.2	187947	0	0	187947
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-1014.1	136904	0	0	136904
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-673.2	90882	0	0	90882
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	3195.2	-431352	0	0	-431352
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	3846.2	-519237	0	0	-519237
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-60.5	8168	0	0	8168
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	9290.5	-1254218	0	0	-1254218
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	8699.5	-1174433	0	0	-1174433
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	2809	-379215	0	0	-379215
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-1146.6	154791	0	0	154791
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-44.6	6021	0	0	6021
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-59.2	7992	0	0	7992
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	NP7563A	-2046.9	276332	0	0	276332
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	8495.7	-1146920	0	0	-1146920
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	8677.8	-1171503	0	0	-1171503
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	116.2	-15687	0	0	-15687
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1071A	235.3	-31766	0	0	-31766
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	-64	8640	0	0	8640
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	-140.1	18914	0	0	18914
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	2563.7	-346100	0	0	-346100
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	5325.1	-718889	0	0	-718889
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-3641.3	491576	0	0	491576
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-3732.7	503915	0	0	503915
	31	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	712.5	-96188	0	0	-96188
	32	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	749.7	-101210	0	0	-101210
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8720A	-5775.7	779720	0	0	779720
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8731A	-5809	784215	0	0	784215
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-1	ER1040A	4034.9	-544712	0	0	-544712
	36	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-2	ER1130A	4044.7	-546035	0	0	-546035
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-4845.3	654116	0	0	654116
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-4387.2	592272	0	0	592272
		<b>TOTAL</b>		<b>-3515306</b>		<b>-16929</b>	<b>-3532235</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVAH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.