



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2000
ISO: 9001-2000

Tel No. :033-24235199, 24235005 FAX No.:033-24221802, 24171358 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH

Date: 20.02.2018

1. CE (Trans/O&M), BSEB, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSEB, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JBVNL, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Deptt. Of Power, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (CLD), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. GM, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 29.01.2018-04.02.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(J. BANDYOPADHYAY)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 29/01/18 to 04/02/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	1094688
SIKKIM	POOL	2727
WBSETCL	POOL	2355251

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 29/01/18 to 04/02/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAiH_HIGH	REACTIVE CHARGE MVAiH (Rs)	MVAiH_LOW	REACTIVE CHARGE MVAiL (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-1522	205470	0	0	205470
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2230.9	301172	0	0	301172
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-887.5	119813	0	0	119813
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	-74.3	10031	0	0	10031
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	0	0	0	0	0
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	511.4	-69039	0	0	-69039
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3742	505170	0	0	505170
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1474.4	199044	-0.2	-27	199017
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-687.2	92772	0	0	92772
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-1000.2	135027	-54.6	-7371	127656
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP860A	-1896.7	256055	-64.5	-8707.5	247347
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	-635.6	85806	0	0	85806
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	8.4	-1134	-144.7	-19534.5	-20669
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2614.6	352971	0	0	352971
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-2796.5	377528	0	0	377528
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	1044.2	-140967	0	0	-140967
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	999.6	-134946	0	0	-134946
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-727.2	98172	0	0	98172
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2054.5	277358	0	0	277358
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8675A	291.5	-39353	0	0	-39353
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8673A	279.1	-37679	0	0	-37679
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3231.3	436226	0	0	436226
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	484.2	-65367	0	0	-65367
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-318.6	43011	0	0	43011
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-308.8	41688	0	0	41688
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	60.9	-8222	0	0	-8222
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	59.8	-8073	0	0	-8073
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	306.6	-41391	0	0	-41391
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	210.1	-28364	0	0	-28364
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	217.9	-29417	0	0	-29417
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	226.3	-30551	0	0	-30551
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	215.2	-29052	0	0	-29052
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	47.7	-6440	136.8	18468	12029
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	0	0	0	0	0
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-179.8	24273	0	0	24273
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1226.6	165591	0	0	165591
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-1258.1	169844	0	0	169844
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0.7	-95	0	0	-95
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	1.4	-189	0	0	-189
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	-8	1080	0	0	1080
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-29.4	3969	0	0	3969
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-119.1	16079	0	0	16079
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-139.2	18792	0	0	18792
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2456.3	-331601	0	0	-331601
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2467.1	-333059	0	0	-333059
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-407.8	55053	0	0	55053
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-480.4	64854	0	0	64854
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-1	ER1284A	2281.4	-307989	0	0	-307989
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-2	ER1289A	2277.2	-307422	0	0	-307422
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-1	ER1171A	113.4	-15309	-0.3	-40.5	-15350
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-2	ER1177A	111.3	-15026	-0.3	-40.5	-15066
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-1	ER1256A	-8.1	1094	-0.7	-94.5	999
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-2	ER1258A	-4.2	567	-0.4	-54	513
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-1	ER1172A	-364.3	-364.3	-364.3	-364.3	-364.3
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-2	ER1229A	-344.8	-344.8	-344.8	-344.8	-344.8
		TOTAL		2077116	0	-18111	2059006	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-5969	805815	0	0	805815
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-1552.8	209628	0	0	209628
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	3898.6	-526311	0	0	-526311
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3502.4	-472824	0	0	-472824
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-2105.5	284243	0	0	284243
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-203.4	27459	0	0	27459
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-241.4	32589	0	0	32589
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	37.8	-5103	0	0	-5103
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	321.4	-43389	0	0	-43389
		TOTAL		312107	0	0	312107	
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) -II	NP6458A	-5785.6	781056	0	0	781056
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-100	13500	0	0	13500
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-262.4	35424	0	0	35424
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-9.8	1323	0	0	1323
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-57.6	7776	0	0	7776
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-6682.2	902097	0	0	902097
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	9417.5	-1271363	0	0	-1271362.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-784.4	105894	0	0	105894
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-228.2	30807	0	0	30807
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-572	77220	0	0	77220
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-8494.2	1146717	0	0	1146717
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-6657.1	898709	0	0	898708.5
	14	400 KV KODERMA(DVC) - Gayal(PG)-I	NP7891A	2229.4	-300969	0	0	-300969
	15	400 KV KODERMA(DVC) - Gayal(PG)-II	NP7890A	2294.9	-309812	0	0	-309811.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-8761.8	1182843	0	0	1182843
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	-8859.9	1196087	0	0	1196086.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7289.9	984137	0	0	984136.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1194.6	-161271	0	0	-161271
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-7644	1031940	0	0	1031940
	21	400 KV RANCHI(PG)-RTPS(DVC)-2	NP7871A	6201.7	-837230	0	0	-837229.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-3	NP7853A	7317.4	-987849	0	0	-987849
		TOTAL		4527036	0	0	4527036	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	2199.6	-296946	0	0	-296946
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	390.6	-52731	0	0	-52731
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	385.9	-52096.5	0	0	-52096.5
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	0	0	-193.7	-26149.5	-26149.5
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	-419.2	56592	0	0	56592
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	2842.1	-383683.5	5.7	769.5	-382914
	8	132 KV BARIPADA (PG) - BARIPADA (GRIDCO)	NP5916A	-626	84510	0	0	84510
	9	132 KV BARIPADA (PG) - BANGRIPOSHI (GRIDCO)	NP5912A	229.6	-30996	0	0	-30996
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-696	93960	0	0	93960
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3589.6	484596	0	0	484596
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO) -I	NP5112A	-3608.6	487161	0	0	487161
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO) -II	NP5101A	-3569.8	481923	0	0	481923
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO) -I	NP5915A	-26.4	3564	0	0	3564
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO) -II	NP5913A	14.4	-1944	0	0	-1944
	16	220 KV BALIMELA (GRIDCO) - UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA (PG)	NP7916A	-6208.3	838120.5	0	0	838120.5
	18	400 KV MMUNDALI (GRIDCO) - ANGUL (PG) -I	ER1054A	20203.2	-2727432	0	0	-2727432
	19	400 KV MMUNDALI (GRIDCO) - ANGUL (PG) -II	ER1055A	9711.4	-1311039	0	0	-1311039
	20	400 KV MERAMUNDALI (GRIDCO) - TSTPP (NTPC)	NP7932A	5708.8	-770688	0	0	-770688
	21	400 KV MENDHASAL (GRIDCO) - PANDIABIL (PG) -I	NP5980A	-956.4	129114	0	0	129114
	22	400 KV MENDHASAL (GRIDCO) - PANDIABIL (PG) -II	NP7498A	-1167.9	157666.5	0	0	157666.5
	23	400 KV DUBURI (GRIDCO) - PANDIABIL (PG)	NP7915A	-4228.7	570874.5	0	0	570874.5
	24	220 KV BOLANGIR (PG) - KATAPALI (GRIDCO)	NP8790A	12.4	-1674	-799.3	-107905.5	-109579.5
	25	220 KV BOLANGIR (PG) - SADEIPALI (GRIDCO)	NP8789A	0	0	-1656.9	-223681.5	-223681.5
	26	220 KV PANDIABIL (PG) - ATRI (GRIDCO) -1	ER1018A	1234.7	-166684.5	0	0	-166684.5
	27	220 KV PANDIABIL (PG) - SAMANGARA (GRIDCO) -1	NP8051A	1655.9	-223546.5	0	0	-223546.5
	28	132 KV BARIPADA (PG) - JALESWAR (GRIDCO)	NP5914A	-401	54135	0	0	54135
	29	132 KV BARIPADA (PG) - BHOGRAI (GRIDCO)	ER1115A	10.5	-1417.5	0	0	-1417.5
	30	400KV SUNDERGARH (PG) - STERLITE (GRIDCO) -I	ER1059A	-7201.9	972256.5	0	0	972256.5
	31	400KV SUNDERGARH (PG) - STERLITE (GRIDCO) -II	ER1058A	-7639.6	1031346	0	0	1031346
	32	220 KV PANDIABIL (PG) - ATRI (GRIDCO) -2	ER1099A	1204.9	-162661.5	0	0	-162661.5
			TOTAL		-737721		-356967	-1094688
	SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-178.10	24044	0	0
2		132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-57.00	7695	0	0	7695
3		66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.4	-54	-54
4		132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	136.70	-18455	15.1	2038.5	-16416
5		132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	135.60	-18306	14.5	1957.5	-16349
6		132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.20	-1647	0	0	-1647
		TOTAL		-6669		3942	-2727	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPORE	NP6445A	-2663.5	359573	0	0	359573
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	-316.2	42687	-11.2	-1512	41175
	3	220 KV SUBHASGRAM (PG) - SUBHASGRAM -I (WBSETCL)	NP5080A	584.9	-78962	0	0	-78962
	4	220 KV SUBHASGRAM (PG) - SUBHASGRAM -II (WBSETCL)	NP5847A	448.1	-60494	0	0	-60494
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	-144	19440	0	0	19440
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	-102.7	13865	0	0	13865
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1669.5	225383	0	0	225383
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1369.2	184842	0	0	184842
	9	132KV BIRPARA (PG) - BIRPARA (WBSETCL) -I	ER1110A	-489	66015	0	0	66015
	10	132KV BIRPARA (PG) - BIRPARA (WBSETCL) -II	NP6470A	-273.4	36909	0	0	36909
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL) -I	NP5882A	5895	-795825	0	0	-795825
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL) -II	NP5881A	6140.2	-828927	0	0	-828927
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-73.3	9896	0	0	9896
	14	400 KV DURGAPUR (PG) - BIDHANAGAR (WBSETCL) -I	NP5831A	4284.8	-578448	0	0	-578448
	15	400 KV DURGAPUR (PG) - BIDHANAGAR (WBSETCL) -II	NP6459A	3033.4	-409509	0	0	-409509
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-567.8	76653	0	0	76653
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-1044.6	141021	0	0	141021
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-119.3	16106	0	0	16106
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	44.2	-5967	0	0	-5967
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	-1995.2	269352	0	0	269352
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL) -I	NP6548A	6313.5	-852323	0	0	-852323
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL) -II	NP7557A	7734.9	-1044212	0	0	-1044212
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE -II	ER1072A	112.4	-15174	0	0	-15174
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE -I	ER1071A	138.9	-18752	0	0	-18752
	25	220 KV SUBHASGRAM (PG) - EMBYPASS CESC (WB) LINE -I	ER1144A	240.3	-32441	0	0	-32441
	26	220 KV SUBHASGRAM (PG) - EMBYPASS CESC (WB) LINE -II	NP7936A	236.6	-31941	0	0	-31941
	27	220 KV SUBHASGRAM (PG) - KLC BANTALA (WB)	NP8708A	1097	-148095	0	0	-148095
	28	220 KV SUBHASGRAM (PG) - NEW TOWN (WB)	NP8709A	2621.5	-353903	0	0	-353903
	29	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE -I	ER1141A	-1260.7	170195	0	0	170195
	30	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE -II	NP7937A	-1214.3	163931	0	0	163931
	31	400 KV SAGARDIGHI (WB) - BEHRAMPORE (PG) LINE -I	NP8723A	-2750.2	371277	0	0	371277
	32	400 KV SAGARDIGHI (WB) - BEHRAMPORE (PG) LINE -II	NP8724A	-2780.7	375395	0	0	375395
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG) -II	NP8720A	-1132	152820	0	0	152820
	34	400 KV KHARAGPUR (WB) - CHAIBASA (PG) -I	NP8731A	-1134.3	153131	0	0	153131
	35	400 KV PPSP NEW (WB) - RANCHI NEW (PG) -1	ER1040A	3038.8	-410238	0	0	-410238
	36	400 KV PPSP NEW (WB) - RANCHI NEW (PG) -2	ER1130A	3041	-410535	0	0	-410535
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC) -1	ER1133A	-3312.6	447201	0	0	447201
	38	400 KV GOKARNA (WB) - FARAKKA (NTPC) -2	ER1138A	-3157.9	426317	0	0	426317
		TOTAL		-2353739		-1512	-235251	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVARh, w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with IISTS.

5) "NA" means meter reading not available.