



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000
ISO: 9001-2000

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH

Date: 04.05.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)


Sub: Provisional Reactive Energy (VARH) Charges for the week from 09.04.2018-15.04.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. BANDYOPADHYAY)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 09/04/18 to 15/04/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5196226

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 09/04/18 to 15/04/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-2606.8	364952	0	0	364952
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2983.4	417676	0	0	417676
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-2401.9	336266	0	0	336266
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	-276.8	38752	0	0	38752
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-553.8	77532	0	0	77532
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	-433.6	60704	0	0	60704
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3536.8	495152	0	0	495152
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1724.4	241416	0	0	241416
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-1007	140980	0	0	140980
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-823.3	115262	0	0	115262
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-3264.7	457058	0	0	457058
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	-534.8	74872	0	0	74872
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	39.8	-5572	17.4	2436	-3136
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2164.1	302974	-22.1	-3094	299880
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-2477.3	346822	0	0	346822
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	1628.7	-228018	0	0	-228018
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	1616.3	-226282	0	0	-226282
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-629.1	88074	0	0	88074
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2219.8	310772	0	0	310772
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	0	0	0	0	0
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	0	0	0	0	0
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2230.5	312270	0	0	312270
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	958.3	-134162	0	0	-134162
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-463.9	64946	0	0	64946
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-437	61180	0	0	61180
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	237.4	-33236	0	0	-33236
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	230.4	-32256	0	0	-32256
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	228.9	-32046	0	0	-32046
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	-40.8	5712	0	0	5712
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	-40.2	5628	0	0	5628
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	-53.9	7546	0	0	7546
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	-58.7	8218	0	0	8218
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	8	-1120	12.5	1750	630
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	474.9	-66486	0	0	-66486
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-232.1	32494	0	0	32494
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-3411.8	477652	0	0	477652
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-3962.7	554778	0	0	554778
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	0	0	0
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	0	0	0
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	0	0	0
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-980.7	137298	0	0	137298
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-971.3	135982	0	0	135982
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1508.5	-211190	0	0	-211190
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2123.3	-297262	0	0	-297262
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1953.4	273476	0	0	273476
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2125.9	297626	0	0	297626
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-1	ER1284A	1992.5	-278950	0	0	-278950
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-2	ER1289A	1965	-275100	0	0	-275100
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-1	ER1171A	76.4	-10696	-18.6	-2604	-13300
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-2	ER1177A	71.1	-9954	-31.2	-4368	-14332
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-1	ER1256A	1.3	-182	-100.1	-14014	-14196
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-2	ER1258A	25.1	-3514	-96.3	-13482	-16996
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-1	ER1172A	-83.6	11704	-83.6	-11704	-83.6
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-2	ER1229A	-74.4	10416	-74.4	-10416	-74.4
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-448.7	62818	-448.7	-62818	-448.7
		TOTAL		4482982		-118314	4364668	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-5280.7	739298	0	0	739298
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	427.2	-59808	0	0	-59808
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	4194	-587160	0	0	-587160
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2868.2	-401548	0	0	-401548
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-2059.7	288358	0	0	288358
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-105.6	14784	0	0	14784
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-134.2	18788	0	0	18788
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	25.2	-3528	0	0	-3528
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	-280.7	39298	0	0	39298
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	-10.7	1498	-73.2	-10248	-8750
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	-7.6	1064	-75.4	-10556	-9492
			TOTAL		51044		-20804	30240
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-4971.6	696024	0	0	696024
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	26.8	-3752	0	0	-3752
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-92.8	12992	0	0	12992
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	218.6	-30604	0	0	-30604
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	300	-42000	0	0	-42000
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-4774.3	668402	0	0	668402
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	5162.4	-722736	0	0	-722736
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1268.9	177646	0	0	177646
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1148.1	160734	0	0	160734
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1329.9	186186	0	0	186186
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-9502.1	1330294	0	0	1330294
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-8054.3	1127602	0	0	1127602
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1.7	-238	0	0	-238
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-362.7	50778	0	0	50778
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-7476.1	1046654	0	0	1046654
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-7516.8	1052352	0	0	1052352
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6353.8	889532	0	0	889532
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-855.9	119826	0	0	119826
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-6540.7	915698	0	0	915698
	21	400 KV RANCHI(PG)-RTPS(DVC)-2	NP7871A	6400.3	-896042	0	0	-896042
	22	400 KV RANCHI(PG)-RTPS(DVC)-3	NP7853A	6360.4	-890456	0	0	-890456
		TOTAL		5848892		0	5848892	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	0	0	0	0	0
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	1265.4	-177156	0	0	-177156
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	1308.7	-183218	0	0	-183218
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	-1025.3	143542	0	0	143542
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	-1084.9	151886	0	0	151886
	7	400 KV INDRAVATI (PG) - INDRAVATI (P/H)	NP5966A	1475	-206500	1.7	238	-206262
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-350.8	49112	0	0	49112
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	396.7	-55538	0	0	-55538
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2044.6	286244	0	0	286244
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3420	478800	0	0	478800
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3746.6	524524	0	0	524524
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3512.2	491708	0	0	491708
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1130.9	158326	0	0	158326
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-924.5	129430	0	0	129430
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	NP7916A	-570	79800	0	0	79800
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	0	0	0	0	0
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	22	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-238	33320	0	0	33320
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	9.8	-1372	0	0	-1372
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-2.8	-392	-392
	26	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	45.7	-6398	0	0	-6398
	27	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	71.8	-10052	0	0	-10052
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-62.7	8778	0	0	8778
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	100.1	-14014	0	0	-14014
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	32	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-2	ER1099A	31.6	-4424	0	0	-4424
		TOTAL		1876798		-154	1876644	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-100.50	14070	0	0	14070
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-107.40	15036	0	0	15036
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.1	-14	-14
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	81.80	-11452	0	0	-11452
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	77.80	-10892	0	0	-10892
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	14.30	-2002	0	0	-2002
		TOTAL		4760		-14	4746	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPURE	NP6445A	-894.2	125188	-252.9	-35406	89782
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	0	0	-1085.8	-152012	-152012
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	241.1	-33754	-632.4	-88536	-122290
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	63	-8820	-262	-36680	-45500
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-696.9	-97566	-97566
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0	0	-822.1	-115094	-115094
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-928.4	129976	0	0	129976
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1274.9	178486	0	0	178486
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-958.8	134232	0	0	134232
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-714.1	99974	0	0	99974
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	3556.3	-497882	0	0	-497882
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	3864.1	-540974	0	0	-540974
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-53.1	7434	0	0	7434
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	10547.3	-1476622	0	0	-1476622
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	8041.7	-1125838	0	0	-1125838
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-4590.9	642726	0	0	642726
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-1279.6	179144	0	0	179144
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-95.8	13412	0	0	13412
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-19.4	2716	0	0	2716
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2499.4	-349916	0	0	-349916
	21	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-I	NP6548A	3822.1	-535094	0	0	-535094
	22	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-II	NP7557A	4694.6	-657244	0	0	-657244
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-202.1	28294	-51.6	-7224	21070
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1071A	-178.7	25018	-90	-12600	12418
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	-7.1	994	-315	-44100	-43106
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	-10.8	1512	-697.7	-97678	-96166
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	-40.4	5656	-150.7	-21098	-15442
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	586.3	-82082	-1.9	-266	-82348
	29	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	711.8	-99652	0.3	42	-99610
	30	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	987.4	-138236	0	0	-138236
	31	400 KV SAGARDIGHI(WB)-BEHRAMPURE(PG) LINE-I	NP8723A	-1734.1	242774	0	0	242774
	32	400 KV SAGARDIGHI(WB)-BEHRAMPURE(PG) LINE-II	NP8724A	-1636.6	229124	0	0	229124
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-878.2	122948	0	0	122948
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-887.1	124194	0	0	124194
	35	400 KV PPS NEW(WB)-RANCHI NEW(PG)-1	ER1040A	6276.7	-878738	0	0	-878738
	36	400 KV PPS NEW(WB)-RANCHI NEW(PG)-2	ER1130A	6279.8	-879172	0	0	-879172
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-2045	286300	0	0	286300
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-1685.1	235914	0	0	235914
		TOTAL		-4488008		-708218	-5196226	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVARH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.