



Agenda
for
150th OCC Meeting

Date: 11.10.2018
Eastern Regional Power Committee
14, Golf Club Road, Tollygunge
Kolkata: 700 033

Eastern Regional Power Committee

Agenda for 150th OCC Meeting to be held on 11th October, 2018 at ERPC, Kolkata

Item no. 1: Confirmation of minutes of 149th OCC meeting of ERPC held on 18.09.2018

The minutes of 149th OCC meeting were uploaded in ERPC website and circulated vide letter dated 24.09.2018 to all the constituents.

Members may confirm the minutes.

PART A : ER GRID PERFORMANCE

Item no. A1: ER Grid performance during September, 2018

The average consumption of Eastern Region for September- 2018 was 441.4 Mu. Eastern Region achieved maximum energy consumption of 478 Mu on 29thSep - 2018. Total Export schedule of Eastern region for September - 2018 was 1205 Mu, whereas actual export was 809Mu. The under export of Eastern Region is mainly due to over drawl of DVC, West Bengal and Odisha.

ERLDC may present the performance of Eastern Regional Grid covering the followings:

1. Frequency profile
2. Over drawl/under injection by ER Entities

Over drawl figure of West Bengal and Odisha from 01-10-2018 to 07-10-2018 are shown below:

	DVC		Odisha		West Bengal	
	OD (MU)	Max OD (MW)	OD (MU)	Max OD (MW)	OD (MU)	Max OD (MW)
01-10-2018	3.66	435.40	8.35	794.12	1.59	564.38
02-10-2018	7.05	602.08	7.16	921.24	3.70	528.83
03-10-2018	5.66	568.76	9.30	832.40	3.38	459.42
04-10-2018	6.20	562.21	8.70	926.09	4.66	622.79
05-10-2018	10.06	622.93	10.26	791.06	0.13	440.95
06-10-2018	7.98	784.57	2.87	614.76	0.83	373.14
07-10-2018	1.29	271.92	3.60	675.19	1.88	693.69

It may be seen that for the month of the October till date,

- West Bengal over drawl was in the range of 1 to 5mu on daily basis while maximum over drawl touched 4.66 mu on 04-10-18 and 693 mw maximum deviation on 07-10-18.
- Odisha over drawl was in the range of 3 to 11mu while maximum over drawl touched 10.26mu on 05-10-18 and 926 mw maximum deviation on 04-10-18.
- DVC over drawl was in the range of 1 to 10mu while maximum over drawl touched 10.06 mu on 05-10-18 and 785 mw maximum deviation on 06-10-18.

In 149th OCC persistent overdraw matter of West Bengal, Odisha and DVC was discussed, where in all parties were agreed to take corrective measures to avoid such persistent over-drawl. During the meeting, DVC expressed during October month their over drawl shall reduce

substantially due to change on STOA sell profile and expected improvement in coal supply. Odisha also informed that due to increase in hydro generation, they would manage their drawl as per schedule during October month and west Bengal also assured to improved their internal generation and purchase profile in coming month to avoid such huge over drawl. However, for the month of September and till date October-2018 as shown above, appreciable improvement to avoid over drawal of West Bengal, DVC and Odisha was not observed.

West Bengal, DVC and Odisha may please deliberate the reason of continuous overdrawal and future action plan to mitigate such contingency situation.

DVC may please furnish action plan taken for improvement of coal supply issues and schedule date for restoration of plants out on coal shortage.

Beneficiaries are also advised to maximize their internal generation and increase their power purchase quantum in STOA/Power Exchange or from any other source to maintain their drawl as per schedule.

In case of repetitive non-compliance of ERLDC instruction to curtail overdrawal during real time operation continues in future, ERLDC will have no other option but to approach appropriate commission with respect to erring entities.

- 3. Performance of Hydro Power Stations during peak hours**
- 4. Performance of ISGS during RRAS**
- 5. Reactive Power performance of Generators**
- 6. Restricted Governor /Free Governor Mode Operation of generators in ER**

PART B: ITEMS FOR DISCUSSION

Item No. B.1: Status of projects funded under PSDF schemes

In the PSDF review meeting, it was advised to RPCs to monitor the status of all the projects funded by PSDF. Therefore, constituents are requested to update the status of projects which are being funded by PSDF in the desired format.

A. Projects approved:

SN	Name of Constituent	Name of Project	Date of approval from PSDF	Target Date of Completion	PSDF grant approved (in Rs.)	Amount drawn till date (inRs.)	Latest status
1	WBSETCL	Renovation & up-gradation of protection system of 220 kV & 400 kV Substations in W. Bengal	31-12-14	April 2018	108.6 Cr	37 Cr.	100 % Supply is Completed 98 % Erection is completed Work would be completed by October 2018
2		Renovation & modernisation of transmission system for relieving congestion in Intra-State Transmission System.	22-05-17	25 months from date of release of 1 st instalment	70.13	21.03 Cr	Order has been placed for 96.44 Cr. Work is in progress.
3		Installation of switchable reactor at 400kV & shunt capacitors at 33kV	22-05-17	19 months from date of release of 1 st instalment	43.37	6.59 Cr	Order has been placed and work is in progress.
4	WBPDC	Implementation of Islanding scheme at Bandel Thermal Power Station	10.04.17	March 2018	1.39 Cr	1.25 Cr	<i>The implementation would be completed by July 2018.</i>
5		Upgradation of Protection and SAS			23.48	2.348 Cr	Bid opened and order has been placed.
6	OPTCL	Renovation & Up-gradation of protection and control systems of Sub-stations in the State of Odisha in order to rectify protection related deficiencies.	10.05.15	30.11.18	162.5 Cr.	37.79 Cr	Total contract awarded for Rs. 51.35 Cr
7		Implementation of OPGW based reliable communication at 132kV and above substations	15.11.17		25.61 Cr.		Agreement signed on 03.01.2018
8		Installation of 125 MVAR Bus Reactor along with construction of associated bay each at 400kV Grid S/S of Mendhasal, Meramundali & New Duburi for VAR control & stabilisation of system voltage	27.07.18		27.23 Cr		
9	OHPC	Renovation and up-gradation of protection and control system of 4 nos.OHPC substations.		<i>U.Kolab-March 19 Balimela-Feb 2019 U.Indravati-Jan 19 Burla-Nov 2018, Chiplima Dec 2018</i>	22.35 Cr.	2.235 Cr	Placed work order for Balimela.
10	BSPTCL	Renovation and up-gradation of 220/132/33 KV GSS Biharshariff, Bodhgaya, Fatuha, Khagaul, Dehri -on-sones & 132/33 kV GSS Kataiya	11/5/15	31.07.2018	64.02 crore	56.04 crore	85% of work has been completed. Contract awarded for Rs.71.37 Cr till date. The work would be completed by October 2018.
11		Installation of capacitor bank at different 35 nos. of GSS under BSPTCL	5/9/2016	12 th March 2019	18.88 crore	Nil	Work awarded for all GSS.

12		Renovation & up-gradation of protection and control system of 12 nos. 132/33 KV GSS under BSPTCL.	02.01.17	31 st March 2018	49.22 Cr.		75% work completed for seven no. GSS as part of R & M work. Revised DPR is to be submitted for rest 5 no. GSS.
13	JUSNL	Renovation and up-gradation of protection system	September 2017	2 years	138.13 crores		Board of Directors approval is pending for work award.
14	DVC	Renovation and upgradation of control & protection system and replacement of Substation Equipment of 220/132/33 kV Ramgarh Substation	02.01.17	01.06.2019	25.96 Cr	2.596 Crore on 01.06.2017	Work awarded for 28.07 Cr. Work would be completed by May 2019.
15		Renovation and upgradation of control & protection system including replacement of substation equipment at Parulia, Durgapur, Kalyaneshwari, Jamshedpur, Giridih, Barjora, Burnpur, Dhanbad and Burdwan Substation of DVC	27.11.17	24 Months from the date of release of fund.	140.5 Cr.	1 st installment of 14.05 Cr. received on 21.12.2017	Work awarded for 6.45 Cr. Price bid opened for West Bengal portion and technical bid opened for Jharkhand portion.
16	POWERGRID	Installation of STATCOM in ER		June 2018	160.28 Cr	16.028 Cr	Work is in progress, expected to complete by June 2018. STATCOM at Rourkela has been commissioned.
17	ERPC	Creation & Maintenance of web based protection database and desktop based protection calculation tool for Eastern Regional Grid	17.03.16	Project is alive from 30 th October 2017	20 Cr.	4.94 Cr. + 9.88 Cr.	1) Protection Database Project has been declared 'Go live' w.e.f. 31.10.17. 2) Pending training on PDMS at Sikkim and 3 rd training on PSCT has been also completed at ERPC Kolkata.
18a	ERPC	Training for Power System Engineers	27.07.18		0.61 Cr.	Nil	Approved
18b		Training on Power market trading at NORD POOL Academy for Power System Engineers of Eastern Regional Constituents	27.07.18		5.46 Cr.	Nil	

B. Projects under process of approval:

SN	Name of Constituent	Name of Project	Date of Submission	Estimated cost (in Rs.)	Latest status
1	Sikkim	Renovation & Upgradation of Protection System of Energy and Power Department, Sikkim.	09-08-17	68.95 Cr	The proposal requires third party protection audit. Issue was discussed in the Monitoring Group meeting in Siliguri on 8.6.2018. Sikkim was asked to coordinate with ERPC.
2		Drawing of optical ground wire (OPGW) cables on existing 132kV & 66kV transmission lines and integration of leftover substations with State Load Despatch Centre, Sikkim	09-08-17	25.36 Cr	Scheme was approved by Appraisal Committee. It was sent to CERC for concurrence.
3	JUSNL	Reliable Communication & Data Acquisition System upto 132kV Substations.	23-08-17	102.31 Cr	Scheme was approved by Appraisal Committee. It was sent to CERC for concurrence.
4	OPTCL	Implementation of Automatic Demand Management System (ADMS) in SLDC, Odisha	22-12-17	3.26 Cr	Scheme was approved by Appraisal Committee. It was sent to CERC for concurrence.
5		Protection upgradation and installation of SAS for seven numbers of 220/132/33kV Grid substations (Balasore, Bidanasi, Budhipadar, Katapalli, Narendrapur, New-Bolangir & Paradeep).	12-03-18	41.1 Cr.	Scheme examined by TSEG on 20.03.2018. Inputs sought from the entity are awaited.
6	WBSETCL	Implementation of Integrated system for	22-12-17	25.96 Cr	Scheme examined by TSEG on

		Scheduling, Accounting, Metering and Settlement of Transactions (SAMAST) system in West Bengal			20.03.2018. Inputs received on 24.05.2018. This scheme again reviewed by sub group meeting held on 24.07.2018. The entity was asked to provide the Interface meter details by depiction of interface points on grid network map with each intra-state entity.
7		Installation of Bus Reactors at different 400kV Substation within the state of West Bengal for reactive power management of the Grid	12-03-18	78.75 Cr.	Scheme examined by TSEG on 20.03.2018. Inputs received on 22.05.2018. Shall be examined in the next TSEG meeting.
8		Project for establishment of reliable communication and data acquisition at different substation at WBSETCL.	10-05-18	80.39 Cr.	Scheme examined by TSEG on 24.07.2018. Inputs sought from entity.
9	BSPTCL	Implementation of Scheduling, Accounting, Metering and settlement of Transaction in Electricity (SAMAST) in SLDC Bihar.	27-02-18	93.76 Cr.	Scheme examined by TSEG on 20.03.2018 & 31.05.2018. Further inputs furnished by BSPTCL on 1.8.2018. Shall be examined in the next meeting of TSEG.

Respective constituents may update the status.

Item No. B.2: Coal stock position of ER Generators

A meeting on issues related to augmentation of coal supply and its transportation to various power stations in the Eastern Region for Puja festival 2018 held on 04.10.2018 at Kolkata.

The action plan of rake dispatch of coal from different subsidiaries of Coal India Ltd. Were formulated which is enclosed at **Annexure-B2**.

The respective constituents are requested to furnish the Coal stock position of their power station in the OCC Meeting.

Members may update.

Item No. B.3: Charging of 132kV Purnea(PG)-Kishanganj(old)-Baisi-Dalkhola line in Synchronous mode-BSPTCL

In view of providing reliable power to Nepal and to resolve low voltage issues at Kishanganj, BSPTCL requested for charging of 132kV Purnea(PG)-Kishanganj(old)-Baisi-Dalkhola line in Synchronous mode. Details are given in **Annexure-B3**.

In 149th OCC, WBSETCL informed that increasing power flow through 132kV Baisi-Dalkhola line during any contingency in Bihar network would cause overloading of ICTs at Dalkhola.

OCC opined that power flow through 132kV Baisi-Dalkhola line can be restricted with proper over current relay setting and the line can be automatically disconnected immediately to avoid overloading of ICTs at Dalkhola.

OCC advised WBSETCL to go through the proposal and send their comments to BSPTCL with a copy to ERPC and ERLDC.

BSPTCL and WBSETCL may update.

Item No. B.4: Request for drawal of 715 MW from Gaya(PG) festival season-BSPTCL

Presently, the maximum demand of BSPTCL from the ICTs of Gaya (PG) are as follows:

1. 220 kv Gaya(PG)-Bodhgaya ckt. (D/C) -300 MW
2. 220 kv Gaya(PG)-Sonenagar(new) (D/C) -215 MW
3. 220 kv Gaya(PG)-Dehri ckt.(D/C)-200 MW

So, Total Load in peak hr at Gaya (PG) comes out to 715 MW.

*Total load of Dehri is 215 MW & out of this 15 MW load is drawn in peak hours through 220 kv Pusauli (PG)-Dehri (S/C) line.

Load of 215 MW at 220/132 Dehri end cannot be met through 220 kv Pusauli(PG)-Dehri single ckt. transmission line so Dehri GSS is operated in synchronous mode with Gaya(PG) and Pusauli(PG).

Also, it may be noted here that Gaya(PG) has ICTs of capacity (1X500+1X315) MVA through which Gaya (PG) allow only 652 MW maximum.

In the aforesaid circumstances, it is hereby requested to kindly instruct Gaya (PG) to allow load drawal max up to 725 MW so that uninterrupted/unrestricted power supply can be supplied to all concerned GSS. It is very much necessary in light of coming festivals of Durga Puja, Deepawali & Chath.

BSPTCL may explain. Members may discuss.

Item No. B.5: 40/45 MW power assistance from Sahupuri (UP) (NR) to BSPTCL GSS Karmnasa-BSPTCL

Kindly allow 40/45 MW power assistance from Sahupuri (UP) (NR) to BSPTCL GSS Karmnasa (presently Karmnasa is availing power from GSS [Pusauli (BSPTCL)]). Due to this operation Pusauli (BSPTCL) load will be offloaded, resulting meeting same 40 MW load of Dehri grid.

This will reduce load on Gaya (PG), which presently facing power transmission constraint during peak hour.

Gaya (PG) capacity augmentation work by addition of one 500 MVA will be completed by December 2018 end and by that time this operation will allow BSPTCL to meet its demand in this region during peak hrs. It will remain much helpful in meeting demand during coming festivals of Durga Puja, Deepawal & Chath.

BSPTCL may explain. Members may discuss.

Item No. B.6: Bypassing arrangement of LILO of 400kV Lines at Angul-OPTCL

LILO of Meramundali-Bolangir/Jeypore 400 kV S/C line and LILO of one Ckt of Talcher-Meramundali 400 kV D/C line has been done at Angul 765/400kV Sub-station.

In 18th Standing Committee it was decided that Power grid would establish a switching arrangement at Angul substation such that, the above 400 kV LILO may be operated either by-passing Angul substation or terminating at Angul substation as and when required depending upon the power flow condition.

In 19th Standing Committee, it was inferred that LILOs of the above two lines needs to be by-passed to maintain the fault level at Meramundali S/S under normal operating conditions.

The necessary arrangement to be done by Powergrid for by-pass arrangement is under implementation and will be commissioned shortly.

The fault level at Meramundali will further increase after the commissioning of Meramundali- Mendhasal 2ndckt of D/C line.

Odisha wants for Normally closed arrangement at Angul so as to relieve the fault level problem at Meramundali. Odisha further agrees that as and when the situation demands the isolator may be put in open condition.

The following standard operating procedure may be approved by the OCC for implementation of bypass arrangement.

- The isolator will be normally closed so as to ensure the fault level at Meramundali stays within the permissible limits of 40 kA.
- Under severe contingencies like line outage or generator outage ERLOC in consultation with SLOC will open the isolator i.e. to restore the LILO of the above two lines.

OPTCL may explain. Members may discuss.

Item No. B.7: Establishment of Renewable Energy Management Centre (REMC) in Eastern Region---GRIDCO

Implementation of the state-of-the-art Renewable Energy forecasting & monitoring systems is now a global best practice. For the same, it is proposed by Ministry of Power, Govt of India to establish Renewable Energy Management Centres (REMC) to address the intermittency, variability and uncertainty issues of Renewable power integration to the grid. Renewable Energy Management Centre (REMC) is part of the 'Green Energy Corridor scheme dealt by MNRE, GoI.

In order to facilitate integration of the targeted 175 GW of Renewable capacity by 2022, a comprehensive transmission plan is chalked out comprising of intra-state and inter-state transmission system strengthening infrastructure as well as Control infrastructure i.e. establishment of REMCs at SLDC/RLDC/NLDC level.

The REMC scheme will help the grid operator to effectively manage power system operations with economy, reliability & security with an objective to forecast of RE generation on different levels such as State/ region aggregated, pooling station wise etc. based on information from Forecast Service Provider (FSP) as well as Weather Service Provider (WSP), Renewable Generation Scheduling, real time tracking of generation of RE sources, integration with REMC SCADA & its Visualization & close coordination with respective LDC for RE generation & integration with existing SCADA. Owner of REMC will be the existing SLDCs, RLDCs & NLDC.

At present, the REMC scheme is proposed for the Renewable rich States & regions i.e. Tamil Nadu, Andhra Pradesh & Karnataka in Southern Region. Gujarat, Madhya Pradesh & Maharashtra in Western Region and Rajasthan in Northern Region co-located with SRLDC, WRLDC, NRLDC & NLDC. No REMC has been decided yet for Eastern Region & North Eastern Region. The Scheme is proposed to be financed from 100 % Gross Budgetary Support. No financial component & support is involved from the State Govts. & State Discoms.

PGCIL, the CTU will be implementing the scheme and will hand over the REMC to respective states & POSOCO upon commissioning. From the tentative State wise break up of RE generation by 2022, it can be seen that in Eastern Region also, there will be RE capacity addition of around 12,500 MW by 2022 in Bihar, Jharkhand, Odisha, West Bengal & Sikkim.

To address the issues of RE power integration. commissioning of REMC is a necessary step. GRIDCO is proposing REMC under the 'Green Energy Corridor scheme' for Eastern Region States (to be established in ER state LDCs & at ERLDC), which need to be placed before MNRE, Govt. of India through ERPC In a relevant forum, GRIDCO has already appealed to MNRE for establishment of REMC in Odisha and MNRE has also confirmed the concern of Odisha. A combined proposal is to be submitted from ERPC to MNRE for the ER states.

Members may discuss.

Item No. B.8: Certification of OPTCL lines as non-ISTS lines carrying ISTS power.

OPTCL vide no. RT&C-NON-ISTS/2017/281 dated 21.08.2018 had sought the Certification of non-ISTS line carrying ISTS power as per the direction of CERC in ROP dated 08.08.2018 under Petition No. 25/TT/2018.

Accordingly, in line with 34th TCC decision, ERPC Secretariat and ERLDC conducted the load flow study using WebNet software for all the quarters of 2014-15, 2015-16, 2016-17, 2017-18 & 2018-19 (upto Q2).

Also, in 129th OCC held on 17.01.2017 it was decided that STU lines carrying ISTS power greater than 50% of the total power as per the WebNet software of the validated data for each quarter will be considered as non-ISTS line carrying ISTS power. The same was also approved by 35th TCC/ERPC.

Accordingly, as per the study result it is clear that the following OPTCL lines are mostly being utilized more than 50% for carrying ISTS power, hence these elements may be considered as non-ISTS line carrying ISTS power for the tariff period 2014-19.

SN	Name of Line	Remarks
1	400 kV Indravati-Indravati S/C	
2	400 kV Rengali-Keonjhar S/C	
3	400 kV Keonjhar-Baripada	
4	400 kV Baripada-Kharagpur S/C	Natural ISTS
5	220 kV Jeypore-Jaynagar D/C	
6	220 kV Rengali-Rengali D/C	
7	220 kV Balimela-U.Sileru S/C	Natural ISTS
8	220 Joda-Jindal S/C	
9	132 kV Joda-Kenduposi S/C	Natural ISTS

Members may discuss.

Item No. B.9: Shut-down/ outage related issue of HVDC back to back station at Pusauli-Powergrid

The ± 500 MW HVDC back to back station was taken on shut down from 20.03.18 (at 11.50 hrs) up to 28.04.18 (till 12.09 hrs) for over hauling of Converter Transformer at HVDC station, Pusauli. The need to take these transformers for Over-haul had mainly arisen due to frequent faults taking place in the state- owned down-stream 220kV as also the 132 kV system. These fault caused transient disturbance in HVDC back to back system and adversely affected its performance causing aging effect, mainly witnessed in the Converter Transformer. This also affects the insulation parameter of oil in the Converter transformer , requiring an over- haul of oil and Oil-flow system due to which the converter transformer were taken on shut-down / outage

Further, the auxiliary power is availed through the 132 kV line of the state which was having frequent faults and interruptions/ voltage dip since its Commissioning. This resulted in unreliable

supply of power to the auxiliary system feeding the control and protection of the HVDC scheme which resulted in frequent tripping/interruption in service of the HVDC back to back scheme causing switching-on and switching-off of the Converter transformer.

Both these above causes necessitated a preventive action and required that the Converter transformer be taken up for a suitable Over-haul. It is important to note that had these Converter transformer not been taken on such maintenance , it may have led to a major disturbance / outage.

However the Power-flow on AC-by pass was maintained and these shut-down / outage [of the HVDC back to back system] has not compromised in any way , with the overall power system performance, within or across the region.

The outage / shut-down of HVDC back to back link was mainly caused due to faults arising in 220 kV down-stream system owned by other utilities and also due to frequent tripping/failure of the 132 kV state-owned feeder supplying the auxiliary power. Both these are entirely beyond the scope / jurisdiction of POWERGRID and therefore the above shut-down period may be considered as a Force majeure for the calculation of availability

Powergrid may explain. Members may decide.

Item No. B.10: Replacement of old RTUs in Eastern Region for reporting of RTU/SAS to backup Control Centre: Inclusion of Chandwa, Kishenganj & Daltonganj S/s in said project -Powergrid

"Replacement of old RTUs in Eastern Region for reporting of RTU/SAS to backup Control Centre" pertaining to POWERGRID Sub-stations was approved by ERPC in the 37th TCC/ ERPC meeting.

It is to inform that while 16 Nos. Sub-stations of POWERGRID/ER-1 were slated to be upgraded under the aforementioned project , as per ERLDC's "Report on Replacement of Old RTUs in Eastern Region for reporting of RTU/SAS to backup Control Centre" dtd. 23.08.2017, the Nos. of Substations of POWERGRID/ER-1 considered in the approved list of ERPC comes out to be 15 only. It is to inform that the name of Kishenganj S/s of ER-1 has been missed out inadvertently , which may be added, thus totaling to 16 nos.

Further, 400 kV Chandwa GIS S/s (SAS based) is also missed out inadvertently in the list of Sub-stations approved in the 37^h ERPC for Replacement/ Up gradation of SAS.

Moreover , when the said report was being prepared by ERLDC, Daltonganj S/s of POWERGRID/ER-1 was still under construction. The said S/s has been commissioned in Mar 2018. Hence, Daltonganj S/s of POWERGRID/ER-1 may also please be included in the RTU Replacement project, in line with the requirement of reporting of RTU/SAS to backup Control Centre.

All the above three (03) Sub-station of POWERGRID/ER-1 are SAS based Sub-stations and Hardware/ License Upgradation shall be required to be carried out in the said Sub-stations , subsequently .

By including Chandwa , Kishenganj & Daltonganj Substations , the total nos. of Sub-station of POWERGRID/ER -1 for RTU/SAS Upgradation under the aforementioned project shall become 18 (namely Biharsharif, Jamshedpur , Purnea 400 , Purnea 220, Sasaram HVDC, Muzaffarpur , Patna, Banka, Lakhisarai, Ranchi, New Ranchi, Chaibasa, Gaya, Sasaram 765, Ara, Chandwa, Kishenganj & Daltonganj).

Powergrid may explain. Members may decide.

Item No. B.11: Long Outage of transmission elements in Eastern Region

a) 400 kV Barh – Motihari – D/C :

Line was out of service since 28/06/18 due to reduced clearance as water level in Gandak river has increased.

In 149th OCC, DMTCL informed that the line would be restored by 25th September 2018.

DMTCL may please update.

b) 400 kV Rangpo – Dikchu :

Line was out of service from 06/07/18 due to ROW issue.

TPTL may please update restoration plan

c) 400kV Purnea-Biharsariff-DC:

Line was out of service from 10/08/18 due to tower collapse as Ganga River has changed its course. ENICL informed that restoration of the line is in progress using a temporary arrangement and the restoration of the line would take 50 days approximately. ENICL may please update the current status and also submit fortnight status report to ERLDC/ERPC through mail.

In 149th OCC, ENCIL informed that one more tower of 400 kV Purnea-Biharsharif D/C line had collapsed and restoration of the line using interim arrangement is not possible now. They are planning for permanent restoration of the line, which would take long time. ENCIL agreed to communicate the schedule to ERPC and ERLDC.

ENICL may update.

d) 400 KV Patna – Kisanganj - D/C

Line was out of service from 01/09/18 due to tower collapse as Ganga River has changed its course. Powergrid ER-I may please update the current status and also submit fortnight status report to ERLDC/ERPC through mail.

In 149th OCC, Powergrid informed that they will put all the efforts to bring the line by March 2019.

Powergrid may update.

e) Breakers at 400/220kV Indravati (OHPC) S/s

In 141st OCC, it was explained that 3x105 MVA 400/220kV ICT-I tie breaker, 220kV Bus coupler and transfer bus breakers are not in service at 400/220kV Indravati (OHPC) S/s.

In 142nd OCC, OHPC submitted the action plan as follows:

1. 220kV Bus Coupler: CB and CT needed to be replaced. They would restore the Bus coupler by August 2018.
2. 220kV Bus tie: CB and CT needed to be replaced. They would restore the Bus Tie by November 2018.
3. 400kV Tie-1 Breaker: CB and CT needed to be replaced. They would restore the 400kV Tie-I by January 2019.

In 148th OCC, OHPC informed that 220kV Bus Coupler would be restored by end of August 2018.

In 149th OCC, OHPC informed that 220kV Bus Coupler had been installed and the same would be put in service in September 2018.

OHPC may please update.

Item No. B.12: Guidelines for the charging of Transmission line connecting two generating plants after tripping on fault or outage

There is a prevailing issue on the charging of transmission line connecting two generating complex after its outage/tripping. It has been observed sometimes that either of the utility is not ready for charging of the line from their end after its tripping on fault/outage. This results in the delay in the restoration of line and thus affecting the reliability of both the generating station. In view of this, there is a need of guideline on charging of such transmission lines.

List of such transmission lines is given below:

- I. 400 kV Farakka-Kahalgaon Q/C.
- II. 400 kV Kahalgaon-Barh D/C.

As a general guideline following may be considered

- If voltage difference between two system is more than 5 kV system which have lower voltage should charge the line
- In case voltage difference is less than 5 kV system which have higher fault level should charge
- If only one end has line reactor than the end which is not having the line reactor should attempt to charge first.

In 149th OCC, NTPC informed that they had communicated the issue to their Corporate Office and awaiting for the reply.

NTPC may update.

Item No. B.13: Review of Cyber Security Works/Activities- CEA

CEA vide letter informed that Secretary (Power) is going to review the cyber security related works /activities being carried out in Power Sector. In this regard, it is requested to provide the State wise status on following action points pertaining to cyber security at the earliest:

1. Appointment of organization-wise Chief Information Security Officers and its status
2. Identification of organization-wise Critical Infrastructure and its status
3. Preparation of organization-wise Crisis Management Plan and its status
4. Status of Cyber Security Mock Drill activity in coordination with CERT-In
5. Status of Training / Workshops on Cyber Security organized / participated by power sector entities
6. Status of action taken on CERT-In / NCIIPC advisories

In 148th OCC, all the constituents were advised to send the latest status to mserpc-power@nic.in within a week.

The same has been received from WBSETCL only.

Members may comply.

Item No. B.14: Data for preparation Load Generation Balance Report (LGBR) of ER for the year 2019-20

As per the IEGC, RPC Secretariat is responsible for finalization of the Annual Load Generation Balance Report (LGBR) for Peak as well as Off-peak scenarios and the annual outage plan for the respective region

To facilitate the preparation of LGBR of Eastern Region by ERPC Secretariat within the schedule period, the following data/information for the year **2019-20** in respect of the constituents/utilities of Eastern Region is urgently required:

- i) The unit wise and station wise monthly energy generation proposed from existing units during 2019-20 (thermal/hydro/RES).
- ii) Annual maintenance programme for each of the generating units (thermal and hydro both).
- iii) Generating units under R&M / long outage indicating date of outage and reasons of outage and expected date of return (thermal and hydro both).
- iv) Partial and forced outage figures (in %) of generating units for the last 3 years.
- v) Month wise peak demand (MW) – restricted and unrestricted peak demand.
- vi) Month wise off-peak demand (MW).
- vii) Month wise energy requirement (in MU).
- viii) Month wise & source wise power (both MU & MW) purchase and/or sale plan.
- ix) Schedule of commissioning of new generating units during 2019-20 and unit-wise monthly generation programme (in MU).
- x) Allocation of power from new generating units.
- xi) Month wise and annual planned outage of transmission system (Transmission lines 220kV and above / ICTs / Reactors/ other elements).

Information may please also be submitted in the form of soft copy through email (mail ID: mserpc-power@nic.in / erpcjha@yahoo.co.in).

In 149th OCC, all the constituents were advised to submit the relevant information in the form of soft copy through email (mail ID: mserpc-power@nic.in / erpcjha@yahoo.co.in) by 31st October 2018.

Members may furnish the above data at the earliest.

Item No. B.15: Installation of PMU for observation of the dynamic performance of STATCOMs--ERLDC

Four STATCOMs (Rourkela, Jeypore, Kishenganj, New Ranchi) are being commissioned in the Eastern Region to improve the dynamic var compensation in the grid and for the improvement of the transient stability. STATCOM is a dynamic VAR compensation device and provides the fast reactive support to the grid during transient as well steady state operation. In order to analyze the dynamic performance of STATCOM (STATCOM+ MSR /MSC) during day-to-day operation, it is desired to install PMU on the Coupling Transformer of the STATCOM as a part of the URTDSM project.

In the 37th ERPC meeting, the followings were decided:

- i) Power Grid shall first explore the possibilities by diverting the unutilized PMUs under URTDSM project and would complete the work on urgent basis.
- ii) If adequate no. of PMUs are not available under URTDSM project, balance PMUs will be implemented under project "Upgradation of SCADA / RTUs / SAS in the Central sector stations and strengthening of OPGW network".

In 147th OCC, ERLDC informed that spare connection was available at 765kV Ranchi S/s which could be used for integration of Ranchi STATCOM. Since PMUs available at Ind Bharat and

Monnet S/s could not be shifted due prevailing administrative issues, PMUs at Tenughat and Patratu might be diverted for STATCOM integration at Rourkela, Jeypore and Kishanganj S/s.

In 149th OCC, Powergrid informed that URTDSM project is at final stage of implementation and no spare PMU, no spare channel is available to provide PMU on the Coupling Transformer of the STATCOM.

OCC once again advised Powergrid to explore the possibilities to provide PMU on the coupling Transformer and submit a written report to ERPC and ERLDC covering the following points:

- *Availability of spare PMUs in URDTSM project*
- *Availability of spare channels in PMUs installed at Rourkela, Jeypore, Kishanganj and New Ranchi*
- *Diverting PMUs at Tenughat and Patratu to Rourkela, Jeypore, Kishanganj and New Ranchi*

Members may update.

Item No. B.16: Status of Emergency Restoration system (ERS) of respective Transmission Licencees

CEA vide mail dated 28-09-2018 has requested to provide Status of Emergency Restoration system (ERS) of respective Transmission Licencees in respective Regions as per the format given below:

State-wise Emergency Restoration system				
Transmission Licensee	Requirement of Total no of ERS in State	Number of ERS available in state	No of ERS to Be Procured	Remark if Any .

Transmission Licencees may submit the details as per the format.

Item No. B.17: Delay in furnishing information to ERLDC/ERPC regarding of Commissioning of new Transmission Elements/ Generating Units within State

The above matter was deliberated in various OCC meetings and data submission format was also circulated. All states and transmission licensees agreed to submit the list of transmissions elements synchronized for the first time during last month within 7th day of the current month to ERLDC through mail.

For the Month of September-2018, states and transmission licensees did not submit their List of Transmission element and generators synchronised **in the previous Month** and List of Transmission element and generators expected to be synchronised during next Month.

Members may please note.

Item No. B.18: Additional agenda

PART C: ITEMS FOR UPDATE

Item no. C.1: Status of UFRs healthiness installed in Eastern Region

UFR Healthiness Certification for the month of September, 2018 has been received from CESC, WBSETCL, DVC, BSPTCL and JUSNL.

OPTCL may update.

Item no. C.2: Status of Islanding Schemes healthiness installed in Eastern Region

At present, the following islanding schemes are in service:

1. CESC as a whole Islanding Scheme, CESC
2. BkTPS Islanding Scheme, WBPDCCL
3. Tata Power Islanding Scheme, Haldia
4. Chandrapura TPS Islanding Scheme, DVC
5. Farakka Islanding Scheme, NTPC

In 108th OCC meeting, respective constituents agreed to certify that the islanding schemes under their control area are in service on monthly basis.

The healthiness certificate for Islanding Scheme for September, 2018 has been received from CTPS, DVC, NTPC, West Bengal, JUSNL, WBPDCCL and CESC.

Members may note.

Item no. C.3: Status of Implementation of islanding schemes in ER

1. Islanding scheme at Bandel TPS-WBPDCCL

In 145th OCC, WBPDCCL informed that the implementation at Power station would be completed by May 2018. Implementation part at Substation for load segregation would be done by WBSETCL.

In 38th TCC Meeting, WBPDCCL informed that the implementation at Power station has been completed.

In 147th OCC, WBSETCL informed that implementation part at Substation end for load segregation would be completed by end of July 2018.

In 148th OCC, WBPDCCL and WBSETCL informed that islanding scheme had been implemented and it can be put in service.

In 149th OCC, OCC decided to put the islanding scheme in service after Puja.

Members may decide.

2. Islanding scheme at IbTPS- OPGC

The islanding scheme was discussed in 68th PCC Meeting held on 18-06-2018. PCC opined that the draft scheme submitted by Odisha was three years old and the draft scheme is needed to be reviewed with existing network configuration.

In 69th PCC Meeting, it was decided that ERLDC and ERPC would study and finalize the islanding scheme in next PCC Meeting.

Members may note.

Item no. C.4: Healthiness of SPS existing in Eastern Region

The Status of healthiness certificate for August, 2018 is given below:

Sl. No.	Name of the SPS	Healthiness certificate received from	Healthiness certificate not received from
1.	Talcher HVDC	NTPC, GMR, & JITPL	Powergrid,
2.	Rangpo	Chuzachen,	Dikchu, Dansenergy, Powergrid, Teesta-III
3.	SPS of 220 kV Muzaffarpur-Dhalkebar D/C	Nil	Powergrid
4.	SPS in CESC system	CESC	Nil
5.	SPS for Power Export to Bangladesh	Nil	Powergrid
6.	SPS at Chuzachen	Chuzachen	Nil

Members may update.

Item no. C.5: Implementation of Automatic Demand Management Scheme (ADMS)-ERLDC

The latest status along with proposed logic as follows:

Sl No	State/Utility	Logic for ADMS operation	Implementation status/target	Proposed logic (if different from under implementation logic)
1	West Bengal	F <49.7 AND deviation > 12 % or 150 MW	Implemented on 25.11.16	F <49.9 AND deviation > 12 % or 150 MW
2	DVC	F <49.7 AND deviation > 12 % or 150 MW	Implemented on 17.06.2016	
3	Bihar	F <49.7 AND deviation > 12 % or 150 MW	3 months Feeders identified. Implemented by June 2018	F <49.9 AND deviation > 12 % or 150 MW
4	Jharkhand	1. System Frequency < 49.9 Hz AND deviation > 12 % or 25 MW 2. System Frequency < 49.9 Hz AND deviation > 12 % or 50 MW 3. System Frequency < 49.9 Hz AND deviation > 12 % or 75 MW	9 Months Tendering for RTU installation is in progress. Implemented by May 2018	Condition 1: Block I feeders will be selected for load shedding Condition 2: Block I & II feeders will be selected for load shedding Condition 3: Block I, II & III feeders will be selected for load shedding
5	Odisha	1. System Frequency < 49.9 Hz 2. Odisha over-drawl > 150 MW 3. DISCOM over-drawl > (40 MW)	10 Months Sent for PSDF approval.	Logic 2 and 3 is AND or OR, in case it is AND then ADMS may not operated when discom are in schedule but GRIDCO is overdrawing due to less generation at state embedded generators
6.	Sikkim			Sikkim informed that they have submitted a proposal to PSDF Committee for installation of OPGW cables which is under approval

				stage. Sikkim added that ADMS scheme would be implemented after installation of OPGW.
--	--	--	--	---

In 142nd OCC, it was opined that uniform logic should be implemented for all the states. OCC decided to review the logic of ADMS after implementation of the scheme by all the states. During the Month of September'18, several number of times ADMS criteria for the state got satisfied. The details for each state are given at **Annexure-C5**.

Members may update.

Item no. C.6: Repair/Rectification of tower at location 79 of 132kV Rangpo-Melli D/c line and Chuzachen(Rangpo)-Gangtok transmission lines - Powergrid

Powergrid informed that their patrolling team has observed bent in part of tower no. 79 of 132kV Rangpo-Melli D/c line and Chuzachen(Rangpo)-Gangtok transmission lines which may further degrade the condition of tower.

In 141st OCC, Sikkim informed that rectification of the tower has been taken up with Gati. The work would be completed by 2nd week of February 2018.

In 37th TCC, it was decided that Sikkim would give a comprehensive proposal to PGCIL within one week regarding handing over of the relevant segments of the line to PGCIL. Thereafter, PGCIL and Sikkim would sit together and sort out the issues involved therein.

In 145th OCC, Sikkim informed that the proposal had been sent to State Govt. for approval.

In 38th TCC, Sikkim informed that State Govt. for approval is pending.

Powergrid and Sikkim may update.

Item no. C.7: Status of Installation of STATCOM in Eastern Region

In the 15th meeting of SCM it was agreed to install STATCOM in combination with mechanically switched Reactors (MSR) and Capacitors (MSC) and co-ordinated control mechanism of MSCs and MSRs at Ranchi, Rourkela, Jeypore and Kishanganj substations in Eastern Region.

The matter was again discussed in the 28th ERPC/TCC meeting held on 12th -13th September, 2014 at Goa, wherein, it was decided that POWERGRID may go ahead with implementation of the STATCOM project in Eastern Region with debt – equity ratio of 70:30 funding. The debt part should be refunded through PSDF and Equity Component (30%) to be funded by POWERGRID to be recovered through regulated tariff mechanism. CTU should initiate the process of availing fund from PSDF.

Powergrid updated the latest status as follows:

SI No	Location /Sub-Station of POWERGRID in ER	STATCOM - Dynamic Shunt Controller (MVAr)	Mechanically Switched Compensation Sl. (MVAr)		Latest status
			Reactor (MSR)	Capacitor (MSC)	
1	Rourkela	±300	2x125		<i>In service from March 2018.</i>
2	Kishanganj	±200	2x125		<i>70% civil work completed. 30% switchyard equipment supplied. Expected to complete by December 2018</i>
3	Ranchi(New)	±300	2x125		<i>Commissioned on 12th July 2018</i>
4	Jeypore	±200	2x125	2x125	<i>Commissioned on 30th June</i>

					2018
--	--	--	--	--	------

Powergrid may update.

Item no. C.8: 220 kV inter-connecting lines of OPTCL with 400/220 kV Bolangir (PG), Keonjhar&Pandiabil S/s

PGCIL has already commissioned the 2x315MVA 400/220kV Bolangir S/s by LILoing of 400kV Meramandali-Jeypore S/C line and 400/220 kV Keonjhar S/s with an objective of supplying power from ER grid to its adjoining areas in Odisha.

In last OCC, OPTCL updated the completion schedule of inter-connecting system as follows:

Sl. No.	Name of the transmission line	Completion schedule
1.	2x315MVA 400/220kV Bolangir S/s	
a.	LILo of one circuit of Sadeipalli-Kesinga220 kV D/C line at Bolangir S/S	<i>Only 7 towers left (Severe ROW problem).By December, 2018.</i>
2.	400/220kV Pandiabil Grid S/s:	
a.	Pratapsasan(OPTCL)-Pandiabil(PG) 220 kV D/C line	By Dec, 2018.
3.	400/220 kV Keonjhar S/S	
a.	Keonjhar (PG)-Keonjhar (OPTCL) 220 kV D/C line	By end of Sep, 2018.
b.	Keonjhar (PG)-Turumunga(OPTCL) 220kV D/C line	By 2019. The work is yet to be started.

OPTCL may update.

Item no. C.9: 220 kV inter-connecting lines of JUSNL with 2x315 MVA, 400/220 kV sub-stations at Chaibasa, Daltonganj&Dhanbad

In lastOCC, JUSNL updated the latest status as follows:

Sl. No.	Name of the transmission line	Completion schedule
1.	Daltonganj 400/220/132kV S/s:	
a.	Daltonganj(POWERGRID)–Latehar220kVD/c	By April, 2019.
b.	Daltonganj (POWERGRID) – Garhwa 220kV D/c	The line expected to be completed by May, 2018 but – Garhwa 220kV is expected to be completed by Dec 2018.
C	Daltonganj (POWERGRID) – Daltonganj (JUSNL) 132kV D/c	The line charged as per original configuration on 26 th July 2018.
D	Daltonganj (POWERGRID) – Chatarpur/Lesliganj 132kV D/c	Tendering is in progress. Expected to be completed by October 2019
2	Chaibasa400/220kVS/s	
A	Chaibasa(POWERGRID)–Noamundi220kVD/c	Not yet started
3	Dhanbad400/220kVS/s	
A	LILo of Govindpur–Jainamore/TTPS 220kVD/c at Dhanbad	ROW issues.Target date November 2018.

JUSNL may update.

Item no. C.10: 220 kV inter-connecting lines of WBSETCL with 400/220 kV, 2x315 MVA Alipurduar & 2x500 MVA Rajarhat sub-stations

In lastOCC, WBSETCL updated the latest status as follows:

Sl. No.	Name of the transmission line	Completion schedule
1.	2x500MVA, 400/220kV Rajarhat---	
a.	Rajarhat-N. Town-3 (WBSETCL) 220 kV D/C line	Matching, ROW problem
b.	Rajarhat-N. Town-2 (WBSETCL) 220 kV D/C line	ROW problem
c.	Rajarhat- Barasat (WBSETCL) 220 kV D/C line	ROW problem
2	Subashgram400/220kVS/s	

a	Subashgram–Baraipur220kVD/cline	Mar 2019, 50% of work has been completed.
---	---------------------------------	---

WBSETCL may update.

Item no. C.11: Update on status of telemetry

CERC vide order dated 28.02.2016 on Petition No. 007/SN/2014 directed NLDC and respective RLDCs to update the status of telemetry every month at their respective websites and take up the issue of persistent non-availability of data from Generating Stations/substations at RPC meetings for appropriate action.

ERLDC may present. Members may update.

Item no. C.12: Transfer capability determination by the states

In order to ensure, safe and secure operation of the grid, the states should carry out the power system study for operational planning and power transfer capability through their respective transmission links with the rest of the grid.

It was decided in the NPC meeting that to begin with, power system study for assessment of operational limits / power transfer capability for each state will be done by the concerned RLDC in association with concerned SLDC. Monthly TTC /ATC will be uploaded by the SLDCs at their respective websites and also communicated to concerned RLDC & NLDC subsequently.

Latest status of State ATC/TTC declared by states for the month of January -2019

SI No	State/Utility	TTC import(MW)		RM(MW)		ATC (Import) MW		Remark
		Import	Export	Import	Export	Import	Export	
1	BSPTCL	--	--	--	--	--	--	Last available for Jan-18
2	JUSNL	1270	--	170	--	1100	--	Dec-18
3	DVC	1359	3438	61	47	1298	3391	
4	OPTCL	1835	--	82	--	1753	--	Nov-18
5	WBSETCL	3820	--	300	--	3520	--	Nov-18
6	Sikkim	--	--	--	--	--	--	

BSPTCL has provided updated base case.

BSPTCL and Sikkim may update the status.

Item no. C.13: Replacement of GPRS communication with Optical Fiber for AMR

In ER, 80% meters are connected through Automated Meter Reading (AMR). At present the communication system used for data transfer from each location is GPRS. It has been observed that many locations are not communicating with AMR system due to poor/no GPRS signal. Many substations have their own optical fiber which is also used for the LAN network of respective stations. TCS has successfully connected 02 locations (Subhasgram-PG and Binaguri-PG) in ER-II with PGCIL intranet and these two locations are smoothly reporting to AMR system after connecting with PGCIL LAN. The proposed network will not only provide better communication but also reduce the cost of GSM.

In 147th OCC, POWERGRID informed that the replacement of GPRS communication of the Remaining 34 locations would be completed by August 2018.

POWERGRID may please update the progress.

Item no. C.14: Accounting of state drawl from Substation of PGCIL/ISTS Licensee in ER

As per Clause 7(1) (C) of CEA (Installation and Operation of Meters) Regulations, 2006 & its subsequent amendments, Main Meters for drawl computation through ICT should be installed on HV side of ICT and meters installed on LV side of ICT should be considered as Standby meters .

In view of the above it is proposed that Sate drawl from PGCIL/ISTS Licensee S/S may be computed by using the meter installed on HV side of ICTs in line with CEA regulation.

In 146th OCC, Powergrid informed that the SEM installation in ER-I stations has been completed and the same at ER-II stations would be completed by June 2018. Powergrid(Odisha) informed they will complete the SEM installation by July,2018.

However locations in ER-I for ex, Purnea, Banka, Lakhisarai, and Ranchi are still pending.

A List of Time drifted Meters installed at ICTs at PGCIL S/station in ER was prepared by ERLDC from AMR system and vide letter dated 04.07.18, PGCIL was requested for replacement of the same.

In 147th OCC, Powergrid informed that the list had been received from ERLDC and the replacement of SEMs is in progress.

However Meter at either side of ICTs at Purnea(2 nos of 220/132 ICT), Birpara (1 no of 220/132 ICT) and Baripada(2 nos of 400/220 ICT) is yet to be installed. Further Meters installation at IV side of many ICTs is also pending.

Powergrid may update.

Item no. C.15: Mock Black start exercises in Eastern Region – ERLDC

Tentative Schedule for mock black start exercise for FY 2018-19 is given below:

Sl no	Name of Hydro Station	Schedule	Tentative Date	Schedule	Tentative Date
		Test-I		Test-II	
1	U.Kolab	Last week of May, 2018	Completed on 8 th June,2018	Last Week of January2019	In Sep 2018
2	Maithon	1stweek of June 2018	Completed on 6 th June,2018	1stWeek of February2019	
3	Rengali	2ndweek of June 2018	Done on 18 th August,2018.	Last week of November 2018	
4	U. Indarvati	3rdweek of June 2018	Planned in Oct,2018.	2ndweek of February2019	
5	Subarnarekha	1stweek of October 2018	Done on 10 th August,2018.	1stweek of January2019	
6	Balimela	3rdweek of October 2018		1stweek of March 2019	
7	Teesta-V	2ndweek of Nov 2018	Done on 3 rd May 2018	Last week of February2019	
8	Chuzachen	Last Week of May2018	In May 2018	2 nd week of January2019	
9	Burla	Last Week of June 2018	Completed on 7 th June,2018	Last week of February2019	
10	TLDP-III	1 st Week of June 2018	After Monsoon	2ndWeek of January2019	
11	TLDP-IV	Last Week of June 2018	After Monsoon	1 st Week of February2019	

12	Teesta-III	Last week of Oct 2018		First Week of March 2019	
13	Jorthang	First Week of May 2018		First Week of Feb 2019	
14	Tasheding	2 nd Week of May 2018		2 nd Week of Feb 2019	
15	Dikchu	3 rd Week of May 2018		3 rd Week of Feb 2019	

Members may update.

Item no. C.16: Implementation of Web based PSP report in ERLDC

After successful parallel testing of Web based PSP and with continuous support from ER beneficiaries and generators, the web based PSP has successfully migrated from excel based PSP reporting to Web based PSP reporting portal on 07th September 2018. However, some utilities are still not filling-in data in Web based portal regularly during night hours. It is once again requested to the parties to fill the 24hrs generated energy, energy exchange data in ERLDC portal by 02:00hrs on daily basis regularly for error free and in time publication of the report during night hour.

Members may comply.

Item no. C.17: Flexible Operation of thermal power stations- Identification of pilot projects--CEA

Central Electricity Authority vide letter dated 16th February 2018 informed that a special Task Force was constituted under IGEF Sub-Group-I for enhancing the flexible operation of existing coal-fired power plants. The committee has recommended for implementation of measures for 50%, 40% and 25% minimum load in thermal power stations. The measures for 50% minimum load operation requires no investment or minimal investment. (Report is available on CEA website under TRM division)

Subsequently, a meeting was held under the chairmanship of Member (Thermal) on 8th February 2018 where in it was decided that 55% minimum load operation would be implemented nationwide in first phase. Further, Six units, including two units of NTPC and one unit each from DVC, GSECL, APGENCO, MSPGCL, would be taken up for 55% minimum load operation on pilot basis as 55% minimum load operation in line with the CERC notification dated 6th April 2016 and 5th May 2017 (IEGC 4th Amendment).

In 142nd OCC, NTPC informed all the units of NTPC were capable of 55% minimum load operation. DVC informed that they were planning to implement at DSTPS.

In 37th TCC, DVC informed that they would demonstrate the capability of 55% minimum load operation for one unit of DSTPS by March 2018.

In 144th OCC, DVC informed that an exercise to test 55% minimum load operation had been conducted at DSTPS recently. The details of the test results, as and when received, would be shared with OCC members.

In 146th OCC, DVC informed that they could bring down their machine up to 60 % without oil support and with the available quality of coal.

In 38th TCC, DVC assured that the necessary demonstration to bring down their machine up to 55% would be done by July 2018.

DVC may update.

Item no. C.18: Issuance of TOC for DSTPS-RTPS OPGW link by DVC

In 19th SCADA O & M meeting held on 7th April 2017 at ERLDC, Kolkata, POWERGRID had informed that they were not able to complete the OPGW work in DSTPS – RTPS in DVC Sector under Microwave Replacement Package due to severe ROW issue. POWERGRID further informed that they had mobilized the team several times but work could not be completed due to heavy ROW / compensation issues related to TL construction resulting non-completion of 2 nos. OPGW drum (approx. 9 Km) out of total 69.182 Km. POWERGRID again informed that this issue was discussed in various forums but the solution could not be provided by DVC. DVC informed that they are not able to resolve the issue as this was an old ROW / compensation issue related to TL construction. OPGW work in this link could not be completed due to ROW/Compensation issues since September-2013.

In 36th ERPC meeting, matter was deliberated and DVC informed that they would try to resolve ROW issues by 31st October-2017. Otherwise they would provide the necessary certificate.

In 20th SCADA O&M meeting held on 15th December-2017, POWERGRID informed that DVC had not yet issued TOC for this link. DVC confirmed that they will issue TOC and request for a letter from POWERGRID. POWERGRID issued the request letter on 20.12.2017. However, ToC is yet to be issued by DVC.

In 37th TCC, DVC informed that the ROW issue would likely to be resolved after the Panchayat Election of West Bengal.

In 38th TCC, DVC assured that the issue would be resolved by July 2018. In case the issue is not resolved MS, ERPC will take up the matter with DVC for early resolution of the issue.

In 147th OCC, DVC informed that they had taken up the issue with appropriate administration and the issue would be resolved soon.

DVC may update.

Item no. C.19: PSS tuning of Generators in Eastern region

Several Cases of Low frequency Oscillations have been observed in the Eastern Region. In view of this, it is desirable to have the PSS tuning of Generators in Eastern region to improve the system damping. It is mandatory as per existing CERC and CEA regulation to tune 100 MW and above generating units.

In view of that, Generating station may kindly update the following details to ERLDC/ERPC:

Name of Generating Power Plant:

Unit No	Type of Excitation System (Static/ Brushless /Other)	IEEE Model (IEEET1/ ESST1A/ Other)	Name of Excitation System Vendor (ABB/GE /Hitachi/ other)	Whether PSS is Tuned of not (If tuned Date of tuning)	Whether Report of tuning Submitted or not.

In line with regulations, all generating power plant to take up the PSS tuning activities at earliest with their vendors and submit the report after PSS tuning for verification. The response data with PSS tuning also to be shared with ERLDC/ERPC for validation in either excel or .csv format. This will be monitored in OCC on regular basis.

OCC advised all the generators to submit the relevant data as per the format to ERLDC and ERPC.

Generators may kindly submit the details and inform the tentative plan for PSS Tuning.

Item no. C.20: Submission of Thermal Loading of Transmission line and associated terminal equipment by ISTS licensee

In line with the MoM of 4th NRCE Meeting dt.03-11-14 and “Operational Guidelines for determination Of TTC, ATC and TRM for the Short-Term Horizon (0-3 Months)” published by NRCE dt.20-02-15, thermal limit for transmission line has to be used for calculation of ATC/TTC. However, the thermal loading of transmission line depend on the Maximum Conductor Temperature, End equipment thermal rating. This has to be submitted by the Owner of the equipment. Further, the equipment owner also has to confirm that relay setting has been aligned so that the line can be operated up to its thermal limit. In the absence of complete details, ERLDC is utilising the data from the CEA Planning Criteria for thermal rating as given below :

Conductor Type	Ampacity per conductor(A)*	Thermal loading limit of line (MVA)
765 kV Quad ACSR_Bersimis	732	3880
765 kV HexaACSR_Zebra	560	4452
400 kV Twin ACSR_Moose	631	874
400 kV Quad ACSR_Moose	631	1749
400 kV Quad ACSR_Bersimis	732	2029
400 kV Triple Snowbird	630	1309
400 kV Twin ACSR_Lapwing	773	1071
220 kV Single AACR_Zebra	557	212
220 kV Single ACSR_Zebra	560	213
220 kV Twin ACSR_Moose	631	481
132 kV Single ACSR_Zebra	560	128
132 kV Single ACSR_Panther	366	84

*Ambient and Maximum conductor temperature are taken as 45°C and 75°C respectively. Apart from above specifically mentioned in CEA transmission planning criteria following loading limit is considered for HTLS line while calculating ATC/TTC

Conductor Type	Ampacity per conductor(A)*	Thermal loading limit of line (MVA)
400 kV Twin HTLS	1262	1750
220 kV Single HTLS	1020	390
132 kV Single HTLS	732	168

In view of this, it is desired that all ISTS Licensee and STU(for 400 kV and important 220 kV lines) may kindly submit the following details to ERLDC for utilisation in ATC/TTC calculation:

- a) Transmission line wise Ampacity and Thermal loading along with Maximum Conductor Temperature and conductor type.
- b) End Equipment Rating and
- c) Confirmation whether the relay setting has been adopted in line with the thermal rating of the line
- d) Any constraint during thermal loading of line

OCC advised all the ISTS licensees and STUs to submit the relevant data to ERLDC and ERPC.

Members may note and comply.

Item no. C.21: FLEXIBILITY IN GENERATION & SCHEDULING OF THERMAL POWER STATIONS TO REDUCE EMISSIONS-MOP, GOI ORDER

CEA vide letter dated 18th July 2018 informed that a committee has been constituted in CEA under Chief Engineer (TPRM) to develop a road map to enable flexible operation of thermal power stations for smooth integration of intermittent RES generation.

CEA requested for plant performance data as per the format enclosed at **Annexure-C21**. CEA requested to submit the hard copy and softcopy (in excel) to cetrmcea@yahoo.com.

OCC advised all the Generators to submit the plant performance data as per the format to CEA.

Members may note and comply.

Item no. C.22: Load Trimming Scheme on 400/132 kV Motihari ICTs.

400/132 kV Motihari substation is having a two ICTs each with 200 MVA capacity. It has been observed that due to higher load catering of Bihar along with Nepal, the ICTs are running without N-1 reliability. On 22nd August 2018 at 14:59 Hrs, the ICTs combined load increased to 280 MW and one ICT got tripped on mal-operation of OSR relay due to moisture ingress. This led to overloading of other ICT, which tripped in overcurrent protection. This led to the loss of 280 MW of Bihar and Nepal.

Such unreliable operation of ICTs due to higher load is not desirable and following action point may be desired:

1. Implementation of Load Trimming Scheme (LTS) on Motihari ICTs.
2. BSPTCL Long term plan to ensure the meeting such high demand in the areas.
3. Prevention of Tripping of Motihari ICT on OSR relay mis-operation during moisture ingress in rainy season.
4. Capacity augmentation for long term measures may be planned.

In 149th OCC, it was informed that one more ICT of 315 MVA had been planned in 13th Plan which would be commissioned by May 2020.

OCC advised Bihar to plan a load-trimming scheme till the availability of 3rd ICT.

BSPTCL and DMTCL may update.

PART D:: OPERATIONAL PLANNING

Item no. D.1: Anticipated power supply position during November'18

The abstract of peak demand (MW) vis-à-vis availability and energy requirement vis-à-vis availability (MU) for the month of November 18 were prepared by ERPC Secretariat on the basis of Provisional LGBR for 2015-16 and feedback of constituents, keeping in view that the units are available for generation and expected load growth etc. is at **Annexure-D.1**.

Members may confirm.

Item no. D.2: Shutdown proposal of transmission lines and generating units for the month of November 18

Members may finalize the Shutdown proposals of transmission lines and generating stations for the month of November 18.

Shutdown proposals of generating stations:

System	Station	Unit	Size (MW)	Period		No. of Days	Reason
				From	To		
Bihar	MTPS (KBUNL)	3	195	15.11.18	14.12.18	30	Boiler Overhauling
WBPDC	Kolaghat TPS	4	210	01.11.18	10.11.18	10	Boiler License
	Santalidih TPS	5	250	12.11.18	22.11.18	11	Boiler License
CESC	BUDGE-BUDGE	3	250	12.11.18	29.11.18	18	Not Specified

ERLDC may place the list transmission line shutdown. Members may confirm.

1. Shutdown of 400kV Main Bus Darbhanga

Alipurduar Transmission Limited vide mail informed that ATL/KPTL is executing the bay extension work at 400 KV GIS Darbhanga S/S. To integrate the new system with the existing system require shut down as mentioned below:

- 400KV Main bus I (DMTCL): 10th October to 17th October 2018 – 8 days , 192 Hrs. For integration of Main Bus –I. Substation will remain charged on Main Bus – II
- 400KV Main bus II (DMTCL): 19th October to 26th October 2018 – 8 days, 192 Hrs. For integration of Main Bus –II. Substation will remain charged on Main Bus - I
- 400KV Main bus I (DMTCL) & 400KV Main bus II (DMTCL) : 28th October 2018 to 29th October 2018- 2 days , 48 Hrs. For integration of Bus Bar protection . Substation will remain in shut down for two days.

The detailed procedure which will be followed during the shutdown is mentioned below:

Work plan for connection of DMTCL's & KPTL's Main BUS I & II		
Step wise activity for connection of Main Bus I & II between DMTCL & KPTL by TBEA, ZONFA.		
Sr. No	Duration	400KV Main bus I must be in de-energised condition
R phase		
1	3 days	Reduce SF6 gas pressure for last section of Main bus I (DMTCL side) till zero MPA(Mega paskal).
2		Reduce SF6 gas pressure for second last section of Main bus I (from DMTCL side)

		till 0.1 MPA.
3		Extention bellow to be connected between DMTCL & KPTL main Bus I
4		Vacuuming of complete portion. (3 sections)
5		SF6 Gas filling of up to 0.4 MPA (3 sections)
6		SF6 Gas filling in second last section of DMTCL & KPTL to be increased till 0.4 MPA.
7	2 days	Repeat Activity no 1 to 6 for Y Phase
8	2 days	Repeat Activity no 1 to 6 for B Phase
9	1 days	Testing of Main Bus I
10		Gas quality test By Zonfa .
11		Contact resistance measurement by Zonfa.
12		Stability test by voltech
13		Primary injection test by voltech.
Sr. No	Duration	400KV Main Bus II must be in de-energised condition
		R Phase
1	3 days	Reduce SF6 gas pressure of last section of Main bus I till zero MPA(Mega paskal)
2		Reduce SF6 gas pressure of second last section of Main bus I till 0.1 MPA.
3		Extention bellow to be connected between last section of DMTCL & first section of KPTL's main Bus
4		vacuuming of complete
5		SF6 Gas filling of up to 0.4 MPA
6		SF6 Gas filling in second last section & 2nd section of KPTL to be increased till 0.4 MPA.
7	2 days	repeat Activity no 1 to 6 for Y Phase
8	2 days	repeat Activity no 1 to 6 for B Phase
9	1 days	Testing of Main Bus I
10		Gas quality test By Zonfa .
11		Contact resistance measurement by Zonfa.
12		Stability test by voltech
13		Primary injection test by voltech.
Stepwise activity for BB augmentation By Siemens		
Sr.No	Duration	Both Main bus I & II must be in de-energised condition
1	No	Outdoor CT circuit wiring from LCC to BB panels TBs 1). 412LCC & 2). 414 LCC
2	No	Mounting and termination of the Test block for the present scope
3	No	Outdoor cabling from respective LCC to BB panel TB (for BI/BO)
4	No	Mounting of CMR relay for present scope
5	Yes, 2 days	Mounting of new modules in both the panels
6		All internal wiring from Panel TBS to Relay modules
7		All internal wiring for CMR relay, from Test blocks to IO modules
8		Relay configuration for new added bays
9		Testing of Relays for all the bays

Alipurduar Transmission Limited may explain. Members may approve.

Item no. D.3: Prolonged outage of Power System elements in Eastern Region

(i) Thermal Generating units:

S.No	Station	Owner	Unit	Capacity	Reason(s)	Outage	Expected date
			No	(MW)		Date	of revival
1	FSTPP	NTPC	5	500	HP TURBINE LEAKAGE	30-Sep-18	
2	KOLAGHAT	WBPDC	1	210	POLLUTION CONTROL PROBLEM	10-May-18	
3	KOLAGHAT	WBPDC	3	210	POLLUTION CONTROL PROBLEM	23-Feb-17	
4	CTPS	DVC	3	130	TURBINE BLADE DAMAGE	30-Jul-17	
5	KODARMA	DVC	2	500	ANNUAL OVERHAULING	9-Sep-18	
6	WARIA	DVC	4	210	BOILER TUBE LEAKAGE	24-Sep-18	
7	VEDANTA	GRIDCO	2	600	PROBLEM IN BOILER	8-Feb-18	
8	VEDANTA	GRIDCO	4	600	LEAKAGE IN LUBE OIL SYSTEM	2-Oct-18	
9	JITPL	JITPL	2	600	COAL SHORTAGE	26-Jun-18	
10	KBUNL STG-I	BSPHCL	2	110	COAL SHORTAGE	21-Aug-18	
11	TENUGHAT	JUVNL	2	210	COAL SHORTAGE	17-Jul-18	
12	RAGHUNATHPUR	DVC	1	600	COAL SHORTAGE	1-Jun-18	
13	MEJIA	DVC	4	210	COAL SHORTAGE	13-Sep-18	
14	MEJIA	DVC	8	500	COAL SHORTAGE	4-Oct-18	
15	MEJIA	DVC	7	500	COAL SHORTAGE	1-Sep-18	
16	DSTPS	DVC	1	500	COAL SHORTAGE	16-Sep-18	

(ii) Hydro Generating units:

SL NO	Station	Owner	Unit No	Capacity	Reason(s)	Outage
1	BURLA	OHPC	1	37.5	R & M WORK	25.10.16
2	BURLA	OHPC	2	37.5	R & M WORK	16.10.15
3	BURLA	OHPC	5	37.5	R & M WORK	25.10.16
4	BURLA	OHPC	6	37.5	R & M WORK	16.10.15
5	BALIMELA	OHPC	1	60	R & M WORK	05.08.16
6	BALIMELA	OHPC	2	60	R & M WORK	20.11.17
7	U.KOLAB	OHPC	2	80	Repair of MIV & Draft tube gate leakage	28.05.17
8	CHIPLIMA	OHPC	1	24	FLOOD CONTROL	21.7.18
9	CHIPLIMA	OHPC	2	24	FLOOD CONTROL	21.7.18
10	CHIPLIMA	OHPC	3	24	FLOOD CONTROL	21.7.18

It is therefore seen that about 422 MW hydro capacity in Odisha is under forced outage / planned outage and therefore not available for providing the much needed peaking support during evening peak. SLDC / OHPC may please indicate restoration plan of the units.

(iii) Transmission elements

SL NO	Transmission Element / ICT	Owner	Outage From	Reasons for Outage
1	220 KV BALIMELA - U' SILERU	Odisha/AP	10.03.18	LINE ANTITHEFT CHARGED FROM UPPER SILERU ON 17-04-18
4	400 KV IBEUL- JHARSAGUDAD/C	IBEUL	29.04.18	TOWER COLLAPSE AT LOC 44,45
5	400 KV DIKCHU-RANGPO	TPTL	6.07.18	INITIALLY S/D AVAILED BY TVTPL/LINE COULD NOT BE CLOSED AFTER S/D DUE TO LOCAL ISSUES.
6	220 KV BUDHIPADAR – RAIGARH(Chhattisgarh)	OPTCL	24-08-18	UNDER SHUTDOWN FO LILO WORK AT RAIGARH PG.
7	400KV NEW PURNEA- BIHARSARIFF-D/C	ENICL	10.8.18	TOWER COLLAPSE AT LOC 47/0
8	400 KV PATNA- KISHANGANJ D/C	POWERGRID	1.9.18	TOWER COLLAPSE AT LOC 129. PILING DAMAGED
10	MAIN BAY OF MEJIA – MAITHON – III AND MEJIA U-8 AT MEJIA	DVC	8.9.18	LINE CB VACCUM INTERRUPTER PROBLEM IN MEJIA SIDE AND TRANSFER BUS USED TO CHARGE MEJIA – MAITHON - III

(Reported as per Clause 5.2(e) of IEGC)

** Transmission licensees whose line were out due to tower collapse/ bend, may please update the detail restoration plan and as on date work progress status in OCC.

Also Monthly progress report to be submitted to ERLDC/ERPC till restoration of the element.

Members may update.

PART E::ITEMS FOR INFORMATION

The following agenda items are placed for information and necessary compliance:

Item No. E.1: Restricted Governor /Free Governor Mode Operation of generators in ER

CERC vide their letter dated 05-06-2017 desired to know the present status of RGMO/FGMO response of all eligible thermal and hydro units. Accordingly ERLDC vide letter no.ERLDC/SS/FGMO/2017 dated 07-06-17 requested all concerned power stations and SLDCs to provide updated status of FGMO/ RGMO of units under their control.

The latest status of the RGMO/FGMO of ER generators is enclosed in **Annexure-E1**.

Generators may update.

Item No. E.2: Preparation of crisis management plan for Cyber Security in Power Sector in line with CERT-IN.

The activity of the preparation of Crisis Management Plan for countering the cyber attacks and its implementation including the Mock Drills, audits etc. is being monitored by CEA regularly in line with crisis management plant of Ministry of Power. Power Utilities (including generation, transmission & distribution utilities) of eastern region are to furnish regularly the updated status to on the same to Chief Engineer, Distribution Planning & Development Division, CEA.

In 142nd OCC, ERLDC informed that, in line with Enquiry Committee Recommendation, cyber security audit is being conducted on regular basis for SCADA system installed at ERLDC and SLDC as well but cyber security audit for telecom infrastructure installed in Eastern Region is not being carried out.

OCC advised all the constituents to conduct the cyber security audit on telecom infrastructure installed in Eastern Region. It is further advised that compliance / mitigation of the points observed during the audit should also be completed for improvement of the telecom infrastructure in ER.

In 37th TCC meeting, it was decided that a workshop would be conducted by CEA at ERPC for further benefit of ER Constituents.

In 144th OCC, ERLDC informed that they have already conducted a workshop with the help of NPTI, Durgapur on 21st March 2018.

A workshop on cyber security was conducted by CEA at ERPC, Kolkata on 09-05-2018.

As suggested by CEA, a format would be circulated among ER constituents for furnishing the information of the their respective systems for discussion in OCC Meeting. The format is enclosed at **Annexure-E2**.

OCC advised all the constituents to submit the information to ERPC as per Annexure-E2.

Item No. E.3: Certification through BIS as per IS 18001:2007 to all generating/ transmission units.

In 84th OCC meeting all constituents were requested to interact with BIS with intimation to ERPC and get certified as per CEA direction.

As per the information received from the constituents the following generators certified with IS 18001:

- All NTPC stations in Eastern Region
- Teesta, NHPC

- All OHPC generating units
- All CESC generating units
- All units of WBPDCCL
- DGPC units

Item No. E.4: Status of Disturbance Recorder, Stand alone Event Logger and Time Synchronization equipment.

The status of DR/EL and GPS as updated in previous OCCs is enclosed at **Annexure-E.4**.

Constituents are also requested to furnish their list of new DR/EL which are not included in the list.

TeestaUrja Limited vide letter dated 8th September 2017 informed that Disturbance Recorder, Stand alone Event Logger and Time Synchronization equipments are available at Teesta III HEP.

Item No. E.5: Status of Emergency Restoration System (ERS Towers) for Eastern Region constituents

CEA vide letter dated 21.07.2017 requested to send the status of state-wise availability of ERS towers and requirement of ERS towers.

In 136th OCC, MS, ERPC informed that CEA vide letter dated 21.07.2017 has sought the latest status on ERS. Therefore, OCC advised all constituents to send the updated status to ERPC secretariat vide mail (mserpc-power@nic.in).

Latest status is enclosed at **Annexure- E.5**.

In 138th OCC, WBSETCL informed that they are having total 10 ERS towers, 5 at Arambagh and 5 at Gokharno.

In 139th OCC, JUSNL informed that they are having eight 220/132kV ERS towers at following locations:

- Hatia – 3 nos
- Ranchi – 2 nos
- Dumka – 3 nos

Item No. E.6: Status of 1st Third Party Protection Audit:

The compliance status of 1st Third Party Protection Audit observations is as follows:

Name of Constituents	Total Observations	Complied	% of Compliance
Powergrid	54	46	85.19
NTPC	16	14	87.50
NHPC	1	1	100.00
DVC	40	26	65.00
WB	68	49	72.06
Odisha	59	42	71.19
JUSNL	34	25	73.53
BSPTCL	16	5	31.25
IPP (GMR, Sterlite and MPL)	5	5	100.00

* Pending observations of Powergrid are related to PLCC problems at other end.

The substation wise status of compliance are available at ERPC website (Observations include PLCC rectification/activation which needs a comprehensive plan).

In 118th OCC, all the constituents were advised to comply the pending observations at the earliest. All the STUs informed that most of the observations are related to funding from PSDF. DPRs have been submitted to PSDF committee.

Members may comply.

Item No. E.7: DATA FOR GEOSPATIAL ENERGY PORTAL OF NEETI AAYOG--CEA

NITI Aayog is developing a user friendly GIS based Energy Map of India, which would provide true locations of all energy resources in India including power plants, coal and oil reserves, transmission lines etc.

CEA sought the information of name, voltage level, capacity, longitude and latitude of 33kV and 66 kV substations and lines.

The information may be shared with CEA vide email: cedpd-cea@gov.in.

Members may comply.

Item No. E.8: Providing relevant data by Power Utilities I Stations in National Power Portal.

CEA vide letter dated 26th June 2018 informed that National Power Portal (NPP) (URL: npp.gov.in), has been launched by Hon'ble Minister of Power on 14th November, 2017. NPP is modified and more user-friendly data portal than the existing Information Management System (IMS) in CEA. Reports prepared from NPP are of vital importance for Power Sector data analytics in order to frame policies, regulations , future road-map for Power Sector etc. at Central as well as at State level. Accordingly, all power utilities have been issued user ID and password, either organisation-wise or station-wise, based on their request , for providing their data on NPP.

NPP has replaced IMS since 1st June, 2018. A Circular (which is available in Circular Section of CEA Website, i.e. cea.nic.in) has been issued by CEA to all power utilities/stations on 14.06.2018 for providing their data online in NPP only.

In this regard, letters/mails have been issued to Utilities to provide their data online through NPP. A letter dated 20.06.2018 was also issued to all SLDC, requesting them to direct the power utilities I stations under their purview for providing data on NPP.

Any issue/problem faced by utilities may kindly be communicated to itcea@nic.in, npp.support@gov.in, ceopm-cea@gov.in and if required, IT Division, CEA may be contacted on 011-26732368 or 011-26732303

CEA requested to pursue the power utilities / stations under their purview for providing data on NPP. Further, a workshop/presentation may be arranged if required in each region in which IT Division, CEA will provide a brief demonstration regarding data entering process and report generation into NPP.

Members may comply.

Item No. E.9: Commissioning of new transmission elements in Eastern Region

The details of new units/transmission elements commissioned in the month of September - 2018 based on information furnished by the constituents are depicted below:

Monthly commissioning List of Transmission element and generators: September - 2018					
SL NO	Element Name	Owner	Charging Date	Charging Time	Remarks
1	400kV Farakka-Baharampur-I	Powergrid	01-09-2018	18:28	
2	400kV Farakka-Baharampur-II	Powergrid	01-09-2018	18:34	
3	125MVAR Bus Reator at Banka	Powergrid	27-09-2018	11:32	
4	50MVAR Line reactor of 400kV Sasaram-Daltonganj-I at Daltonganj	Powergrid	27-09-2018	17:09	
5	125MVAR Bus Reator at Bolangir	Powergrid	28-09-2018	23:29	5

The following elements would commission during October 2018:

1. 400kV DC line from Ib to Lapanga and 400kV LILO of Vedanta-Meramundali line at 400/220/132/33kV Lapanga S/s in Multi Circuit Tower.
2. 2X20 MVA, 220/33kV Keonjhar GIS S/s with 220kV DC line from Keonjhar (PGCIL S/s) to Keonjhar (OPTCL S/s).

Item No. E.10: Checklist for submission of updated data for Protection Database

The network data in Protection Database needs to be updated on regular basis on account of commissioning of new elements in the CTU as well as STU networks. Accordingly, a checklist has been prepared which is enclosed in **Annexure-E9**.

All the constituents are requested to submit the checklist on monthly bases in every OCC/PCC meetings.

In 139th OCC, all the constituents were advised to submit the data to ERPC vide mail (mserpc-power@nic.in) as per the checklist for last three months.

OCC advised all the constituents to submit the data to ERPC vide mail (mserpc-power@nic.in) as per the checklist for last three months.

Constituents may comply.

Item No. E.11: UFR operation during the month of September'18

System frequency touched a maximum of 50.20 Hz at 13:03 Hrs of 22/09/18 and a minimum of 49.57 Hz at 18:23Hrs of 24/09/18. Hence, no report of operation of UFR has been received from any of the constituents.

Item No. E.12: Non-compliance of directions issued by SLDC

Vide clause no 5.5.1.(c)(h) of IEGC, non-compliance of SLDC directions by SEB/Distribution licenses/bulk consumers to curtail overdrawal are to be reported to ERLDC for incorporating the same in weekly report to be prepared and published by ERLDC.

All SLDCs are to inform ERLDC the instances of non-compliance of SLDC directions by SEB/Distribution licenses/bulk consumers to curtail overdrawal, within two days after the day of operation.

No report from any constituent has yet received. Hence, ERLDC would be considering 'Nil' report for all constituents for September 18.

Item No. E.13: Grid incidences during the month of September, 2018

Sr No	GD/ GI	Date	Time	S/S involved	Summary	Load loss (MW)	Gen loss (MW)
1	GD-I	04-09-2018	12:00	JLHEP	At 12:00 hrs , 220 kV Jorethang - New Melli D/C tripped on RYBN fault resulting tripping of all running units of Jorethang due to loss of evacuation path. 220 Kv Tashiding New Melli S/C tripped at same time on R-Y-B-N fault.	0	97
2	GD-I	16-09-2018	11:13	JLHEP	220 kV Jorethang - New Melli D/C & 220 Kv Tashiding New Melli S/C tripped at 11:13 hrs resulting tripping of all running units of Jorethang due to loss of evacuation path.	0	97
3	GD-I	16-09-2018	15:38	Purnea	220 kV Purnea - Purnea D/C tripped from New Purnea end along with 220/132 kV ICTs and 132 kV Purnea - Purnea T/C at Old Purnea (PG) S/S. Failure of Y phase CT of 132 kV Purnea - Tribenigunj S/C at Tribenigunj reported at same time.	178	0
4	GD-I	16-09-2018	20:52	Purnea	220 kV Purnea - Purnea D/C tripped from New Purnea end along with 220/132 kV ICTs and 132 kV Purnea - Purnea T/C at Old Purnea (PG) S/S. At the same time, 220/132 Kv ICTs at Kishangunj tripped leading to a load loss around 212 MW at Kishangunj and its surrounding area	407	0
5	GD-I	17-09-2018	10:59	Sadaipalli	At 10:52 hrs 220 kV Katapalli Sadaipalli S/C tripped. While taking charging attempt of this line, 220 kV Bolangir-Sadaipalli S/C tripped resulting load loss at Sadaipalli.	121	0
6	GD-I	22-09-2018	14:38	Dikchu	400 kV Teesta III Dikchu S/C tripped at 14:38 hrs on B-N fault. Relay indication at Teesta III: B-N, F/C 9.1 KA, 15.6 km from Teesta III; at Dikchu: B-N, Z-IV, E/F, F/C 9.195 KA, -700 m from Dikchu. On Investigation it was found some of the bushes/plantation came in to contact with B phase conductor in the out yard between ICT & GIS at Dikchu. Both units at Dikchu tripped on differential protection though overvoltage and over speed protection operated correctly. O/C earth fault protection of 400/132 kv ICT picked up but did not tripped as time delay (1.2 s) was more than fault	0	96

					clearing time.		
7	GI-II	25-09-2018	14:40	Alipurduar	400 KV Alipurduar- Binaguri I and 400 KV Alipurduar- Bongaigaon II are on a multi circuit tower. R phase conductor of 400 KV Alipurduar - Binaguri I broke and fell on 400 KV Alipurduar - Bongaigaon II (between loc. 8 & 9, 3 KM from Alipurduar) resulting tripping of both the circuits at same time.	0	0
8	GD-I	27-09-2018	13:14	Tenughat	220 kV TVNL - PTPS S/C and 220 kV TVNL - Biharshariff S/C tripped on same time resulting tripping running unit (unit #1) at Tenughat end.	0	159


**COAL INDIA LIMITED
MARKETING & SALES**

Coal Bhawan, Premises No. 4 MAR, Plot no. AF-III,
Action Area 1A, New Town, Rajarhat, Kolkata - 700 156
E-mail: gmsnm.cil@coalindia.in
Phone: 033 - 2324 6617 | Fax: 033 - 2324 4229

October 05, 2018

Ref.: CIL/M&S/ Power/301

The General Manager/HOD (M&S)
ECL, BCCL, CCL, MCL.

Dear Sir,

A meeting was conveyed by Eastern Regional Power Committee (ERPC) with different stake holders consisting of representatives of different power plants of NTPC, DVC, IPPs, Railways, CIL and its subsidiary companies etc. on 04.10.2018 for enhancement of supply of coal to power plants during the festival season of October 2018. It was observed that number of power plants are having the stock of less than 3 three days and require a special contingent plan for the dispatch of coal to them to sustain the enhanced requirement during the festive month.

The requirement of the plants was discussed in details and in light of the previous meeting taken by Govt. of West Bengal during last fortnight, the following plan of rake dispatch of coal from different subsidiaries were formulated which is to be adhere during the month:

Power House	MGR/Road (In Tonne)	ECL	BCCL	No of Rakes		Total	Remarks
				CCL	MCL		
Farakka	ECL:16000	4.5	0.5			5	
Kahalgaoon	ECL:22000	4		2		4	
KANTI Muzfr		0.5			10	2.5	
Talcher Kaniha	MCL:12000					10	
WBPDC		7	4	1	4	16	8 rakes from ECL btw 10 th to 18 th Oct. (including supply under Auction)
DPL		0.5	0.75		0.5	1.75	
CESC		1	0.25			1.25	
HALDIA					2	2	Requested for resumption of supply from Sardega siding
TVNL	CCL:3000			1		1	
MPL	CCL:3000 BCCL:4500			0.75		0.75	
CTPS	CCL:6000		0.25			0.25	
BTPS	CCL:5000			1		1	
Koderma				2		2	
DSTPS		1	1.5		1	3.5	To divert the coal Of Koderma to DSTPS from BCCL
Mejia		1	5		1	7	To supply under B/L on best effort basis
Raghunathpur	Through Road from BCCL & CCL		0.5			0.5	

It is requested that coal supply may be done accordingly so that no power plant come under stress during festive period.

Yours faithfully,

General Manager (M&S)

CC : Director (Marketing), CIL
GM (Operations/M&S), CIL
HoD (M&S), New Delhi

BIHAR STATE POWER TRANSMISSION COMPANY LTD., PATNA

A subsidiary company of Bihar State Power (Holding) Company Ltd., Patna

CIN – U40102BR2012SGC018889

[SAVE ENERGY FOR BENEFIT OF SELF AND NATION]

Head Office, Vidyut Bhawan, Bailey Road, Patna – 800021



Letter No171...../

Dated 10/09/2018

From

G. K. Choubey;
Chief Engineer (System Operation)
BSPTCL, Patna

To

Sri Surojit Banerjee;
DGM (Operation);
ERLDC

Subject:- Synchronisation of 132 kV Purnea (PG) - Kishanganj (old) – Baisi – Dalkola (WB) transmission line.

Sir,

Presently BSPTCL GSS Baisi (2X20) MVA is drawing 4 MW radial power from 220/132/33 kV Dalkola station of West Bengal.

(2X160+2X50) MVA, 220/132/33 kV Kishanganj (new) is the source of power for BSPTCL & have four 132 kV circuits feed power to 132/33 kV Forbesganj GSS – two directly & two via 132/33 kV Kishanganj (old). Finally from 132/33 kV Forbesganj GSS power supply to 132/33 kV Kataiya GSS by three 132 KV circuits (SLD of this area enclosed).

Besides other loads, GSS Kataiya also feed power (max up to 132 MW) to Duhabi by 132 kV Kataiya - Duhabi (S/C) (ACCR conductor). Nepal also get power from GSS Kataya by 132 kV Kataya – Kusaha (S/C) (ACSR Panther conductor) – loading max. upto 80 MW. This power is drawn from GSS Supoul through 132 kV TB of Kataya GSS.

Presently out of the two circuits of 132 KV Kishanganj (new) - Kishanganj (old), one circuit feed power only to Kishanganj (old) & other circuit goes bypassing GSS kishanganj by ERS arrangement. Installed near Kishanganj (old) GSS. Due to this only three 132 kV circuit is left for Forbesganj. This reduces availability of power for Nepal. Power flow scenario from Kishanganj (new) is listed below:-

SI No	Name of GSS	Peak Load (in MW)	Remarks
1	Kishanganj (old)	46	*
2	Forbisganj	55	
3	Baisi	4	*
4	Kataiya	27	
5	Kishnaganj (New)	11	33 kV load.

6	Nepal (Duhabi +Rajbiraj)	(120+12)=132	Duhabi on 132 kV & Rajbiraj on 33 kV.
7	Araria	11	
8	Barsoi	28	*
	Total	314	Out of the 314 MW, except *89 MW power rest goes to Farbisganj.

So (314-89*) i.e. 225 MW power flow through three 132 kV circuits – more than its capacity. It leads to load shedding in BSPTCL GSS for allowing full load to Nepal. Support from 132 kV Purnea – Triveniganj – Farbisganj at GSS Farbisganj remain very less (10/15 MW).

132 kV Purnea (PG) – Kishanganj (old) line is kept open as power received on very low voltage & on synchronising with Kishanganj (new) power flows towards Purnea (PG) side leading to reducing power availability at Kishanganj (old).

If power is drawn at Kishanganj (old) from 132 kV Purnea (PG) - Kishanganj (old) (S/C) line & this line is synchronised with 132 KV Dalkola (WB) – Baisi - Kishanganj (old) line then, one circuit of 132 kV Kishanganj (new) - Kishanganj (old) will be free, resulting optimum power supply to Nepal as well as BSPTCL GSS (Forbesganj, Kataiya).

Load flow study result in PSS@E on synchronising 132 kV Dalkola – Baisi – Kishanganj (old) with Purnea (PG) is detailed below (study result enclosed):-

SI No	Line	Power flow (in MW)
1	132 kV Dalkola-Kishanganj transmission line	16
2	132 kV Purnea (PG)-Kishanganj transmission line	35

The study reveals that on synchronising 132 kV Purnea (PG) – Kishanganj (old) – Baisi - Dalkola transmission line, 15-16 MW power will be fed to BSPTCL system from Baisi through 132 kV Dalkola (WB) - Baisi transmission line & 35 MW power will be fed to Kishanganj (old) through 132 kV Purnea (PG) - Kishanganj transmission line. This power is less than the power (25-30 MW) agreed by WBSPTCL in last meeting. By this arrangement voltage at Kishanganj remains 129 kV & besides 132 kV Purnea (PG) – Kishanganj (old) also utilised. .

WBSPTCL is requested to allow the above synchronisation.


Encl:- As mentioned above.

G. K. Choubey
10.9.2018
(G. K. Choubey)
Chief Engineer
(System Operation)

CC:- Member Secretary, ERPC

For inclusion in 149th OCC meeting as an agenda item.

SYNCHRONISATION OF 132 KV PURNEA(PG) - KISHANGANJ (OLD) - BAISI - DALKOLA(WB) TRANSMISSION LINE



A. West Bengal

SI No	Date & Time	West Bengal O/D (MW)	Frequency (Hz)	ADMS Optd (Y/N)	Relief (MW)
1	15-09-2018 22:08	294	49.6996		
2	15-09-2018 22:09	303	49.6947		
3	15-09-2018 22:10	294	49.6947		
4	15-09-2018 22:11	293	49.6751		
5	15-09-2018 22:12	286	49.6751		
6	15-09-2018 22:13	278	49.6996		
7	22-09-2018 18:23	189	49.6947		
8	22-09-2018 18:24	201	49.6996		
9	22-09-2018 18:25	211	49.6947		
10	28-09-2018 18:18	162	49.6947		
11	28-09-2018 18:19	167	49.6800		
12	28-09-2018 18:20	175	49.6556		
13	28-09-2018 18:21	165	49.6800		
14	28-09-2018 18:22	162	49.6849		
15	28-09-2018 18:23	190	49.6849		
16	28-09-2018 18:24	204	49.6947		
17	28-09-2018 18:38	267	49.6996		
18	28-09-2018 18:40	206	49.6752		
19	28-09-2018 18:41	190	49.6947		
20	28-09-2018 18:42	170	49.6458		
21	28-09-2018 18:43	179	49.6458		
22	28-09-2018 18:44	196	49.6556		
23	28-09-2018 18:45	199	49.6849		
24	29-09-2018 18:28	173	49.6947		
25	29-09-2018 18:29	209	49.6947		

B. DVC

SI No	Date & Time	DVC O/D (MW)	Frequency (Hz)	ADMS Optd (Y/N)	Relief (MW)
1	11-09-2018 19:15	352	49.6702		
2	11-09-2018 19:16	320	49.6702		
3	11-09-2018 19:17	352	49.6849		
4	11-09-2018 19:18	347	49.6702		
5	11-09-2018 19:19	338	49.6702		
6	11-09-2018 19:20	377	49.6507		
7	11-09-2018 19:21	346	49.6702		
8	11-09-2018 19:22	349	49.6800		
9	14-09-2018 18:41	282	49.6849		
10	14-09-2018 18:42	269	49.6849		
11	14-09-2018 18:44	233	49.6996		
12	15-09-2018 18:58	386	49.6800		
13	15-09-2018 18:59	367	49.6849		
14	16-09-2018 00:16	206	49.6947		

15	16-09-2018 00:17	242	49.6947		
16	16-09-2018 00:18	293	49.6702		
17	16-09-2018 00:19	220	49.6996		
18	16-09-2018 00:20	217	49.6751		
19	16-09-2018 00:21	208	49.6996		
20	28-09-2018 18:18	298	49.6947		
21	28-09-2018 18:19	214	49.6800		
22	28-09-2018 18:20	234	49.6556		
23	28-09-2018 18:21	278	49.6800		
24	28-09-2018 18:22	252	49.6849		
25	28-09-2018 18:23	283	49.6849		
26	28-09-2018 18:24	239	49.6947		
27	28-09-2018 18:38	171	49.6996		
28	28-09-2018 18:40	198	49.6752		
29	28-09-2018 18:41	229	49.6947		
30	28-09-2018 18:42	226	49.6458		
31	28-09-2018 18:43	215	49.6458		
32	28-09-2018 18:44	221	49.6556		
33	28-09-2018 18:45	216	49.6849		
34	29-09-2018 18:28	339	49.6947		
35	29-09-2018 18:29	308	49.6947		
36	29-09-2018 18:30	345	49.6996		
37	29-09-2018 18:31	374	49.6751		
38	29-09-2018 18:32	305	49.6800		
39	29-09-2018 18:35	401	49.6947		
40	29-09-2018 18:36	403	49.6751		
41	29-09-2018 18:37	337	49.6360		
42	29-09-2018 18:38	327	49.6214		
43	29-09-2018 18:39	281	49.6214		
44	29-09-2018 18:40	332	49.6214		
45	29-09-2018 18:41	350	49.6312		
46	29-09-2018 18:42	322	49.6556		

C. Orisaa

SI No	Date and Time	Orissa O/D (MW)	Frequency (Hz)
1	24-09-2018 18:15	509	49.67999268
2	24-09-2018 18:17	430	49.67999268
3	24-09-2018 18:18	388	49.64580536
4	24-09-2018 18:19	419	49.60673523
5	24-09-2018 18:20	380	49.59696579
6	24-09-2018 18:21	248	49.61161804
7	24-09-2018 18:22	305	49.57743073
8	24-09-2018 18:23	355	49.57743073
9	24-09-2018 18:24	363	49.58231354
10	24-09-2018 18:25	352	49.60185242
11	24-09-2018 18:26	324	49.60185242
12	24-09-2018 18:27	289	49.60673523
13	24-09-2018 18:42	202	49.69470215

14	24-09-2018 18:43	205	49.67510986
15	24-09-2018 18:44	278	49.66045761
16	24-09-2018 18:45	304	49.63115311
17	24-09-2018 18:46	379	49.59696579
18	24-09-2018 18:47	327	49.58720016
19	24-09-2018 18:48	374	49.58720016
20	24-09-2018 18:49	439	49.59696579
21	24-09-2018 18:50	315	49.63603973
22	24-09-2018 18:51	342	49.67510986
23	24-09-2018 19:12	349	49.69955444
24	24-09-2018 19:13	345	49.67512131
25	24-09-2018 19:14	287	49.68491364
26	24-09-2018 19:15	287	49.6604805
27	24-09-2018 19:16	319	49.67512131
28	24-09-2018 19:17	234	49.67512131
29	24-09-2018 19:18	206	49.69955444
30	28-09-2018 18:18	418	49.69467163
31	28-09-2018 18:19	453	49.68003082
32	28-09-2018 18:20	446	49.65558624
33	28-09-2018 18:21	546	49.68003082
34	28-09-2018 18:22	459	49.68490982
35	28-09-2018 18:23	338	49.68490982
36	28-09-2018 18:24	205	49.69467163
37	28-09-2018 18:45	161	49.68490982
38	29-09-2018 18:28	396	49.6946907
39	29-09-2018 18:29	357	49.6946907
40	29-09-2018 18:30	349	49.69957352
41	29-09-2018 18:31	288	49.67512512
42	29-09-2018 18:32	374	49.68000793
43	29-09-2018 18:35	443	49.6946907
44	29-09-2018 18:36	448	49.67512512
45	29-09-2018 18:37	411	49.63603973
46	29-09-2018 18:38	377	49.62139893
47	29-09-2018 18:39	287	49.62139893
48	29-09-2018 18:40	286	49.62139893
49	29-09-2018 18:41	296	49.63116074
50	29-09-2018 18:42	304	49.65560532

D. Bihar

SI No	Date & Time	Bihar O/D (MW)	Frequency (Hz)
1	07-09-2018 18:49	208	49.69469452
2	07-09-2018 18:50	226	49.67025757
3	07-09-2018 18:51	255	49.67025757
4	07-09-2018 18:52	265	49.67025757
5	07-09-2018 18:53	291	49.6604805
6	07-09-2018 18:54	301	49.65559387
7	07-09-2018 18:55	291	49.68492126
8	24-09-2018 18:45	163	49.63115311

9	24-09-2018 18:46	166	49.59696579
10	24-09-2018 18:47	168	49.58720016
11	28-09-2018 18:22	159	49.68490982
12	28-09-2018 18:23	170	49.68490982
13	28-09-2018 18:24	185	49.69467163

E. Jharkhand

SI No	Date & Time	Jharkhand O/D (MW)	Frequency (Hz)
1	24-09-2018 18:44	160	49.66045761
2	24-09-2018 18:45	168	49.63115311
3	24-09-2018 18:47	152	49.58720016

SLDC may kindly update on the ADMS Operation and implementation.

**Anticipated Power Supply Position for the month of
Nov-18**

SL.NO	PARTICULARS	PEAK DEMAND MW	ENERGY MU
1	BIHAR		
	i) NET MAX DEMAND	4500	2592
	ii) NET POWER AVAILABILITY- Own Source (including bilateral)	371	239
	- Central Sector	3044	1721
	iii) SURPLUS(+)/DEFICIT(-)	-1086	-631
2	JHARKHAND		
	i) NET MAX DEMAND	1280	780
	ii) NET POWER AVAILABILITY- Own Source (including bilateral)	341	161
	- Central Sector	806	427
	iii) SURPLUS(+)/DEFICIT(-)	-133	-192
3	DVC		
	i) NET MAX DEMAND (OWN)	2800	1745
	ii) NET POWER AVAILABILITY- Own Source	5146	2778
	- Central Sector	323	176
	Long term Bi-lateral (Export)	1426	1027
	iii) SURPLUS(+)/DEFICIT(-)	1243	182
4	ODISHA		
	i) NET MAX DEMAND	4100	2268
	ii) NET POWER AVAILABILITY- Own Source	2961	1450
	- Central Sector	1143	624
	iii) SURPLUS(+)/DEFICIT(-)	4	-194
5	WEST BENGAL		
5.1	WBSEDCL		
	i) NET MAX DEMAND (OWN)	4950	2577
	ii) CESC's DRAWAL	0	0
	iii) TOTAL WBSEDCL's DEMAND	4950	2577
	iv) NET POWER AVAILABILITY- Own Source	3255	1999
	- Import from DPL	216	0
	- Central Sector	1906	1038
	v) SURPLUS(+)/DEFICIT(-)	427	460
	vi) EXPORT (TO B'DESH & SIKKIM)	10	7
5.2	DPL		
	i) NET MAX DEMAND	249	155
	ii) NET POWER AVAILABILITY	465	187
	iii) SURPLUS(+)/DEFICIT(-)	216	32
5.3	CESC		
	i) NET MAX DEMAND	1750	742
	ii) NET POWER AVAILABILITY - OWN SOURCE	670	394
	FROM HEL	540	337
	FROM CPL/PCBL	0	0
	Import Requirement	540	11
	iii) TOTAL AVAILABILITY	1750	742
	iv) SURPLUS(+)/DEFICIT(-)	0	0
6	WEST BENGAL (WBSEDCL+DPL+CESC) (excluding DVC's supply to WBSEDCL's command area)		
	i) NET MAX DEMAND	6949	3474
	ii) NET POWER AVAILABILITY- Own Source	4390	2579
	- Central Sector+Others	2986	1375
	iii) SURPLUS(+)/DEFICIT(-)	427	480
7	SIKKIM		
	i) NET MAX DEMAND	85	37
	ii) NET POWER AVAILABILITY- Own Source	1	0
	- Central Sector+Others	151	63
	iii) SURPLUS(+)/DEFICIT(-)	67	26
8	EASTERN REGION At 1.03 AS DIVERSITY FACTOR		
	i) NET MAX DEMAND	19140	10896
	Long term Bi-lateral by DVC	1426	1027
	EXPORT BY WBSEDCL	10	7
	ii) NET TOTAL POWER AVAILABILITY OF ER (INCLUDING C/S ALLOCATION)	21662	11594
	iii) PEAK SURPLUS(+)/DEFICIT(-) OF ER (ii)-(i)	1086	-336

Details of stations/Units required to operate under RGMO/FGMO as per IEGC							Whether operating under RGMO	indicate in case of status is not available	
Name of State	Type	Name of Utility	Sector (CS/SS/Private)	Name of Station	Name of Stage/ Unit	Installed capacity (MW)			
JHARKHAND	Thermal	TVNL	SS	Tenughat	1	210	No	Difficulties in implementing RGMO & exemption not	
			SS		2	210	No		
	Hydro	JSEB	SS	Subarnrekha	1	65	Yes		
			SS		2	65	Yes		
WEST BENGAL	Thermal	WBPDCCL	SS	Bandel TPS	1	82.5	No	Unit#6 could not be implemented because of some technical problem	
			SS		2	82.5	No		
			SS		3	82.5	No		
			SS		4	82.5	No		
			SS		5	210	No		
			SS	6	250	No			
			SS	7	250	No			
			SS	Kolaghat	1	210	No		Nil
			SS		2	210	No		Nil
			SS		3	210	No		Nil
			SS		4	210	No		Nil
			SS		5	210	No		Nil
			SS		6	210	No		Nil
			SS	Bakreshwar	1	210	Yes		
			SS		2	210	Yes		
			SS		3	210	Yes		
			SS		4	210	Yes		
			SS		5	210	Yes		
			SS	Sagardighi	1	300	No		Without OEM support it is not possible to put in FGMO/RGMO. At present OEM support is not
			SS		2	300	No		
	Hydro	PPSP	SS	PPSP	1	225	Yes	In 134th OCC WBPDCCL informed that the units are in RGMO/FGMO mode	
			SS		2	225	Yes		
			SS		3	225	Yes		
			SS		4	225	Yes		
		Thermal	CESC	SS	Budge-Budge	1	250		Yes
				SS		2	250		Yes
				SS		3	250		Yes
		Thermal	DPL	SS	DPL	1	300		Yes
				SS		2	300		Yes
				SS		7	300		Yes
Orissa	Thermal	OPGC	SS	IB TPS	1	210	No	Not adequate response in RGMO	
			SS		2	210	No		
	Hydro	OHPC	SS	Burla	1	49.5	No		
			SS		2	49.5	No		
			SS		3	32	No		
			SS		4	32	No		
			SS		5	37.5	No		
			SS		6	37.5	No		
			SS		7	37.5	No		
			SS	Balimela	1	60	No		
			SS		2	60	No		
			SS		3	60	No		
			SS		4	60	No		
			SS		5	60	No		
			SS		6	60	No		
			SS		7	75	No		
			SS		8	75	No		
			SS	Rengali	1	50	No		
			SS		2	50	No		
			SS		3	50	No		
			SS		4	50	No		
			SS		5	50	No		
			SS	Upper Kolab	1	80	No		
			SS		2	80	No		
			SS		3	80	No		
			SS		4	80	No		
			SS	Indravati	1	150	No		
			SS		2	150	No		

			SS	IIIravau	3	150	No				
			SS		4	150	No				
			64								
Central Sector	Thermal	DVC	CS	Bokaro-A	1	500	Yes				
			CS	Bokaro-B	3	210	No	Not possible due to non availability of Electro hydraulic governing. The units will be decommissioned shortly.			
			CS	CTPS	3	130	No	Not possible due to non availability of Electro hydraulic governing. The units will be decommissioned shortly.			
			CS		7	250	Yes				
			CS		8	250	Yes				
			CS	DTPS	4	210	No	Not possible due to non availability of Electro hydraulic governing. The units will be decommissioned shortly.			
			CS	Mejia	1	210	No	Not possible due to non availability of Electro			
			CS		2	210	No	availability of Electro			
			CS		3	210	No	Action has been initiated to put in RGMO, but testing is not yet completed.			
			CS		4	210	Yes				
			CS		5	250	Yes				
			CS		6	250	Yes				
			CS	Mejia - B	7	500	Yes				
			CS		8	500	Yes				
			CS	DSTPS	1	500	Yes				
			CS		2	500	Yes				
			CS	KODERMA	1	500	Yes				
			CS		2	500	Yes				
			CS	RTPS	1	600	Yes				
			CS		2	600	Yes				
			Hydro			CS	Panchet	1	40	No	RGMO mode of operation would not be possible for
						CS		2	40	No	
			Thermal	NTPC		CS	Farakka STPP-I	1	200	Yes	
						CS		2	200	Yes	
						CS		3	200	Yes	
						CS	Farakka STPP-II	1	500	Yes	
						CS		2	500	Yes	
						CS	Farakka-U#6		500	Yes	Kept in RGMO mode from April, 2014
CS	Kahalgoan STPP	1				210	Yes				
CS		2				210	Yes				
CS		3				210	Yes				
CS		4				210	Yes				
CS		5				500	Yes				
CS		6				500	Yes				
CS		7				500	Yes				
CS	Talcher STPP Stg-I	1				500	Yes				
CS		2				500	Yes				
CS	Barh	5				660	Yes				
CS		6				660	Yes				
Hydro	NHPC					CS	Teesta HEP	1	170	Yes	
			CS	2	170	Yes					
			CS	3	170	Yes					
			42								
IPP	Thermal	IPP	PS	Maithon RB TPP	1	525	Yes				
			PS		2	525	Yes				
			PS	Sterlite	1	600	Yes				
			PS		2	600	Yes				
			PS		3	600	Yes				
			PS		4	600	Yes				
			PS	Adhunik Power	1	270	Yes				
			PS		2	270	Yes				
			IPP			PS	JLHEP	1	48	No	(RoR project with 3 hours pondage)
						PS		2	48	No	
PS	Chujachen HEP	1				49.5	No	(RoR project with 3 hours pondage)			
PS		2				49.5	No				
PS		1				200	No	could be put in RGMO			

Hydro	IPP	PS	Teesta Urja	2	200	No	could be put in RGMO mode but because of transmission evacuation constraint RGMO/FGMO is disabled
		PS		3	200	No	
		PS		4	200	No	
		PS		5	200	No	
		PS		6	200	No	
		PS		1	48	No	
		PS	Dikchu	2	48	No	(RoR project with 3 hours pondage)

Quarterly Preparedness Monitoring -AGENDA

(Status as on :
)

S.No.	State	Sector (G/T/D)	Utilities	Status of CISO Nomination	Critical Infra Identified	Crisis managem ent Plan Prepared	Status of CS mock drill	Status of Training/ Workshops organized/ participated by utility	Action taken on CERT- In/NCIIPC Advisories
1	Tamilnadu	T	TANGEDCO	Yes/No	Yes/No	Yes/No	Done on —		

Annexure – E.4

AVAILABILITY STATUS OF EVENT LOGGER, DISTURBANCE RECORDER & GPS

Sl. NO	Substation	Protection & Control System						Remarks
		Availability			Time Synchronization			
		EL	DR	GPS	Relay	DR	EL	
1	Subhasgram	Yes	Yes	Yes	Yes	Yes	Yes	
2	Maithon	Yes	Yes	Yes	Yes	Yes	Yes	
3	Durgapur	Yes	Yes	Yes	Yes	Yes	Yes	
4	Malda	Yes	Yes	Yes	Yes	Yes	Yes	
5	Dalkhola	Yes	Yes	Yes	Yes	Yes	Yes	
6	Siliguri	Yes	Yes	Yes	Yes	Yes	Yes	
7	Binaguri	Yes	Yes	Yes	Yes	Yes	Yes	
8	Birpara	Yes	Yes	Yes	Yes	Yes	Yes	
9	Gangtok	Yes	Yes	Yes	Yes	Yes	Yes	
10	Baripada	Yes	Yes	Yes	Yes	Yes	Yes	
11	Rengali	Yes	Yes	Yes	Yes	Yes	No	New EL would be implemented in BCU under NTAMC project by March'2015
12	Indravati (PGCIL)	Yes	Yes	Yes	Yes	Yes	No	EL is old one(model-PERM 200), provision for time synchronisation is not available. New EL would be implemented in BCU under NTAMC project by March'2015
13	Jeypore	Yes	Yes	Yes	Yes	Yes	Yes	EL is old and not working satisfactorily. New EL would be implemented in BCU under NTAMC project by March, 2015
14	Talcher	Yes	Yes	Yes	Yes	Yes	Yes	
15	Rourkela	Yes	Yes	Yes	Yes	Yes	Yes	
16	Bolangir	Yes	Yes	Yes	Yes	Yes	Yes	
17	Patna	Yes	Yes	Yes	Yes	Yes	Yes	
18	Ranchi	Yes	Yes	Yes	Yes	Yes	Yes	
19	Muzaffarpur	Yes	Yes	Yes	Yes	Yes	Yes	
20	Jamshedpur	Yes	Yes	Yes	Yes	Yes	Yes	
21	New Purnea	Yes	Yes	Yes	Yes	Yes	Yes	
22	Gaya	Yes	Yes	Yes	Yes	Yes	Yes	
23	Banka	Yes	Yes	Yes	Yes	Yes	Yes	
24	Biharsariif	Yes	Yes	Yes	Yes	Yes	Yes	
25	Barh	Yes	Yes	Yes	Yes	Yes	Yes	
26	Sagardighi	No	Yes	Yes	Yes	Yes	No	EL is under process of restoration with help from OEM, China
27	Kahalgaon	Yes	Yes	Yes	Yes	Yes	Yes	
28	Farakka	Yes	Yes	No	No	No	No	Time synchronization available for Farakka-Kahalgaon line-III & IV. The same will be implemented in rest of the lines by December, 2014.
29	Meramundali	Defunct	Yes	Yes	Yes	Yes	Yes	
30	Tisco	Yes	Yes	Yes	Yes	Yes	Yes	
31	Bidhannagar	No	Yes	Yes	No	No	No	Using DR & EL available in Numerical

Eastern Regional Power Committee

The status of ERS towers in Eastern Region as updated in OCC meetings is given below:

- 1) ERS towers available in Powergrid S/s is as given below:

Sl. No.	Name of S/S	No. of ERS towers available
1	Durgapur, ER-II	1 Set (8 towers)
2	Rourkela, ER-II	3 towers incomplete shape
3	Jamshedpur, ER-I	15 towers (10 nos Tension tower and 5 nos suspension tower)

- 2) The present status of ERS towers in OPTCL system is as follows:

Sl. No.	Name of S/S	No. of ERS towers available
1	Mancheswar	2 nos, 400 kV ERS towers
2	Mancheswar, Chatrapur & Budhipadar	42 nos, 220 kV ERS towers

- 12 nos. of new 400 kV ERS towers have been received.
- Another, 16 nos of 400 kV towers accompanied with 6 sets of T&P are required which is under process

- 3) The present status of ERS towers in WBSETCL system is as follows:

Sl. No.	Name of S/S	No. of ERS towers available
1	Gokarna	2 sets
2	Arambag	2 sets

- 4) The present status of ERS towers in BSPTCL system is as follows:

Sl. No.	Type	Quantity	Remarks
1	Tension ERS Tower	12	New
2	Suspension ERS Tower	20	New
3	Old ERS Tower	10	1 no. is defective
Total		42	

- As informed in ERS meeting held on 10-11-2014 taken by Member (Power System), CEA; 2 sets (12 tension & 20 suspension) of ERS towers had been procured and currently available in BSPTCL system (as mentioned in above table with remarks "New").
- Same ERS tower is used in both 220 kV and 132 kV circuits.

- 5) In 25th ERPC meeting held on 21.09.2014, E R P C concurred to the proposal of procurement of four sets of ERS and it was also informed that, the proposed four sets of ERS will be kept at Sikkim, Siliguri, Ranchi and Gaya and will be used by all constituents of ER during emergencies.

Powergrid informed that four sets of ERS for Eastern Region will be procured.

- 5) DVC informed that they are in process of procuring two (2) sets of 400 kV ERS towers.

Checklist for Submission of new transmission elements for updation in Protection Database

**NAME OF ORGANISATION:
FOR THE MONTH OF:**

SUBSTATION DETAIL:

SI No	DETAILS OF ELEMENTS	DATA TYPE	Status of Submission (Y/N)	Remarks
1	TRANSMISSION LINE	LINE LENGTH, CONDUCTOR TYPE, VOLTAGE GRADE		
2	POWER TRANSFORMER	NAMEPLATE DETAILS		
3	GENERATOR	TECHNICAL PARAMETERS		
4	CURRENT TRANSFORMER	NAMEPLATE DETAILS		
5	VOLTAGE TRANSFORMER	NAMEPLATE DETAILS		
6	RELAY DATA	MAKE, MODEL and FEEDER NAME		
7	RELAY SETTINGS	NUMERICAL RELAYS: CSV or XML file extracted from Relay ELECTROMECHANICAL RELAYS: SNAPSHOT of RELAY		
8	REACTOR	NAMEPLATE DETAILS		
9	CAPACITOR	NAMEPLATE DETAILS		
9	UPDATED SLD			

SIGNATURE:
NAME OF REPRESENTATIVE:
DESIGNATION:
CONTACT:
E-MAIL ID: