





# Fast Response Ancillary Services

ERLDC, POSOCO

# Load Following and Regulation



# Frequency Profile – Different Time Scales



# Utilization of existing hydro resources



- At the 13th Technical Committee Meeting of FOR POSOCO presented on the topic “Optimization of Hydro resources”. Key highlights:
  - All-India Hydro installed capacity ~45 GW, of which about 12 GW are ISGS projects and balance are within the States
  - With optimum utilization, hydro can be significantly used for peaking demand
  - Can enhance PLF of thermal plants by ensuring hydro plants are not run during off-peak hours
  - States are also required to adopt aforementioned CERC principles in the state-level hydro tariff regulations

# Endorsing the role of hydro plants



- Hydro generating stations are capable of providing a fast ramping capability
- Can be gainfully utilized for **frequency regulation services** to meet the system requirements
- The total energy despatched for hydro under FRAS is to be made zero and hence, no energy charges shall be payable
- A presentation on FRAS from Hydro Generators was made at the 63rd Meeting of FOR
- The Forum endorsed the recommendations of the Technical Committee for pilot studies on FRAS for Hydro, along with pilot studies on 5-Minutes Scheduling, Metering, Accounting and Settlement


# Role of Hydro in System Balancing in India



Inertia  
Decreasing,  
175 GW RE,  
Need to have  
more hydro  
machines

Mandated as  
per Grid Code  
for all; Need for  
faster response  
from Hydro

AGC Pilot  
Project  
Operational;  
Hydro stations  
may be put on  
AGC on pilot  
basis



# Present Issues in Hydro Scheduling under RRAS



Need for fast regulation service and ramping support

Hydro : Energy limited Resource  
Thermal: Ramp limited Resource

Other than power generation commitments

Marginal Cost is zero

**And hence, FRAS Proposal...**



## ISGS Hydro Plants in different regions - their capacity and type

SI No	Name	Utility	Region	Type (S/R/P)	I/C (MW)	
1	Teesta-V	NHPC	ER	P	510	
2	Rangit			P	60	
3	Bairasiul		NR	P	180	
4	Chamera-II			P	300	
5	Chamera-I			P	540	
6	Uri Stage – I			R	480	
7	Salal			R	690	
8	Dhauliganga			P	280	
9	Tanakpur			R	94.2	
10	Chamera-III			P	231	
11	Parbati III			P	520	
12	Sewa-II			P	120	
13	Dulhasti		P	390		
14	Uri Stage – II		R	240		
15	Naptha Jhakri	SJVN	NR	P	1500	
16	Rampur			P	412	
17	Tehri	THDC		S	1000	
18	Koteshwar			S	400	
19	Koldam	NTPC		P	800	
20	Kopili	NEEPCO		NER	S	200
21	Kopili-II				S	25
22	Khandong				S	50
23	Ranganadi				P	405
24	Loktak	NHPC		S	105	
25	Pong	BBMB	NR	S	396	
26	Dehar			R	990	
27	Bhakra complex			S	1379	
			<b>Total</b>		<b>12297</b>	

Type	MW
Storage (S)	3555
RoR with Pondage (P)	6248
RoR (R )	2494
<b>Total</b>	<b>12297</b>



# Proposal - Fast Response Ancillary Service (1)



- Stack of hydropower stations
  - Based on MW regulation possible by plant, balance energy etc.
  - Factoring congestion
- Despatch Instructions from Nodal Agency
  - FRAS Regulation Up (maximum available balance energy/reserve/MW)
  - FRAS Regulation Down (minimum available balance energy/reserve/MW)
  - Net energy squared off for each hydro station same day
    - [Net energy  $E_{net} = \sum E_{up} - \sum E_{down}$  (in MWh) should be zero over the day]
  - Combination of FRAS Regulation Up and Down despatch instructions
- Only for short durations ( $\neq$  5-6 dispatches in a day)
- Reservoir based stations priority over pondage based stations

# Proposal - Fast Response Ancillary Service (2)





- Scheduling
  - 5 - minute FRAS despatch schedules by Nodal Agency
    - Aggregated (3 five minute blocks)
    - Compatibility with the existing scheduling philosophy
    - Settlement and deviation accounting purposes
  - Regional Virtual Ancillary Entity – Hydro or VAE-H
    - Counterparty to FRAS despatch instructions
- Accounting and Settlement
  - No fixed charge or variable charges to be paid
  - Incentive on mileage basis
    - $E_m = \sum | E_{up} | + \sum | E_{down} |$
    - To start with, 10p/kWh for both regulation UP & DOWN services

# Triggering Criteria



- Hour boundary frequency changes
- Sudden changes in demand
- Ramp management
- Grid contingency
- RE Variation




<49.7	<49.90	<49.97	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	49.90-50.05	49.7-50.2	49.97-50.03	50.05-50.1	>50	>50.03	>50.05	>50.2	
0.00	4.61	29.05	0.21	4.40	44.47	48.37	2.56	79.22	100.00	43.31	13.65	50.86	27.64	16.17	0.00	
Average Frequency :				49.997	Frequency Variation Index :		0.032	Standard Deviation :		0.056	Mileage		45.61			

# Scheduling and Settlement



- FOR Technical Committee Sub-Group
  - Introduction of Five Minute Scheduling, Metering, Accounting and Settlement in Indian Electricity Market
  - Pilot Project Envisaged - in Parallel with 15-Minute Framework
- Three Regions (NR, ER and NER) – Central Sector Hydro Stations
  - 05 Minute Scheduling, 05 Minute Metering, 05 Minute Deviation Settlement



# Data Exchanges



- **NLDC/RLDCs with FRAS Providers**

- Web based Automated Solution
- Technical Details for FRAS Despatch
- Telephonic/SMS/E-mail

- **FRAS Providers and RPCs**

- Ancillary Services information
- Accounting & Settlement

- **Information on NLDC Website**

- FRAS Instruction Summary
- Monthly report
- FRAS Providers details


NLDC RRAS Management

Available URS:

Regions: ER  NER  NR  SR  WR

Bid Areas: A2  AR  ER-Area  NR-Area  S1  S2  SR-Area  W1  W2  W3  WR-Area

Generator	Ins. Cap.	Region	Var Cost	15:30	15:45	16:00	16:15	16:30	16:45	17:00	17:15	17:30	17:45	18:00	18:15	18:30	18:45
SIPAT-I	1980	WR	122	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SIPAT-II	1000	WR	125	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SINGRAULI	2000	NR	126	0	0	0	0	0	0	1.88	1.88	1.88	1.88	1.88	1.88	1.88	1.88
RIHAND3	1000	NR	127	45	45	79.87	79.87	79.87	79.87	0.03	0.03	0.03	80.94	80.94	80.94	80.94	80.94
RIHAND2	1000	NR	129	39	72.9	72.9	72.9	72.9	72.9	0.3	34.2	34.2	34.2	0.3	0.3	0.3	0.3
KSTPS-III	500	WR	129	0	0	0	0	0	0	0	0	0	0	0	0	0	0
KSTPS	2100	WR	131	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CGPL	4150	WR	135	224	224	224	224	224	224	224	224	224	224	224	224	224	224
RIHAND1	1000	NR	144	0	0	0	0	13.55	0	0	0	0	0	0	0	0	0
TALST2	2000	SR	146	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TSTPP-I	1000	ER	146	0	0	0	0	0	0	0	0	0	0	50	91.17	91.17	91.17
SASAN	3960	WR	153	76.5	76.5	76.5	76.5	76.5	76.5	0	0	0	0	0	0	0	0
VSTPS-III	1000	WR	153	0	0	0	0	0	0	0	0	0	0	0	0	0	0
VSTPS-V	500	WR	156	0	0	0	0	0	0	0	0	0	0	0	0	0	0
VSTPS-IV	1000	WR	157	0	0	0	0	0	0	0	0	0	0	0	0	0	0
AGTTP	130	AR	158	0	0	0	0	0	0	0	0	0	0	0	0	0	0
VSTPS-II	1000	WR	162	0	0	0	0	0	0	0	0	0	0	0	0	0	0
VSTPS-I	1260	WR	166	0	0	0	0	0	0	0	0	0	0	0	0	0	0
AGBPP	291	AR	179	0	0	0	0	0	0	0	0	0	0	0	0	0	0
KHSTPP-II	1500	ER	199	91.71	91.71	91.71	91.71	91.71	91.71	121.27	233.27	345.54	450.28	450.28	450.28	450.28	375.2
VALLURTECI	1500	SR	203	0	0	0	0	0	0	0	0	0	0	0	0	0	0



# Discussion with Central Sector Hydro Generators


- Meeting held on 09th March, 2018 at NLDC, Delhi
- Participants
  - CEA, NHPC, SJVN, BBMB, THDC, NEEPCO, NTPC and POSOCO
- Deliberations held & broad consensus achieved
  - FRAS Implementation
  - Primary Response improvement through droop settings
  - 5-Minute scheduling, despatch and settlement on pilot basis
  - Other ancillary services – reactive power, black start
  - Need for fast communication of instructions
  - Mark up for regulation– to be decided by CERC

# Information Requirement of Hydro Units



- Installed capacity of unit =P
- Start time; standstill to synchronization of unit to grid (in minutes)
- Minimum load at which unit stably run after synchronization (MW) - P1
- Ramp rate (MW/min)
- Forbidden zone or high cavitation zone (From MW to MW) - P2 to P3
- Maximum loading possible on unit (continuous) P4 (Note; range from P to P4 should be normally available for primary response unless it is a case of overflowing hydro)
- Cumecs/MW for P1, P3, P and P4 generation level as well as cumecs from standstill to synchronization. Which value is used for declaring MWh capability?
- How many units can be started simultaneously or is it sequential operation? The constraints in this regard.

# Teesta-V HPS; Unit size 170 MW





# Honouring Constraints



- Drinking Water
- Irrigation
- Contractual Obligations with State Government
- Weather Phenomena, Monsoon etc.
- Legacy Control System
- Wildlife
- Water level and Head
- High Silt, flash floods, Cloud burst, Land slides
- Shortage of Skilled and Unskilled Manpower
- Acidic Corrosion and Erosion
- Special Occasions like Water Sport activities, Snan, Mela etc.
- Any other...



# A Small Step for Hydro....

# A Giant Leap for Indian Power System

