



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH

Date: 25.06.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 04.06.2018-10.06.2018**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

  
25/6/18

**MEMBER SECRETARY**

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 04/06/18 to 10/06/18**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4206496

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 04/06/18 to 10/06/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/L (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-3056.5	427910	0	0	427910
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2985	417900	0	0	417900
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-2081.7	291438	0	0	291438
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	25.8	-3612	-134.4	-18816	-22428
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-19.8	2772	-11.5	-1610	1162
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	12.7	-1778	-97.8	-13692	-15470
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1772.7	248178	0	0	248178
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1010.9	141526	-113.8	-15932	125594
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-363.1	50834	-88.5	-12390	38444
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-369.5	51730	0	0	51730
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-112.6	15764	-0.9	-126	15638
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	6.2	-868	-68.7	-9618	-10486
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	12.7	-1778	20.7	2898	1120
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2938	411320	0	0	411320
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-2888.6	404404	-0.1	-14	404390
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	666.4	-93296	0	0	-93296
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	663	-92820	0	0	-92820
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-423.1	59234	-77.2	-10808	48426
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1530.8	214312	0	0	214312
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8675A	0	0	-1.2	-168	-168
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8673A	0	0	-1.2	-168	-168
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3450.3	483042	0	0	483042
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	9.1	-1274	0	0	-1274
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-214.1	29974	0	0	29974
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-216.2	30268	0	0	30268
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	-31.8	4452	0	0	4452
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	-22	3080	0	0	3080
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	183.5	-25690	0	0	-25690
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	-196.3	27482	0	0	27482
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	-183.6	25704	0	0	25704
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	-200.2	28028	0	0	28028
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	-214.3	30002	0	0	30002
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	7.4	-1036	0	0	-1036
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	1694.2	-237188	0	0	-237188
	35	220 KV PATNA(PG) - KHAGAIL(BSPHCL)	NP5832A	-956.8	133952	0	0	133952
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1649.2	230888	0	0	230888
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-2162.7	302778	0	0	302778
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	-6.2	-868	-868
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	-18.9	-2646	-2646
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	-45.7	-6398	-6398
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	-19	-2660	-2660
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1509.2	211288	0	0	211288
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1336.9	187166	0	0	187166
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1536.3	-215082	0	0	-215082
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1253.2	-175448	0	0	-175448
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1907.5	267050	0	0	267050
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2127.7	297878	0	0	297878
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-I	ER1284A	701.1	-98154	0	0	-98154
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-II	ER1289A	690.3	-96642	0	0	-96642
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-I	ER1171A	2.2	-308	-222.8	-31192	-31500
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-II	ER1177A	4.8	-672	-226.6	-31724	-32396
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-I	ER1256A	-47	6580	-186.5	-26110	-19530
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-II	ER1258A	-48	6720	-181	-25340	-18620
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-I	ER1172A	-43.9	6146	-187.5	-26250	-43.9
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-II	ER1229A	-44.1	6174	-180.6	-25284	-44.1
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-823.7	115318	0	0	-823.7
	57	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-I	ER1279A	306.5	-42910	0	0	306.5
	58	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-II	ER1280A	452.9	-63406	0	0	452.9
	59	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-I	ER1375A	1159.5	-162330	0	0	1159.5
	60	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-II	ER1380A	1109.4	-155316	0	0	1109.4
	61	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-I	ER1277A	0	0	0	0	0
	62	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-II	ER1278A	0	0	0	0	0
		<b>TOTAL</b>			<b>3701684</b>		<b>-258916</b>	<b>3442768</b>
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-6570.6	919884	0	0	919884
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-237.4	33236	0	0	33236
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	653.6	-91504	0	0	-91504
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1432.8	-200592	0	0	-200592
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1617.2	226408	0	0	226408
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-286.2	40068	0	0	40068
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-366	51240	0	0	51240
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	378.2	-52948	0	0	-52948
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	389.7	-54558	0	0	-54558
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	0	0	0	0	0
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	0	0	0	0	0
		<b>TOTAL</b>		<b>871234</b>		<b>0</b>	<b>871234</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) - I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) - II	NP6458A	-2868.6	401604	0	0	401604
	3	220 KV MAITHON (PG) - DHANBAD (DVC) - I	NP6529A	21.4	-2996	0	0	-2996
	4	220 KV MAITHON (PG) - DHANBAD (DVC) - II	ER1147A	0.4	-56	0	0	-56
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) - I	NP6509A	64.6	-9044	0	0	-9044
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) - II	NP6510A	74.4	-10416	0	0	-10416
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	NP7408A	-2065	289100	0	0	289100
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	963.6	-134904	0	0	-134904
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP8557A	532.4	-74536	0	0	-74536
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1673.1	234234	0	0	234234
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1492	208880	0	0	208880
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-563.3	778862	0	0	778862
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-484.9	678146	0	0	678146
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	5304.3	-742602	0	0	-742602
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	5731.2	-802368	0	0	-802368
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-4289.2	600488	0	0	600488
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-4361.8	610652	0	0	610652
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-1096.4	153496	0	0	153496
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-5031.1	704354	0	0	704354
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3025.7	423598	0	0	423598
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	621	-86940	0.7	98	-86842
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	687.8	-96292	0	0	-96292
		<b>TOTAL</b>		<b>3123260</b>		<b>98</b>	<b>3123358</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	448.4	-62776	0	0	-62776
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	467.6	-65464	0	0	-65464
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	272.6	-38164	0	0	-38164
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1716.4	-240296	0	0	-240296
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	1689.6	-236544	0	0	-236544
	7	400 KV INDRAVATI (PG) - INDRAVATI (P/H)	NP5966A	1618.8	-226632	0	0	-226632
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-18.6	2604	-66.6	-9324	-6720
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	6.4	-896	-28.5	-3990	-4886
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1026.8	143752	0	0	143752
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4245	594300	0	0	594300
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-5693	797020	0	0	797020
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4423.8	619332	0	0	619332
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1891.1	264754	0	0	264754
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1291.8	180852	0	0	180852
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-89.3	12502	0	0	12502
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	0	0	0	0	0
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-I	NP5980A	0	0	-64.3	-9002	-9002
	22	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-II	NP7498A	0	0	-110.1	-15414	-15414
	23	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	NP7915A	-30.1	4214	0	0	4214
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	2.8	392	392
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	1.6	-224	-25.6	-3584	-3808
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-I	ER1018A	0	0	-3.4	-476	-476
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-I	NP8051A	0	0	-3.1	-434	-434
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-7.5	1050	0	0	1050
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	0.9	-126	-2.4	-336	-462
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-853.6	119504	0	0	119504
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-1222.3	171122	0	0	171122
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-II	ER1099A	0	0	-3.5	-490	-490
		<b>TOTAL</b>		<b>2039884</b>		<b>-42658</b>	<b>1997226</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-71.10	9954	0	0	9954
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-55.50	7770	0	0	7770
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	9.80	-1372	0	0	-1372
		<b>TOTAL</b>		<b>16352</b>		<b>0</b>	<b>16352</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	ER1477A	0	0	-3145.2	-440328	-440328
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-3024.4	-549416	-549416
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM(WBSETCL)	NP5080A	-40.3	5642	-5372.8	-752192	-746550
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	-170.4	23856	-4092.9	-573006	-549150
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-1705.4	-238756	-238756
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0	0	-2111.8	-295652	-295652
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	19.1	-2674	0	0	-2674
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-48.4	6776	0	0	6776
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-1176.7	164738	0	0	164738
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-1034.2	144788	0	0	144788
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-1700.1	238014	0	0	238014
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	-76.2	10668	0	0	10668
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	22.7	-3178	0	0	-3178
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	4508.8	-631232	0	0	-631232
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	1350.5	-189070	0	0	-189070
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-255.7	35798	0	0	35798
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-339.4	47516	0	0	47516
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-38.6	5404	0	0	5404
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-35.8	5012	0	0	5012
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	1026.5	-143710	0	0	-143710
	21	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-I	NP6548A	609.2	-85288	0	0	-85288
	22	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-II	NP7557A	924.4	-129416	0	0	-129416
	23	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-I	ER1071A	-498.6	69804	0	0	69804
	24	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-II	ER1072A	-214.1	29974	0	0	29974
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	-26.2	3668	-557.9	-78106	-74438
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	-3.5	490	-836.6	-117124	-116634
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	-29.1	4074	-1756.2	-245868	-241794
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	34.2	-4788	-601.2	-84168	-88956
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	612.5	-85750	1766	247240	161490
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	789.2	-110488	1381.6	193424	82936
	31	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	-143.8	20132	0	0	20132
	32	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	-98.1	13734	0	0	13734
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-468	65520	0	0	65520
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-446.1	62454	0	0	62454
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	2821.8	-395052	0	0	-395052
	36	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	3216.7	-450338	0	0	-450338
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-1	140	0	0	140
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-2.1	294	0	0	294
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0.4	-56	0	0	-56
	40	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
		<b>TOTAL</b>		<b>-1272544</b>		<b>-2933952</b>	<b>-4206496</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.