



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000
ISO: 9001-2000

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH

Date: 04.06.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)


Sub: Provisional Reactive Energy (VARH) Charges for the week from 14.05.2018-20.05.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. BANDYOPADHYAY)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 14/05/18 to 20/05/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4114656

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 14/05/18 to 20/05/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-2531.4	354396	0	0	354396
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2548.3	356762	0	0	356762
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1532.6	214564	0	0	214564
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	33	-4620	0	0	-4620
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-3.7	518	0	0	518
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	31	-4340	0	0	-4340
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-4442.7	621978	0	0	621978
	8	132 KV ARAH (PG) - ARAH (BSPHCL)	NP6051A	-1152.1	161294	-16.9	-2366	158928
	9	132 KV ARAH (PG) - DUMRAO (BSPHCL)	NP6054A	-547.1	76594	-27.3	-3822	72772
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-381.1	53354	0	0	53354
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-349.7	48958	0	0	48958
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	-0.7	98	0	0	98
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-23.7	3318	-1004.3	-140602	-137284
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-1426.4	199696	0	0	199696
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-1734.6	242844	0	0	242844
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	863.9	-120946	0	0	-120946
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	833.5	-116690	0	0	-116690
	18	132 KV ARAH(PG)-JAGDISHPUR(BSPHCL)	NP7425A	-474.5	66430	-8.5	-1190	65240
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2263.3	316862	0	0	316862
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	157.1	-21994	0	0	-21994
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	30.2	-4228	0	0	-4228
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2859.3	400302	0	0	400302
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	411.4	-57596	0	0	-57596
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-96.6	13524	0	0	13524
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-84.8	11872	0	0	11872
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	58.3	-8162	0	0	-8162
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	59.9	-8386	0	0	-8386
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	252	-35280	0	0	-35280
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	-78.5	10990	0	0	10990
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	-66.9	9366	0	0	9366
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	-82.8	11592	0	0	11592
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	-84.4	11816	0	0	11816
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	33.5	-4690	888.1	124334	119644
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	1894.7	-265258	0.1	14	-265244
	35	220 KV PATNA(PG) - KHAGAUL(BSPHCL)	NP5832A	-954.3	133602	0	0	133602
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1757.3	246022	0	0	246022
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-2307.4	323036	0	0	323036
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	4.6	-644	0	0	-644
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	4.9	-686	0	0	-686
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	-15.7	2198	0	0	2198
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	-24.8	3472	0	0	3472
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-460.9	64526	0	0	64526
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-513.4	71876	0	0	71876
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1891.6	-264824	0	0	-264824
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1744.5	-244230	0	0	-244230
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1302.3	182322	0	0	182322
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1509	211260	0	0	211260
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-1	ER1284A	1146.9	-160566	0	0	-160566
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-2	ER1289A	1403.4	-196476	0	0	-196476
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-1	ER1171A	135.5	-18970	-119.8	-16772	-35742
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-2	ER1177A	130.3	-18242	-118.1	-16534	-34776
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-1	ER1256A	-53.3	7462	-202.8	-28392	-20930
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-2	ER1258A	-42.9	6006	-198.1	-27734	-21728
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-1	ER1172A	-86.9	12166	-86.9	-12166	-86.9
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-2	ER1229A	-61.1	8554	-61.1	-8554	-61.1
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-861.4	120596	-861.4	-120596	-861.4
		TOTAL		3023398		-254380	2769018	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-7247.2	1014608	0	0	1014608
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-183.6	25704	0	0	25704
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	933.4	-130676	0	0	-130676
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2489.2	-348488	0	0	-348488
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-2067.3	289422	0	0	289422
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-95.6	13384	0	0	13384
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-143.2	20048	0	0	20048
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	679.1	-95074	0	0	-95074
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	679.9	-95186	0	0	-95186
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	0	0	-558.4	-78176	-78176
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	0	0	-575.5	-80570	-80570
			TOTAL		693742		-158746	534996
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) -II	NP6458A	-4143.6	580104	0	0	580104
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-202.6	28364	0	0	28364
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-429.2	60088	0	0	60088
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-108.2	15148	0	0	15148
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-99.8	13972	0	0	13972
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-3777.6	528864	-0.3	-42	528822
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	4392.7	-614978	0	0	-614978
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-362.9	50806	0	0	50806
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1974.9	276486	0	0	276486
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2023	283220	0	0	283220
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-7489.9	1048586	0	0	1048586
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-5714.6	800044	0	0	800044
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	2534.1	-354774	0	0	-354774
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	3253.5	-455490	0	0	-455490
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-6819.9	954786	0	0	954786
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-6824.8	969472	0	0	969472
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-2467.3	345422	0	0	345422
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-6993.1	979034	0	0	979034
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4121.8	577052	0	0	577052
	21	400 KV RANCHI(PG)-RTPS(DVC)-2	NP7871A	1636.1	-229054	0	0	-229054
	22	400 KV RANCHI(PG)-RTPS(DVC)-3	NP7853A	1676.8	-234752	0.7	98	-234654
		TOTAL		5622400		56	5622456	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	458.4	-64176	0	0	-64176
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	795.7	-111398	0	0	-111398
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	687.6	-96264	0	0	-96264
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1306.6	-182924	0	0	-182924
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	1301.8	-182252	0	0	-182252
	7	400 KV INDRAVATI (PG) - INDRAVATI (P/H)	NP5966A	2878.9	-403046	0	0	-403046
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-219.9	30786	-2.4	-336	30450
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	108.6	-15204	-0.6	-84	-15288
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1855.6	259784	0	0	259784
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4835.6	676984	0	0	676984
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-5095.8	713412	0	0	713412
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2541.8	355852	0	0	355852
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1486.3	208082	0	0	208082
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1198.7	167818	0	0	167818
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	NP7916A	-2286.4	320096	0	0	320096
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	16.3	-2282	0	0	-2282
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	NP5980A	-33.6	4704	0	0	4704
	22	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	NP7498A	-34.4	4816	0	0	4816
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-792.4	110936	0	0	110936
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	248.6	-34904	7.6	1064	-33740
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	131.1	-18354	-134.4	-18816	-37170
	26	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	163.2	-22848	0	0	-22848
	27	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	114.1	-15974	0	0	-15974
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	67.7	-9478	0	0	-9478
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	91.9	-12866	-1.1	-154	-13020
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-269.6	37744	0	0	37744
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-388.2	54348	0	0	54348
	32	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-2	ER1099A	143.3	-20062	0	0	-20062
		TOTAL		1753430		-18326	1735104	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-112.70	15778	0	0	15778
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-101.90	14266	0	0	14266
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	6.30	-882	0	0	-882
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	5.00	-700	0	0	-700
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.00	-2100	0	0	-2100
		TOTAL		26362		0	26362	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPURE	NP6445A	-877.6	122864	-1160.5	-162470	-39606
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	NP6446A	-277	38780	-1871.2	-261968	-223188
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM-I(WBSETCL)	NP5080A	390.1	-54614	-1761.4	-246596	-301210
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	258.3	-36162	-796.5	-111510	-147672
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	-28.8	4032	-253.5	-35490	-31458
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	-27.7	3878	-400.7	-56098	-52220
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-710	99400	0	0	99400
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-699.4	97916	0	0	97916
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-985.2	137928	0	0	137928
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-644.3	90202	0	0	90202
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	1548.6	-216804	0	0	-216804
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	2222.8	-311192	0	0	-311192
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-66.9	9366	0	0	9366
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	6449	-902860	0	0	-902860
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	3758.1	-526134	0	0	-526134
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-3732.7	522578	0	0	522578
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-509.8	71372	0	0	71372
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-72.6	10164	0	0	10164
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-15.9	2226	0	0	2226
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2277.5	-318850	0	0	-318850
	21	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-I	NP6548A	2900.4	-406056	0	0	-406056
	22	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-II	NP7557A	4083.6	-571704	0	0	-571704
	23	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-II	ER1072A	-508.1	71134	0	0	71134
	24	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-I	ER1071A	-385	53900	0	0	53900
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	93.3	-13062	-427	-59780	-72842
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	50.3	-7042	-749.9	-104986	-112028
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	145.2	-20328	-512.4	-71736	-92064
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	571.7	-80038	-52.3	-7322	-87360
	29	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	387.9	-54306	243.5	34090	-20216
	30	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	527.1	-73794	145.3	20342	-53452
	31	400 KV SAGARDIGHI(WB)-BEHRAMPURE(PG) LINE-I	NP8723A	-898.7	125818	0	0	125818
	32	400 KV SAGARDIGHI(WB)-BEHRAMPURE(PG) LINE-II	NP8724A	-852.6	119364	0	0	119364
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-349.7	48958	0	0	48958
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-358.4	50176	0	0	50176
	35	400 KV PPS NEW(WB)-RANCHI NEW(PG)-1	ER1040A	6912.7	-967778	0	0	-967778
	36	400 KV PPS NEW(WB)-RANCHI NEW(PG)-2	ER1130A	6921.4	-968996	0	0	-968996
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-1	ER1133A	-2958.3	414162	0	0	414162
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-2	ER1138A	-2745.5	384370	0	0	384370
		TOTAL		-3051132		-1063524	-4114656	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVARh.w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.