



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2000
ISO: 9001-2000

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH

Date: 21.06.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17. (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)


Sub: Provisional Reactive Energy (VARH) Charges for the week from 28.05.2018-03.06.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. BANDYOPADHYAY)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VARH) Charge Statement
for the period 28/05/18 to 03/06/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4302382

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

 21/06/18
MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-159.2	22288	0	0	22288
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	407.3	-57022	0	0	-57022
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	204	-28560	0	0	-28560
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1040	-145600	0	0	-145600
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	966.8	-135352	0	0	-135352
	7	400 KV INDRAVATI (PG) - INDRAVATI (P/H)	NP5966A	938.7	-131418	0	0	-131418
	8	132 KV BARIPADA (PG) - BARIPADA (GRIDCO)	NP5916A	-71.6	10024	-33.4	-4676	5348
	9	132 KV BARIPADA (PG) - BANGRIPOSHI (GRIDCO)	NP5912A	10.1	-1414	-18.2	-2548	-3962
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-946	132440	0	0	132440
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4615	646100	0	0	646100
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-5552.6	777364	0	0	777364
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4658	652120	0	0	652120
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2119.3	296702	0	0	296702
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1514.7	212058	0	0	212058
	16	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA (PG)	NP7916A	-368.2	51548	0	0	51548
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	83.2	-11648	0	0	-11648
	19	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	137.6	-19264	0	0	-19264
	20	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	21.4	-2996	0	0	-2996
	21	400 KV MENDHASAL (GRIDCO) - PANDIABILI (PG)-I	NP5980A	0	0	-170.5	-23870	-23870
	22	400 KV MENDHASAL (GRIDCO) - PANDIABILI (PG)-II	NP7498A	0	0	-267.5	-37450	-37450
	23	400 KV DUBURI (GRIDCO) - PANDIABILI (PG)	NP7915A	-23.2	3248	0	0	3248
	24	220 KV BOLANGIR (PG) - KATAPALI (GRIDCO)	NP8790A	206.7	-28938	0	0	-28938
	25	220 KV BOLANGIR (PG) - SADEIPALI (GRIDCO)	NP8789A	90.2	-12628	-51.1	-7154	-19782
	26	220 KV PANDIABILI (PG) - ATRI (GRIDCO) -I	ER1018A	0	0	-23.2	-3248	-3248
	27	220 KV PANDIABILI (PG) - SAMANGARA (GRIDCO) -I	NP8051A	0	0	-12.3	-1722	-1722
	28	132 KV BARIPADA (PG) - JALESWAR (GRIDCO)	NP5914A	-4.3	602	0	0	602
	29	132 KV BARIPADA (PG) - BHOGRAI (GRIDCO)	ER1115A	20.3	-2842	-3.7	-518	-3360
	30	400KV SUNDERGARH (PG) - STERLITE (GRIDCO) -I	ER1059A	-3873.1	542234	0	0	542234
	31	400KV SUNDERGARH (PG) - STERLITE (GRIDCO) -II	ER1058A	-4217.1	590394	0	0	590394
	32	220 KV PANDIABILI (PG) - ATRI (GRIDCO) -II	ER1099A	0	0	-23.2	-3248	-3248
		TOTAL		3359440		-84434	3275006	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-83.50	11690	0	0	11690
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-46.30	6482	0	0	6482
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.20	-1708	0	0	-1708
		TOTAL		16464		0	16464	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	ER1477A	-18.6	2604	-3300.8	-462112	-459508
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0.4	-56	-2602.1	-364294	-364350
	3	220 KV SUBHASGRAM (PG) - SUBHASGRAM (WBSETCL)	NP5080A	-116.2	16268	-4721.5	-661014	-644742
	4	220 KV SUBHASGRAM (PG) - SUBHASGRAM-II (WBSETCL)	NP5847A	-377.2	52808	-3433.5	-480690	-427882
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER11143A	-0.7	98	-516.5	-72310	-72212
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0.2	-28	-859.7	-120358	-120386
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-40.3	5642	0	0	5642
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-70.7	8998	0	0	8998
	9	132KV BIRPARA (PG) - BIRPARA (WBSETCL) -I	ER1110A	-745.3	104342	0	0	104342
	10	132KV BIRPARA (PG) - BIRPARA (WBSETCL) -II	NP6470A	-596.3	83482	0	0	83482
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL) -I	NP5882A	-1295.1	181314	0	0	181314
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL) -II	NP5881A	632.1	-88494	0	0	-88494
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	4.5	-630	0	0	-630
	14	400 KV DURGAPUR (PG) - BIDHANAGAR (WBSETCL) -I	NP5831A	5842.5	-617950	0	0	-617950
	15	400 KV DURGAPUR (PG) - BIDHANAGAR (WBSETCL) -II	NP6459A	3650.9	-511126	0	0	-511126
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1577.2	220808	0	0	220808
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-555.5	77770	0	0	77770
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-16.1	2254	0	0	2254
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	-31.4	4396	0	0	4396
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	1905.8	-266812	0	0	-266812
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL) -I	NP6548A	1241	-173740	0	0	-173740
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL) -II	NP7557A	1610.9	-225526	0	0	-225526
	23	220 KV DALKHOILA (PG) - DALKHOILA (WBSETCL) -LINE-I	ER1071A	-225.4	31556	0	0	31556
	24	220 KV DALKHOILA (PG) - DALKHOILA (WBSETCL) -LINE-II	ER1072A	-72	10080	-0.1	-14	10066
	25	220 KV SUBHASGRAM (PG) - EMBYPASS CESC (WB) -LINE-I	ER1144A	71.4	-9996	-455.3	-63742	-73738
	26	220 KV SUBHASGRAM (PG) - EMBYPASS CESC (WB) -LINE-II	NP7936A	20.2	-2828	-647.6	-90664	-93492
	27	220 KV SUBHASGRAM (PG) - KLC BANTALA (WB)	NP8708A	52.5	-7350	-1703.6	-238504	-245854
	28	220 KV SUBHASGRAM (PG) - NEW TOWN (WB)	NP8709A	157.7	-22078	-689.7	-96558	-118636
	29	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) -LINE-I	ER1141A	577.4	-80836	2241.9	313866	233030
	30	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) -LINE-II	NP7937A	708.2	-99148	1870.3	261842	162694
	31	400 KV SAGARDIGHI (WB) - BEHRAMPUR (PG) -LINE-I	NP8723A	-442.8	61992	0	0	61992
	32	400 KV SAGARDIGHI (WB) - BEHRAMPUR (PG) -LINE-II	NP8724A	-423.9	59346	0	0	59346
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG) -I	NP8731A	-542.9	76006	0	0	76006
	34	400 KV KHARAGPUR (WB) - CHAIBASA (PG) -II	NP8720A	-515.2	72128	0	0	72128
	35	400 KV PPSP NEW (WB) - RANCHI NEW (PG) -II	ER1040A	4656.6	-651924	0	0	-651924
	36	400 KV PPSP NEW (WB) - RANCHI NEW (PG) -I	ER1130A	4650.1	-651014	0	0	-651014
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC) -I	ER1133A	-1169.2	163688	0	0	163688
	38	400 KV GOKARNA (WB) - FARAKKA (NTPC) -II	ER1138A	-1037.3	145222	0	0	145222
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB) -I	ER1044A	0	0	0	0	0
	40	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB) -II	ER1047A	0	0	0	0	0
		TOTAL		-2227834		-2074548	-4302382	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH, w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.