



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH

Date: 10.07.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)


**Sub: Provisional Reactive Energy (VARH) Charges for the week from 18.06.2018-24.06.2018**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

  
(J. BANDYOPADHYAY)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 18/06/18 to 24/06/18**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4569768

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 18/06/18 to 24/06/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/L (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-1314.8	184072	0	0	184072
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-1248.4	174776	0	0	174776
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-686.6	96124	0	0	96124
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	1.4	-196	-220.9	-30926	-31122
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	16.5	-2310	-40.2	-5628	-7938
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	9.7	-1358	-148.5	-20790	-22148
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2927.2	409808	0	0	409808
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-818.7	114618	-48.6	-6804	107814
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-230.1	32214	-36.8	-5152	27062
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-67.1	9394	-1.7	-238	9156
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-50.6	7084	-7	-980	6104
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	-3.4	476	-81.5	-11410	-10934
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-819	-114660	-114660
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-1404.8	196672	0	0	196672
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-1587.6	222264	-28.2	-3948	218316
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	-128.4	17976	0	0	17976
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	-117.7	16478	0	0	16478
	18	132 KV ARAH(PG)-JAGDISHPUR(BSPHCL)	NP7425A	-289.9	40586	-32.5	-4550	36036
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1368	191520	0	0	191520
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	0	0	0	0	0
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	0	0	0	0	0
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2613.6	365904	-0.1	-14	365890
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	238.8	-33432	0	0	-33432
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-25.3	3542	0	0	3542
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-26.8	3752	0	0	3752
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	20.2	-2828	0	0	-2828
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	18.3	-2562	0	0	-2562
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	96.3	-13482	0	0	-13482
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	-186	26040	-7.6	-1064	24976
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	-185.3	25942	-7.6	-1064	24878
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	-195.3	27342	-7.9	-1106	26236
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	-171.7	24038	-8.5	-1190	22848
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	0	0	703.1	98434	98434
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	647.3	-90622	0	0	-90622
	35	220 KV PATNA(PG) - KHAGAIL(BSPHCL)	NP5832A	-578	80920	0	0	80920
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-840.6	117684	0	0	117684
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-609.5	85330	0	0	85330
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	0	0	0
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	0	0	0
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	0	0	0
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1156.4	161896	-0.1	-14	161882
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-987.5	138250	-0.1	-14	138236
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1951.8	-273252	0	0	-273252
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1920.7	-268898	0	0	-268898
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1018.6	142604	0	0	142604
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1189.9	166586	0	0	166586
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-I	ER1284A	1190.1	-166614	0	0	-166614
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-II	ER1289A	1178.1	-164934	0	0	-164934
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-I	ER1171A	145.1	-20314	-212.7	-29778	-50092
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-II	ER1177A	144.1	-20174	-215.1	-30114	-50288
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-I	ER1256A	-66.9	9366	-172.8	-24192	-14826
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-II	ER1258A	-67.3	9422	-168.8	-23632	-14210
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-I	ER1172A	1.3	-182	-146	-20440	1.3
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-II	ER1229A	1.3	-182	-140.7	-19698	1.3
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-1018.5	142590	0	0	-1018.5
	57	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-I	ER1279A	377	-52780	0	0	377
	58	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-II	ER1280A	552	-77280	0	0	552
	59	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-I	ER1375A	860.4	-120456	0	0	860.4
	60	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-II	ER1380A	791.1	-110754	0	0	791.1
	61	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-I	ER1277A	-554.7	77658	0	0	-554.7
	62	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-II	ER1278A	26.3	-3682	0	0	26.3
		<b>TOTAL</b>			<b>1896636</b>		<b>-258972</b>	<b>1637664</b>
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-7277	1018780	0	0	1018780
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-788.5	110390	0	0	110390
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	670.2	-93828	0	0	-93828
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	743.4	-104076	0	0	-104076
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-572	80080	0	0	80080
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-99	13860	0	0	13860
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-159.2	22288	0	0	22288
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	339	-47460	0	0	-47460
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	336.2	-47068	0	0	-47068
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	0	0	0	0	0
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	0	0	0	0	0
		<b>TOTAL</b>		<b>952966</b>		<b>0</b>	<b>952966</b>	
DVC	1	220 KV DURGAAPUR (PG) - PARULIA (DVC) - I	NP6456A	0	0	0	0	0
	2	220 KV DURGAAPUR (PG) - PARULIA (DVC) - II	NP6458A	-5238.6	733404	0	0	733404
	3	220 KV MAITHON (PG) - DHANBAD (DVC) - I	NP6529A	24	-3360	0	0	-3360
	4	220 KV MAITHON (PG) - DHANBAD (DVC) - II	ER1147A	-9.4	1316	0	0	1316
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) - I	NP6509A	83.8	-11732	0	0	-11732
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) - II	NP6510A	103.2	-14448	0	0	-14448
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKAPADA(PG)	NP7408A	-1794.5	251230	0	0	251230
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1364	-190960	0	0	-190960
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-2995.3	419342	0	0	419342
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	85.1	-11914	0	0	-11914
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-166.5	23310	0	0	23310
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-2520.3	352842	0	0	352842
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-1754	245560	0	0	245560
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1907.9	-267106	0	0	-267106
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	2439.6	-341544	0	0	-341544
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-4686.9	656166	0	0	656166
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-4787.4	670236	0	0	670236
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-3020.6	422884	0	0	422884
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-7319.5	1024730	0	0	1024730
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3451.9	483266	0	0	483266
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	3458.5	-484190	0	0	-484190
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3543.6	-496104	0	0	-496104
		<b>TOTAL</b>		<b>3462928</b>		<b>0</b>	<b>3462928</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	169.6	-23744	0	0	-23744
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-29.8	4172	0	0	4172
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-244.7	34258	0	0	34258
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	869.8	-121772	0	0	-121772
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	881.1	-123354	0	0	-123354
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	498.3	-69762	1	140	-69622
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-42.8	5992	-140.9	-19726	-13734
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	33.3	-4662	-91.7	-12838	-17500
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	44.8	-6272	0	0	-6272
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3557.8	498092	0	0	498092
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-5943	832020	0	0	832020
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3357.6	470064	0	0	470064
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2152.8	301392	0	0	301392
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1613.1	225834	0	0	225834
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-0.7	98	0	0	98
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	0	0	0	0	0
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-I	NP5980A	0	0	-68.2	-9548	-9548
	22	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-II	NP7498A	0	0	-295.5	-41370	-41370
	23	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	NP7915A	-1	140	0	0	140
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	108.4	15176	15176
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-79.6	-11144	-11144
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-I	ER1018A	0	0	16.2	2268	2268
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-I	NP8051A	0	0	-28.8	-4032	-4032
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	12.5	-1750	-4.5	-630	-2380
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	16.6	-2324	-5.7	-798	-3122
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-110.5	15470	0	0	15470
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-90.1	12614	0	0	12614
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-II	ER1099A	0	0	22.1	3094	3094
		<b>TOTAL</b>		<b>2046506</b>		<b>-79408</b>	<b>1967098</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-54.50	7630	0	0	7630
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-33.60	4704	0	0	4704
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.1	-14	-14
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	1.9	266	266
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	1.9	266	266
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	14.30	-2002	0	0	-2002
		<b>TOTAL</b>		<b>10332</b>		<b>518</b>	<b>10850</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	ER1477A	-2.1	294	-2260.9	-316526	-316232
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-2051.9	-287266	-287266
	3	220 KV SUBHASGRAM(PG)-SUBHASGRAM(WBSETCL)	NP5080A	-117.7	16478	-4691.1	-656754	-640276
	4	220 KV SUBHASGRAM(PG)-SUBHASGRAM-II(WBSETCL)	NP5847A	-494.3	69202	-3527.1	-493794	-424592
	5	132 KV MALDA (PG) - MALDA (WBSETCL) -I	ER1143A	0	0	-2845.6	-398384	-398384
	6	132 KV MALDA (PG) - MALDA (WBSETCL) -II	ER1150A	0	0	-3075.7	-430598	-430598
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	63.4	-8876	0	0	-8876
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	44.3	-6202	0	0	-6202
	9	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -I	ER1110A	-1463.1	204834	0	0	204834
	10	132KV BIRPARA(PG) - BIRPARA(WBSETCL) -II	NP6470A	-1401.1	196154	0	0	196154
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-3002.4	420336	0	0	420336
	12	220 KV BINAGURI (PG)-JALPAIGURI(WBSETCL)-II	NP5881A	-66.4	9296	0	0	9296
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	22.2	-3108	0	0	-3108
	14	400 KV DURGAPUR(PG) - BIDHANAGAR(WBSETCL)-I	NP5831A	5030.1	-704214	0	0	-704214
	15	400 KV DURGAPUR (PG) - BIDHANAGAR(WBSETCL)-II	NP6459A	4021.1	-562954	0	0	-562954
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-105.9	14826	0	0	14826
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-479.8	67172	0	0	67172
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-10.8	1512	0	0	1512
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-29.4	4116	0	0	4116
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2651.4	-371196	0	0	-371196
	21	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-I	NP6548A	-1090.9	152726	0	0	152726
	22	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-II	NP7557A	-1270.8	177912	0	0	177912
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	42.9	-6006	-152.2	-21308	-27314
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	29.6	-4144	-238.5	-33390	-37534
	25	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-I	ER1144A	48	-6720	-407.2	-57008	-63728
	26	220 KV SUBHASGRAM(PG)-EMBYPASS CESC(WB) LINE-II	NP7936A	18.5	-2590	-646.5	-90510	-93100
	27	220 KV SUBHASGRAM(PG)-KLC BANTALA(WB)	NP8708A	1.9	-266	-1228	-171920	-172186
	28	220 KV SUBHASGRAM(PG)-NEW TOWN(WB)	NP8709A	-287.6	40264	208.5	29190	69454
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	361.5	-50610	2244.2	314188	263578
	30	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	416.4	-58296	2024.2	283388	225092
	31	400 KV SAGARDIGHI(WB)-BEHRAMPUR(PG) LINE-I	NP8723A	292.2	-40908	0	0	-40908
	32	400 KV SAGARDIGHI(WB)-BEHRAMPUR(PG) LINE-II	NP8724A	209.2	-29288	0	0	-29288
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-148.8	20832	0	0	20832
	34	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-110.5	15470	0	0	15470
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	6557.2	-918008	0	0	-918008
	36	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	6552.8	-917392	0	0	-917392
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-160.1	22414	0	0	22414
	38	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-127.6	17864	0	0	17864
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	40	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
		<b>TOTAL</b>		<b>-2239076</b>		<b>-2330692</b>	<b>-4569768</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.