



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2000  
ISO: 9001-2000

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/3215 - 3225

Date: 16.08.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 23.07.2018-29.07.2018**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(J. BANDYOPADHYAY)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 23/07/18 to 29/07/18**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	68096
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	592970

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 23/07/18 to 29/07/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/L (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-1801.2	252168	0	0	252168
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2308	323120	0	0	323120
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1402.3	196322	0	0	196322
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	0	0	-57.5	-8050	-8050
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	39.6	-5544	-0.1	-14	-5558
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	6.7	-938	-20.5	-2870	-3808
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1815.3	254142	0	0	254142
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-781.9	109466	-294.6	-41244	68222
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-555.2	77728	-300.7	-42098	35630
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-830.6	116284	0	0	116284
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-509.6	71344	0	0	71344
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	0	0	0	0	0
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	3	-420	0.1	14	-406
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-1479.4	207116	-0.1	-14	207102
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-1292.1	180894	0	0	180894
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	580.2	-81228	0	0	-81228
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	578	-80920	0	0	-80920
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-245.9	34426	-233.5	-32690	1736
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1640	229600	0	0	229600
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	0	0	0	0	0
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	0	0	0	0	0
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-426.3	59682	0	0	59682
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-1596.3	223482	0	0	223482
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-176.3	24682	0	0	24682
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-176.8	24752	0	0	24752
	26	132 KV LAKHISARAI(PG)-JAMUI (BSPHCL)-I	NP7887A	51.6	-7224	0	0	-7224
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	49	-6860	0	0	-6860
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	216.9	-30366	0	0	-30366
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	-737.7	103278	-2.5	-350	102928
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	-744.3	104202	-2.5	-350	103852
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	-806.5	112910	-2.8	-392	112518
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	-812.4	113736	-2.8	-392	113344
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	63	-8820	1.5	210	-8610
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	1727.8	-241892	0	0	-241892
	35	220 KV PATNA(PG) - KHAGAIL(BSPHCL)	NP5832A	-1740.1	243614	0	0	243614
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1699.4	237916	0	0	237916
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-1682.8	235592	0	0	235592
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	0	0	0
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	0	0	0
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	0	0	0
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-597.2	83608	0	0	83608
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-586.4	82096	0	0	82096
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2536.2	-355068	0	0	-355068
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2523	-353220	0	0	-353220
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-993.8	139132	-0.1	-14	139118
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1113.7	155918	0	0	155918
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-I	ER1284A	1864.9	-261086	0	0	-261086
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-II	ER1289A	1838.8	-257432	0	0	-257432
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-I	ER1171A	129.6	-18144	-4.3	-602	-18746
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-II	ER1177A	91.9	-12866	-4.4	-616	-13482
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-I	ER1256A	-141.9	19866	-7	-980	18886
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-II	ER1258A	-138.6	19404	-6.7	-938	18466
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-I	ER1172A	-177.2	24808	-15.7	-2198	-177.2
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-II	ER1229A	-176.7	24738	-15.3	-2142	-176.7
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-2789.4	390516	0	0	-2789.4
	57	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-I	ER1279A	581.2	-81368	0	0	581.2
	58	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-II	ER1280A	515.6	-72184	0	0	515.6
	59	220 KV GAYA(PG)-KHIZIRSAI(BSPHCL)-I	ER1375A	1087	-152180	0	0	1087
	60	220 KV GAYA(PG)-KHIZIRSAI(BSPHCL)-II	ER1380A	0	0	0	0	0
	61	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-I	ER1277A	-402.6	56364	0	0	-402.6
	62	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-II	ER1278A	39.7	-5558	0	0	39.7
		<b>TOTAL</b>		<b>2499588</b>		<b>-135730</b>	<b>2363858</b>	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-5161.7	722638	0	0	722638
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	999.2	-139888	0	0	-139888
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	3067.1	-429394	0	0	-429394
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2594.4	-363216	0	0	-363216
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1304.2	182588	0	0	182588
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-367.8	51492	0	0	51492
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-339.6	47544	-0.2	-28	47516
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	499.5	-69930	0	0	-69930
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	498.7	-69818	0	0	-69818
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	-2	280	-2.1	-294	-14
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	-1.9	266	-2.4	-336	-70
		<b>TOTAL</b>		<b>-67438</b>		<b>-658</b>	<b>-68096</b>	
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) - I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) - II	NP6458A	-4815.2	674128	0	0	674128
	3	220 KV MAITHON (PG) - DHANBAD (DVC) - I	NP6529A	-86	12040	0	0	12040
	4	220 KV MAITHON (PG) - DHANBAD (DVC) - II	ER1147A	-389.8	54572	0	0	54572
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) - I	NP6509A	33.2	-4648	0	0	-4648
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) - II	NP6510A	82.2	-11508	0	0	-11508
	7	400 KV TATA JAMSHEDPUR (DVC)- BARI PADA(PG)	NP7408A	-807.7	113078	0	0	113078
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	482.2	-67508	0	0	-67508
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP8557A	-215.4	30156	0	0	30156
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	261	-36540	0	0	-36540
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	152.6	-21364	0	0	-21364
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-2836	397040	0	0	397040
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-2673.1	374234	0	0	374234
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	2137.8	-299292	0	0	-299292
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	2007	-280980	0	0	-280980
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-4611.4	645596	0	0	645596
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-4718.3	660562	0	0	660562
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6583.1	921634	0	0	921634
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-5944.5	832230	0	0	832230
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3033.9	424746	0	0	424746
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7980.6	-1117284	0	0	-1117284
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7923.3	-1109262	0	0	-1109262
		<b>TOTAL</b>		<b>2191630</b>		<b>0</b>	<b>2191630</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	982	-137480	0	0	-137480
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	386.5	-54110	0	0	-54110
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	177.9	-24906	0	0	-24906
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1953.1	-273434	0	0	-273434
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	2046.3	-286482	0	0	-286482
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	97.4	-13636	0	0	-13636
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	0	0	-0.4	-56	-56
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1478.2	206948	0	0	206948
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4202.6	588364	0	0	588364
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4584.8	641872	0	0	641872
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4298.6	601804	0	0	601804
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-865.2	121128	0	0	121128
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-669.5	93730	0	0	93730
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	NP7916A	0	0	0	0	0
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	0	0	0	0	0
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO) - PANDIABILI(PG)-I	NP5980A	0	0	0	0	0
	22	400 KV MENDHASAL (GRIDCO) - PANDIABILI(PG)-II	NP7498A	0	0	0	0	0
	23	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	NP7915A	-10.1	1414	0	0	1414
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	53	7420	7420
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	5.4	-756	0	0	-756
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-I	ER1018A	5.6	-784	0	0	-784
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-I	NP8051A	8.6	-1204	0	0	-1204
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	5.5	-770	0	0	-770
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	0	0	0	0	0
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-5245.5	734370	0	0	734370
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-5455.7	763798	0	0	763798
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-II	ER1099A	0.3	-42	0	0	-42
		<b>TOTAL</b>		<b>2959824</b>		<b>7364</b>	<b>2967188</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-37.30	5222	0	0	5222
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-8.90	1246	0	0	1246
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.60	-1764	0	0	-1764
		<b>TOTAL</b>		<b>4704</b>		<b>0</b>	<b>4704</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - BEHRAMPUR	ER1477A	-29.1	4074	-247.6	-34664	-30590
	2	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-2201	-308140	-308140
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	NP5848A	-54.5	7630	0	0	7630
	4	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	NP5845A	-36.9	5166	-1.3	-182	4984
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1077.2	150808	0	0	150808
	6	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	NP7977A	-1413.6	197904	0	0	197904
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	7.2	-1008	0	0	-1008
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	12.7	-1778	0	0	-1778
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	NP6474A	-1404.1	196574	0	0	196574
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	NP5891A	-1404.1	196574	0	0	196574
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-2070.4	289856	0	0	289856
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	-208.9	29246	0	0	29246
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-1.1	154	0	0	154
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	2308.7	-323218	0	0	-323218
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	1979	-277060	0	0	-277060
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-269.7	37758	0	0	37758
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-589.7	82568	0	0	82568
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	6.8	-952	0	0	-952
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-36.1	5054	0	0	5054
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2618.6	-366604	0	0	-366604
	21	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-I	NP6548A	-1832.6	256564	0	0	256564
	22	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-II	NP7557A	-1987.7	278278	0	0	278278
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-136	19040	0	0	19040
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	5.2	-728	0	0	-728
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	-107.1	14994	-0.2	-28	14966
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	-119.1	16674	0	0	16674
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	-148.5	20790	0	0	20790
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-175.7	24598	5.8	812	25410
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-160.5	22470	0	0	22470
	30	400 KV SAGARDIGHI(WB)-BEHRAMPUR(PG) LINE-I	NP8723A	845.7	-118398	0	0	-118398
	31	400 KV SAGARDIGHI(WB)-BEHRAMPUR(PG) LINE-II	NP8724A	521.3	-72982	0	0	-72982
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-825.9	115626	0	0	115626
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-796	111440	0	0	111440
	34	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-I	ER1040A	4555.4	-637756	0	0	-637756
	35	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-II	ER1130A	4549.9	-636986	0	0	-636986
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-388.1	54334	0	0	54334
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-346.7	48538	0	0	48538
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
		<b>TOTAL</b>		<b>-250768</b>		<b>-342202</b>	<b>-592970</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.