



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/4403-4413

Date: 25.09.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 03.09.2018-09.09.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 03/09/18 to 09/09/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	2693880

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 03/09/18 to 09/09/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/L (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-3391.5	474810	0	0	474810
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-3360.9	470526	0	0	470526
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1950	273000	0	0	273000
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	-5.6	784	-188.5	-26390	-25606
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-47.4	6636	-40.4	-5656	980
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	-18.7	2618	-116.3	-16282	-13664
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2062.5	288750	0	0	288750
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-675.9	94626	-385.6	-53984	40642
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-414.9	58086	-340.1	-47614	10472
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-137.1	19194	0	0	19194
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-107.1	14994	0	0	14994
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	0	0	0	0	0
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-46.6	6524	-216.8	-30352	-23828
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2256.8	315952	-11.3	-1582	314370
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-2348.5	328790	-0.1	-14	328776
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	1007.6	-141064	0	0	-141064
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	1010.1	-141414	0	0	-141414
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-315.1	44114	-316.9	-44366	-252
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2516	352240	0	0	352240
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	0	0	0	0	0
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	0	0	0	0	0
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1513.1	211834	0	0	211834
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-1959.3	274302	0	0	274302
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-146.1	20454	0	0	20454
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-153	21420	0	0	21420
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	-14.9	2086	0	0	2086
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	-6.4	896	0	0	896
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	217.1	-30394	0	0	-30394
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	66.1	-9254	0	0	-9254
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	70.7	-9898	0	0	-9898
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	78.5	-10990	0	0	-10990
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	67.9	-9506	0	0	-9506
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	143.3	-20062	167.9	23506	3444
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	1581.5	-221410	0	0	-221410
	35	220 KV PATNA(PG) - KHAGAIL(BSPHCL)	NP5832A	-966.2	135298	0	0	135298
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-405.5	56770	0	0	56770
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-1148.5	160790	0	0	160790
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	0	0	0
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	0	0	0
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	0	0	0
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-124.6	17444	0	0	17444
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-329.1	46074	0	0	46074
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2216.8	-310352	0	0	-310352
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2183.6	-305704	0	0	-305704
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2206.5	308910	0	0	308910
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2402.1	336294	0	0	336294
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-I	ER1284A	1286.2	-180068	3	420	-179648
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPTCL)-II	ER1289A	1267.9	-177506	3.3	462	-177044
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPTCL)-I	ER1171A	-297.8	41692	-11.5	-1610	40082
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPTCL)-II	ER1177A	-281.7	39438	-11.6	-1624	37814
	52	132 KV MOTIHARI(DMTCL)-MOTIHAR(BSPTCL)-I	ER1256A	-283.1	39634	-8.2	-1148	38486
	53	132 KV MOTIHARI(DMTCL)-MOTIHAR(BSPTCL)-II	ER1258A	-281.3	39382	-8.2	-1120	38262
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPTCL)-I	ER1172A	-154.9	21686	-5.5	-770	-154.9
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPTCL)-II	ER1229A	-231.8	32452	-16.2	-2268	-231.8
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-1115.6	156184	0	0	-1115.6
	57	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPTCL)-I	ER1279A	437.2	-61208	2.6	364	437.2
	58	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPTCL)-II	ER1280A	0	0	0	0	0
	59	220 KV GAYA(PG)-KHIZIRSAI(BSPTCL)-I	ER1375A	0	0	0	0	0
	60	220 KV GAYA(PG)-KHIZIRSAI(BSPTCL)-II	ER1380A	0	0	0	0	0
	61	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPTCL)-I	ER1277A	-461.7	64638	-13.8	-1932	-461.7
	62	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPTCL)-II	ER1278A	29.6	-4144	0.1	14	29.6
	63	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	64	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL		3146318		-21946	2934372	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-5130.1	718214	-0.2	-28	718186
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	-0.4	-56	-56
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	-126	17640	0	0	17640
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	4215.6	-590184	0	0	-590184
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2683	-375620	0	0	-375620
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1281.2	179368	0	0	179368
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-668.8	93632	0	0	93632
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-608	85120	0	0	85120
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	384.2	-53788	0	0	-53788
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	392.1	-54894	0	0	-54894
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	-32.3	4522	-4.3	-602	3920
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	-26.6	3724	-4.8	-672	3052
			TOTAL		27734		-1358	26376
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) - I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) - II	NP6458A	-3022.2	423108	0	0	423108
	3	220 KV MAITHON (PG) - DHANBAD (DVC) - I	NP6529A	-98.4	13776	0	0	13776
	4	220 KV MAITHON (PG) - DHANBAD (DVC) - II	ER1147A	-227	31780	0	0	31780
	5	220 KV MAITHON (PG) - KALYANESWAR (DVC) - I	NP6509A	452.6	-63364	0	0	-63364
	6	220 KV MAITHON (PG) - KALYANESWAR (DVC) - II	NP6510A	696.2	-97468	0	0	-97468
	7	400 KV TATA JAMSHEDPUR (DVC)- BARI PADA(PG)	NP7408A	-1601.2	224168	0	0	224168
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	2080.1	-291214	0	0	-291214
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-458.6	64204	0	0	64204
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER11008A	-203.6	28504	0	0	28504
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER11031A	-325.6	45584	0	0	45584
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-5899.8	825972	0	0	825972
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-5000.4	700056	0	0	700056
	14	400 KV KODERMA(DVC) - Gayi(PG)-I	NP7891A	1145.8	-160412	0	0	-160412
	15	400 KV KODERMA(DVC) - Gayi(PG)-II	NP7890A	1270.8	-177912	0	0	-177912
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3096.3	433482	0	0	433482
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3164.7	443058	0	0	443058
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6351.7	889238	0	0	889238
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	58.1	-8134	0	0	-8134
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3980.7	557298	0	0	557298
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	9034.5	-1264830	0	0	-1264830
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	9048.3	-1266762	0	0	-1266762
		TOTAL		1350132		0	1350132	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-1204.6	168644	0	0	168644
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-466.3	65282	0	0	65282
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-520.3	72842	0	0	72842
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1713.8	-239932	0	0	-239932
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	1777.8	-248892	0	0	-248892
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	95.2	-13328	0	0	-13328
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-124.7	17458	-28.1	-3934	13524
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	106.2	-14868	-14.2	-1988	-16856
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-4824	675360	0	0	675360
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5186.6	726124	0	0	726124
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2961.2	414568	0	0	414568
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2753.6	385504	0	0	385504
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-551	77140	0	0	77140
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-378.1	52934	0	0	52934
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-1451.1	203154	0	0	203154
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	1111.9	-155666	0	0	-155666
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	1741.1	-243754	0	0	-243754
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	686.5	-96110	0	0	-96110
	21	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-I	NP5980A	-96.6	13524	0	0	13524
	22	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-II	NP7498A	-66.9	9366	0	0	9366
	23	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	NP7915A	-898.1	125734	0	0	125734
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	84.6	11844	11844
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	16.3	-2282	0	0	-2282
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-I	ER1018A	252.9	-35406	0	0	-35406
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-I	NP8051A	220	-30800	0	0	-30800
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	71.6	-10024	-0.1	-14	-10038
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	68.1	-9534	-2.7	-378	-9912
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-5269.5	737730	0	0	737730
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-5577	780780	0	0	780780
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-II	ER1099A	219	-30660	0	0	-30660
		TOTAL		3394888		5530	3400418	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-84.50	11830	0	0	11830
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-25.90	3626	0	0	3626
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	16.00	-2240	0	0	-2240
		TOTAL		13216		0	13216	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-18.5	2590	-1194.9	-167286	-164696
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	NP5848A	-223.7	31318	-269.4	-37716	-6398
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	NP5845A	-172.4	24136	-337.4	-47236	-23100
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1477.1	206794	0	0	206794
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	NP7977A	-1900.2	266028	0	0	266028
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-1031.1	144354	0	0	144354
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	47.3	-6622	0	0	-6622
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	51.7	-7238	0	0	-7238
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1041A	-312.5	43750	0	0	43750
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	NP5891A	-652.6	91364	0	0	91364
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-859.1	120274	0	0	120274
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	121.7	-17038	0	0	-17038
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	14.6	-2044	0	0	-2044
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	7254.2	-1015588	0	0	-1015588
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	3379	-473060	0	0	-473060
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-15.3	2142	0	0	2142
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	559.9	-78386	0	0	-78386
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	14.6	-2044	0	0	-2044
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-61.7	8638	0	0	8638
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3076	-430640	0	0	-430640
	21	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-I	NP6548A	1825.9	-255626	0	0	-255626
	22	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-II	NP7557A	2940.7	-411698	0	0	-411698
	23	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-I	ER1071A	-534.2	74788	0	0	74788
	24	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-II	ER1072A	-93.7	13118	0	0	13118
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	-235.9	33026	-307.8	-43092	-10066
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	-243.8	34132	-293.7	-41118	-6986
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	-362.5	50750	-514.2	-71988	-21238
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-677.2	94808	601.2	84168	178976
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-708.5	99190	487.5	68250	167440
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	-391.1	54754	0	0	54754
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	-367.9	51506	0	0	51506
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	259.4	-36316	0	0	-36316
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	274	-38360	0	0	-38360
	34	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-II	ER1040A	5108.2	-715148	0	0	-715148
	35	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-I	ER1130A	4103.7	-574518	0	0	-574518
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-795	111300	0	0	111300
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-603.1	84434	0	0	84434
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	-73.1	-10234	-10234
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	-107.5	-15050	-15050
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-61.1	8554	0	0	8554
		TOTAL		-2412578		-281302	-2693880	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.