



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/1489-1499

Date: 18.09.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)


Sub: Provisional Reactive Energy (VARH) Charges for the week from 27.08.2018-02.09.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

 18/9/18
(J. BANDYOPADHYAY)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 27/08/18 to 02/09/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	152418
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	937188

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 27/08/18 to 02/09/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/L (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-2930.9	410326	0	0	410326
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2620.9	366926	0	0	366926
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1185.6	165984	0	0	165984
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	2.1	-294	-159.2	-22288	-22582
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-42.9	6006	-5.7	-798	5208
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	-4.6	644	-98.9	-13846	-13202
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2229.2	312088	0	0	312088
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-380	53200	-675.9	-94626	-41426
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-160.2	22428	-601	-84140	-61712
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-223.6	31304	0	0	31304
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-174.4	24416	0	0	24416
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	0	0	0	0	0
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	4.3	-602	-183.1	-25634	-26236
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-1808.4	253176	-67.1	-9394	243782
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-891.7	124838	0	0	124838
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	671.2	-93968	0	0	-93968
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	668.6	-93604	0	0	-93604
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-180.3	25242	-577	-80780	-55538
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2332.4	326536	0	0	326536
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	0	0	0	0	0
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	0	0	0	0	0
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2838.7	397418	0	0	397418
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-1656.6	231924	0	0	231924
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-24.5	3430	0	0	3430
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-29.1	4074	0	0	4074
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	-1.2	168	0	0	168
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	0.3	-42	0	0	-42
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	182.1	-25494	0	0	-25494
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	53	-7420	0	0	-7420
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	57.9	-8106	0	0	-8106
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	63.9	-8946	0	0	-8946
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	54.1	-7574	0	0	-7574
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	33	-4620	178	24920	20300
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	1112.2	-155708	0	0	-155708
	35	220 KV PATNA(PG) - KHAGAIL(BSPHCL)	NP5832A	-1583.2	221648	0	0	221648
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1187.3	166222	0	0	166222
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-1702.1	238294	0	0	238294
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	0	0	0
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	0	0	0
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	0	0	0
	42	220 KV MUJAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-261.4	36596	0	0	36596
	43	220 KV MUJAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-152.6	21364	0	0	21364
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2516.8	-352352	0	0	-352352
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2479.1	-347074	0	0	-347074
	46	220 KV KANTI (BSPHCL)-MUJAFFARPUR (PG)-I	NP7398A	-2598.2	363748	0	0	363748
	47	220 KV KANTI (BSPHCL)-MUJAFFARPUR (PG)-II	NP7452A	-2776	388640	0	0	388640
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-I	ER1284A	982.1	-137494	2.4	336	-137158
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-II	ER1289A	960.1	-134414	3.3	462	-133952
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-I	ER1171A	-213.9	29946	-11.2	-1568	28378
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-II	ER1177A	-200.1	28014	-12	-1680	26334
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-I	ER1256A	-255	35700	-8.2	-1148	34552
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-II	ER1258A	-252.5	35350	-7.7	-1078	34272
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-I	ER1172A	-471.6	66024	-11.4	-1596	-471.6
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-II	ER1229A	-469.8	65772	-10.3	-1442	-469.8
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-2117.7	296478	0	0	-2117.7
	57	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-I	ER1279A	307.8	-43092	1.7	238	307.8
	58	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-II	ER1280A	0	0	0	0	0
	59	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-I	ER1375A	0	0	0	0	0
	60	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-II	ER1380A	0	0	0	0	0
	61	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-I	ER1277A	-443.8	62132	-8.4	-1176	-443.8
	62	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-II	ER1278A	20.4	-2856	0.1	14	20.4
	63	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-I	ER1348A	0	0	0	0	0
	64	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-II	ER1376A	0	0	0	0	0
		TOTAL			3392396		-315224	3077172
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-4779.7	669158	0	0	669158
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	961.9	-134666	0	0	-134666
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	4190.1	-586614	0	0	-586614
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2063.6	-288904	0	0	-288904
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1339.4	187516	0	0	187516
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-214.4	30016	0	0	30016
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-188.6	26404	0	0	26404
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	191.2	-26768	0	0	-26768
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	194	-27160	0	0	-27160
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	-5.2	728	-9.7	-1358	-630
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	-4.7	658	-10.2	-1428	-770
		TOTAL		-149632		-2786	-152418	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2560.6	358484	0	0	358484
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-1.4	196	0	0	196
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-21	2940	0	0	2940
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	100.8	-14112	0	0	-14112
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	161.2	-22568	0	0	-22568
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	NP7408A	-731.9	102466	0	0	102466
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	818.5	-114590	0	0	-114590
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1002.5	140350	0	0	140350
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	117.6	-16464	0	0	-16464
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-16.9	2366	0	0	2366
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4644.7	650258	0	0	650258
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3382.8	473592	0	0	473592
	14	400 KV KODERMA(DVC) - Gayi(PG)-I	NP7891A	1907.2	-267008	0	0	-267008
	15	400 KV KODERMA(DVC) - Gayi(PG)-II	NP7890A	2052	-287280	0	0	-287280
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2540.6	355684	0	0	355684
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2611.2	365568	0	0	365568
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-5291.9	740866	0	0	740866
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	84.3	-11802	0	0	-11802
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2842.5	397950	0	0	397950
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7501.3	-1050182	0	0	-1050182
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7585	-1061900	0	0	-1061900
		TOTAL		744814		0	744814	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-60.8	8512	0	0	8512
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-470.9	65926	0	0	65926
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-645.5	90370	0	0	90370
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1845.7	-258398	0	0	-258398
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	1900.5	-266070	0	0	-266070
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	5.2	-728	0	0	-728
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	0	0	-124.6	-17444	-17444
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	0	0	-32.2	-4508	-4508
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-4061	568540	0	0	568540
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5937.6	831264	0	0	831264
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3731.2	522368	0	0	522368
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3366.2	471268	0	0	471268
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1046.9	146566	0	0	146566
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-693.1	97034	0	0	97034
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	NP7916A	-143.9	20146	0	0	20146
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	87.5	-12250	0	0	-12250
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI(PG)-I	NP5980A	0	0	0	0	0
	22	400 KV MENDHASAL (GRIDCO)-PANDIABILI(PG)-II	NP7498A	0	0	0	0	0
	23	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	NP7915A	-137	19180	0.3	42	19222
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	23.3	3262	3262
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	0	0	0
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-I	ER1018A	34.2	-4788	0	0	-4788
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-I	NP8051A	43.4	-6076	0	0	-6076
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	0.4	-56	-6.2	-868	-924
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	0	0	-5.6	-784	-784
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-529.3	74102	0	0	74102
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-577.9	80906	0	0	80906
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-II	ER1099A	13.2	-1848	0	0	-1848
		TOTAL		2445968		-20300	2425668	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-45.70	6398	0	0	6398
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-14.50	2030	0	0	2030
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	14.20	-1988	0	0	-1988
		TOTAL		6440		0	6440	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-1574.6	-220444	-220444
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	NP5848A	-138.5	19390	-257.2	-36008	-16618
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	NP5845A	-101.5	14210	-318	-44520	-30310
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1026	143640	0	0	143640
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	NP7977A	-1285.6	179984	0	0	179984
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-829	116060	0	0	116060
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	22.6	-3164	0	0	-3164
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	17.8	-2492	0	0	-2492
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1041A	-370.3	51842	0	0	51842
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	NP5891A	-662	92680	0	0	92680
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-2033.7	284718	0	0	284718
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	-56	7840	0	0	7840
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	23.7	-3318	0	0	-3318
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	3660	-512400	0	0	-512400
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	1259.7	-176358	0	0	-176358
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-196.8	27552	0	0	27552
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-604.7	84658	0	0	84658
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	8.1	-1134	0	0	-1134
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-44.4	6216	0	0	6216
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	1247.5	-174650	0	0	-174650
	21	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-I	NP6548A	550.7	-77098	0	0	-77098
	22	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-II	NP7557A	1100.4	-154056	0	0	-154056
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-421.7	59038	-5.7	-798	58240
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-68.1	9534	-16.4	-2296	7238
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	-162.7	22778	-286.5	-40110	-17332
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	-177	24780	-270	-37800	-13020
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	-255.1	35714	-478.3	-66962	-31248
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-353.7	49518	615.8	86212	135730
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-329.8	46172	492.2	68908	115080
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	52.3	-7322	0	0	-7322
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	32	-4480	0	0	-4480
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	297.4	-41636	0	0	-41636
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	311.9	-43666	0	0	-43666
	34	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-II	ER1040A	2765.2	-387128	0	0	-387128
	35	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-I	ER1130A	2731.3	-382382	0	0	-382382
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-164.7	23058	0	0	23058
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-167.9	23506	0	0	23506
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	-54.3	-7602	-7602
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	-71.2	-9968	-9968
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-161.4	22596	0	0	22596
		TOTAL		-625800		-311388	-937188	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.