



सत्यमेव जयते

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/5313-5317

Date: 24.10.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 24.09.2018-30.09.2018**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

*for*  24/10/18  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 24/09/18 to 30/09/18**

***REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL***

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	303198
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	485240

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 24/09/18 to 30/09/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-1602.7	224378	0	0	224378
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-1501.6	210224	0	0	210224
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-639.5	89530	0	0	89530
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) - I	NP6001A	-3.2	448	-389.7	-54558	-54110
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) - II	NP6002A	-39.8	5372	-110.8	-15512	-9940
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) - III	NP6003A	-22.8	3192	-302.1	-42294	-39102
	7	220 KV PUSALI (PG) - DEHRI (BSPHCL)	NP6093A	-2691.4	376796	0	0	376796
	8	132 KV ARAH (PG) - ARAH (BSPHCL)	NP6051A	-168.9	23646	-1136.5	-159110	-135464
	9	132 KV ARAH (PG) - DUMRAO (BSPHCL)	NP6054A	-87.6	12264	-1236.3	-173082	-160818
	10	220 KV KHAGAILU(BSPHCL) - ARAH (PG)-I	NP6641A	-30.5	4270	-1.2	-168	4102
	11	220 KV KHAGAILU(BSPHCL) - ARAH (PG)-II	NP6060A	-17	2380	-2.8	-392	1988
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	0	0	0	0	0
	13	132 KV PUSALI(PG)-MOHANIA(BSPHCL)	NP6094A	1.2	-168	-617.8	-86492	-86660
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2052.6	287364	-10.3	-1442	285922
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-1472.9	206206	-78.7	-11018	195188
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	297.1	-41594	0	0	-41594
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	297.8	-41692	0	0	-41692
	18	132 KV ARAH(PG) - JAGDISHPUR(BSPHCL)	NP7425A	-86	9240	-1143.5	-16090	-150850
	19	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1681.6	235424	0	0	235424
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	0	0	33	4620	4620
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	0	0	3.8	532	532
	22	220KV NEW PUSALI(BSPHCL) - PUSALI(PG)	NP8665A	-3890.4	544656	0	0	544656
	23	220KV NEW PUSALI(BSPHCL) - ARA (PG)	NP8664A	-1680	235200	0	0	235200
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-9.6	1344	0	0	1344
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-11.9	1666	0	0	1666
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	0.6	-84	0	0	-84
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	0.2	-28	0	0	-28
	28	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	109.7	-15358	0	0	-15358
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	134.5	-18830	0	0	-18830
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	138	-19320	0	0	-19320
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	156.5	-21910	0	0	-21910
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	137	-19180	0	0	-19180
	33	132 KV PUSALI(PG)-KUDRA(BSPHCL)	NP6095A	6.8	-952	732	102480	101528
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP8665A	574.5	-80430	0	0	-80430
	35	220 KV PATNA(PG) - KHAGAILU(BSPHCL)	NP8632A	-484.9	67886	0	0	67886
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-386.9	54166	0	0	54166
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-538.7	75418	0	0	75418
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	0	0	-31.3	-4382	-4382
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	0	0	-31.3	-4382	-4382
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0	0	-157.3	-22022	-22022
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	0	0	-93.5	-13090	-13090
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-327.5	45850	0	0	45850
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-308.2	43148	0	0	43148
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1907.6	-267064	0	0	-267064
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1874.3	-262402	0	0	-262402
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2154.6	301644	0	0	301644
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2420.5	338870	0	0	338870
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-I	ER1284A	929.6	-130144	0	0	-130144
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-II	ER1289A	917.9	-128506	0	0	-128506
	50	132 KV MOTHARI(DMTCL)-BETIAH(BSPHCL)-I	ER1171A	-411.7	57638	-1.3	-182	57456
	51	132 KV MOTHARI(DMTCL)-BETIAH(BSPHCL)-II	ER1177A	-395.4	55366	-1.4	-196	55160
	52	132 KV MOTHARI(DMTCL)-MOTHARI(BSPHCL)-I	ER1256A	-253.7	35518	-0.6	-84	35434
	53	132 KV MOTHARI(DMTCL)-MOTHARI(BSPHCL)-II	ER1258A	-254.6	35644	-0.6	-84	35560
	54	132 KV MOTHARI(DMTCL)-RAXAUL(BSPHCL)-I	ER1172A	-321.4	44996	-3.3	-462	-321.4
	55	132 KV MOTHARI(DMTCL)-RAXAUL(BSPHCL)-II	ER1229A	-326	45640	-3.1	-434	-326
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8662A	-606.6	84924	0	0	84658
	57	220 KV DARBHANGA(DMTCL)-LOKAM(BSPHCL)-I	ER1279A	348.5	-48790	0	0	348.5
	58	220 KV DARBHANGA(DMTCL)-LOKAM(BSPHCL)-II	ER1280A	0	0	0	0	0
	59	220 KV GAYA(PG)-KHIZRSARAI(BSPHCL)LINE-I	ER1375A	667.8	-93492	0	0	667.8
	60	220 KV GAYA(PG)-KHIZRSARAI(BSPHCL)LINE-II	ER1380A	616.8	-86352	0	0	616.8
	61	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-I	ER1277A	-430.6	60294	0	0	-430.6
	62	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-II	ER1278A	24.4	-3416	0.1	14	24.4
	63	220 KV PURNEA(PG)-BEGUSARAI(BSPHCL)-I	ER1348A	0	0	0	0	0
	64	220 KV PURNEA(PG)-BEGUSARAI(BSPHCL)-II	ER1376A	0	0	0	0	0
		<b>TOTAL</b>		<b>2541070</b>		<b>-641830</b>	<b>1899240</b>	
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-5420.7	758898	0	0	758898
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	0	0	0
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5870A	-1868.1	261534	0	0	261534
	4	220 KV RANCHI(PG) - CHANDIL(JUVNL)	NP5874A	2215.1	-310114	0	0	-310114
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	848.2	-118748	0	0	-118748
	6	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-649.8	90972	0	0	90972
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	0	0	0	0	0
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	0	0	0	0	0
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-I	NP8868A	16.9	-2366	0	0	-2366
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	21.4	-2996	0	0	-2996
	12	132 KV DAL TONGANJ(PG)-DAL TONGANJ(JUVNL)-I	ER1199A	-21	2940	-6.3	-882	2058
	13	132 KV DAL TONGANJ(PG)-DAL TONGANJ(JUVNL)-II	ER1193A	-17.3	2422	-8.8	-1232	1190
		<b>TOTAL</b>		<b>682542</b>		<b>-2114</b>	<b>680428</b>	
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) -II	NP6458A	-931.6	130424	0	0	130424
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	0	0	0	0	0
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-680.8	95312	0	0	95312
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	457.3	-64022	0	0	-64022
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	335.6	-46984	0	0	-46984
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	286.3	-40082	0	0	-40082
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-3005.4	420756	0	0	420756
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-1673.1	234234	0	0	234234
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	597.5	-83650	0	0	-83650
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	945.8	-132412	0	0	-132412
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)H(MAIN)	NP6524A	-2530.8	354312	0	0	354312
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)H(MAIN)	NP6522A	-2495.6	349384	0	0	349384
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-2057	287980	0	0	287980
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	5036.7	-705138	0	0	-705138
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-736.5	103110	0	0	103110
	21	400 KV RANCHI(PG)-RTPS(DVC)-I	NP7871A	4242.4	-593936	0	0	-593936
	22	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7853A	4374.9	-612486	0	0	-612486
		<b>TOTAL</b>		<b>-303198</b>		<b>0</b>	<b>-303198</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO)-I	NP5929A	-196.6	27524	0	0	27524
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO)-II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO)-I	NP5989A	42.1	-5894	0	0	-5894
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO)-II	NP5990A	21.4	-2996	0	0	-2996
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO)-I	ER1096A	213.5	-29890	0	0	-29890
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO)-II	ER1013A	283.1	-39634	0	0	-39634
	7	400 KV INDRAVATI (PG) - INDRAVATI PH	NP5966A	0	0	0	0	0
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	0	0	-54.4	-7616	-7616
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	0	0	-41.3	-5782	-5782
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-4820	674800	0	0	674800
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-1322.2	185108	0	0	185108
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4946.8	692552	0	0	692552
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4828.4	675976	0	0	675976
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-330.8	46312	0	0	46312
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-668.4	93576	0	0	93576
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	0	0	0	0	0
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	-0.3	42	0	0	42
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	22	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	0	0	0	0	0
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	1319.7	184758	184758
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-470	-65800	-65800
	26	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-I	ER1018A	0	0	0	0	0
	27	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-I	NP8051A	0	0	0	0	0
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	0.3	-42	-3.6	-504	-546
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	0	0	-2.8	-392	-392
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-2719.7	380758	0	0	380758
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-2979.2	417088	0	0	417088
	32	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-II	ER1099A	0	0	0	0	0
		<b>TOTAL</b>		<b>3115280</b>		<b>104664</b>	<b>3219944</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-131.90	18466	0	0	18466
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-41.60	5824	0	0	5824
	3	86 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	16.50	-2310	0	0	-2310
		<b>TOTAL</b>		<b>21980</b>		<b>0</b>	<b>21980</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-3635.2	-508928	-508928
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1538A	-18.3	2562	-699.3	-97902	-95340
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-18	2520	-1070.5	-149870	-147350
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-457.1	63994	0	0	63994
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-182.1	25494	0	0	25494
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-606.8	84952	0	0	84952
	7	132 KV SILIGURI (PG) - NUP(WBSETCL)	ER1080A	46.6	-6524	0	0	-6524
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	17.6	-2464	0	0	-2464
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1041A	-361.5	50610	0	0	50610
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	NP5891A	-787.1	110194	0	0	110194
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-2074.8	290472	0	0	290472
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	-254.3	35602	0	0	35602
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	15.2	-2128	0	0	-2128
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	926.2	-129668	0	0	-129668
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	5.8	-812	0	0	-812
	16	400 KV SAGARDIGI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-31.9	4466	0	0	4466
	17	400 KV SAGARDIGI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-18.1	2534	0	0	2534
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	25.9	-3626	0	0	-3626
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-93.3	13062	0	0	13062
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	842.6	-117964	0	0	-117964
	21	400 KV KHARAGPUR(PG) - SAGARDIGI(WBSETCL)-I	NP6548A	0	0	0	0	0
	22	400 KV KHARAGPUR(PG) - SAGARDIGI(WBSETCL)-II	NP7557A	41.4	-5796	0	0	-5796
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)-LINE-I	ER1071A	-333.3	46662	0	0	46662
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)-LINE-II	ER1072A	-85.2	11928	-4.4	-616	11312
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	-53.2	7448	-1296.5	-181510	-174062
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	-56.3	7882	-1211.1	-169554	-161672
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	-86.7	12138	-1951.3	-273182	-261044
	28	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-23.5	3290	2185	305900	309190
	29	400 KV SUBHASGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-27.4	3836	1940.4	271656	275492
	30	400 KV SAGARDIGI(WB)-BERHAMPURE(PG) LINE-I	NP8723A	-52.3	7322	0	0	7322
	31	400 KV SAGARDIGI(WB)-BERHAMPURE(PG) LINE-II	NP8724A	-46.5	6510	0	0	6510
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	38.5	-5390	0	0	-5390
33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	42.8	-5992	0	0	-5992	
34	400 KV PPSPP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	678.1	-94934	0	0	-94934	
35	400 KV PPSPP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	663.9	-92946	0	0	-92946	
36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	0	0	0	0	0	
37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	0	0	0	0	0	
38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	-34.4	-4816	-4816	
39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	-40.8	-5712	-5712	
40	400 KV SAGARDIGI(WB)-FARAKKA(NTPC)-II	ER1131A	-29	4060	0	0	4060	
		<b>TOTAL</b>		<b>329294</b>		<b>-814534</b>	<b>-485240</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVARh.w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.