



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/6168-6178

Date: 16.10.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 17.09.2018-23.09.2018**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(J. BANDYOPADHYAY)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 17/09/18 to 23/09/18**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	1436260

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 17/09/18 to 23/09/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/L (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-I	NP5841A	-2699.8	377972	0	0	377972
	2	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-II	NP5840A	-2653.2	371448	0	0	371448
	3	220 KV BIHARSHARIF(BSPHCL) - BIHARSHARIF(PG)-III	NP5843A	-1626.1	227654	0	0	227654
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP6081A	-6	840	-102.1	-14294	-13454
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP6082A	-41.3	5782	-11.3	-1582	4200
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP6083A	-16.1	2254	-6.1	-8554	-6300
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-5018.6	702604	0	0	702604
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-370.4	51856	-584.3	-81802	-29946
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-296.1	41454	-610	-85400	-43946
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-340.9	47726	0	0	47726
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-304.1	42574	0	0	42574
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	0	0	0	0	0
	13	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-28.1	3934	-93.2	-130368	-126434
	14	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-I	NP7396A	-2578.9	361046	-2.7	-378	360668
	15	220 KV GAYA (PG)-BODHGAYA(BSPHCL) LINE-II	NP8661A	-764.1	106974	0	0	106974
	16	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-I	NP7857A	644.8	-90272	0	0	-90272
	17	220 KV GAYA (PG)-DEHRI(BSPHCL) LINE-II	NP6098A	643.6	-90104	0	0	-90104
	18	132 KV ARAH(PG)- JAGDISHPUR(BSPHCL)	NP7425A	-195.8	27412	-575	-80500	-53088
	19	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2302.5	322350	0	0	322350
	20	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-II	NP8675A	50.4	-7056	0	0	-7056
	21	132 KV BANKA(PG)-SULTANGANJ(BSPHCL) LINE-I	NP8673A	49.7	-6958	0	0	-6958
	22	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2868	401520	0	0	401520
	23	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-2382.6	333564	-0.1	-14	333550
	24	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-I	NP7888A	-101.1	14154	0	0	14154
	25	132 KV LAKHISARAI(PG)-LAKHISARAI(BSPHCL)-II	NP7431A	-102.1	14294	0	0	14294
	26	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-I	NP7887A	2.5	-350	0	0	-350
	27	132 KV LAKHISARAI(PG)-JAMUI(BSPHCL)-II	NP7430A	6.5	-910	0	0	-910
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	205	-28700	0	0	-28700
	29	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	305.4	-42756	0	0	-42756
	30	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	308.8	-43232	0	0	-43232
	31	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	342.1	-47894	0	0	-47894
	32	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	318.1	-44534	0	0	-44534
	33	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	87.3	-12222	871.3	121982	109760
	34	220 KV PATNA(PG) - FATUA(BSPHCL)	NP5865A	1926.1	-269654	0	0	-269654
	35	220 KV PATNA(PG) - KHAGAIL(BSPHCL)	NP5832A	-1477.8	206892	0	0	206892
	36	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-I	NP7864A	-1241.3	173782	0	0	173782
	37	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-II	NP7838A	-1575.2	220528	0	0	220528
	38	132 KV BANKA(PG)-BANKA(BSPHCL)-I	NP7832A	9.1	-1274	0	0	-1274
	39	132 KV BANKA(PG)-BANKA(BSPHCL)-II	NP8694A	7.9	-1106	0	0	-1106
	40	132 KV BANKA(PG)-SABOUR(BSPHCL)-I	NP7834A	0.2	-28	0	0	-28
	41	132 KV BANKA(PG)-SABOUR(BSPHCL)-II	NP8696A	1.5	-210	0	0	-210
	42	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-104.4	14616	0	0	14616
	43	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	87.6	-12264	0	0	-12264
	44	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1386.5	-194110	0	0	-194110
	45	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2067.2	-289408	0	0	-289408
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1934.6	270844	0	0	270844
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2109	295260	0	0	295260
	48	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-I	ER1284A	1464.1	-204974	0	0	-204974
	49	220 KV DARBHANGA(DMTCL)-MOTIPUR(BSPHCL)-II	ER1289A	1446.3	-202482	0	0	-202482
	50	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-I	ER1171A	-233.1	32634	-0.5	-70	32564
	51	132 KV MOTIHARI(DMTCL)-BETIAH(BSPHCL)-II	ER1177A	-217.8	30492	-0.4	-56	30436
	52	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-I	ER1256A	-252	35280	-0.2	-28	35252
	53	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-II	ER1258A	-254	35560	-0.2	-28	35532
	54	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-I	ER1172A	-167.7	23478	-1.1	-154	-167.7
	55	132 KV MOTIHARI(DMTCL)-RAXAUL(BSPHCL)-II	ER1229A	-162.7	22778	-1.1	-154	-162.7
	56	220 KV PATNA(PG)-SIPARA(BSPHCL) LINE-III	NP8862A	-2097.9	293706	0	0	-2097.9
	57	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-I	ER1279A	560.6	-78484	0	0	560.6
	58	220 KV DARBHANGA(DMTCL)-LOKAHI(BSPHCL)-II	ER1280A	0	0	0	0	0
	59	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-I	ER1375A	1140.2	-159628	0	0	1140.2
	60	220 KV GAYA(PG)-KHIZIRSARAI(BSPHCL)-II	ER1380A	1111.6	-155624	0	0	1111.6
	61	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-I	ER1277A	-173.3	24262	0	0	-173.3
	62	220 KV DARBHANGA(DMTCL)-DARBHANGA(BSPHCL)-II	ER1278A	32.3	-4522	0	0	32.3
	63	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-I	ER1348A	0	0	0	0	0
	64	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-II	ER1376A	0	0	0	0	0
		<b>TOTAL</b>			<b>3148768</b>		<b>-281400</b>	<b>2867368</b>
JUVNL	1	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-I	NP6103A	-5226.2	731668	0	0	731668
	2	220 KV RAMCHANDRAPUR(JUVNL) - JAMSHEDPUR(PG)-II	NP5119A	0	0	-0.2	-28	-28
	3	220 KV RANCHI(PG) - HATIA(JUVNL)	NP5879A	59.4	-8316	0	0	-8316
	4	220 KV RANCHI(PG) - CHANDLI(JUVNL)	NP5874A	4009.1	-561274	0	0	-561274
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2586.4	-362096	0	0	-362096
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1479.4	207116	0	0	207116
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-484.6	67844	0	0	67844
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-452.6	63364	0	0	63364
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - II	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8868A	407.3	-57022	0	0	-57022
	11	220 KV CHAIBASA(PG)-CHAIBASA(JUVNL)-II	NP8869A	402.6	-56364	0	0	-56364
	12	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-I	ER1199A	-38.9	5446	-1.3	-182	5264
	13	132 KV DALTONGANJ(PG)-DALTONGANJ(JUVNL)-II	ER1193A	-32.5	4550	-1.7	-238	4312
		<b>TOTAL</b>		<b>34916</b>		<b>-448</b>	<b>34468</b>	
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) - I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) - II	NP6458A	-1692.4	236936	0	0	236936
	3	220 KV MAITHON (PG) - DHANBAD (DVC) - I	NP6529A	-155.8	21812	0	0	21812
	4	220 KV MAITHON (PG) - DHANBAD (DVC) - II	ER1147A	-348.4	48776	0	0	48776
	5	220 KV MAITHON (PG) - KALYANESWARARI (DVC) - I	NP6509A	727.4	-101836	0	0	-101836
	6	220 KV MAITHON (PG) - KALYANESWARARI (DVC) - II	NP6510A	894.8	-125272	0	0	-125272
	7	400 KV TATA JAMSHEDPUR (DVC)- BARI PADA(PG)	NP7408A	-1351.8	189252	0	0	189252
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	2242.5	-313950	0	0	-313950
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-226.1	31654	0	0	31654
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-339.5	47530	0	0	47530
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-6495.5	909370	0	0	909370
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4971.1	695954	0	0	695954
	14	400 KV KODERMA(DVC) - Gay@PG-I	NP7891A	1921.8	-269052	0	0	-269052
	15	400 KV KODERMA(DVC) - Gay@PG-II	NP7890A	2319	-324660	0	0	-324660
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3566.1	499254	0	0	499254
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3673	514220	0	0	514220
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-5883.3	823662	0	0	823662
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2976.4	-416696	0	0	-416696
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2963.3	414862	0	0	414862
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	8834.5	-1236830	0	0	-1236830
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8853.5	-1239490	0	0	-1239490
		<b>TOTAL</b>		<b>405496</b>		<b>0</b>	<b>405496</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-17.4	2436	0	0	2436
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	709.4	-99316	0	0	-99316
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	420.7	-58898	0	0	-58898
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1150.7	-161098	0	0	-161098
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	1241.2	-173768	0	0	-173768
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1599.9	-223986	0	0	-223986
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-122.5	17150	-135.5	-18970	-1820
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	54.7	-7658	-103.4	-14476	-22134
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3956.6	553924	0	0	553924
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3772	528080	0	0	528080
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3695.4	517356	0	0	517356
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3593.2	503048	0	0	503048
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-498	69720	0	0	69720
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-329.8	46172	0	0	46172
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-1559.3	218302	0	0	218302
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	3483	-487620	0	0	-487620
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	4632.8	-648592	0	0	-648592
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	3281.3	-459382	0	0	-459382
	21	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-I	NP5980A	-401.4	56196	0	0	56196
	22	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-II	NP7498A	-327.9	45906	0	0	45906
	23	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	NP7915A	-1627.3	227822	0	0	227822
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	8.9	-1246	30.3	4242	2996
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	194.2	-27188	0	0	-27188
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-I	ER1018A	577.8	-80892	0	0	-80892
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-I	NP8051A	454.8	-63672	0	0	-63672
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	14.7	-2058	-14.1	-1974	-4032
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	15.1	-2114	-15.3	-2142	-4256
	30	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-7703.6	1078504	0	0	1078504
	31	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-8007.6	1121064	0	0	1121064
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-II	ER1099A	545	-76300	0	0	-76300
		<b>TOTAL</b>		<b>2411892</b>		<b>-33320</b>	<b>2378572</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-83.20	11648	-0.7	-98	11550
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-32.60	4564	-0.3	-42	4522
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.3	-42	-42
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	17.50	-2450	0	0	-2450
		<b>TOTAL</b>		<b>13762</b>		<b>-182</b>	<b>13580</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-1725.9	-241626	-241626
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	NP5848A	-82.3	11522	-592.3	-82922	-71400
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	NP5845A	-6.7	938	-754.8	-105672	-104734
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1387.1	194194	0	0	194194
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1634.9	228886	0	0	228886
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-924.7	129458	0	0	129458
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	10.4	-1456	0	0	-1456
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	6.4	-896	0	0	-896
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1041A	-426.5	59710	0	0	59710
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	NP5891A	-866.6	121324	0	0	121324
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-1474.4	206416	0	0	206416
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	92.2	-12908	0	0	-12908
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	4534.3	-634802	0	0	-634802
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	2056.3	-287882	0	0	-287882
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1288.3	180362	0	0	180362
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-445.6	62384	0	0	62384
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	20.4	-2856	0	0	-2856
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-66.9	9366	0	0	9366
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3668.7	-513618	0	0	-513618
	21	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-I	NP6548A	1189.7	-166558	0	0	-166558
	22	400 KV DURGAPUR(PG) - SAGARDIGHI(WBSETCL)-II	NP7557A	2386.1	-334054	0	0	-334054
	23	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-I	ER1071A	-404.7	56658	0	0	56658
	24	220 KV DALKHOILA(PG)-DALKHOILA(WBSETCL)LINE-II	ER1072A	-84.5	11830	0	0	11830
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	-108.6	15204	-634.8	-88872	-73668
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	-118.4	16576	-623.1	-87234	-70658
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	-152.2	21308	-1070.8	-149912	-128604
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-695.5	97370	1303.6	182504	279874
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-574.2	80388	1136.6	159124	239512
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	271.6	-38024	0	0	-38024
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	256.3	-35882	0	0	-35882
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	332.9	-46606	0	0	-46606
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	355.4	-49756	0	0	-49756
	34	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-II	ER1040A	2927.7	-409878	0	0	-409878
	35	400 KV PPSP NEW (WB)-RANCHI NEW(PG)-I	ER1130A	2881.8	-403452	0	0	-403452
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-1096.1	153454	0	0	153454
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-1028.4	143976	0	0	143976
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	-16.7	-2338	-2338
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	-18	-2520	-2520
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-860.8	120512	0	0	120512
		<b>TOTAL</b>		<b>-1016792</b>		<b>-419468</b>	<b>-1436260</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.