



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/6591-6601

Date: 11.12.2018

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 19.11.2018-25.11.2018**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 30.11.2018.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,



(J. Bandyopadhyay)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 19/11/18 to 25/11/18**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	1410864
JUVNL	POOL	328804
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	3887422

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

  
MEMBER SECRETARY

## DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 19/11/18 to 25/11/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE
BSPHCL	1	220 KV BIHARSHARIF (BSPHCL) - BIHARSHARIF (PG)-I	NP5841A	-2492	348880	0	0	348880
	2	220 KV BIHARSHARIF (BSPHCL) - BIHARSHARIF (PG)-II	NP5840A	-3365	471100	0	0	471100
	3	220 KV BIHARSHARIF (BSPHCL) - BIHARSHARIF (PG)-III	NP5843A	-2343	328020	0	0	328020
	4	132 KV PURNEA (PG) - PURNEA (BSPHCL) -I	NP8081A	109.7	-15358	0	0	-15358
	5	132 KV PURNEA (PG) - PURNEA (BSPHCL) -II	NP8082A	121.5	-17010	0	0	-17010
	6	132 KV PURNEA (PG) - PURNEA (BSPHCL) -III	NP8083A	196	-23240	0	0	-23240
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP8093A	-5.2	726	0	0	726
	8	132 KV ARAH (PG)- ARAH (BSPHCL)	NP6051A	-1431	200340	0	0	200340
	9	132 KV ARAH (PG)- DUMRAO (BSPHCL)	NP6054A	-834.2	116788	0	0	116788
	10	220 KV KHAGAIL (BSPHCL) - ARAH (PG)-I	NP8641A	-1127.2	157808	0	0	157808
	11	220 KV KHAGAIL (BSPHCL) - ARAH (PG)-II	NP6050A	-1095.1	153314	0	0	153314
	12	132 KV PURNEA (PG) - KISHANGANJ (BSPHCL)	NP6084A	567.3	-79422	0	0	-79422
	13	132 KV PUSAULI (PG)-MOHANIA (BSPHCL)	NP6094A	264	-36980	0	0	-36980
	14	220 KV GAYA (PG)-BODHGAYA (BSPHCL) LINE-I	NP7396A	-1402.1	196294	0	0	196294
	15	220 KV GAYA (PG)-BODHGAYA (BSPHCL) LINE-II	NP8661A	-1457.3	204022	0	0	204022
	16	220 KV GAYA (PG)-DEHRI (BSPHCL) LINE-I	NP7857A	1157.9	-162106	0	0	-162106
	17	220 KV GAYA (PG)-DEHRI (BSPHCL) LINE-II	NP6098A	1155.4	-161756	0	0	-161756
	18	132 KV ARAH (PG)- JAGDISHPUR (BSPHCL)	NP7425A	-628.7	85018	0	0	85018
	19	132 KV KAHALGAON (NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2018.9	282546	0	0	282546
	20	132 KV BANKA (PG)-SULTANGANJ (BSPHCL) LINE-II	NP8675A	0	0	0	0	0
	21	132 KV BANKA (PG)-SULTANGANJ (BSPHCL) LINE-I	NP8673A	0	0	0	0	0
	22	220KV NEW PUSAULI (BSPHCL) - PUSAULI (PG)	NP8685A	-467.2	65408	0	0	65408
	23	220KV NEW PUSAULI (BSPHCL) - ARA (PG)	NP8684A	-3031.6	424424	0	0	424424
	24	132 KV LAKHISARAI (PG)-LAKHISARAI (BSPHCL)-I	NP7888A	-18	2520	0	0	2520
	25	132 KV LAKHISARAI (PG)-LAKHISARAI (BSPHCL)-II	NP7431A	-19	2660	0	0	2660
	26	132 KV LAKHISARAI (PG)-JAMUI (BSPHCL)-I	NP7887A	0.8	-112	0	0	-112
	27	132 KV LAKHISARAI (PG)-JAMUI (BSPHCL)-II	NP7430A	1	-140	0	0	-140
	28	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	296.3	-41482	0	0	-41482
	29	220 KV KISHANGANJ (PG)-KISHANGANJ (BSPTCL)-I	ER1283A	1272.7	-178178	0	0	-178178
	30	220 KV KISHANGANJ (PG)-KISHANGANJ (BSPTCL)-II	ER1296A	1294.1	-181174	0	0	-181174
	31	220 KV KISHANGANJ (PG)-KISHANGANJ (BSPTCL)-III	ER1159A	1417	-198380	0	0	-198380
	32	220 KV KISHANGANJ (PG)-KISHANGANJ (BSPTCL)-IV	ER1154A	1346.4	-188496	0	0	-188496
	33	132 KV PUSAULI (PG)-KUDRA (BSPHCL)	NP8095A	-80.6	11264	0	0	11264
	34	220 KV PATNA (PG) - FATUA (BSPHCL)	NP8685A	3973.5	-556290	0	0	-556290
	35	220 KV PATNA (PG) - KHAGAIL (BSPHCL)	NP8832A	-1195.8	167412	0	0	167412
	36	220 KV PATNA (PG)-SIPARA (BSPHCL) LINE-I	NP7864A	-1036.9	145166	0	0	145166
	37	220 KV PATNA (PG)-SIPARA (BSPHCL) LINE-II	NP7838A	-420.2	58828	0	0	58828
	38	132 KV BANKA (PG)-BANKA (BSPHCL)-I	NP7832A	0	0	0	0	0
	39	132 KV BANKA (PG)-BANKA (BSPHCL)-II	NP8694A	0	0	0	0	0
	40	132 KV BANKA (PG)-SABOUR (BSPHCL)-I	NP7834A	0	0	0	0	0
	41	132 KV BANKA (PG)-SABOUR (BSPHCL)-II	NP8696A	0	0	0	0	0
	42	220 KV MUZAFFARPUR (PG)-HAJIPUR (BSPHCL) LINE-I	ER1226A	1288.8	-180572	0	0	-180572
	43	220 KV MUZAFFARPUR (PG)-HAJIPUR (BSPHCL) LINE-II	ER1228A	1151.3	-161182	0	0	-161182
	44	220 KV PURNEA (PG)-MADHEPURA (BSPHCL) LINE-I	ER1175A	3412.6	-477764	0	0	-477764
	45	220 KV PURNEA (PG)-MADHEPURA (BSPHCL) LINE-II	ER1176A	3421.1	-478954	0	0	-478954
	46	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1892.9	265006	0	0	265006
	47	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1907.7	267078	0	0	267078
	48	220 KV DARBHANGA (DMTCL)-MOTIPUR (BSPTCL)-I	ER1284A	4916.3	-688282	0	0	-688282
	49	220 KV DARBHANGA (DMTCL)-MOTIPUR (BSPTCL)-II	ER1289A	4589.5	-684530	0	0	-684530
	50	132 KV MOTHARI (DMTCL)-BETIAH (BSPTCL)-I	ER1171A	808.7	-113218	0	0	-113218
	51	132 KV MOTHARI (DMTCL)-BETIAH (BSPTCL)-II	ER1177A	788.6	-110404	0	0	-110404
	52	132 KV MOTHARI (DMTCL)-MOTIHARI (BSPTCL)-I	ER1256A	-91.5	12810	0	0	12810
	53	132 KV MOTHARI (DMTCL)-MOTIHARI (BSPTCL)-II	ER1258A	-79.5	11130	0	0	11130
	54	132 KV MOTHARI (DMTCL)-RAKHAL (BSPTCL)-I	ER1172A	-849.8	118972	0	0	-849.8
	55	132 KV MOTHARI (DMTCL)-RAKHAL (BSPTCL)-II	ER1229A	-831.5	116410	0	0	-831.5
	56	220 KV PATNA (PG)-SIPARA (BSPHCL) LINE-III	NP8682A	-2033.6	284704	0	0	-2033.6
	57	220 KV DARBHANGA (DMTCL)-LOKAH (BSPTCL)-I	ER1279A	5163.9	-722946	0	0	-722946
	58	220 KV DARBHANGA (DMTCL)-LOKAH (BSPTCL)-II	ER1280A	0	0	0	0	0
	59	220 KV GAYA (PG)-KHIZIR SARAI (BSPTCL)-I	ER1375A	1610.8	-225512	0	0	-225512
	60	220 KV GAYA (PG)-KHIZIR SARAI (BSPTCL)-II	ER1380A	1601.7	-224238	0	0	-224238
	61	220 KV DARBHANGA (DMTCL)-DARBHANGA (BSPTCL)-I	ER1277A	-55.3	7742	0	0	-55.3
	62	220 KV DARBHANGA (DMTCL)-DARBHANGA (BSPTCL)-II	ER1278A	90.5	-12670	0	0	-12670
	63	220 KV PURNEA (PG)-BEGUSARA (BSPTCL)-I	ER1348A	0	0	0	0	0
	64	220 KV PURNEA (PG)-BEGUSARA (BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			-1410864	0	0	-1410864
JUVNL	1	220 KV RAMCHANDRAPUR (JUVNL) - JAMSHEDPUR (PG)-I	NP6103A	-5213.7	729918	0	0	729918
	2	220 KV RAMCHANDRAPUR (JUVNL) - JAMSHEDPUR (PG)-II	NP6109A	0	0	0	0	0
	3	220 KV RANCHI (PG) - HATIA (JUVNL)	NP5879A	19.9	-2786	0	0	-2786
	4	220 KV RANCHI (PG) - CHANDI (JUVNL)	NP5874A	4878.8	-682752	0	0	-682752
	5	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3468.2	-485548	0	0	-485548
	6	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1622.8	227192	0	0	227192
	7	220 KV MAITHON (PG) - DUMKA (JUVNL) - I	NP8727A	-204.6	28644	0	0	28644
	8	220 KV MAITHON (PG) - DUMKA (JUVNL) - II	NP7399A	-166.6	23324	0	0	23324
	9	220 KV RANCHI (PG) - HATIA (JUVNL) - I	NP7464A	0	0	0	0	0
	10	220 KV CHAIBASA (PG)-CHAIBASA (JUVNL)-I	NP8868A	590.6	-82684	0	0	-82684
	11	220 KV CHAIBASA (PG)-CHAIBASA (JUVNL)-II	NP8869A	600.8	-84112	0	0	-84112
	12	132 KV DALTONGANJ (PG)-DALTONGANJ (JUVNL)-I	ER1199A	0	0	0	0	0
	13	132 KV DALTONGANJ (PG)-DALTONGANJ (JUVNL)-II	ER1193A	0	0	0	0	0
		TOTAL			-328804	0	0	-328804
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) -II	NP6458A	-3707.2	519008	0	0	519008
	3	220 KV MAITHON (PG) - CHANBAD (DVC) -I	NP6529A	-2	280	0	0	280
	4	220 KV MAITHON (PG) - CHANBAD (DVC) -II	ER1147A	-163.2	22848	0	0	22848
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	88	-9520	0	0	-9520
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	232.8	-32592	0	0	-32592
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA (PG)	NP7408A	-1998.2	279746	0	0	279746
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	4519.5	-632730	0	0	-632730
	9	400 KV MEJIA (DVC)-MAITHON (PG)	NP6557A	-447.7	62678	0	0	62678
	10	400 KV MEJIA (DVC)-MAITHON (PG) LINE-I	ER1008A	-476.2	66668	0	0	66668
	11	400 KV MEJIA (DVC)-MAITHON (PG) LINE-II	ER1031A	-603.1	84434	0	0	84434
	12	400 KV KODERMA (DVC) - BIHARSHARIFF (PG)-LINE-I	NP7831A	-6283.3	879662	0	0	879662
	13	400 KV KODERMA (DVC) - BIHARSHARIFF (PG)-LINE-II	NP7830A	-3901.5	546210	0	0	546210
	14	400 KV KODERMA (DVC) - GAYA (PG)-I	NP7891A	604.1	-84574	0	0	-84574
	15	400 KV KODERMA (DVC) - GAYA (PG)-II	NP7890A	507.4	-71036	0	0	-71036
	16	400 KV DSTPS (DVC)-JAMSHEDPUR (PG)-II (MAIN)	NP6524A	-5310.8	743512	0	0	743512
	17	400 KV DSTPS (DVC)-JAMSHEDPUR (PG)-II (MAIN)	NP6522A	-5348.8	748832	0	0	748832
	18	400 KV RTPS (DVC)-RANCHI (PG)	NP7973A	-8147.3	1140622	0	0	1140622
	19	400 KV RTPS (DVC)-MAITHON (PG)	NP7974A	4192.4	-586936	0	0	-586936
	20	400KV MEJIA (DVC) - JAMSHEDPUR (PG)	NP6508A	-5798.4	811776	0	0	811776
	21	400 KV RANCHI (PG)-RTPS (DVC)-I	NP7871A	10195.2	-1427328	0	0	-1427328
	22	400 KV RANCHI (PG)-RTPS (DVC)-II	NP7853A	10143.6	-1420104	0	0	-1420104
		TOTAL			1641458	0	0	1641458



EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO)-I	NP5929A	0	0	0	0	0
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO)-II	NP5933A	0	0	0	0	0
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO)-I	NP5989A	1546.9	-216566	0	0	-216566
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO)-II	NP5990A	1344.8	-188272	0	0	-188272
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO)-I	ER1096A	196.8	-27552	0	0	-27552
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO)-II	ER1013A	245.8	-34412	0	0	-34412
	7	400 KV INDRAVATI (PG) - INDRAVATI PH	NP5986A	351.7	-49238	0	0	-49238
	8	132 KV BARIPADA (PG) - BARIPADA (GRIDCO)	NP5916A	-130.8	18312	0	0	18312
	9	132 KV BARIPADA (PG) - BANGRIPOSHI (GRIDCO)	NP5912A	226	-31640	0	0	-31640
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1649	230440	0	0	230440
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3937.6	551264	0	0	551264
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3938	551320	0	0	551320
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3289	457660	0	0	457660
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	165.9	-23226	0	0	-23226
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	238.1	-33334	0	0	-33334
	16	220 KV BALIMELA (GRIDCO)-UPPER SILERUI(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-1041.5	145810	0	0	145810
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	17	-2380	0	0	-2380
	20	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABLI(PG)-I	NP5980A	-91.9	12866	0	0	12866
	22	400 KV MENDHASAL (GRIDCO)-PANDIABLI(PG)-II	NP7408A	-35.9	5026	-0.3	-42	4984
	23	400 KV DUBURI (GRIDCO)-PANDIABLI(PG)	NP7915A	-1479.2	207088	0	0	207088
	24	220 KV BOLANGIR (PG)-KATAPALI (GRIDCO)	NP8790A	0	0	100	14000	14000
	25	220 KV BOLANGIR (PG)-SADEIPALI (GRIDCO)	NP8789A	0	0	0	0	0
	26	220 KV PANDIABLI (PG)-ATRI (GRIDCO)-I	ER1018A	1364.5	-191030	0	0	-191030
	27	220 KV PANDIABLI (PG)-SAMANGARA (GRIDCO)-I	NP8051A	637.8	-89292	0	0	-89292
	28	132 KV BARIPADA (PG)-JALESWAR (GRIDCO)	NP5914A	89.3	-12502	0	0	-12502
	29	132 KV BARIPADA (PG)-BHOGRAI (GRIDCO)	ER1115A	49.2	-6888	0	0	-6888
	30	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-6394.5	895230	0	0	895230
	31	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-6594.6	923244	0	0	923244
	32	220 KV PANDIABLI (PG)-ATRI (GRIDCO)-II	ER1099A	1247.9	-174706	0	0	-174706
			<b>TOTAL</b>		<b>2917222</b>		<b>13958</b>	<b>2931180</b>
	SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-129.20	18088	0	0
2		132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-122.20	17108	-34.8	-4872	12236
3		86 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.9	-126	0
4		132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP8029A	0.00	0	0	0	0
5		132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP8028A	0.00	0	0	0	0
6		132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.20	-2128	0	0	-2128
		<b>TOTAL</b>		<b>33068</b>		<b>-4998</b>	<b>28070</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-2278.9	319046	-142.6	-19964	299082
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	2032.9	-284606	0	0	-284606
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	2038.6	-285404	0	0	-285404
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-785.8	110012	0	0	110012
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-795.6	111384	0	0	111384
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-99.6	13944	0	0	13944
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1385.7	193996	0	0	193996
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1154.1	161574	0	0	161574
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2738.2	383348	0	0	383348
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1585	221900	0	0	221900
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	5528.1	-773934	0	0	-773934
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	6248.6	-874804	0	0	-874804
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-68.9	9646	0	0	9646
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6327.6	-885864	0	0	-885864
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	6175.6	-864584	0	0	-864584
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-2056.3	287882	0	0	287882
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-3063.4	428876	0	0	428876
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-94.7	13258	0	0	13258
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	16.6	-2324	0	0	-2324
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	5099.4	-713916	0	0	-713916
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	5760.3	-806442	0	0	-806442
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	8362.7	-1170778	0	0	-1170778
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-505.2	70728	0	0	70728
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-295.4	41356	0	0	41356
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-3063.8	428904	0	0	428904
	29	400 KV SUBHASGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-3126.2	437688	0	0	437688
	30	400 KV SAGARDIGHI (WB)-BERHAMPORE (PG) LINE-I	NP8723A	1857.1	-259994	0	0	-259994
	31	400 KV SAGARDIGHI (WB)-BERHAMPORE (PG) LINE-II	NP8724A	1895.1	-233114	0	0	-233114
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-550.8	77112	0	0	77112
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-426.6	59724	0	0	59724
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	2445.4	-342356	0	0	-342356
35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	2274.1	-318374	0	0	-318374	
36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-2249.2	314888	0	0	314888	
37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-2044.2	286188	0	0	286188	
38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	1073.1	-150234	0	0	-150234	
39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	981.9	-137468	0	0	-137468	
40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-1895	265300	0	0	265300	
		<b>TOTAL</b>		<b>-3867458</b>		<b>-19964</b>	<b>-3887422</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVArh.w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.