



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /7315-25

Date: 04.01.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 03.12.2018-09.12.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 14.12.2018.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 03/12/18 to 09/12/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	1988462
SIKKIM	POOL	0
WBSETCL	POOL	3530660

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 03/12/18 to 09/12/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVAH_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-872.9	122206	0	0	122206
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2642.5	369950	0	0	369950
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1300.9	182126	0	0	182126
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	155.3	-21742	-0.3	-42	-21784
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	199.9	-27986	0	0	-27986
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	195.5	-27370	0	0	-27370
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1845.4	258356	0	0	258356
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-525.6	73584	-0.1	-14	73570
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-587.8	82292	0	0	82292
	10	220 KV KHAGAILI(BSPHCL) - ARAH (PG)-I	NP8641A	-1476.1	206654	0	0	206654
	11	220 KV KHAGAILI(BSPHCL) - ARAH (PG)-II	NP6060A	-911.5	127610	0	0	127610
	12	132 KV PUSAULI(PG)-MOHANAJI(BSPHCL)	NP6094A	35.6	-4984	-0.2	-28	-5012
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARAH 160 MVA ICT-3	ER1313A	874.6	-122444	0.1	14	-122430
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1849.8	258972	0	0	258972
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-141.5	19810	0	0	19810
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-3087.2	432208	0	0	432208
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	157.9	-22106	0	0	-22106
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	164.5	-23030	0	0	-23030
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	303.6	-42504	0	0	-42504
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	1152.9	-161406	0	0	-161406
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	1171	-163940	0	0	-163940
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	1284.3	-179802	0	0	-179802
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	1215.2	-170128	0	0	-170128
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	77	-10780	0	0	-10780
	27	HV side of 400/220 Patna ICT-1	ER1408A	-884.1	123774	0	0	123774
	28	HV side of 400/220 Patna ICT-2	ER1407A	0	0	0	0	0
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1788.7	250418	0	0	250418
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-326.3	45682	0	0	45682
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-330.4	46256	0	0	46256
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	1411.6	-197624	0	0	-197624
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	1276.5	-178710	0	0	-178710
	34	220 KV PURNEA(PG)-MADEHPURA(BSPHCL) LINE-I	ER1175A	2895.1	-405314	0	0	-405314
	35	220 KV PURNEA(PG)-MADEHPURA(BSPHCL) LINE-II	ER1176A	2898.5	-405790	0	0	-405790
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1122.4	157136	0	0	157136
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1129.2	158088	0	0	158088
	38	HV side of 400/220 Darbhanga DMTC ICT-1	ER1274A	0.6	-84	0	0	-84
	39	HV side of 400/220 Darbhanga DMTC ICT-2	ER1275A	6.1	-854	0	0	-854
	40	132 KV MOTIHARI(DMTC)-MOTIHARI(BSPHCL)-I	ER1256A	-266.3	37282	0	0	37282
	41	132 KV MOTIHARI(DMTC)-MOTIHARI(BSPHCL)-II	ER1258A	-256.8	35962	0	0	35962
	42	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-II	ER1376A	0	0	0	0	0
		TOTAL		821758		-70	821688	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3783.6	529704	0	0	529704
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3287.3	460222	0	0	460222
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-1565.4	219156	0	0	219156
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5879A	1262.9	-176906	0	0	-176906
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1574.4	-220416	0	0	-220416
	6	220 KV FARAKKA (NTPC)-LALAMATIA (JUVNL)	NP5211A	3874.8	-542472	0	0	-542472
	7	132 KV KAHALGAON (NTPC)-LALAMATIA (JUVNL)	NP5244A	-1519.7	212758	0	0	212758
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-295	41300	0	0	41300
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-268.2	37548	0	0	37548
	10	HV side meter data of 400/220 Chaibassa ICT-1	NP8637A	246.8	-34552	0	0	-34552
	11	HV side meter data of 400/220 Chaibassa ICT-2	NP8678A	218	-30520	0	0	-30520
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-76.5	10710	0	0	10710
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-72.8	10192	0	0	10192
		TOTAL		516824		0	516824	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2231.6	312424	0	0	312424
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-141	19740	0	0	19740
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-348.4	48776	0	0	48776
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	517	-72380	0	0	-72380
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	717	-100380	0	0	-100380
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-3997.5	559650	0	0	559650
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	3192.6	-446964	0	0	-446964
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	2561.8	-358652	0	0	-358652
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-330.6	46284	0	0	46284
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-670.9	93926	0	0	93926
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-5704.4	798616	0	0	798616
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3991.6	558824	0	0	558824
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	830.9	-116326	0	0	-116326
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	700.8	-98112	0	0	-98112
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-HI(MAIN)	NP6524A	-5508	771120	0	0	771120
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-HI(MAIN)	NP6522A	-5560.3	778442	0	0	778442
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6436.8	901152	0	0	901152
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2729.7	-382158	0	0	-382158
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4611.9	645666	0	0	645666
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7702.1	-1078294	0	0	-1078294
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7660.7	-1072498	0	0	-1072498
		TOTAL		1808856		0	1808856	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeyapore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeyapore ICT-2	ER1571A	-10.2	1428	0	0	1428
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-59.8	8372	0	0	8372
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-65.9	9226	0	0	9226
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2930.6	410284	0	0	410284
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2400.8	336112	0	0	336112
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2018.6	282604	0	0	282604
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1957	273980	0	0	273980
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-276.8	38752	0	0	38752
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-3184	445760	0	0	445760
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	15841.6	-2217824	0	0	-2217824
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	14495.7	-2029398	0	0	-2029398
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	12484.7	-1747858	0	0	-1747858
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	-759.9	106386	0	0	106386
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	-815.5	114170	0	0	114170
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-4426.8	619752	0	0	619752
	23	HV side meter of 400/220 Bolangi-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangi-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-1503	210420	0	0	210420
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	-1545.8	216412	0	0	216412
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3325.4	465556	0	0	465556
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3338.6	467404	0	0	467404
		TOTAL		-1988462		0	-1988462	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-68.50	9590	0	0	9590
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-93.30	13062	0	0	13062
	3	86 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.4	-56	-56
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	16.10	-2254	0	0	-2254
			TOTAL		20398		-56	20342
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-3349.8	468972	-326.8	-45752	423220
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	2481.9	-347466	0	0	-347466
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	2408.7	-337218	0	0	-337218
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-594.9	83286	0	0	83286
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-611.9	85666	0	0	85666
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-46.9	6566	0	0	6566
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-956.9	133966	0	0	133966
	8	132 KV SILIGURI (PG) - NSU (WBSETCL)	NP5889A	-792.6	110964	0	0	110964
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2802.3	392322	0	0	392322
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-956	133840	0	0	133840
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	5265	-737100	0	0	-737100
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	6375.8	-892612	0	0	-892612
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-42.7	5978	0	0	5978
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6903.6	-966504	0	0	-966504
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	7282.8	-1019592	0	0	-1019592
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1953.8	273532	0	0	273532
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-3990.8	558712	0	0	558712
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-99.4	13916	0	0	13916
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	48.5	-6790	0	0	-6790
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	3532	-494480	0	0	-494480
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	4519.3	-632702	0	0	-632702
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	5703.2	-798448	0	0	-798448
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-I	ER1071A	-593.4	83076	0	0	83076
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-II	ER1072A	-213	29820	0	0	29820
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP818A	0	0	0	0	0
	28	400 KV SUBHASGRAM (PG) - HALDIA CESC (WB) LINE-I	ER1141A	-3290.2	460628	0	0	460628
	29	400 KV SUBHASGRAM (PG) - HALDIA CESC (WB) LINE-II	NP7937A	-3345.4	468356	0	0	468356
	30	400 KV SAGARDIGHI (WB) - BERHAMPURE (PG) LINE-I	NP8723A	2534.9	-354886	0	0	-354886
	31	400 KV SAGARDIGHI (WB) - BERHAMPURE (PG) LINE-II	NP8724A	2284.7	-319858	0	0	-319858
	32	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-I	NP8731A	-559.6	78344	0	0	78344
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-II	NP8720A	-485.5	67970	0	0	67970
	34	400 KV PPS NEW (WB) - RANCHI NEW (PG)-I	ER1040A	3558.3	-498162	0	0	-498162
	35	400 KV PPS NEW (WB) - RANCHI NEW (PG)-II	ER1130A	2045.1	-286314	0	0	-286314
	36	400 KV GOKARNA (WB) - FARAKKA (NTPC)-I	ER1133A	-2586.2	362068	0	0	362068
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC)-II	ER1138A	-2353.7	329518	0	0	329518
	38	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-I	ER1044A	554.5	-77630	0	0	-77630
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-II	ER1047A	523.4	-73276	0	0	-73276
	40	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-II	ER1131A	-1504.5	210630	0	0	210630
		TOTAL		-3484908		-45752	-3530660	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH, w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.