



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8661-8671

Date: 31.01.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 14.01.2019-20.01.2019


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 25.01.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)

MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 14/01/19 to 20/01/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4244422

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 14/01/19 to 20/01/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-687.9	96306	0	0	96306
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1840.7	257698	0	0	257698
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-991.7	138838	0	0	138838
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	204.2	-28588	0	0	-28588
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	250.7	-35098	0	0	-35098
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	247.8	-34692	0	0	-34692
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-4404.7	616658	0	0	616658
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1124.2	157388	0	0	157388
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1154.6	161644	0	0	161644
	10	220 KV KHAGAU(L)BSPHCL) - ARAH (PG)-I	NP8641A	0	0	0	0	0
	11	220 KV KHAGAU(L)BSPHCL) - ARAH (PG)-II	NP6060A	0	0	0	0	0
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-550.6	-77084	-77084
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1677.5	-234850	0	0	-234850
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1594.6	223244	0	0	223244
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-951.1	133154	0	0	133154
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	-1139.8	159572	0	0	159572
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-63	8820	0	0	8820
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-77.6	10864	0	0	10864
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	240.1	-33614	0	0	-33614
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1225.2	-171528	0	0	-171528
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1238.1	-173334	0	0	-173334
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1368.3	-191562	0	0	-191562
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1284.5	-179830	0	0	-179830
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	61.3	-8582	389	54460	46878
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1146.8	160552	0	0	160552
	28	HV side of 400/220 Patna ICT-2	ER1407A	0	0	0	0	0
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1880.8	263312	0	0	263312
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	1214.8	-170072	0	0	-170072
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	1084.4	-151816	0	0	-151816
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2882.8	-403592	0	0	-403592
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2890.1	-404614	0	0	-404614
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1125.4	157556	0	0	157556
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1166	163240	0	0	163240
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	0	0	0	0	0
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	0	0	0	0	0
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	88.1	-12334	0	0	-12334
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	107.6	-15064	0	0	-15064
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	1109.5	-155330	0	0	1109.5
		TOTAL		304346	-22624	0	281722	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1793.6	251104	0	0	251104
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1622.6	227164	0	0	227164
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-827.9	115906	0	0	115906
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	602.9	-84406	0	0	-84406
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	805	-112700	0	0	-112700
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2888	-404320	0	0	-404320
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1118	156520	0	0	156520
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-118	16520	0	0	16520
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-87.2	12208	0	0	12208
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	27.7	-3878	0	0	-3878
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	17.2	-2408	0	0	-2408
	12	HV side meter of 400/220 Daltongarj ICT-1	ER1197A	-34.1	4774	0	0	4774
	13	HV side meter of 400/220 Daltongarj ICT-2	ER1317A	-31.9	4466	0	0	4466
		TOTAL		180950	0	0	180950	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2173.4	304276	0	0	304276
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	8.6	-1204	0	0	-1204
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	6.6	-924	0	0	-924
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	24.8	-3472	0	0	-3472
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	65	-9100	0	0	-9100
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-2763.2	386848	0	0	386848
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2005.8	-280812	0	0	-280812
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	178.8	-25032	0	0	-25032
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0.7	-98	0	0	-98
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-127.1	17794	0	0	17794
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-2983.6	417704	0	0	417704
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2291.3	320782	0	0	320782
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	2145.7	-300398	0	0	-300398
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	2315.9	-324226	0	0	-324226
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3284.7	459858	0	0	459858
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3398.2	475748	0	0	475748
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-3382.2	473508	0	0	473508
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1334.9	-186886	0	0	-186886
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3219.2	450688	0	0	450688
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	4494.9	-629286	0	0	-629286
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	4403.9	-616546	0	0	-616546
		TOTAL		929222	0	0	929222	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-5.9	826	0	0	826
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	15.1	-2114	0	0	-2114
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	1960	-274400	0	0	-274400
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-16.9	2366	0	0	2366
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-27.2	3808	0	0	3808
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2502	350280	0	0	350280
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2955	413700	0	0	413700
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3056	427840	0	0	427840
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2961.8	414652	0	0	414652
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-186.1	26054	0	0	26054
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-1554.1	217574	0	0	217574
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	8922.6	-1249164	0	0	-1249164
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	11245.4	-1574356	0	0	-1574356
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	7138.1	-999334	0	0	-999334
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	-826.5	115710	0	0	115710
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	-926.1	129654	0	0	129654
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-3925.4	549556	0	0	549556
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-1976.4	276696	0	0	276696
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	-1857.1	259994	0	0	259994
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-6771.9	948066	0	0	948066
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-6882.6	963564	0	0	963564
		TOTAL		1000972		0	1000972	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-63.40	8876	0	0	8876
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-124.60	17444	0	0	17444
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.4	-56	-56
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	18.20	-2548	0	0	-2548
		TOTAL		23772		-56	23716	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-281.4	39396	-12.7	-1778	37618
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1080.3	-151242	0	0	-151242
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1055.7	-147798	0	0	-147798
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-923.5	129290	0	0	129290
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1000.3	140042	0	0	140042
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-293.7	41118	0	0	41118
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1390.5	194670	0	0	194670
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1054.3	147602	0	0	147602
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2761.7	386638	0	0	386638
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1357.3	190022	0	0	190022
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	7169.9	-1003786	0	0	-1003786
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	7516.8	-1052352	0	0	-1052352
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-45.9	6426	0	0	6426
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	7001.4	-980196	0	0	-980196
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	10232.7	-1432578	0	0	-1432578
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-455.6	63784	0	0	63784
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-3032.3	424522	0	0	424522
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-153.5	21490	0	0	21490
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	117.8	-16492	0	0	-16492
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2353.1	-329434	0	0	-329434
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	639.3	-89502	0	0	-89502
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	1888.3	-264362	0	0	-264362
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-902.6	126364	0	0	126364
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-419.1	58674	0	0	58674
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-816.9	114366	0	0	114366
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-843.1	118034	0	0	118034
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	3165.4	-443156	0	0	-443156
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	2615.6	-366184	0	0	-366184
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-255.7	35798	0	0	35798
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-249.2	34888	0	0	34888
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	1408	-197120	0	0	-197120
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	1409	-197260	0	0	-197260
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-961.8	134652	0	0	134652
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-852.7	119378	0	0	119378
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	633.4	-88676	0	0	-88676
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	561.6	-78624	0	0	-78624
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-492.6	68964	0	0	68964
		TOTAL		-4242644		-1778	-4244422	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVArh.w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.