



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/7925-35

Date: 17.01.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 31.12.2018-06.01.2019

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 11.01.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 31/12/18 to 06/01/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4813578

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 31/12/18 to 06/01/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-882.2	123508	0	0	123508
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2452	343280	0	0	343280
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1279.2	179088	0	0	179088
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	186.9	-26166	0	0	-26166
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	219.6	-30744	0	0	-30744
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	225.4	-31556	0	0	-31556
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3051.3	427182	0	0	427182
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-477.8	66892	-4.4	-616	66276
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-499.3	69902	-3.8	-532	69370
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-235.9	33026	-0.1	-14	33012
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-220.4	30856	0	0	30856
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	-16.2	2268	-316.8	-44352	-42084
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0.2	-28	0	0	-28
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	691.5	-96810	4.6	644	-96166
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-996.8	139552	0	0	139552
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-141.9	19866	0	0	19866
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	-3051.2	427168	0	0	427168
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-128.1	17934	0	0	17934
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-140.1	19614	0	0	19614
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	285.3	-39942	0	0	-39942
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1074.3	-150402	0	0	-150402
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1093	-153020	0	0	-153020
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1203.9	-168546	0	0	-168546
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1138.7	-159418	0	0	-159418
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	85.8	-12012	221.1	30954	18942
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1477.4	206836	0	0	206836
	28	HV side of 400/220 Patna ICT-2	ER1407A	0	0	0	0	0
	29	HV side of 400/220 Patna ICT-3	ER1231A	-2304.8	322672	0	0	322672
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-121.6	17024	0	0	17024
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-125.4	17556	0	0	17556
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	1296	-181440	0	0	-181440
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	1163.8	-162932	0	0	-162932
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2836.8	-397152	0	0	-397152
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2851.6	-399224	0	0	-399224
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7388A	-871	121940	0	0	121940
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-876.4	122696	0	0	122696
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	0	0	0	0	0
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	0	0	0	0	0
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-64.9	9086	0	0	9086
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-42.6	5964	0	0	5964
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	3179.8	-445172	0	0	3179.8
		TOTAL		269346	-13916	-13916	255430	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2679.4	375116	0	0	375116
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2226.3	311682	0	0	311682
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1168.6	163604	0	0	163604
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	141.7	-19838	0	0	-19838
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	644.8	-90272	0	0	-90272
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3499	-489860	0	0	-489860
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1646.4	230496	0	0	230496
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-145.8	20412	0	0	20412
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-121.8	17052	0	0	17052
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	124.5	-17430	0	0	-17430
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	104.2	-14588	0	0	-14588
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-5.6	784	0	0	784
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-5.2	728	0	0	728
		TOTAL		487886	0	0	487886	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2346.8	328552	0	0	328552
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-3	420	0	0	420
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-118.6	16604	0	0	16604
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	47	-6580	0	0	-6580
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	99.6	-13944	0	0	-13944
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-3567.3	499422	0	0	499422
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2157.8	-302092	0	0	-302092
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-111.2	15568	0	0	15568
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-446.2	62468	0	0	62468
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-574.2	80388	0	0	80388
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4912.4	687736	0	0	687736
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3763.2	526848	0	0	526848
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1238.1	-173334	0	0	-173334
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	1082.5	-151550	0	0	-151550
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-5299.1	741874	0	0	741874
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-5457.8	764092	0	0	764092
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4102.9	574406	0	0	574406
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1189.4	-166516	0	0	-166516
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3671.5	514010	0	0	514010
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	5199.5	-727930	0	0	-727930
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5089.1	-712474	0	0	-712474
		TOTAL		2557968	0	0	2557968	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI-PH)	NP5966A	0	0	0.3	42	42
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-4.9	686	0	0	686
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-17.1	2394	0	0	2394
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2722	381080	0	0	381080
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2440.2	341628	0	0	341628
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2274.2	318388	0	0	318388
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2219.6	310744	0	0	310744
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-184.1	25774	0	0	25774
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-2715.7	380198	0	0	380198
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	9921.8	-1389052	0	0	-1389052
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	12995.5	-1819370	0	0	-1819370
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	6854.5	-959630	0	0	-959630
	20	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-I	NP5980A	-1066.2	149268	0	0	149268
	21	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-II	NP7498A	-1075.6	150584	0	0	150584
	22	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	NP7915A	-3869.4	541716	0	0	541716
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-1891.3	264782	0	0	264782
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	-1884.7	263858	0	0	263858
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-5433.7	760719	0	0	760719
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-5532.1	774494	0	0	774494
		TOTAL		498260		42	498302	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-65.30	9142	0	0	9142
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-111.90	15666	0	0	15666
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.7	-98	-98
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	14.40	-2016	0	0	-2016
		TOTAL		22792		-98	22694	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-754	105560	-15.5	-2170	103390
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1047.2	-146608	0	0	-146608
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1039.3	-145502	0	0	-145502
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-602.8	84392	0	0	84392
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-629	88060	0	0	88060
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-111.1	15554	0	0	15554
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1300.9	182126	0	0	182126
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-969.9	135786	0	0	135786
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2736.3	383082	0	0	383082
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1195.1	167314	0	0	167314
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	6609.9	-925386	0	0	-925386
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	7756.6	-1085924	0	0	-1085924
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-89.3	12502	0	0	12502
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	7149.4	-1000916	0	0	-1000916
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	8910.9	-1247526	0	0	-1247526
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1112.5	155750	0	0	155750
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-3616.2	506268	0	0	506268
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-139.6	19544	0	0	19544
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	71.1	-9954	0	0	-9954
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3611.3	-505582	0	0	-505582
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	2050.1	-287014	0	0	-287014
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	3074.2	-430388	0	0	-430388
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-644.8	90272	0	0	90272
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-241.1	33754	0	0	33754
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	507.2	-71008	0	0	-71008
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	471	-65940	0	0	-65940
	30	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-I	NP8723A	2891.3	-404782	0	0	-404782
	31	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-II	NP8724A	2540.8	-355712	0	0	-355712
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-4.3	602	0	0	602
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	11.7	-1638	0	0	-1638
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	1716.8	-240352	0	0	-240352
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	1712.4	-239736	0	0	-239736
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-1408	197120	0	0	197120
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-1250.9	175126	0	0	175126
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	572.4	-80136	0	0	-80136
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	512.6	-71764	0	0	-71764
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-1083.2	151648	0	0	151648
		TOTAL		-4811408		-2170	-4813578	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVARh.w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTD.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.