



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8914-8924

Date: 08.02.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 21.01.2019-27.01.2019


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 01.02.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)

MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 21/01/19 to 27/01/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4142684

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

 8/2/19
MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 21/01/19 to 27/01/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1289.8	180572	0	0	180572
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3006.1	420854	0	0	420854
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1801.5	252210	0	0	252210
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	299.9	-41986	0	0	-41986
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	361.3	-50582	0	0	-50582
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	360.2	-50428	0	0	-50428
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1949.3	272902	0	0	272902
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-897.8	125692	0	0	125692
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-927.7	129878	0	0	129878
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	0	0	0	0	0
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	0	0	0	0	0
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	-61.4	8596	-223.8	-31332	-22736
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1323.3	-185262	0	0	-185262
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1755	245700	0	0	245700
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1318.9	184646	0	0	184646
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	-1378.9	193046	0	0	193046
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-246.5	34510	0	0	34510
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-266.9	37366	0	0	37366
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	287.1	-40194	0	0	-40194
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1698	-237720	0	0	-237720
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1720.3	-240842	0	0	-240842
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1886.6	-264124	0	0	-264124
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1795.9	-251426	0	0	-251426
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	204.2	-28588	144.2	20188	-8400
	27	HV side of 400/220 Patna ICT-1	ER1408A	-2581.9	361466	0	0	361466
	28	HV side of 400/220 Patna ICT-2	ER1407A	0	0	0	0	0
	29	HV side of 400/220 Patna ICT-3	ER1231A	-3787	530180	0	0	530180
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-775.1	108514	0	0	108514
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-766.8	107352	0	0	107352
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	1398.2	-195748	0	0	-195748
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	1250.5	-175070	0	0	-175070
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2989.5	-418530	0	0	-418530
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	3005.8	-420812	0	0	-420812
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-887.6	124264	0	0	124264
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-903.6	126504	0	0	126504
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	738.3	-103362	0	0	-103362
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	798.1	-111734	0	0	-111734
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	123.6	-17304	0	0	-17304
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	141.3	-19782	0	0	-19782
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-II	ER1376A	3706.2	-518868	0	0	3706.2
		TOTAL		71890	0	-11144	60746	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1452.6	203364	0	0	203364
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1208.7	169218	0	0	169218
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-782.4	109536	0	0	109536
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	865	-121100	0	0	-121100
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1119.5	-156730	0	0	-156730
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2960	-414400	0	0	-414400
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1352.6	189364	0	0	189364
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-368	51520	0	0	51520
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-342.2	47908	0	0	47908
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	31.3	-4382	0	0	-4382
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	22.1	-3094	0	0	-3094
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL		71204	0	0	71204	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2566.4	359296	0	0	359296
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-12.8	1792	0	0	1792
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-44.6	6244	0	0	6244
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	399.2	-55888	0	0	-55888
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	557	-77980	0	0	-77980
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-1806.7	252938	0	0	252938
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2915.9	-408226	0	0	-408226
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-122.1	17094	0	0	17094
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1112.3	155722	0	0	155722
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1246.8	174552	0	0	174552
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-5609.1	785274	0	0	785274
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4752.4	665336	0	0	665336
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	2037.6	-285264	0	0	-285264
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	2021.4	-282996	0	0	-282996
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3930.5	550270	0	0	550270
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-4093.5	573090	0	0	573090
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4315.9	604226	0	0	604226
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-415	58100	0	0	58100
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3811.9	533666	0	0	533666
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	5630.2	-788228	0	0	-788228
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5603.3	-784462	0	0	-784462
		TOTAL		2054556	0	0	2054556	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-3.3	462	0	0	462
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	3895.5	-545370	0	0	-545370
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	34.5	-4830	0	0	-4830
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	19.2	-2688	0	0	-2688
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2778.8	389032	0	0	389032
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2700	378000	0	0	378000
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3187.8	446292	0	0	446292
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3090.4	432656	0	0	432656
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-123.7	17318	0	0	17318
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-1736.3	243082	0	0	243082
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	8441.1	-1181754	0	0	-1181754
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	9838.2	-1377348	0	0	-1377348
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	5252.4	-735336	0	0	-735336
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	-758.9	106246	0	0	106246
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	-855.2	119728	0	0	119728
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-3691.6	516824	0	0	516824
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-1846.1	258454	0	0	258454
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	-1822.9	255206	0	0	255206
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-4614	645960	0	0	645960
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-4717.4	660436	0	0	660436
		TOTAL		622370		0	622370	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-86.10	12054	0	0	12054
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-153.30	21462	0	0	21462
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.6	-84	-84
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.60	-2184	0	0	-2184
		TOTAL		31332		-84	31248	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	0	0	0
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	882.4	-123536	0	0	-123536
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	877.3	-122822	0	0	-122822
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1804.6	252644	0	0	252644
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1852.6	259364	0	0	259364
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-597.3	83622	0	0	83622
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-2030	284200	0	0	284200
	8	132 KV SILIGURI (PG) - NB (WBSETCL)	NP5889A	-1359	190260	0	0	190260
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3068.5	429590	0	0	429590
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1622.8	227192	0	0	227192
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	7092.3	-992922	0	0	-992922
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	7895.1	-1105314	0	0	-1105314
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-120	16800	0	0	16800
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	10060.7	-1408498	0	0	-1408498
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	12116.4	-1696296	0	0	-1696296
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-2190.9	306726	0	0	306726
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-2481.6	347424	0	0	347424
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-169.3	23702	0	0	23702
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	103.3	-14462	0	0	-14462
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	1385.2	-195328	0	0	-195328
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	1966.6	-275324	0	0	-275324
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	3089.4	-432516	0	0	-432516
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-1459.3	204302	0	0	204302
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-835.2	116928	0	0	116928
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-1269.8	177772	0	0	177772
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-1302.3	182322	0	0	182322
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	3095.7	-433398	0	0	-433398
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	2786.6	-390124	0	0	-390124
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-819.3	114702	0	0	114702
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-803.8	112532	0	0	112532
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	2634.2	-368788	0	0	-368788
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	2624.3	-367402	0	0	-367402
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-1774.5	248430	0	0	248430
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-1670.9	233926	0	0	233926
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	1018.9	-142646	0	0	-142646
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	983.5	-137690	0	0	-137690
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-1799.6	251944	0	0	251944
		TOTAL		-4142684		0	-4142684	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVARh.w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.