



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /3001-3011

Date: 26.06.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 03.06.2019-09.06.2019

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 14.06.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 03/06/19 to 09/06/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	1552
WBSETCL	POOL	4410335

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 03/06/19 to 09/06/19

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-561.3	81389	-2.2	-319	81070
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2419.9	350886	0	0	350886
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1442.7	209192	0	0	209192
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-8	1160	-58.6	-8497	-7337
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-21	3045	-7.2	-1044	2001
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-3.4	493	-36	-5220	-4727
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-5515.3	799719	0	0	799719
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-327.2	47444	0	0	47444
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-358.8	52026	0	0	52026
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-258.9	37541	-0.1	-14.5	37526
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-223.1	32350	0	0	32350
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-552.2	-80069	-80069
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	427.8	62031	62031
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	282.8	41006	41006
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	564	-81780	0	0	-81780
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1649.6	239192	0	0	239192
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-4348	630460	0	0	630460
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	1333.5	-193358	0	0	-193358
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-8.5	1233	0	0	1233
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-10.1	1465	0	0	1465
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	95.7	-13877	0	0	-13877
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	611.3	-88639	0	0	-88639
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	599.7	-86957	0	0	-86957
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	669.8	-97121	0	0	-97121
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	633	-91785	0	0	-91785
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-0.3	44	356.2	51649	51693
	27	HV side of 400/220 Palma ICT-1	ER1408A	-4408	639160	0	0	639160
	28	HV side of 400/220 Palma ICT-2	ER1407A	-5134.2	744459	0	0	744459
	29	HV side of 400/220 Palma ICT-3	ER1231A	-4786.9	694101	0	0	694101
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	113.6	-16472	0	0	-16472
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	109.2	-15834	0	0	-15834
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1374.4	199288	0	0	199288
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1226.3	177814	0	0	177814
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1323.1	-191850	0	0	-191850
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1290.5	-187123	0	0	-187123
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3141.1	455460	0	0	455460
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3557	515765	0	0	515765
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	426.4	-81828	0	0	-81828
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	1188.4	-172318	0	0	-172318
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-417.1	60480	0	0	60480
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-416.8	60436	0	0	60436
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			4735657		59523	4795179
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-920.8	133516	0	0	133516
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-566.1	82085	0	0	82085
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-654.3	94874	0	0	94874
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	300.4	-43558	0	0	-43558
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	351.6	-50982	0	0	-50982
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	769.4	-111563	0	0	-111563
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-598.1	86725	0	0	86725
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-466.2	67599	0	0	67599
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-541.4	78503	0	0	78503
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	271.6	-39382	0	0	-39382
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	252.8	-36656	0	0	-36656
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-7.7	1117	0	0	1117
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-7.3	1059	0	0	1059
		TOTAL			263335		0	263335
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2421.2	351074	0	0	351074
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-246.4	35728	0	0	35728
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-320.4	46458	0	0	46458
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-319.8	46371	0	0	46371
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-448.8	65076	0	0	65076
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	152.9	-22171	0.3	43.5	-22127
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	249.7	-36207	0	0	-36206.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	4417.8	-640581	0	0	-640581
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-6022.2	873219	0	0	873219
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-6009.1	871320	0	0	871319.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-1589.5	230478	0	0	230477.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1318.9	191241	0	0	191240.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-2705.2	392254	0	0	392254
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-3340	484300	0	0	484300
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2943.7	426837	0	0	426836.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2961.9	429476	0	0	429475.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4711.5	683168	0	0	683167.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	3665.9	-531556	0	0	-531555.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-1222.1	177205	0	0	177204.5
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	3007.7	-436117	0	0	-436116.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3287.8	-476731	0	0	-476731
		TOTAL			3160841		44	3160884

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	68.9	-9990.5	0	0	-9990.5
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	138.4	-20068	0	0	-20068
	7	400 KV INDRAVATI (PG) - INDRAVATI PH	NP5966A	469.7	-68106.5	0	0	-68106.5
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	69.8	-10121	0	0	-10121
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	69.3	-10048.5	0	0	-10048.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1323.2	191864	0	0	191864
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3058.6	443497	0	0	443497
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4183.4	606593	0	0	606593
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2925.4	424183	0	0	424183
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	74.1	-10744.5	0.3	43.5	-10701
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-9.3	1348.5	0	0	1348.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	217	-31465	0	0	-31465
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	315.9	-45805.5	0	0	-45805.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	2.1	-304.5	0.3	43.5	-261
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	-36.6	5307	-29.1	-4219.5	1087.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	-36.9	5350.5	-14.6	-2117	3233.5
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1563A	5	-725	74.1	10744.5	10019.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1596A	0.7	-101.5	184.7	26781.5	26680
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3363.3	487678.5	0	0	487678.5
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3452	500540	0	0	500540
TOTAL				2458881		31277	2490158	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-6.80	986	-15.7	-2276.5	-1291
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	1.80	-261	0	0	-261
TOTAL				725		-2277	-1552	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	1615.9	234306	234306
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	20.2	-2929	-10.4	-1508	-4437
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	26.6	-3857	-32.9	-4771	-8628
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1950.1	282765	0	0	282765
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2043.3	296279	0	0	296279
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	1800	-261000	0	0	-261000
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-35.1	5090	0	0	5090
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-85.6	12412	0	0	12412
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1330	192850	0	0	192850
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-94	13630	0	0	13630
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-634.2	91959	0	0	91959
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	488.3	-70804	0	0	-70804
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	105.6	-15312	0	0	-15312
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	8345.8	-1210141	0	0	-1210141
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	16236.7	-2354322	0	0	-2354322
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-488.4	70818	0	0	70818
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-332.7	48242	0	0	48242
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	123.7	-17937	0	0	-17937
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-161.5	23418	0	0	23418
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2659.2	-385584	0	0	-385584
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	327.6	-47502	0	0	-47502
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	737.5	-106938	0	0	-106938
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-397.4	57623	0	0	57623
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-125.4	18183	0	0	18183
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	171.5	-24868	0.6	87	-24781
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-46.2	6699	9.7	1407	8106
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	575	-83375	0	0	-83375
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	309.6	-44892	0	0	-44892
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-56.5	8193	0	0	8193
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-37.5	5438	0	0	5438
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	4220.3	-611944	0	0	-611944
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	4169.3	-604549	0	0	-604549
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-205	29725	0	0	29725
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-150.5	21823	0	0	21823
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	1.1	-160	0	0	-160
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0.4	-58	0	0	-58
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-146	21170	0	0	21170
TOTAL				-4639855		229521	-4410335	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.