



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/2427-37

Date: 06.06.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 13.05.2019-19.05.2019

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 24.05.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 13/05/19 to 19/05/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4119450

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 13/05/19 to 19/05/19

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-821.1	119060	0	0	119060
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2626.4	380628	0	0	380628
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1315.3	190719	0	0	190719
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-49.4	7163	0	0	7163
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-97	14065	0	0	14065
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-41	5945	0	0	5945
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3551.7	514997	0	0	514997
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-212	30740	-1.9	-275.5	30465
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-243.2	35264	-1.7	-246.5	35018
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-320.6	46487	0	0	46487
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-277	40165	0	0	40165
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-0.2	29	-368.1	-53374.5	-53346
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	10.1	1464.5	1465
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	12.8	1856	1856
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	401.8	-58261	1.5	217.5	-58044
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-2112.9	306371	0	0	306371
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2411.5	349668	0	0	349668
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	947.8	-137431	0	0	-137431
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	81.8	-11861	0	0	-11861
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	128.8	-18676	0	0	-18676
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	139.5	-20228	0	0	-20228
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1287.4	-186673	0	0	-186673
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1251.7	-181497	0	0	-181497
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1364.1	-197795	0	0	-197795
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1341.8	-194561	0	0	-194561
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	1	-145	157.8	22881	22736
	27	HV side of 400/220 Palma ICT-1	ER1408A	-6902.2	1000819	0	0	1000819
	28	HV side of 400/220 Palma ICT-2	ER1407A	-7951.3	1152939	0	0	1152939
	29	HV side of 400/220 Palma ICT-3	ER1231A	-7351.7	1065997	0	0	1065997
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-13.9	2016	0	0	2016
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-13.7	1987	0	0	1987
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1954.4	283388	0	0	283388
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1812.8	262856	0	0	262856
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1146	-166170	0	0	-166170
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1178A	1155.7	-167577	0	0	-167577
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3076.2	446049	0	0	446049
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3519	510255	0	0	510255
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	98.4	-14268	0	0	-14268
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	83.9	-12166	0	0	-12166
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-377.9	54796	0	0	54796
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-379.1	54970	0	0	54970
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	201.2	-29174	0	0	201.2
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	-29.1	4220	0	0	-29.1
TOTAL					5485307		-27478	5457829
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1185.4	171883	0	0	171883
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-663.5	96208	0	0	96208
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-876.6	127107	0	0	127107
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	-122.2	17719	0	0	17719
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	-90.8	13166	0	0	13166
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	892.8	-129456	0	0	-129456
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-684.4	99238	0	0	99238
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	73.4	-10643	0	0	-10643
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	35.4	-5133	0	0	-5133
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	58.1	-8425	0	0	-8425
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	38	-5510	0	0	-5510
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
TOTAL					366154		0	366154
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	477.5	-69238	0	0	-69237.5
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2230	323350	0	0	323350
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-550.8	79866	0	0	79866
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-608	88160	0	0	88160
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-619.8	89871	0	0	89871
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-424.4	61538	0	0	61538
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	70.1	-10165	0	0	-10164.5
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	798.6	-115797	0	0	-115797
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	4419.2	-640784	0	0	-640784
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-5942.9	861721	0	0	861720.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-5959.7	864157	0	0	864156.5
	12	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-I	NP7831A	-3094.9	448761	0	0	448760.5
	13	400 KV KODERMA(DVC) - BIHARSHARIF(PG)-LINE-II	NP7830A	-2087.7	302717	0	0	302716.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-3926.2	569299	0	0	569299
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-4782.1	693405	0	0	693404.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2204.6	319667	0	0	319667
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2270.9	329281	0	0	329280.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-884.9	128311	0	0	128310.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-1769.9	256636	0	0	256635.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-695.6	100862	0	0	100862
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	1685.5	-244398	0	0	-244397.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	1787.4	-259173	0	0	-259173
TOTAL					4178045		0	4178045

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI PH	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	1.3	-188.5	0	0	-188.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-846.6	122757	0	0	122757
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3489.4	505963	0	0	505963
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4282.4	620948	0	0	620948
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2380.2	345129	0	0	345129
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	0	0	0	0	0
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	0	0	0	0	0
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	0	0	0	0	0
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	24.7	-3581.5	6.4	928	-2653.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	17.8	-2581	1.7	246.5	-2334.5
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0.4	58	58
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	80.2	11629	11629
	25	HV side of 400/220 Pandiabili ICT-1	ER1563A	4.3	-623.5	16.6	2407	1783.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1596A	808.1	-117174.5	2.4	348	-116826.5
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-5897	855065	0	0	855065
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-6152.3	862083.5	0	0	862083.5
TOTAL				3217797		15617	3233413	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-62.00	8990	0	0	8990
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-48.20	6989	0	0	6989
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.1	-14.5	-15
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	5.00	-725	0	0	-725
TOTAL				15254		-15	15240	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	782.8	113506	113506
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-111.1	16110	-1795.3	-260319	-244209
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-81	11745	-1930.8	-279966	-268221
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2857.5	414338	0	0	414338
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2950.1	427765	0	0	427765
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	1580.1	-229115	0	0	-229115
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-506.8	73486	0	0	73486
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-521.5	75618	0	0	75618
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2508.1	363675	0	0	363675
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-757.2	109794	0	0	109794
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	4767.3	-691259	0	0	-691259
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	5790.5	-839623	0	0	-839623
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-23.1	3350	0	0	3350
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	5931.3	-860039	0	0	-860039
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	13959.1	-2024070	0	0	-2024070
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-543.8	78851	0	0	78851
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	28.4	-4118	0	0	-4118
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-40.1	5815	0	0	5815
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-16.2	2349	0	0	2349
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3609.7	-523407	0	0	-523407
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	731	-105995	0	0	-105995
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	1267.1	-183730	0	0	-183730
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-1691.2	245224	0	0	245224
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-666.7	96672	0	0	96672
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	6.7	-972	3461.8	501961	500990
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	12.7	-1842	3414.2	495059	493218
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	882.7	-127992	0	0	-127992
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	779.5	-113028	0	0	-113028
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	436.1	-63235	0	0	-63235
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	439.1	-63670	0	0	-63670
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	2986.5	-433043	0	0	-433043
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	2959.2	-429084	0	0	-429084
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-210.5	30523	0	0	30523
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-48	6960	0	0	6960
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	86.7	-12572	0	0	-12572
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	61.7	-8947	0	0	-8947
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-439.8	63771	0	0	63771
TOTAL				-4689692		570242	-4119450	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.