



सत्यमेव जयते

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/2921-31

Date: 17.06.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 27.05.2019-02.06.2019**


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 07.06.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

  
for MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 27/05/19 to 02/06/19**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	32292
WBSETCL	POOL	3603337

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 27/05/19 to 02/06/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1420	205900	-1	-145	205755
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3728.3	540604	0	0	540604
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2297.4	333123	0	0	333123
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	83.7	-12137	-9.2	-1334	-13471
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	67.7	-9817	-4.8	-696	-10513
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	102.8	-14906	-7.6	-1102	-16008
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-6167.5	894288	0	0	894288
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-787.8	114231	0	0	114231
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-839.7	121757	0	0	121757
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG-I)	NP8641A	-305.4	44283	0	0	44283
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG-II)	NP6060A	-259	37555	0	0	37555
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-0.5	73	-56.4	-8178	-8106
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	91.9	13325.5	13326
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	79.3	11498.5	11499
	15	220 KV SIDE OF 220/132 ARAH 160 MVA ICT-3	ER1313A	1330	-192850	0	0	-192850
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1243.4	180293	0	0	180293
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-4164.4	603838	0	0	603838
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	1409.2	-204334	0	0	-204334
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-106.6	15457	0	0	15457
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-119	17255	0	0	17255
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	136.9	-19851	0	0	-19851
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1442.3	-209134	0	0	-209134
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1426.9	-206901	0	0	-206901
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1560.7	-226302	0	0	-226302
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1488.4	-215818	0	0	-215818
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	8.6	-1247	38.1	5524.5	4278
	27	HV side of 400/220 Patna ICT-1	ER1408A	-6244.7	905482	0	0	905482
	28	HV side of 400/220 Patna ICT-2	ER1407A	-7200.5	1044073	0	0	1044073
	29	HV side of 400/220 Patna ICT-3	ER1231A	-6695.2	970804	0	0	970804
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	222.8	-32306	0	0	-32306
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	227.6	-33002	0	0	-33002
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1482.9	215021	0	0	215021
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1397.3	202609	0	0	202609
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1784.4	-258738	0	0	-258738
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1785.4	-258883	0	0	-258883
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3555.6	515562	0	0	515562
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3874.5	561803	0	0	561803
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	1244.5	-180453	0	0	-180453
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	1443.9	-209366	0	0	-209366
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-315.1	45690	0	0	45690
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-315.9	45806	0	0	45806
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	106.4	-15428	0	0	106.4
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		<b>TOTAL</b>		<b>5314033</b>		<b>18894</b>	<b>5332926</b>	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2024.6	293567	0	0	293567
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1356.6	196707	0	0	196707
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-1478	214310	0	0	214310
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	-40.6	5887	0	0	5887
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	-5.3	769	0	0	769
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1130.6	-163937	0	0	-163937
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-724.8	105096	0	0	105096
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-129.8	18821	0	0	18821
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-200.6	29087	0	0	29087
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	289.2	-41934	0	0	-41934
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	218.1	-31625	0	0	-31625
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-271.8	39411	0	0	39411
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-240.1	34815	0	0	34815
		<b>TOTAL</b>		<b>700974</b>		<b>0</b>	<b>700974</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2198.8	318826	0	0	318826
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-491.4	71253	0	0	71253
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-564.8	81896	0	0	81896
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-624	90480	0	0	90480
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-828.6	120147	0	0	120147
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-1877.2	272194	0	0	272194
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	1830.9	-265481	0	0	-265480.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	7482.5	-1084963	0	0	-1084962.6
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-8891.2	1289224	0	0	1289224
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-8801.9	1276276	0	0	1276275.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3607	523015	0	0	523015
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3011.3	436639	0	0	436638.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-4246.9	615801	0	0	615800.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-5020	727900	0	0	727900
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3484.1	505195	0	0	505194.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	NP6522A	-3543.7	513837	0	0	513836.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-3594.5	521203	0	0	521202.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2713.9	-393516	0	0	-393515.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-1190.3	172594	0	0	172593.5
	21	400 KV RANCHI(PG)-RTPS(DVC)-I	NP7871A	3285.6	-476412	0	0	-476412
	22	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7853A	3451.3	-500439	0	0	-500438.5
		<b>TOTAL</b>		<b>4815668</b>		<b>0</b>	<b>4815668</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

<b>GRIDCO</b>	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-0.2	29	0	0	29
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	480.7	-69701.5	0	0	-69701.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	427.4	-61973	0	0	-61973
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-637	92365	0	0	92365
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3584	519680	0	0	519680
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4536	657720	0	0	657720
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2365.4	342983	0	0	342983
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	210	-30450	0	0	-30450
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-77.8	11281	-0.3	-43.5	11237.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	25.4	-3683	0	0	-3683
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	47.2	-6844	0	0	-6844
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0.3	-43.5	0	0	-43.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	-14.9	2160.5	18.4	2688	4828.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	-9	1305	34.4	4988	6293
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0.2	29	29
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0.7	-101.5	135.6	19662	19560.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	129.4	-18763	113.2	16414	-2349
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3307.1	479529.5	0	0	479529.5
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3508.6	508747	0	0	508747
		<b>TOTAL</b>		<b>2424241</b>		<b>43718</b>	<b>2467958</b>	
<b>SIKKIM</b>	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-0.90	131	-220.9	-32030.5	-31900
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	2.70	-392	0	0	-392
		<b>TOTAL</b>		<b>-261</b>		<b>-32031</b>	<b>-32292</b>	
<b>WBSETCL</b>	1	400 KV JEERAT (WBSETCL) - SUBHASHGRAM (PG)	ER1471A	0	0	301.3	43689	43689
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	-138.9	20141	-1985.7	-287927	-267786
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	-87.1	12630	-2210.1	-320465	-307835
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2437.4	353423	0	0	353423
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2491.9	361326	0	0	361326
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	2152.2	-312069	0	0	-312069
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-243.9	35366	0	0	35366
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-422.4	61248	0	0	61248
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2067.5	299788	0	0	299788
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-276.2	40049	0	0	40049
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	985.7	-142927	0	0	-142927
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	1683.8	-244151	0	0	-244151
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	172.6	-25027	0	0	-25027
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6284.8	-911296	0	0	-911296
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	14762.5	-2140563	0	0	-2140563
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-652.9	94671	0	0	94671
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASHGRAM (PG)	NP6483A	-26.1	3785	0	0	3785
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	252.6	-36627	0	0	-36627
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	-313.4	45443	0	0	45443
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	2497.3	-362109	0	0	-362109
	21	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	643.8	-93351	0	0	-93351
	22	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	1106.4	-160428	0	0	-160428
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-I	ER1071A	-142.9	20721	-0.1	-15	20706
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-II	ER1072A	7.1	-1030	-7.8	-1131	-2161
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-I	ER1141A	15.6	-2262	3996.4	579478	577216
	29	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-II	NP7937A	-120.5	17473	4158.9	603041	620513
	30	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-I	NP8723A	772.2	-111969	0	0	-111969
	31	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-II	NP8724A	605.7	-87827	0	0	-87827
	32	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-I	NP8731A	426	-61770	0	0	-61770
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-II	NP8720A	435.4	-63133	0	0	-63133
	34	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-I	ER1040A	3225.5	-467698	0	0	-467698
	35	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-II	ER1130A	3200.4	-464058	0	0	-464058
	36	400 KV GOKARNA (WB) - FARAKKA (NTPC)-I	ER1133A	-236.6	34307	0	0	34307
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC)-II	ER1138A	-122.2	17719	0	0	17719
	38	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-I	ER1044A	29.1	-4220	0	0	-4220
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-II	ER1047A	7.8	-1131	0	0	-1131
	40	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-II	ER1131A	-383.1	55550	0	0	55550
		<b>TOTAL</b>		<b>-4220008</b>		<b>616671</b>	<b>-3603337</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.