



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



Tel No.:033-24235199, 24235005 FAX No.:033-24221802, 24221358 Web: www.erpc.gov.in

NO. ERPC/MS/OPERATION/2019/ 4053 - 60

DATE: 26.07.2019

FAX MESSAGE NO. - 752

To,

As per list enclosed.

Sub: Notice for special meeting on "Shutdown of 400kV D/C Nabinagar-Sasaram Line"

In 158th OCC Meeting held on 27th June 2019, Powergrid informed that during line patrolling of 400kV D/C Nabinagar-Sasaram Line, the main leg-A and connected bracing between Leg-A & Leg-D was found deformed and bend inside, following the summer cyclone in the month of May 2019.

Powergrid requested for shutdown of 400kV D/C Nabinagar-Sasaram Line for ten days to replace the bend bracing by de-stringing of conductor and after that replacement of leg with support of derrick / hydra with proper guying arrangements. To avoid collapse of said tower, POWERGRID has provided stitching with additional tower member to safeguard the tower and kept under regular vigil. Due to severe bending of leg members, collapse of the said tower cannot be overruled and hence required to be replaced the bend members at the earliest.


OCC opined that no evacuation path would be available for Nabinagar generation plant during the shutdown period of 400kV D/C Nabinagar-Sasaram Line. OCC advised Powergrid to restore the line using ERS and complete the tower repairing work.

In 159th OCC Meeting held on 19th July 2019, Powergrid informed that restoration of the line using ERS would take more than 10 days as it requires destringing of 3.6 km line. The replacement of deformed / bulged leg & bracing would take 10 days.

OCC decided to discuss the issue in separate meeting with the concerned utilities i.e. Eastern Railway, Bihar, BRBCL, Powergrid, ERLDC and ERPC.

As per the OCC decision, a special meeting on “Shutdown of 400kV D/C Nabinagar-Sasaram Line” is here by convened at **ERPC Conference Hall, Kolkata** on **2nd August 2019 (Friday)** at **11:00 hrs.**

You are requested to attend the meeting with all relevant details for fruitful discussion in the meeting. Your participation in the meeting is highly solicited.

 26/7/19
(J. Bandyopadhyay)
Member Secretary

LIST OF ADDRESSES:

1. Director (Operation), BSPTCL, Vidyut Bhavan , Bailey Road, Patna-800021
2. GENERAL MANAGER , POWERGRID, ER-I, PATNA, (FAX NO.0612-2531192)
3. EXECUTIVE DIRECTOR, ERLDC, POSOCO, KOLKATA, (FAX NO. 033-2423-5809)
4. CHIEF ELECTRICAL ENGINEER, EASTERN RAILWAY, KOLKATA-700 001 (FAX NO.: 033-22300446)
5. Chief Electrical Distribution Engineer, Eastern Central Railway, Hajipur.
6. Chief Electrical Distribution Engineer, Eastern Railway, Kolkata.
7. CHIEF ENGINEER (System Operation), BSPTCL, PATNA, (FAX NO. 0612-2504557/2504937)
8. CEO, BRBCL, First Floor, Vidyut Bhavan II, Bailey Road, Patna-800001, FAX: 0612(2504007)