



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/6949-6959

Date: 11.10.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 02.09.2019-08.09.2019

दिनांक -02.09.2019 से 08.09.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 13.09.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-13.09.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।


The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,


for MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 02/09/19 to 08/09/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	6007510
SIKKIM	POOL	0
WBSETCL	POOL	4336892

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


for MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 02/09/19 to 08/09/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-607	88015	0	0	88015
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-4155.2	602504	0	0	602504
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2363.2	342664	0	0	342664
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-19.9	2886	0	0	2886
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-54.5	7903	0	0	7903
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-12.4	1798	0	0	1798
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2924.6	424067	0	0	424067
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-27.6	4002	-73.3	-10628.5	-6627
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-33.3	4829	-66.3	-9613.5	-4785
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG-I)	NP8641A	-13.7	1987	-1.4	-203	1784
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG-II)	NP6060A	-218.7	31712	0	0	31712
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	2.8	-406	-152.6	-22127	-22533
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	68.5	-9933	0	0	-9933
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	27.4	-3973	0	0	-3973
	15	220 KV SIDE OF 220/132 ARAH 160 MVA ICT-3	ER1313A	53.1	-7700	84.1	12194.5	4495
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1303.9	189066	0	0	189066
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-7280.4	1055658	0	0	1055658
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	-366.5	53143	0	0	53143
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	360	-52200	0	0	-52200
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	391.6	-56782	0	0	-56782
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	650.2	-94279	0	0	-94279
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	632.7	-91742	0	0	-91742
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	698.4	-101268	0	0	-101268
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	651.3	-94439	0	0	-94439
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	1	-145	192.4	27898	27753
	27	HV side of 400/220 Palma ICT-1	ER1408A	-4478.5	649383	0	0	649383
	28	HV side of 400/220 Palma ICT-2	ER1407A	-5053.9	732816	0	0	732816
	29	HV side of 400/220 Palma ICT-3	ER1231A	-4712.1	683255	0	0	683255
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	362.1	-52505	0	0	-52505
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	367.8	-53331	0	0	-53331
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2043.8	296351	0	0	296351
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2014	292030	0	0	292030
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	377.1	-54680	0	0	-54680
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	390.6	-56637	0	0	-56637
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3426.1	496785	0	0	496785
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3383.2	490564	0	0	490564
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	172.4	-24998	0	0	-24998
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	178.3	-25854	0	0	-25854
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-87.9	12746	-1.8	-261	12485
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-84.1	12195	-1.5	-217.5	11977
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	184.4	-267003	0	0	184.4
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1761.1	-255360	0	0	1761.1
		TOTAL		5173122		-2958	5170164	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2958.8	429026	0	0	429026
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2083.6	302122	0	0	302122
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-2498.1	362225	0	0	362225
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	555	-80475	0	0	-80475
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	730.5	-105923	0	0	-105923
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	798.4	-115768	0	0	-115768
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	0	0	0	0	0
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-190.4	27608	0	0	27608
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-537.6	77952	0	0	77952
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	315.7	-45777	0	0	-45777
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	314.8	-45646	0	0	-45646
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-8	-1160	-1160
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-7.8	-1131	-1131
		TOTAL		805345		-2291	803054	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	-325.3	47169	0	0	47168.5
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2244.6	325467	0	0	325467
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-46.4	6728	0	0	6728
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-76.2	11049	0	0	11049
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	104	-15080	0	0	-15080
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	157.4	-22823	0	0	-22823
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-865.9	125556	0	0	125555.5
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2128	-308560	0	0	-308560
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	2940.7	-426402	0	0	-426401.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1155.2	167504	0	0	167504
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1223.6	177422	0	0	177422
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3636	527220	0	0	527220
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3142.1	455605	0	0	455604.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1091.2	158224	0	0	158224
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1461.4	211903	0	0	211903
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3606.2	522899	0	0	522899
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3709.4	537863	0	0	537863
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6179.8	896071	0	0	896071
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	6999.7	-1014957	0	0	-1014956.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3555.2	515504	0	0	515504
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	9185.7	-1331927	0	0	-1331926.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8953.1	-1298200	0	0	-1298199.5
		TOTAL		268236		0	268236	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-695	100775	0	0	100775
	6	HV side meter of 400/220 Baripada ICT-2	ER1571A	-1710.5	248022.5	0	0	248022.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	16789.5	-2434477.5	0	0	-2434477.5
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	300.1	-43514.5	0	0	-43514.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	255.1	-36989.5	0	0	-36989.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3934.4	570488	0	0	570488
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3798.6	550797	0	0	550797
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3088.4	447818	0	0	447818
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3037.6	440452	0	0	440452
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	63.7	-9236.5	0	0	-9236.5
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-3105.3	450268.5	0	0	450268.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	22891.6	-3319282	0	0	-3319282
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	15423.5	-2236407.5	0	0	-2236407.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	19057.5	-2763337.5	0	0	-2763337.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	246.6	-35757	0	0	-35757
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	256.5	-37192.5	0	0	-37192.5
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-2022.9	293320.5	0	0	293320.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	20.3	-2943.5	0	0	-2943.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-6221.4	902103	0	0	902103
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-6259.2	907584	0	0	907584
		TOTAL		-6007510		0	-6007510	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-57.10	8280	-11.8	-1711	6569
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-10.50	1523	-1	-145	1378
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	6.30	-914			-914
		TOTAL		8889		-1856	7033	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASHGRAM (PG)	ER1471A	0	0	-1027.4	-148973	-148973
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	-173.7	25187	-0.6	-87	25100
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	-105.3	15269	-21.9	-3176	12093
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1048.6	152047	0	0	152047
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1125.3	163169	0	0	163169
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	13.1	-1900	0	0	-1900
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-52.6	7627	0	0	7627
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-948.9	137591	0	0	137591
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-0.3	44	-0.1	-15	29
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-1914.2	277559	0	0	277559
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	-426.2	61799	0	0	61799
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	1	-145	0	0	-145
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	4975.6	-721462	0	0	-721462
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	1537.4	-222923	0	0	-222923
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	726.9	-105401	0	0	-105401
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASHGRAM (PG)	NP6483A	1382.3	-200434	0	0	-200434
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	42.8	-6206	0	0	-6206
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-84.9	12311	0	0	12311
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	4474.5	-648803	0	0	-648803
	21	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	1471.3	-213339	0	0	-213339
	22	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	2364.1	-342795	0	0	-342795
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-1167.5	169288	0	0	169288
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-439.3	63699	0	0	63699
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-480.3	69644	0	0	69644
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-471.7	68397	0	0	68397
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	4555.3	-660519	0	0	-660519
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	3892.8	-564456	0	0	-564456
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	644.6	-93467	0	0	-93467
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	647.6	-93902	0	0	-93902
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	5326.6	-772357	0	0	-772357
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	5257.8	-762381	0	0	-762381
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-151.5	21968	0	0	21968
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-116.7	16922	0	0	16922
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0	0	0	0	0
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	252.9	-36671	0	0	-36671
		TOTAL		-4184642		-152250	-4336892	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.