



Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/7709-7719

Date: 31.10.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 30.09.2019-06.10.2019

दिनांक -30.09.2019 से 06.10.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 18.10.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-18.10.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VARH) Charge Statement
for the period 30/09/19 to 06/10/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	7520715

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 30/09/19 to 06/10/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-936	135720	-0.1	-14.5	135706
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2349.8	340721	0	0	340721
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1229.7	178307	0	0	178307
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	73.5	-10658	0	0	-10658
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	35.8	-5191	0	0	-5191
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	92.8	-13456	0	0	-13456
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	1728.6	-250647	0	0	-250647
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1001.4	145203	0	0	145203
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1047.4	151873	0	0	151873
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1121.4	162603	0	0	162603
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-1437.5	208438	0	0	208438
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	0	0	0
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	11.4	-1653	0	0	-1653
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	4.1	-595	0	0	-595
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1544.1	-223895	0	0	-223895
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1343.4	194793	0	0	194793
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-86.4	12528	0	0	12528
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	627.5	-90988	0	0	-90988
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	676.2	-98049	0	0	-98049
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-762.7	110592	7.4	1073	111665
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1440.3	-208844	0	0	-208844
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1401	-203145	0	0	-203145
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1551.8	-225011	0	0	-225011
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1481.7	-214847	0	0	-214847
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	0	0	0	0	0
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1344.6	194967	0	0	194967
	28	HV side of 400/220 Patna ICT-2	ER1407A	-2421.5	351118	0	0	351118
	29	HV side of 400/220 Patna ICT-3	ER1231A	-2212	320740	0	0	320740
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	1573	-228085	0	0	-228085
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	1574.9	-228361	0	0	-228361
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1941.1	281460	0	0	281460
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1831.5	265568	0	0	265568
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1367.7	-198317	0	0	-198317
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1652.5	-239613	0	0	-239613
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2301.9	333776	0	0	333776
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2529	366705	0	0	366705
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	7.9	-1146	5	725	-421
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	9.4	-1363	3.9	565.5	-798
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	3531.1	-512010	0	0	3531.1
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	985.3	-142869	-120.5	-17472.5	985.3
		TOTAL		656372		-15124	641248	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-5725.2	830154	0	0	830154
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-4801.8	696261	0	0	696261
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-5230.8	758466	0	0	758466
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2247.4	-325873	0	0	-325873
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2802.6	-406377	0	0	-406377
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1819.2	-263784	0	0	-263784
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1	145	3.7	537	682
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	1272.8	-184556	0	0	-184556
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	1280.2	-185629	0	0	-185629
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	1544.3	-223924	0	0	-223924
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	1501	-217645	0	0	-217645
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-1	-145	-145
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-1.3	-189	-189
		TOTAL		477239		203	477442	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3513.6	509472	0	0	509472
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-874.2	126759	0	0	126759
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-987.4	143173	0	0	143173
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	554.8	-80446	0	0	-80446
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	605.2	-87754	0	0	-87754
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-259.2	37584	0	0	37584
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	4066.6	-589657	0	0	-589657
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	5967	-865215	0	0	-865215
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-3533.4	512343	0	0	512343
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-3600.3	522044	0	0	522043.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4625.9	670756	0	0	670755.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3746.5	543243	0	0	543242.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1825.8	264741	0	0	264741
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-2141.4	310503	0	0	310503
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-5271	764295	0	0	764295
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-5338.5	774083	0	0	774082.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-8305.1	1204240	0	0	1204239.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1439.1	-208670	0	0	-208669.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4086.2	592499	0	0	592499
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	10561	-1513345	0	0	-1513345
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	10440.4	-1513858	0	0	-1513858
		TOTAL		2098788		0	2098788	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-874.6	126817	0	0	126817
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-729.3	105748.5	0	0	105748.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	7066.5	-1024642.5	0	0	-1024642.5
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	52.3	-7583.5	0	0	-7583.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	30.5	-4422.5	0	0	-4422.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3891.8	564311	0	0	564311
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4115.2	596704	0	0	596704
	12	220 KV TSTPP (NTPC) - M MUNDALI (GRIDCO)-I	NP5112A	-4236.2	614249	0	0	614249
	13	220 KV TSTPP (NTPC) - M MUNDALI (GRIDCO)-II	NP5101A	-3625.4	525683	0	0	525683
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-753.2	109214	0	0	109214
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	1174.5	-170302.5	0	0	-170302.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	1368.1	-198374.5	0	0	-198374.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	368.7	-53461.5	0	0	-53461.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	21.8	-3161	0	0	-3161
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	15.2	-2204	0	0	-2204
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-538.5	78082.5	0	0	78082.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	-0.2	-29	-29
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0.7	-101.5	0	0	-101.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3675.2	532904	0	0	532904
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3708.7	537761.5	0	0	537761.5
		TOTAL		2327221		-29	2327192	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-37.00	5365	0	0	5365
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-0.50	73	0	0	73
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	5.30	-769	0	0	-769
		TOTAL		4669		0	4669	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	879.3	127499	127499
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	84	-12180	-81.3	-11789	-23969
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	50.6	-7337	-67.1	-9730	-17067
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1738.1	252025	0	0	252025
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1787.7	259217	0	0	259217
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	0	0	0	0	0
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	2.6	-377	0	0	-377
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2464.6	357367	0	0	357367
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-224.3	32524	0	0	32524
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	1572.1	-227955	0	0	-227955
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	2840	-411800	0	0	-411800
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	12126.9	-1758401	0	0	-1758401
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	6927.5	-1004488	0	0	-1004488
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-3385.1	490840	0	0	490840
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	3431	-497495	0	0	-497495
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	13.1	-1900	0	0	-1900
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-27.2	3944	0	0	3944
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	8406.1	-1218885	0	0	-1218885
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3870.2	-561179	0	0	-561179
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	5073.8	-735701	0	0	-735701
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	17.5	-2538	0	0	-2538
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	90.8	-13166	0	0	-13166
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-464.7	67382	77.7	11267	78648
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-492.4	71398	67.9	9846	81244
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	6595.2	-956304	0	0	-956304
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	6099.3	-884399	0	0	-884399
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	179.6	-26042	0	0	-26042
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	202	-29290	0	0	-29290
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	8249	-1196105	0	0	-1196105
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	7805	-1131725	0	0	-1131725
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-4020.7	583002	0	0	583002
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-3705.5	537298	0	0	537298
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	100.1	-14515	0	0	-14515
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	86.7	-12572	0	0	-12572
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-2769.3	401549	0	0	401549
		TOTAL		-7647808		127093	-7520715	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.