



Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8178-8188

Date: 08.11.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 14.10.2019-20.10.2019

दिनांक -14.10.2019 से 20.10.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 25.10.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-25.10.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।


The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,


for **MEMBER SECRETARY**

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VARH) Charge Statement
for the period 14/10/19 to 20/10/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5016145

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


for MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 14/10/19 to 20/10/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-731.8	106111	0	0	106111
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2285.2	331354	0	0	331354
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1033.4	149843	0	0	149843
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-84.8	12296	0	0	12296
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-184	26680	0	0	26680
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-66.6	9657	0	0	9657
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1168.6	169447	0	0	169447
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-685.4	99383	0	0	99383
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-750.2	108779	0	0	108779
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-655.5	95048	0	0	95048
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-2036.5	295293	0	0	295293
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	-33.3	4829	-46.9	-6800.5	-1972
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1144.5	-165953	0	0	-165953
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3536.8	512836	0	0	512836
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	1319.2	-191284	0	0	-191284
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	257.4	-37323	0	0	-37323
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	284	-41180	0	0	-41180
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1778	-257810	0	0	-257810
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1758.1	-254925	0	0	-254925
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1912.9	-277371	0	0	-277371
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1871.8	-271411	0	0	-271411
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	129.9	-18836	25.3	3668.5	-15167
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1589.8	230521	0	0	230521
	28	HV side of 400/220 Patna ICT-2	ER1407A	-2503.7	363037	0	0	363037
	29	HV side of 400/220 Patna ICT-3	ER1231A	-2319	336255	0	0	336255
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	55	-7975	0	0	-7975
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	54.6	-7917	0	0	-7917
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2710.3	392994	0	0	392994
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2670.3	387194	0	0	387194
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2032.1	-294655	0	0	-294655
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2037	-295365	0	0	-295365
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2683.7	389137	0	0	389137
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2855.1	413990	0	0	413990
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	447.1	-64830	0	0	-64830
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	459.5	-66628	0	0	-66628
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	521.9	-75676	0	0	521.9
		TOTAL		2105545		-3132	2102413	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3211.3	465639	0	0	465639
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1983.3	287579	0	0	287579
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-4219.2	611784	0	0	611784
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	914.9	-132661	0	0	-132661
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1272.8	-184556	0	0	-184556
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2293.2	-332514	0	0	-332514
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1546.3	224214	0	0	224214
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	323.2	-46864	0	0	-46864
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	378.8	-54926	0	0	-54926
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	379.5	-55028	0	0	-55028
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	340.7	-49402	0	0	-49402
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-9.9	-1436	-1436
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-10.2	-1479	-1479
		TOTAL		733265		-2915	730351	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3573.4	518143	0	0	518143
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-101	14645	0	0	14645
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-228.8	33176	0	0	33176
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-1226	177770	0	0	177770
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2658.9	-385541	0	0	-385540.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	2962.6	-429577	0	0	-429577
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1988.7	288362	0	0	288361.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2083.8	302151	0	0	302151
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-5056.5	733193	0	0	733192.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2774.3	402274	0	0	402273.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-953.1	138200	0	0	138199.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1509.5	218878	0	0	218877.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-5072.4	735498	0	0	735498
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-5128.3	743604	0	0	743603.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-5153.8	747301	0	0	747301
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	893.5	-129558	0	0	-129557.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3732	541140	0	0	541140
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	9239.6	-1339742	0	0	-1339742
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	9047	-1311815	0	0	-1311815
		TOTAL		1998100		0	1998100	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	33	-4785	0	0	-4785
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	49.9	-7235.5	0	0	-7235.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	463.7	-67236.5	0	0	-67236.5
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	2.7	-391.5	0	0	-391.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3476.1	504034.5	0	0	504034.5
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2425	351625	0	0	351625
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4402.8	638406	0	0	638406
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4343	629735	0	0	629735
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-418.3	60653.5	0	0	60653.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	522	-75690	0	0	-75690
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	1747.7	-253416.5	0	0	-253416.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-505.1	73239.5	0	0	73239.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0.2	29	29
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0.2	29	29
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	0	0	0
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-4400.4	638058	0	0	638058
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-4627.9	671045.5	0	0	671045.5
		TOTAL		3158042		58	3158100	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-142.50	20663	0	0	20663
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-10.60	1537	0	0	1537
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	11.60	-1682	0	0	-1682
		TOTAL		20518		0	20518	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	1038.4	150568	150568
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	99.6	-14442	-267.3	-38759	-53201
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	87	-12615	-169.8	-24621	-37236
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2470.3	358194	0	0	358194
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2516.2	364849	0	0	364849
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-167.8	27231	0	0	27231
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3262.9	473121	0	0	473121
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1211.4	175653	0	0	175653
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	2893.8	-419601	0	0	-419601
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	4034.6	-585017	0	0	-585017
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-12.5	1813	0	0	1813
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	10756	-1559620	0	0	-1559620
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	1804.9	-261711	0	0	-261711
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-2109.3	305849	0	0	305849
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	692.8	-100456	0	0	-100456
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	67.6	-9802	0	0	-9802
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-141.1	20460	0	0	20460
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	6710.9	-973081	0	0	-973081
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	1163.7	-168737	0	0	-168737
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	2610.9	-378581	0	0	-378581
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-45.4	66033	0	0	66033
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-452.3	65584	0	0	65584
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-356.4	51678	98	14210	65888
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-711.5	103168	79.9	11586	114753
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	4217.1	-611480	0	0	-611480
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	3449.8	-500221	0	0	-500221
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	420.7	-61002	0	0	-61002
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	458.7	-66512	0	0	-66512
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	6303.8	-914051	0	0	-914051
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	6255	-906975	0	0	-906975
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-1075.4	155933	0	0	155933
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-884.4	128238	0	0	128238
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	277.1	-40180	0	0	-40180
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	268.6	-38947	0	0	-38947
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-1352.4	196098	0	0	196098
		TOTAL		-5129129		112984	-5016145	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.