



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8224-8234

Date: 08.11.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 21.10.2019-27.10.2019

दिनांक -21.10.2019 से 27.10.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 01.11.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-01.11.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,


for MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VARH) Charge Statement
for the period 21/10/19 to 27/10/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	1270084
SIKKIM	POOL	0
WBSETCL	POOL	6894214

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


for MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 21/10/19 to 27/10/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1813.2	262914	0	0	262914
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3724.7	540082	0	0	540082
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2292.8	332456	0	0	332456
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-134.5	19503	0	0	19503
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-241.2	34974	0	0	34974
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-65.4	9483	0	0	9483
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	465.9	-67556	0	0	-67556
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1150.7	166852	0	0	166852
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1183.4	171593	0	0	171593
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1935.2	280604	0	0	280604
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-2199.8	318971	0	0	318971
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-195.8	28391	0	0	28391
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1708	-247660	0	0	-247660
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2355.1	341490	0	0	341490
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	494.7	-71732	0	0	-71732
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	548.8	-79576	0	0	-79576
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	579.4	-84013	0	0	-84013
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2228.9	-323191	0	0	-323191
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2203	-319435	0	0	-319435
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2388.8	-346376	0	0	-346376
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2340.7	-339402	0	0	-339402
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	426.3	-61814	0	0	-61814
	27	HV side of 400/220 Patna ICT-1	ER1408A	434.3	-62974	0	0	-62974
	28	HV side of 400/220 Patna ICT-2	ER1407A	-547.7	79417	0	0	79417
	29	HV side of 400/220 Patna ICT-3	ER1231A	-485.6	70412	0	0	70412
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	1167.5	-169288	0	0	-169288
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	1023.1	-148350	0	0	-148350
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2790.6	404637	0	0	404637
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2854.9	413961	0	0	413961
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2835.3	-411119	0	0	-411119
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2685.6	-389412	0	0	-389412
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1643.8	238351	0	0	238351
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1644.1	238395	0	0	238395
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	0	0	0	0	0
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	0	0	0	0	0
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL		830589	0	0	830589	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-4320.1	626415	0	0	626415
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3627.6	526002	0	0	526002
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-4732.5	686213	0	0	686213
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1889.4	-273963	0	0	-273963
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2283	-331035	0	0	-331035
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2621.6	-380132	0	0	-380132
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1238	179510	0	0	179510
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	952.2	-138069	0	0	-138069
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	950.8	-137866	0	0	-137866
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	1513.4	-219443	0	0	-219443
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	1527.6	-221502	0	0	-221502
	12	HV side meter of 400/220 Daltongarj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltongarj ICT-2	ER1317A	0	0	0	0	0
		TOTAL		316129	0	0	316129	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2425.2	351654	0	0	351654
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-491.2	71224	0	0	71224
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-543.8	78851	0	0	78851
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-1983.6	287622	0	0	287622
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	3827.3	-554959	0	0	-554958.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	5307.3	-769559	0	0	-769558.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-4656.5	675193	0	0	675192.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-4733.4	686343	0	0	686343
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-7412.7	1074842	0	0	1074841.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-6286.8	911586	0	0	911586
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1307.3	189559	0	0	189558.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1676	243020	0	0	243020
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-6234.6	904017	0	0	904017
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-6282.4	910948	0	0	910948
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-5857	849265	0	0	849265
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-2337.1	338880	0	0	338879.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3433.1	497800	0	0	497799.5
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	9603.3	-1392479	0	0	-1392478.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	9633.8	-1396901	0	0	-1396901
		TOTAL		3956905	0	0	3956905	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1168.3	169403.5	0	0	169403.5
	6	HV side meter of 400/220 Baripada ICT-1	ER1571A	-674	97730	0	0	97730
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	16454.6	-2385917	0	0	-2385917
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-16.7	2421.5	0	0	2421.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-16.1	2334.5	0	0	2334.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3262	472990	0	0	472990
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-1632.2	236669	0	0	236669
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4510.6	654037	0	0	654037
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4457.4	646323	0	0	646323
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-0.7	101.5	0	0	101.5
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-3849.9	558235.5	0	0	558235.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	12437.2	-1803394	0	0	-1803394
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	12620.2	-1829929	0	0	-1829929
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	4146.1	-601184.5	0	0	-601184.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	144.8	-20996	0	0	-20996
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	133.7	-19386.5	0	0	-19386.5
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-2919	423255	0	0	423255
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-37	5365	0	0	5365
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-7262.2	1053019	0	0	1053019
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-7371.3	1068838.5	0	0	1068838.5
		TOTAL		-1270084		0	-1270084	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-271.60	39382	0	0	39382
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-32.40	4698	0	0	4698
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	14.20	-2059	0	0	-2059
		TOTAL		42021		0	42021	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASHGRAM (PG)	ER1471A	0	0	151.3	21939	21939
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	440.4	-63858	-118.3	-17154	-81012
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	524.8	-76096	-59.9	-8686	-84782
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2349.6	340692	0	0	340692
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2365.3	342969	0	0	342969
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1059.2	153584	0	0	153584
	8	132 KV SILIGURI (PG) - NB (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-4089.5	592978	0	0	592978
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-2831	410495	0	0	410495
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	5544.7	-803982	0	0	-803982
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	6868.5	-995933	0	0	-995933
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-29.4	4263	0	0	4263
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	11930.6	-1729937	0	0	-1729937
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	6193.5	-898058	0	0	-898058
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-4478.2	649339	0	0	649339
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASHGRAM (PG)	NP6483A	832	-120640	0	0	-120640
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	105.6	-15312	0	0	-15312
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-201.5	29218	0	0	29218
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	6949.5	-1007678	0	0	-1007678
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3946.1	-572185	0	0	-572185
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	4566.5	-662143	0	0	-662143
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-232.4	33698	0	0	33698
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-243.9	35366	0	0	35366
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-232.3	33684	10.1	1465	35148
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-256.6	37207	7.9	1146	38353
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	3710	-537950	0	0	-537950
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	3289.8	-477021	0	0	-477021
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	514	-74530	0	0	-74530
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	566.1	-82085	0	0	-82085
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	7259.5	-1052628	0	0	-1052628
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	7164.7	-1038882	0	0	-1038882
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-1810.7	262552	0	0	262552
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-1498.6	217297	0	0	217297
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	1267.4	-183773	0	0	-183773
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	1228.8	-178176	0	0	-178176
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-3686.9	534601	0	0	534601
		TOTAL		-6892923		-1291	-6894214	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.