



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/9044-9054

Date: 04.12.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 11.11.2019-17.11.2019

दिनांक -11.11.2019 से 17.11.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 22.11.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-22.11.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

A 
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 11/11/19 to 17/11/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	632664
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5472924

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

f *g tar*
02/12/19
MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 11/11/19 to 17/11/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-936.9	135851	0	0	135851
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2292.9	332471	0	0	332471
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1219.2	176784	0	0	176784
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	140.1	-20315	0	0	-20315
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	167.9	-24346	0	0	-24346
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	200.8	-29116	0	0	-29116
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	1723	-249835	0	0	-249835
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1022.1	148205	0	0	148205
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1064.3	154324	0	0	154324
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1490.9	216181	0	0	216181
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-2039.8	295771	0	0	295771
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	-165	23925	0	0	23925
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1514.3	-219574	0	0	-219574
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1645.8	238641	0	0	238641
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-36.5	5293	0	0	5293
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	16	-2320	0	0	-2320
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	19	-2755	0	0	-2755
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2212.5	-320813	0	0	-320813
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2181.8	-316361	0	0	-316361
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2380.6	-345187	0	0	-345187
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2303.4	-333993	0	0	-333993
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	349.4	-50663	0	0	-50663
	27	HV side of 400/220 Patna ICT-1	ER1408A	560.3	-81244	0	0	-81244
	28	HV side of 400/220 Patna ICT-2	ER1407A	-434.7	63032	0	0	63032
	29	HV side of 400/220 Patna ICT-3	ER1231A	-379.8	55071	0	0	55071
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	901	-130645	0	0	-130645
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	912.6	-132327	0	0	-132327
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1211.7	175697	0	0	175697
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1268.7	183962	0	0	183962
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2717.3	-394009	0	0	-394009
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2723.6	-394922	0	0	-394922
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-728.6	105647	0	0	105647
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-728.8	105676	0	0	105676
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	2.1	-305	0	0	-305
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	3.2	-464	0	0	-464
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			-632664		0	-632664
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-6710.9	973081	0	0	973081
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-6448.7	935062	0	0	935062
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-4891.8	709311	0	0	709311
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	704.9	-102211	0	0	-102211
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1148.3	-166504	0	0	-166504
	6	220 KV FARAKKA (NTPC)-LALMATA (JUVNL)	NP5211A	2640	-382800	0	0	-382800
	7	132 KV KHALGAON (NTPC)-LALMATA (JUVNL)	NP5244A	-2045.9	296656	0	0	296656
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	558	-80910	0	0	-80910
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	573.4	-83143	0	0	-83143
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	3768.1	-546375	0	0	-546375
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	3639.9	-527786	0	0	-527786
	12	HV side meter of 400/220 Daltongarj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltongarj ICT-2	ER1317A	0	0	0	0	0
		TOTAL			1024382		0	1024382
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3085.6	447412	0	0	447412
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-523.2	75864	0	0	75864
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-3994.2	579159	0	0	579159
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	3554.5	-515403	0	0	-515402.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	2378.6	-344897	0	0	-344897
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-2426.5	351943	0	0	351942.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2570.4	372708	0	0	372708
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-5683.8	824151	0	0	824151
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4851.8	703511	0	0	703511
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-2885.4	418383	0	0	418383
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-3576.9	518651	0	0	518650.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-7385.7	1070927	0	0	1070926.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-7409.1	1074320	0	0	1074319.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-9868	1430860	0	0	1430860
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-238.5	34583	0	0	34582.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-6520.4	945458	0	0	945458
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	8471.7	-1228397	0	0	-1228396.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8185.8	-1186941	0	0	-1186941
		TOTAL			5572191		0	5572191

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	68.6	-9947	0	0	-9947
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	74.6	-10817	0	0	-10817
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1298	188210	0	0	188210
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-906.8	131486	0	0	131486
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-21	3045	0	0	3045
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-13.7	1986.5	0	0	1986.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3103	449935	0	0	449935
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2115.2	306704	0	0	306704
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2012.8	291856	0	0	291856
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2262.8	328106	0	0	328106
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-4666.3	676613.5	0	0	676613.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	11471.2	-1663324	0	0	-1663324
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	13211.9	-1915725.5	0	0	-1915725.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	3955.6	-573562	0	0	-573562
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	364.4	-52838	0	0	-52838
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	225.8	-32741	0	0	-32741
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-3926.8	569386	0	0	569386
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-87.8	12731	0	0	12731
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-7572	1097940	0	0	1097940
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-7622.2	1105219	0	0	1105219
		TOTAL		904264		0	904264	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-137.40	19923	0	0	19923
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-71.80	10411	0	0	10411
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.5	-72.5	-73
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.90	-2306	0	0	-2306
		TOTAL		28029		-73	27956	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	713.8	103501	103501
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1412.2	-204769	-9.3	-1349	-206118
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1428.2	-207089	-8	-1160	-208249
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2254.4	326888	0	0	326888
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2276.5	330093	0	0	330093
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-622.1	90205	0	0	90205
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2777	402665	0	0	402665
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1236.8	179336	0	0	179336
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	5968.4	-865418	0	0	-865418
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	6612.2	-958769	0	0	-958769
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-45.1	6540	0	0	6540
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	13212.1	-1915755	0	0	-1915755
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	5668.7	-821962	0	0	-821962
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-3998.9	579841	0	0	579841
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	4.4	-638	0	0	-638
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-28.9	4191	0	0	4191
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-29.5	4278	0	0	4278
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	6825.1	-989640	0	0	-989640
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3962.8	-574606	0	0	-574606
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	5156.3	-747664	0	0	-747664
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	90.5	-13123	0	0	-13123
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	15.2	-2204	0	0	-2204
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-1225.9	177756	0	0	177756
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	3905	-566225	0	0	-566225
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	3276.7	-475122	0	0	-475122
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-1217.2	176494	0	0	176494
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-1185.8	171941	0	0	171941
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	2827.3	-409959	0	0	-409959
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	4267.3	-618759	0	0	-618759
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	681.6	-98832	0	0	-98832
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-8005.9	1160856	0	0	1160856
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	586.4	-85028	0	0	-85028
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	472.4	-84498	0	0	-84498
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-3028	439060	0	0	439060
		TOTAL		-5573916		100993	-5472924	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.