



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH | 9090-9100

Date: 04.12.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 18.11.2019-24.11.2019

दिनांक -18.11.2019 से 24.11.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 29.11.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-29.11.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat. यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

f दिनांक
04/12/19
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VARH) Charge Statement
for the period 18/11/19 to 24/11/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	1887059
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	1096389
SIKKIM	POOL	3263
WBSETCL	POOL	4154874

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

f
Kolkata
04/12/19
MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 18/11/19 to 24/11/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-492.9	71471	0	0	71471
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1699.2	275384	0	0	275384
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-757.6	109852	0	0	109852
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	168.7	-24462	0	0	-24462
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	194.3	-28174	0	0	-28174
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	225	-32625	0	0	-32625
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	1660.9	-240831	0	0	-240831
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-907.9	131646	0	0	131646
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-949.1	137620	0	0	137620
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1535.4	222633	0	0	222633
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-2326.8	337386	0	0	337386
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-166.8	24186	0	0	24186
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1334.3	-193474	0	0	-193474
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1173.7	170187	0	0	170187
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	1074	-155730	0	0	-155730
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	34.2	-4959	0	0	-4959
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	45.1	-6540	0	0	-6540
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2465.6	-357512	0	0	-357512
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2426.7	-351872	0	0	-351872
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2652	-384540	0	0	-384540
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2576.4	-373578	0	0	-373578
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	327.4	-47473	0	0	-47473
	27	HV side of 400/220 Patna ICT-1	ER1408A	1398.6	-202797	0	0	-202797
	28	HV side of 400/220 Patna ICT-2	ER1407A	428.7	-62162	0	0	-62162
	29	HV side of 400/220 Patna ICT-3	ER1231A	418.3	-60654	0	0	-60654
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	623.1	-90350	0	0	-90350
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	616.8	-89436	0	0	-89436
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-453.8	65801	0	0	65801
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-612.7	88842	0	0	88842
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2945.2	-427054	0	0	-427054
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	3099.9	-449486	0	0	-449486
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-233.3	33829	0	0	33829
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-230.9	33481	0	0	33481
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	9.4	-1363	0	0	-1363
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	29.7	-4307	0	0	-4307
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			-1887059		0	-1887059
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-6087.9	882746	0	0	882746
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-5830.2	845379	0	0	845379
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-4599.6	665492	0	0	665492
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	250.4	-36308	0	0	-36308
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	658.1	-95425	0	0	-95425
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3093.8	-448601	0	0	-448601
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1796.2	260449	0	0	260449
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	469.4	-68063	0	0	-68063
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	484.2	-70209	0	0	-70209
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	3228.4	-468118	0	0	-468118
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	3217.2	-466494	0	0	-466494
	12	HV side meter of 400/220 Daltongarj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltongarj ICT-2	ER1317A	0	0	0	0	0
		TOTAL			1000848		0	1000848
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3389.2	491434	0	0	491434
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-273.4	39643	0	0	39643
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-4179	605955	0	0	605955
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	3668.7	-531962	0	0	-531961.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	2134.9	-309561	0	0	-309560.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1510.2	218979	0	0	218979
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1654.8	239946	0	0	239946
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4343.6	629822	0	0	629822
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3578.5	518883	0	0	518882.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-2813.4	407943	0	0	407943
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-3530.5	511923	0	0	511922.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-6604	957580	0	0	957580
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-5885.5	853398	0	0	853397.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-10225.1	1482640	0	0	1482639.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-33.3	4829	0	0	4828.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-5737.2	831894	0	0	831894
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7600.4	-1102058	0	0	-1102058
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7426.5	-1076843	0	0	-1076842.5
		TOTAL			4774444		0	4774444

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	-16	2320	0	0	2320
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-33.4	4843	0	0	4843
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-70.9	10280.5	0	0	10280.5
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-233.8	33901	0	0	33901
	7	400 KV INDRAVATI (PG) - INDRAVATI P(H)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-33.9	4915.5	0	0	4915.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-26	3770	0	0	3770
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3635.2	527104	0	0	527104
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-1768.8	256476	0	0	256476
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1662.4	241048	0	0	241048
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1330.8	192966	0	0	192966
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-4424.1	641494.5	0	0	641494.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	15898.6	-2305297	0	0	-2305297
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	16034.1	-2324944.5	0	0	-2324944.5
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	9055.3	-1313018.5	0	0	-1313018.5
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	493.1	-71499.5	0	0	-71499.5
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	324	-46980	0	0	-46980
	22	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4057.8	588381	0	0	588381
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-138.5	20082.5	0	0	20082.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-8390.1	1216564.5	0	0	1216564.5
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-8422.1	1221204.5	0	0	1221204.5
		TOTAL		-1096389		0	-1096389	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-96.30	13964	-145.8	-21141	-7178
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-60.30	8744	-15.5	-2247.5	6496
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	17.80	-2581	0	0	-2581
		TOTAL		20126		-23389	-3263	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	1181.3	171289	171289
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1474.4	-213788	-2.6	-377	-214165
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1242.4	-180148	-1.7	-247	-180395
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1995.6	289362	0	0	289362
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2031.6	294582	0	0	294582
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-690.2	100079	0	0	100079
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3172.1	459955	0	0	459955
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1691.8	245311	0	0	245311
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	7229.4	-1048263	0	0	-1048263
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	31	-4495	0	0	-4495
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	12947.3	-1877359	0	0	-1877359
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	4545.2	-659054	0	0	-659054
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-2905.1	421240	0	0	421240
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-536.4	77778	0	0	77778
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-39.4	5713	0	0	5713
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-21.9	3176	0	0	3176
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	6492	-941340	0	0	-941340
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	2805.7	-406827	0	0	-406827
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	3780.3	-548144	0	0	-548144
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-16.6	2407	0	0	2407
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	43.8	-6351	0	0	-6351
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-520.7	75502	0	0	75502
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-I	NP8723A	3254.1	-471845	0	0	-471845
	31	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-II	NP8724A	2800.3	-406044	0	0	-406044
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-1261.4	182903	0	0	182903
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-1230.2	178379	0	0	178379
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	2388.8	-346376	0	0	-346376
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	3562.6	-516577	0	0	-516577
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	1618.5	-234683	0	0	-234683
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-7607.6	1103102	0	0	1103102
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	1001.8	-145261	0	0	-145261
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	752.8	-109156	0	0	-109156
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-2418.5	350683	0	0	350683
		TOTAL		-4325539		170665	-4154874	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTD.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.