



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/11264-11274

Date: 28.01.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 06.01.2020-12.01.2020

दिनांक -06.01.2020 से 12.01.2020 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 17.01.2020.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-17.01.2020 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,


MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 06/01/20 to 12/01/20**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	137460
DVC	POOL	0
GRIDCO	POOL	1798841
SIKKIM	POOL	0
WBSETCL	POOL	3307001

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


for
MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 06/01/20 to 12/01/20

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA@H_HIGH	REACTIVE CHARGE_MVA@H (Rs)	MVA@H_LOW	REACTIVE CHARGE_MVA@L (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-781.5	113318	0	0	113318
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2165.8	314041	0	0	314041
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1169.4	169563	0	0	169563
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	136	-19720	0	0	-19720
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	127.8	-18531	0	0	-18531
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	187.9	-27246	0	0	-27246
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-745.5	108098	0	0	108098
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-856.5	124193	0	0	124193
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-892.2	129369	0	0	129369
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-1254.5	181903	0	0	181903
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-1771.7	256897	0	0	256897
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	49.9	-7236	101.5	0	-7134
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-81.6	11832	0	0	11832
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-25.2	3654	0	0	3654
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1251.4	-181453	0	0	-181453
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2092.6	303427	0	0	303427
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	583.2	-84564	0	0	-84564
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	54.9	-7961	0	0	-7961
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	54.9	-7961	0	0	-7961
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1567.1	-227230	0	0	-227230
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1531.7	-222097	0	0	-222097
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1666.1	-241585	0	0	-241585
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1620.9	-235031	0	0	-235031
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-11.3	1639	0	0	1639
	27	HV side of 400/220 Patna ICT-1	ER1408A	-805.8	116841	0	0	116841
	28	HV side of 400/220 Patna ICT-2	ER1407A	-1794.2	260159	0	0	260159
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1656.7	240222	0	0	240222
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	94.7	-13732	0	0	-13732
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	100.3	-14544	0	0	-14544
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1209.8	175421	0	0	175421
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1186.2	171999	0	0	171999
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	3129.9	-453836	0	0	-453836
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2836.2	-411249	0	0	-411249
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1401.8	203261	0	0	203261
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1436.6	208307	0	0	208307
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	667.4	-96773	0	0	-96773
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	705.3	-102269	0	0	-102269
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL		721129		102	721230	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-5865.9	850556	0	0	850556
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-5220.6	756987	0	0	756987
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-3284.7	476282	0	0	476282
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2224.5	-322553	0	0	-322553
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2710.7	-393052	0	0	-393052
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2041.6	-296032	0	0	-296032
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-662.3	96034	0	0	96034
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	972.2	-140969	0	0	-140969
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	1032.8	-149756	0	0	-149756
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	3545	-514025	0	0	-514025
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	3454.7	-500932	0	0	-500932
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL		-137460		0	-137460	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3409.6	494392	0	0	494392
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-187.8	27231	0	0	27231
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-3458.8	501526	0	0	501526
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	5292.7	-767442	0	0	-767441.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1419.4	-205813	0	0	-205813
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-2220.8	322016	0	0	322016
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2425.1	351640	0	0	351639.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3993.8	579101	0	0	579101
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3599.7	521957	0	0	521956.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	73.6	-10672	0	0	-10672
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-215.3	31219	0	0	31218.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-6402.5	928363	0	0	928362.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-6500.8	942616	0	0	942616
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7640.3	1107844	0	0	1107843.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-536.4	77778	0	0	77778
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4600.3	667044	0	0	667043.5
	21	400 KV RANCHI(PG)-RTPS(DVC)-I	NP7871A	6958.3	-1008954	0	0	-1008953.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6848.4	-993018	0	0	-993018
		TOTAL		3566826		0	3566826	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	360.2	-52229	0	0	-52229
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	371.4	-53853	0	0	-53853
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-80	11600	0	0	11600
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-72.1	10454.5	0	0	10454.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3476.4	504078	0	0	504078
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3386	490970	0	0	490970
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	0	0	0	0	0
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	0	0	0	0	0
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-32.6	4727	0	0	4727
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-4526.9	656400.5	0	0	656400.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	13746.9	-1993300.5	0	0	-1993300.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	13781.1	-1998259.5	0	0	-1998259.5
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	6561.8	-951461	0	0	-951461
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-I	NP5980A	757.5	-109837.5	0	0	-109837.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-II	NP7498A	579.6	-84042	0	0	-84042
	22	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4892.6	709427	0	0	709427
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-456.3	66163.5	0	0	66163.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-3417.1	495479.5	0	0	495479.5
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-3412.7	494841.5	0	0	494841.5
		TOTAL		-1798841		0	-1798841	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-57.80	8381	-12.3	-1783.5	6598
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-108.20	15689	0.5	72.5	15762
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-3.6	-522	-522
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	13.60	-1972	0	0	-1972
		TOTAL		22098		-2233	19865	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	302.4	43848	43848
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	599.6	-86942	-0.4	-58	-87000
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	640.2	-92829	0	0	-92829
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2038.4	295568	0	0	295568
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2101.8	304761	0	0	304761
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1587.6	230202	0	0	230202
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3050.5	442323	0	0	442323
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1583.7	229637	0	0	229637
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	10110.1	-1465965	0	0	-1465965
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-97	14065	0	0	14065
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	11777.2	-1707694	0	0	-1707694
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	4633.7	-671887	0	0	-671887
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-4329.8	627821	0	0	627821
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-269.6	39092	0	0	39092
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-136.2	19749	0	0	19749
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	76.4	-11078	0	0	-11078
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	6521.7	-945647	0	0	-945647
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	2526.7	-366372	0	0	-366372
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-20.4	2958	0	0	2958
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-129.9	18836	0	0	18836
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	1905.6	-276312	0	0	-276312
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-I	NP8723A	759.7	-110157	0	0	-110157
	31	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-II	NP8724A	601.8	-87261	0	0	-87261
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-413.4	59943	0	0	59943
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-384.3	55724	0	0	55724
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1040A	3269	-474005	0	0	-474005
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1130A	3030.1	-439365	0	0	-439365
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	1165.8	-169041	0	0	-169041
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-6732.7	976242	0	0	976242
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	859	-124555	0	0	-124555
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	972.6	-141027	0	0	-141027
40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-3465	502425	0	0	502425	
		TOTAL		-3350791		43790	-3307001	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.