



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /10843-853

Date: 16.01.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 23.12.2019-29.12.2019

दिनांक -23.12.2019 से 29.12.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 03.01.2020.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक- 03.01.2020 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 23/12/19 to 29/12/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	587091
JUVNL	POOL	156977
DVC	POOL	0
GRIDCO	POOL	1537116
SIKKIM	POOL	0
WBSETCL	POOL	1765781

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 23/12/19 to 29/12/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-518.9	75241	0	0	75241
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1615.7	234277	0	0	234277
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-746.1	108185	0	0	108185
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	93.9	-13616	0	0	-13616
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	81.5	-11818	0	0	-11818
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	141.2	-20474	0	0	-20474
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	186.6	-27057	0	0	-27057
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-751.3	108939	0	0	108939
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-782.4	113448	0	0	113448
	10	220 KV KHAGAU(L)BSPHCL) - ARAH (PG)-I	NP8641A	-1188.3	172304	0	0	172304
	11	220 KV KHAGAU(L)BSPHCL) - ARAH (PG)-II	NP6060A	-1872.8	271556	0	0	271556
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	-63	9135	-26.9	-3900.5	5235
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-125.7	18227	0	0	18227
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-23.6	3422	0	0	3422
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1072.6	-155527	0	0	-155527
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1928.3	279604	0	0	279604
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	408.4	-59218	0	0	-59218
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-8.2	1189	0	0	1189
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-11.3	1639	0	0	1639
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-26.1	3785	0	0	3785
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2102.7	-304892	0	0	-304892
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2059.6	-298642	0	0	-298642
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2239.5	-324728	0	0	-324728
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2192.4	-317898	0	0	-317898
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	205.6	-29812	4.6	667	-29145
	27	HV side of 400/220 Patna ICT-1	ER1408A	434.3	-62974	0	0	-62974
	28	HV side of 400/220 Patna ICT-2	ER1407A	-296.1	42935	0	0	42935
	29	HV side of 400/220 Patna ICT-3	ER1231A	-487.3	70659	0	0	70659
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	73.6	-10672	0	0	-10672
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	77.1	-11180	0	0	-11180
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	327.1	-47430	0	0	-47430
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	213.6	-30972	0	0	-30972
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2658.8	-385526	0	0	-385526
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2668	-386860	0	0	-386860
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1422.5	206263	0	0	206263
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1455.7	211077	0	0	211077
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	66.3	-9614	17.8	2581	-7033
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	82.3	-11934	17.4	2523	-8411
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL		-588961		1871	-587091	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-5200.7	754102	0	0	754102
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-4460.7	646802	0	0	646802
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-2816.8	408436	0	0	408436
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2160.4	-313258	0	0	-313258
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2565.1	-371940	0	0	-371940
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2879.1	-417470	0	0	-417470
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1618.9	234741	0	0	234741
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	925	-134125	0	0	-134125
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	1007.8	-146131	0	0	-146131
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	2842.8	-412206	0	0	-412206
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	2799.5	-405928	0	0	-405928
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL		-156977		0	-156977	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3172	459940	0	0	459940
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-93	13485	0	0	13485
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC) -BARIPADA(PG)	NP7408A	-3787.6	549202	0	0	549202
	8	400 KV TATA JAMSHEDPUR (DVC) -JAMSHEDPUR (PG)	NP7406A	4887.5	-708688	0	0	-708687.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1514.5	-219603	0	0	-219602.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-2067.2	299744	0	0	299744
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2193.9	318116	0	0	318115.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3120.5	452473	0	0	452472.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2838.2	411539	0	0	411539
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1232.4	178698	0	0	178698
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1628.6	236147	0	0	236147
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-5953	863185	0	0	863185
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-6057.8	878381	0	0	878381
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6722.5	974763	0	0	974762.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2661.3	-385889	0	0	-385888.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4018.6	582697	0	0	582697
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6790.8	-984666	0	0	-984666
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6704.4	-972138	0	0	-972138
		TOTAL		2947386		0	2947386	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	264.2	-38309	0	0	-38309
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	285.3	-41368.5	0	0	-41368.5
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1145.7	166126.5	0	0	166126.5
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-2202.5	319362.5	0	0	319362.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-224.1	32494.5	0	0	32494.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-167.1	24229.5	0	0	24229.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3340.2	484329	0	0	484329
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-1618	234610	0	0	234610
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1098	159210	0	0	159210
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-541.8	78561	0	0	78561
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-120.4	17458	0	0	17458
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO) - BARIPADA (PG)	NP7916A	-4278.5	620382.5	0	0	620382.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	11113.2	-1611414	0	0	-1611414
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	15567	-2257215	0	0	-2257215
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	6242.8	-905206	0	0	-905206
	20	400 KV MENDHASAL (GRIDCO) - PANDIABILI (PG)-I	NP5980A	755.1	-109489.5	0	0	-109489.5
	21	400 KV MENDHASAL (GRIDCO) - PANDIABILI (PG)-II	NP7498A	539.7	-78256.5	0	0	-78256.5
	22	400 KV DUBURI (GRIDCO) - PANDIABILI (PG)	NP7915A	-5613.5	813957.5	0	0	813957.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0.6	-87	-59.5	-8627.5	-8714.5
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0.6	-87	-59.1	-8569.5	-8655.5
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-665.8	96541	0	0	96541
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-1633.2	236814	0	0	236814
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-1637.5	237437.5	0	0	237437.5
		TOTAL		-1519919		-17197	-1537116	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-60.20	8729	0	0	8729
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-111.60	16182	0	0	16182
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-7.1	-1029.5	-1030
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	11.10	-1610	0	0	-1610
		TOTAL		23302		-1030	22272	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASHGRAM (PG)	ER1471A	0	0	292.8	42456	42456
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	1286.4	-186528	0	0	-186528
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	1284.9	-186311	0	0	-186311
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1989.6	288492	0	0	288492
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2044.6	296467	0	0	296467
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1605.7	232827	0	0	232827
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3022.6	438277	0	0	438277
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1202.1	174305	0	0	174305
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	9404.2	-1363609	0	0	-1363609
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-7.4	1073	0	0	1073
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	8242.5	-1195163	0	0	-1195163
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	3556.6	-515707	0	0	-515707
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-3340.7	484402	0	0	484402
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASHGRAM (PG)	NP6483A	-706.6	102457	0	0	102457
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-133.7	19387	0	0	19387
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	65.4	-9483	0	0	-9483
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	4613.4	-668943	0	0	-668943
	21	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	2580.1	-374115	0	0	-374115
	22	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-I	ER1071A	93.6	-13572	0	0	-13572
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-II	ER1072A	-26.3	3814	0	0	3814
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-I	ER1141A	406.7	-58972	0	0	-58972
	29	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-I	NP8723A	1955.8	-283591	0	0	-283591
	31	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-II	NP8724A	1552.3	-225084	0	0	-225084
	32	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-I	NP8731A	-480.5	69673	0	0	69673
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-II	NP8720A	-440.5	63873	0	0	63873
	34	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-I	ER1040A	-288.9	41891	0	0	41891
	35	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-II	ER1130A	-53.2	7714	0	0	7714
	36	400 KV GOKARNA (WB) - FARAKKA (NTPC)-I	ER1133A	1230.2	-178379	0	0	-178379
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC)-II	ER1138A	-6143.6	890822	0	0	890822
	38	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-I	ER1044A	183.3	-26579	0	0	-26579
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-II	ER1047A	232.5	-33713	0	0	-33713
	40	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-II	ER1131A	-2731.3	396039	0	0	396039
		TOTAL		-1808237		42456	-1765781	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.