

Format AS3: RRAS Provider Parameters by ERPC

FROM: **ERPC**

TO: **NODAL AGENCY (NLDC, DELHI)**


Name of the RRAS Provider Generating Station: **Darlipali STPP**

Name of the Owner Organization : **NTPC Ltd**

Validity of the information: From **01/03/2020 TO 15/03/2020**

Date: **11.03.2020**

S.No.	Title/Parameters	Values/Data
a)	Number of Generating Units	1x800 MW
b)	Total Installed Capacity (MW)	800 MW
c)	Maximum Possible Ex-Bus Injection (MW) (including overload , if any)	787.5
d)	Technical Minimum (MW)	412.5
e)	Type of Fuel	Primary: Coal, Secondary: LDO
f)	Region	Eastern Region
g)	Bid Area	E1
h)	Fixed Cost (paise/KWh up to one decimal place)	206.9
i)	Variable Cost (paise/KWh up to one decimal place)	133.8
j)	Ramp-Up Rate (MW/Min) for each unit	7.5
k)	Ramp-Down Rate (MW/Min) for each unit	7.5
l)	Start-Up from Cold Start, Warm Start and Hot start (in Min) for each unit	Cold: 2220 Warm: 1500
m)	Any other information	Nil


Shyam Kejriwal
SE(Comml), ERPC

No.: ERPC/Comml-II/AS-3