



Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/1652-62

Date: 05.06.2020

1. CE (Trans/O&M), BSPTCL, Vidhut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidhut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidhut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidhut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the period 04.05.2020-17.05.2020**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 22.05.2020.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(S. KEJRIWAL)  
MEMBER SECRETARY(I/C)

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 04/05/20 to 10/05/20**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	237045
JUVNL	POOL	512355
DVC	POOL	0
GRIDCO	POOL	4396755
SIKKIM	POOL	3600
WBSETCL	POOL	6132720

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

  
5/6/2020  
MEMBER SECRETARY 1/c

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 04/05/20 to 10/05/20

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1059.8	158970	0	0	158970
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2333.7	350055	0	0	350055
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1409.6	211440	0	0	211440
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	63.2	-9480	0	0	-9480
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	43.3	-6495	0	0	-6495
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	122.7	-18405	0	0	-18405
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	1554.5	-233175	0	0	-233175
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-494.5	74175	0	0	74175
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-543.9	81585	0	0	81585
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-353.7	53055	0	0	53055
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-614.5	92175	0	0	92175
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	80.5	-12075	0	0	-12075
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	725.6	-108840	0	0	-108840
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-862.5	129375	0	0	129375
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-577.1	86565	0	0	86565
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	74.8	-11220	0	0	-11220
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	80	-12000	0	0	-12000
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-2379.8	356970	0	0	356970
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2306	-345900	0	0	-345900
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2313.2	-346980	0	0	-346980
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2495.7	-374355	0	0	-374355
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2459.9	-368985	0	0	-368985
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-105.3	15795	0	0	15795
	27	HV side of 400/220 Patna ICT-1	ER1408A	244.5	-36675	393.7	59055	22380
	28	HV side of 400/220 Patna ICT-2	ER1407A	-279.6	41940	0	0	41940
	29	HV side of 400/220 Patna ICT-3	ER1231A	-238.4	35760	0	0	35760
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	154.6	-23190	0	0	-23190
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	167.3	-25095	0	0	-25095
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-240.1	36015	0	0	36015
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-321.2	48180	0	0	48180
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	82.2	-12330	0	0	-12330
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2187.5	-328125	0	0	-328125
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1790.4	268560	0	0	268560
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2039.4	305910	0	0	305910
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	28.7	-4305	28.9	4335	30
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	30.1	-4515	27.9	4185	-330
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-66.9	10035	-19	-2850	7185
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2764.9	-414735	0	0	-414735
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1679.8	-251970	0	0	-251970
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	614.9	-92235	0	0	-92235
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	1074.1	-161115	0	0	-161115
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-3625.8	543870	0	0	543870
		<b>TOTAL</b>		<b>-301770</b>		<b>64725</b>	<b>-537045</b>	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-6866.8	1030020	0	0	1030020
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-6453.6	968040	0	0	968040
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-3991.5	598725	0	0	598725
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	3544.6	-531690	0	0	-531690
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	4142	-621300	0	0	-621300
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3747.4	-562110	0	0	-562110
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	110.3	-16545	0	0	-16545
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	320.4	-48060	0	0	-48060
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	255.8	-38370	0	0	-38370
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	4402.7	-660405	0	0	-660405
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	4203.8	-630570	0	0	-630570
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-0.2	-30	-30
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-0.4	-60	-60
		<b>TOTAL</b>		<b>-512265</b>		<b>-90</b>	<b>-512355</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-930.4	139560	0	0	139560
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	573	-85950	0	0	-85950
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-4412	661800	0	0	661800
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	4826.5	-723975	0	0	-723975
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1767.6	-265140	0	0	-265140
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-5811.2	871680	0	0	871680
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-6049.1	907365	0	0	907365
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-8020.1	1203015	0	0	1203015
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-1924.2	288630	0	0	288630
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	9462.1	-1419315	0	0	-1419315
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	9316.1	-1397415	0	0	-1397415
		<b>TOTAL</b>		<b>180255</b>		<b>0</b>	<b>180255</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	1045.9	-156885	0	0	-156885
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	1133.1	-169965	0	0	-169965
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-3924.6	588690	0	0	588690
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	18.6	-2790	0	0	-2790
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-78.4	11760	0	0	11760
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2603.2	390480	0	0	390480
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2535.2	380280	0	0	380280
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2872.4	430860	0	0	430860
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2817	422550	0	0	422550
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-135.3	20295	0	0	20295
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-2743.3	411495	0	0	411495
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	4103.9	-615585	0	0	-615585
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	16426.8	-2464020	0	0	-2464020
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	31513.2	-4726980	0	0	-4726980
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-2707.6	406140	0	0	406140
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1714.5	257175	0	0	257175
	22	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3852.8	577920	0	0	577920
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-401.2	60180	0	0	60180
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-398.9	59835	0	0	59835
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-3320.2	498030	0	0	498030
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	375.1	-56265	0	0	-56265
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	482.5	-72375	0	0	-72375
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	2099.3	-314895	0	0	-314895
	32	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	2217.9	-332685	0	0	-332685
		<b>TOTAL</b>		<b>-4396755</b>	<b>0</b>	<b>0</b>	<b>-4396755</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	24.00	-3600	0	0	-3600
		<b>TOTAL</b>		<b>-3600</b>	<b>0</b>	<b>0</b>	<b>-3600</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-0.7	105	596.1	89415	89520
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	269.3	-40395	0	0	-40395
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	215.2	-32280	0	0	-32280
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1830.9	274635	0	0	274635
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1845.8	276870	0	0	276870
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-250.3	37545	0	0	37545
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3680.3	552045	0	0	552045
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1109.1	166365	0	0	166365
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	9195.8	-1379370	0	0	-1379370
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	11538.5	-1730775	0	0	-1730775
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	7009.1	-1051365	0	0	-1051365
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1780.7	267105	0	0	267105
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	4051.2	-607680	0	0	-607680
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-40	6000	0	0	6000
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-0.6	90	0	0	90
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	4428	-664200	0	0	-664200
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	4379.6	-656940	0	0	-656940
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-776.8	116520	0	0	116520
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-629	94350	0	0	94350
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	99.3	-14895	0	0	-14895
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	2632.3	-394845	0	0	-394845
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	2382.9	-357435	0	0	-357435
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-1142.1	171315	0	0	171315
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-1040.6	156090	0	0	156090
	34	400 KV PPS NEW(WB)-RANCHI NEW(PG)-II	ER1040A	5692	-853800	0	0	-853800
	35	400 KV PPS NEW(WB)-RANCHI NEW(PG)-I	ER1130A	5098.6	-764790	0	0	-764790
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	47.1	-7065	0	0	-7065
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	78.8	-11820	0	0	-11820
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-1516.1	227415	0	0	227415
	41	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	17.4	-2610	11.2	1680	-930
	42	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	0	0	0	0	0
		<b>TOTAL</b>		<b>-6223815</b>	<b>91095</b>	<b>91095</b>	<b>-6132720</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 11/05/20 to 17/05/20**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	356355
GRIDCO	POOL	4027695
SIKKIM	POOL	3240
WBSETCL	POOL	4066275

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

  
5/6/2020  
MEMBER SECRETARY 1/c

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 11/05/20 to 17/05/20

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-915.6	137340	0	0	137340
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2201.5	330225	0	0	330225
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1181.7	177255	0	0	177255
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-72.3	10845	0	0	10845
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-67.1	10065	0	0	10065
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-46.8	7020	0	0	7020
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	653.1	-97965	0	0	-97965
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-124.6	18690	0	0	18690
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-153.3	22995	0	0	22995
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-17.6	2640	0	0	2640
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-233.7	35055	0	0	35055
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	19.7	-2955	-56	-8400	-11355
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-150.2	22530	0	0	22530
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-58.5	8775	0	0	8775
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	188.7	-28305	0	0	-28305
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-669.5	100425	0	0	100425
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	0	0	0	0	0
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	85.7	-12855	0	0	-12855
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	95.7	-14355	0	0	-14355
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-1701.3	255195	0	0	255195
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1804.5	-270675	0	0	-270675
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1800.1	-270015	0	0	-270015
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1961	-294150	0	0	-294150
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1913.6	-287040	0	0	-287040
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-2.5	375	21.7	3255	3630
	27	HV side of 400/220 Patna ICT-1	ER1408A	-639.7	95955	0	0	95955
	28	HV side of 400/220 Patna ICT-2	ER1407A	-1382.7	207405	0	0	207405
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1264.9	189735	0	0	189735
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	135.8	-20370	0	0	-20370
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	138.3	-20745	0	0	-20745
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1322.9	198435	0	0	198435
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1303.5	195525	0	0	195525
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1920.5	-288075	0	0	-288075
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1920.4	-288060	0	0	-288060
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2062.9	309435	0	0	309435
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2295.1	344265	0	0	344265
	38	HV side of 400/220 Darshanaga DMTCL ICT-1	ER1274A	35.9	-5385	2.7	405	-4980
	39	HV side of 400/220 Darshanaga DMTCL ICT-2	ER1275A	41.8	-6270	1.8	270	-6000
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-20.4	3060	0	0	3060
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2020.5	-303075	0	0	-303075
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1466.3	-219945	0	0	-219945
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	654.7	-98205	0	0	-98205
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	486.6	-72990	0	0	-72990
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-3366.2	504930	0	0	504930
		<b>TOTAL</b>		<b>586740</b>		<b>-4470</b>	<b>582270</b>	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-6158.5	923775	0	0	923775
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-5119.7	767955	0	0	767955
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-3229.2	484380	0	0	484380
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2994.2	-449130	0	0	-449130
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	3225.7	-483855	0	0	-483855
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3038.2	-455730	0	0	-455730
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-222.3	33345	0	0	33345
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-156.2	23430	0	0	23430
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-304.6	45690	0	0	45690
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	2778.4	-416760	0	0	-416760
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	2661.2	-399180	0	0	-399180
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-13.8	-2070	-2070
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-16.8	-2520	-2520
		<b>TOTAL</b>		<b>73920</b>		<b>-4590</b>	<b>69330</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1670.2	250530	0	0	250530
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	584	-87600	0	0	-87600
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-2362.6	354390	0	0	354390
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	3382.1	-507315	0	0	-507315
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1468	-220200	0	0	-220200
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-4455.7	668355	0	0	668355
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-4511	676650	0	0	676650
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7629.4	1144410	0	0	1144410
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-1294.2	194130	0	0	194130
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	9410.6	-1411590	0	0	-1411590
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	9454.1	-1418115	0	0	-1418115
		<b>TOTAL</b>		<b>-356355</b>		<b>0</b>	<b>-356355</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	566.9	-85035	0	0	-85035
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	629	-94350	0	0	-94350
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1522.9	228435	0	0	228435
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	141.4	-21210	0	0	-21210
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	24.8	-3720	0	0	-3720
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2872.6	430890	0	0	430890
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2908.4	436260	0	0	436260
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3221	483150	0	0	483150
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3166.6	474990	0	0	474990
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	876.1	-131415	0	0	-131415
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-2473.5	371025	0	0	371025
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	4678.5	-701775	0	0	-701775
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	12682.9	-1902435	0	0	-1902435
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	19910.8	-2986620	0	0	-2986620
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	-971.2	145680	0	0	145680
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	-592.7	88905	0	0	88905
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-2267.2	340080	0	0	340080
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-833.9	125085	0	0	125085
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	1152.4	-172860	0	0	-172860
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	1408.3	-211245	0	0	-211245
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH (PG)-OPGC-1	ER1117A	2837.5	-425625	0	0	-425625
	32	400 KV SUNDERGARH (PG)-OPGC-2	ER1119A	2772.7	-415905	0	0	-415905
		<b>TOTAL</b>		<b>-4027695</b>	<b>0</b>	<b>0</b>	<b>-4027695</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	21.60	-3240	0	0	-3240
		<b>TOTAL</b>		<b>-3240</b>	<b>0</b>	<b>0</b>	<b>-3240</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-84.8	12720	159.9	23985	36705
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	22.8	-3420	-104.9	-15735	-19155
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-11.9	1785	-96.8	-14520	-12735
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1699.8	254970	0	0	254970
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1741.4	261210	0	0	261210
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-883.8	132570	0	0	132570
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3660.5	549075	0	0	549075
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1583.5	237525	0	0	237525
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	9563.3	-1434495	0	0	-1434495
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	10185.1	-1527765	0	0	-1527765
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	4548.3	-682245	0	0	-682245
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-2364	354600	0	0	354600
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	2048.4	-307260	0	0	-307260
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-69.7	10455	0	0	10455
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	6.7	-1005	0	0	-1005
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	3932.1	-589815	0	0	-589815
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3075	-461250	0	0	-461250
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-I	ER1071A	-779.6	116940	0	0	116940
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-II	ER1072A	-526.3	78945	0	0	78945
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-I	ER1141A	199.4	-29910	0	0	-29910
	29	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB) - BERHAMPORE (PG) LINE-I	NP8723A	168	-25200	0	0	-25200
	31	400 KV SAGARDIGHI (WB) - BERHAMPORE (PG) LINE-II	NP8724A	198.5	-29775	0	0	-29775
	32	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-I	NP8731A	-575	86250	0	0	86250
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-II	NP8720A	-520.2	78030	0	0	78030
	34	400 KV PPS NEW (WB) - RANCHI NEW (PG)-II	ER1040A	4686.2	-702930	0	0	-702930
	35	400 KV PPS NEW (WB) - RANCHI NEW (PG)-I	ER1130A	3767.7	-565155	0	0	-565155
	36	400 KV GOKARNA (WB) - FARAKKA (NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-I	ER1044A	314.8	-47220	0	0	-47220
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-II	ER1047A	454.6	-68190	0	0	-68190
	40	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-II	ER1131A	-1658.5	248775	0	0	248775
	41	HV side of 400/220 KV RAJARHAT (PG) ICT-1	ER1526A	44.1	-6615	-10.7	-1605	-8220
	42	220 KV GAZOLE (WB) - MALDA (PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE (WB) - MALDA (PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE (WB) - DALKHOLA (PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE (WB) - DALKHOLA (PG)-2	ER1699A	0	0	0	0	0
		<b>TOTAL</b>		<b>-4058400</b>	<b>-7875</b>	<b>-7875</b>	<b>-4066275</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.