



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

Tel No.:033-24239659/9651 FAX No.:033-24239652/53 Web: www.erpcc.gov.in

सं./ No. ERPC /COM-I/Ramp-cert/2020-21/ **2709-31**

दिनांक / Date: 17.07.2020

To: As per list enclosed / सेवा में: संलग्न सूची के अनुसार

Sub: Certification of Ramping performance of Thermal ISGS of ER for April,2020

With reference to the regulation 30 of Central Electricity Regulatory Commission (Term & Condition of Tariff) Regulation ,2019-24 & final detailed guidelines for assessment of ramping capability of thermal Interstate generating stations issued by NLDC vide letter dated 28.02.2020, wherein it is stated that a statement of summary of calculations shall be prepared by respective RLDCs and certified by RPCs, at the end of each month of the financial year on cumulative basis.

Accordingly, the statement of summary of calculations of ramping performance of thermal ISGS of Eastern Region **up to the month of April,2020 (For FY 2020-21)** furnished by ERLDC has been certified and given at **Annexure-I**. This is for kind information and necessary action by the constituents.

Yours faithfully,

(S. Kejriwal)
Member Secretary(I/C)

List of Addressee

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JBVNL, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004,
4. GM-cum-CE (Trans), JUSNL, Kusai Colony, Duranda, Ranchi, Jharkhand (Fax:0651-2490486)
5. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
6. CE (SLDC), DVC, P.O.: Danesh Seikh Lane, Andul Road, Howrah - 71110 9. FAX-033-2688-5094
7. Sr.GM (PP), GRIDCO, 4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22.
8. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2748509)
9. Sr. General Manager (Finance), OPGC, Odisha (Fax: 06645 222225)
10. CE (Trans.), Energy & Power Deptt., Govt. of Sikkim, Gangtok.-737 101
11. CE (SLDC), WBSETCL, PO. Danesh Sheikh Lane, Howrah-109. (Fax: 033-26886232)
12. AGM (Comml), NTPC Ltd, Loknayak Jaiprakash Bhawan, 2nd floor, Dak Banglow Chowk, Fraser Road, Patna-800 001. (Fax : 0612-2230035 / 2224287 ,2211807)
13. GM (Comml), NTPC Ltd, 7 Institutional Area, Lodhi Road, New Delhi-3 (Fax: 011-24360318)
14. AGM(Comml.), ER-I, Powergrid, Patna (Fax: 0612 2227630)
15. AGM(Comml.), ER-II, Powergrid, Kolkata (Fax NO. 033 2357 2827)
16. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235809)
17. ED, NRLDC, 18A, Shaheed JSS Marg, Katwaria Sarai, New Delhi-110 016. (Fax:011-26852747)
18. GM (Power Sales), GMRKEL, Plot no 29, Satya Nagar, Bhubaneswar- 751 007(Fax: 0674- 2572794)
19. Head (Power Sales), JITPL, Local shopping centre, Sector-B1, Vasant kunj, New Delhi- 110 070
20. AGM, SO, NVVN, SCOPE Complex, Core-5, 1st & 2nd Floor, Lodhi Road, New Delhi-110003 (Fax: 011-24367021)
21. Head (Commercial), TPTCL, Tata Power Co Ltd, B12 & 13, 2nd Floor, Shatabdi Bhawan, Sector 4, NOIDA – 201 301 (Fax: 0120-2540085/0050)
22. AGM, BRBCL, Nabinagar, Aurangabad BIHAR (Fax: 06332 233002).

Annexure-I

Ramp Performance of Thermal Power Stations for Month										April-2020
Number of months in computation (M):										1
Station	Total no. of Time Blocks (Tm)	No. of Time Blocks Where Declared Ramp Up & Down rate $\geq 1\%(T_d)$	Td/Tm	No. of time blocks where scheduled ramp $\geq 1\%/min$ (D)	Out of (D), no. of time blocks where actual ramp $\geq$ scheduled ramp (E)	Out of (D), no. of time blocks where actual ramp $\geq 1\%/min$ (F)	Average actual ramp rate during blocks when scheduled ramp $\geq 1\%/min$ (%/min) (AARR)	E/D	F/D	Recommended change in RoE(%)
BARH	2879	2879	1	290	171	172	0.71	0.59	0.59	-0.25
BRBCL	2768	2647	0.96	403	122	122	0.53	0.3	0.3	-0.25
Darlipali_NTPC	2879	2879	1	3	0	0	0.08	0	0	0
FSTPP-III	2879	2879	1	138	120	120	0.76	0.87	0.87	0
FSTPP I & II	2879	2877	1	312	189	191	0.71	0.61	0.61	-0.25
KHSTPP-I	2879	2879	1	302	123	127	0.59	0.41	0.42	-0.25
KHSTPP-II	2878	2763	0.96	248	81	82	0.54	0.33	0.33	-0.25
MTPS-II	2876	2876	1	494	313	314	0.76	0.63	0.64	-0.25
NPGC	2879	2879	1	347	251	253	0.74	0.72	0.73	-0.25
TSTPP-I	2871	2869	1	270	160	164	0.72	0.59	0.61	-0.25

MEMBER SECRETARY (I/C)