



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpcc.gov.in

NO: ERPC/COM-II/VARH/2776-2786

Date: 23.07.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 29.06.2020-05.07.2020

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 10.07.2020.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
MEMBER SECRETARY(I/C)

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 29/06/20 to 05/07/20**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	96600
GRIDCO	POOL	4290
SIKKIM	POOL	3015
WBSETCL	POOL	1730400

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 29/06/20 to 05/07/20

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-405.4	60810	0	0	60810
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1516.1	227415	0	0	227415
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-617.9	92685	0	0	92685
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-3.5	525	-69.6	-10440	-9915
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-19.3	2895	-10.1	-1515	1380
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-0.8	120	-37.8	-5670	-5550
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-293.1	43965	0	0	43965
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-17.3	2595	-0.2	-30	2565
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-28.4	4260	-0.1	-15	4245
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-6.7	1005	0	0	1005
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-256.8	38520	0	0	38520
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	326.2	48930	48930
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	29.9	-4485	0.1	15	-4470
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-142.8	21420	0	0	21420
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-776.7	116505	0	0	116505
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-15.8	2370	0	0	2370
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-0.2	30	0	0	30
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-0.2	30	0	0	30
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-394.3	59145	0	0	59145
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	1467.3	-220095	0	0	-220095
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	1455.5	-218325	0	0	-218325
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	1577.3	-236595	0	0	-236595
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	1544.4	-231660	0	0	-231660
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-0.2	30	-217.4	-32610	-32580
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1796.2	269430	0	0	269430
	28	HV side of 400/220 Patna ICT-2	ER1407A	-2430.5	364575	0	0	364575
	29	HV side of 400/220 Patna ICT-3	ER1231A	-2270.9	340635	0	0	340635
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	50.2	-7530	0	0	-7530
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	50.6	-7590	0	0	-7590
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1564.6	234690	0	0	234690
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1528.4	229260	0	0	229260
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1714	-257100	0	0	-257100
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1721.1	-258165	0	0	-258165
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3251.5	487725	0	0	487725
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3480.2	522030	0	0	522030
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	133.3	-19995	28.8	4320	-15675
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	148.5	-22275	-2.5	-675	-22950
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-II	ER1258A	-255.9	38385	0	0	38385
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPHCL)-I	ER1348A	2647.3	-397095	0	0	-397095
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPHCL)-II	ER1376A	-84424.4	12663660	-120.4	-18060	12645600
	44	220 KV NADHOKHAR(BSPHCL)-ARA(PG) LINE-1	ER1305A	25.6	-3840	0	0	-3840
	45	220 KV NADHOKHAR(BSPHCL)-PUSAULI(PG) LINE-1	ER1310A	848.6	-127290	0	0	-127290
	46	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-3438.5	515775	0	0	515775
		TOTAL		14328450		-15750	14312700	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3274.1	491115	0	0	491115
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1940.6	291090	0	0	291090
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-1698.6	254790	0	0	254790
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1827.5	-274125	0	0	-274125
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2216.3	-332445	0	0	-332445
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1352.8	-202920	0	0	-202920
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-450.8	67620	0	0	67620
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-22.8	3420	0	0	3420
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-166.4	24960	0	0	24960
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	685.7	-102855	0	0	-102855
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	622.9	-93435	0	0	-93435
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-39.2	5880	-26.2	-3930	1950
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-36.1	5415	-28.1	-4215	1200
		TOTAL		138510		-8145	130365	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2191.6	328740	0	0	328740
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	68.4	-10260	0	0	-10260
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-1469.4	220410	0	0	220410
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	1831.6	-274740	0	0	-274740
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-516.3	77445	0	0	77445
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2811.3	421695	0	0	421695
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2852.1	427815	0	0	427815
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4227.1	634065	0	0	634065
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	603.2	-90480	0	0	-90480
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6140.7	-921105	0	0	-921105
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6067.9	-910185	0	0	-910185
		TOTAL		-96600		0	-96600	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	3	-450	0	0	-450
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	5	-750	0	0	-750
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeyapore ICT-1	ER1550A	-3039.3	455895	0	0	455895
	6	HV side meter of 400/220 Jeyapore ICT-2	ER1571A	-888.9	133335	0	0	133335
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	35.7	-5355	0	0	-5355
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	309.2	-46380	0	0	-46380
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3446.2	516930	0	0	516930
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-1599.2	239880	0	0	239880
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3100	465000	0	0	465000
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3093.4	464010	0	0	464010
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA (PG)	NP7916A	-588.4	88260	0	0	88260
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	2617.8	-392670	0	0	-392670
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	10474.4	-1571160	0	0	-1571160
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-I	NP5980A	-672.4	100860	0	0	100860
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-II	NP7498A	-371.1	55665	0	0	55665
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-481.1	72165	0	0	72165
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-1.7	255	0	0	255
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-1.5	225	0	0	225
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-505.8	75885	0	0	75885
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-1302.3	195345	0	0	195345
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-1248.7	187305	0	0	187305
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH (PG)-OPGC-1	ER1117A	3316.6	-497490	0	0	-497490
	32	400 KV SUNDERGARH (PG)-OPGC-2	ER1119A	3607	-541050	0	0	-541050
		TOTAL		-4290		0	-4290	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-1	NP6029A	0.00	0	0	0	
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	20.10	-3015	0	0	-3015
		TOTAL		-3015		0	-3015	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-3046.2	-456930	-456930
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-237	35550	-93	-13950	21600
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-191.5	28725	-102	-15300	13425
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1486A	-996.9	149535	0	0	149535
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1038.7	155805	0	0	155805
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-176.9	26535	0	0	26535
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2571.6	385740	0	0	385740
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-180	27000	0	0	27000
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	2372	-355800	0	0	-355800
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGA PUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	5538.5	-830775	0	0	-830775
	15	400 KV DURGA PUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	445.3	-66795	0	0	-66795
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-489.8	73470	0	0	73470
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-162.8	24420	0	0	24420
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	30.4	-4560	0	0	-4560
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-93	13950	0	0	13950
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2723.4	-408510	0.7	105	-408405
	21	400 KV DURGA PUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	172.5	-25875	0	0	-25875
	22	400 KV DURGA PUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-1333.3	199995	0	0	199995
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-248.4	37260	0	0	37260
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	195.1	-29285	146	21900	-7365
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	-49.4	7410	0	0	7410
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	-6.5	975	0	0	975
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	108.9	-16335	0	0	-16335
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	119.8	-17970	0	0	-17970
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	2566.6	-384990	0	0	-384990
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	1895.6	-284340	0	0	-284340
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	36.9	-5535	0	0	-5535
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	41.6	-6240	0	0	-6240
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-22.5	3375	0	0	3375
	41	HV side of 400/220 KV RAJARHAT (PG) ICT-1	ER1526A	-54.7	8205	-47.9	-7185	1020
	42	220 KV GAZOLE (WB)-MALDA (PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE (WB)-MALDA (PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE (WB)-DALKHOLA (PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE (WB)-DALKHOLA (PG)-2	ER1699A	0	0	0	0	0
		TOTAL		-1259040		-471360	-1730400	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH, w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.