



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/4749-4759

Date: 28.09.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 07.09.2020-13.09.2020

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 18.09.2020.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 07/09/20 to 13/09/20**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	1183485
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	2460
WBSETCL	POOL	1763220

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 07/09/20 to 13/09/20

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-879.7	131955	0	0	131955
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2216.3	332445	0	0	332445
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1100.6	165090	0	0	165090
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	6.4	-960	-334.6	-50190	-51150
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-28.4	4260	-137.1	-20565	-16305
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	3.7	-555	-230.8	-34620	-35175
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2213.7	332055	0	0	332055
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-7.9	1185	-2.7	-405	780
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-14.1	2115	-2.3	-345	1770
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-0.1	15	0	0	15
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-161.6	24240	0	0	24240
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-533.8	-80070	-80070
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	14.1	-2115	3.6	540	-1575
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-733.4	110010	0	0	110010
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1512	226800	0	0	226800
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	249	-37350	0	0	-37350
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	0	0	0	0	0
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	0	0	0	0	0
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-374.4	56160	0	0	56160
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1253.1	-187965	0	0	-187965
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1274.2	-191130	0	0	-191130
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1379.2	-206880	0	0	-206880
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1344.6	-201690	0	0	-201690
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	0	0	564.9	84735	84735
	27	HV side of 400/220 Patna ICT-1	ER1408A	-2594.6	389190	0	0	389190
	28	HV side of 400/220 Patna ICT-2	ER1407A	-3162.6	474390	0	0	474390
	29	HV side of 400/220 Patna ICT-3	ER1231A	-2961.1	444165	0	0	444165
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	8.1	-1215	0	0	-1215
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	8.4	-1260	0	0	-1260
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1231.5	184725	0	0	184725
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1186.5	177975	0	0	177975
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1596.1	-239415	0	0	-239415
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1589.6	-238440	0	0	-238440
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-4033.2	604980	0	0	604980
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-4491	673650	0	0	673650
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	310.7	-46605	0	0	-46605
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	325.5	-48825	0	0	-48825
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-528.2	79230	0	0	79230
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2092.4	-313860	0	0	-313860
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1445.5	-216825	0	0	-216825
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-253.8	38070	0	0	38070
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	1947.8	-292170	0	0	-292170
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-3515.2	527280	0	0	527280
		TOTAL		2752725		-100920	2651805	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1402.9	210435	0	0	210435
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-846.3	126945	0	0	126945
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-891	133650	0	0	133650
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1563.5	-234525	0	0	-234525
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1952	-292800	0	0	-292800
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1121.8	-168270	0	0	-168270
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	113.5	-17025	0	0	-17025
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	2893	-433950	0	0	-433950
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3259.2	-488880	0.2	30	-488850
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	37.7	-5655	0	0	-5655
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	18.7	-2805	0	0	-2805
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-33.7	-5055	-5055
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-37.2	-5580	-5580
		TOTAL		-1172880		-10605	-1183485	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1428.6	214290	0	0	214290
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-242.8	36420	0	0	36420
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-940.3	141045	0	0	141045
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	748.7	-112305	0	0	-112305
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1693.4	254010	0	0	254010
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-2674.4	401160	0	0	401160
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2544.3	381645	0	0	381645
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-2189.4	328410	0	0	328410
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2194.5	329175	0	0	329175
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6105.1	915765	0	0	915765
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2417.8	-362670	0	0	-362670
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2055.7	308355	0	0	308355
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	8281.2	-1242180	0	0	-1242180
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8223	-1233450	0	0	-1233450
		TOTAL		359670		0	359670	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	-0.3	45	0	0	45
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-0.4	60	0	0	60
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-0.4	60	0	0	60
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-4946.8	742020	0	0	742020
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2874.2	431130	0	0	431130
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3020.4	453060	0	0	453060
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2991.6	448740	0	0	448740
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-571.7	85755	0	0	85755
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	0	0	0	0	0
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	10.4	-1560	0	0	-1560
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	138	-20700	0	0	-20700
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	201.5	30225	30225
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	203.6	30540	30540
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	0	0	0
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-503.7	75555	0	0	75555
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-592.5	88875	0	0	88875
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-1628.2	244230	0	0	244230
	32	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-1623.8	243570	0	0	243570
		TOTAL		2790840		60765	2851605	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	16.40	-2460	0	0	-2460
		TOTAL		-2460		0	-2460	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-797.5	-119625	-119625
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-171.2	25680	0	0	25680
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-115.6	17340	-0.2	-30	17310
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1015.6	152340	0	0	152340
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1082.6	162390	0	0	162390
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-175	26250	0	0	26250
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2118.3	317745	0	0	317745
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-172	25800	0	0	25800
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	2088.2	-313230	0	0	-313230
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	6627.2	-994080	0	0	-994080
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	673.5	-101025	0	0	-101025
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1555.2	233280	0	0	233280
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-99.4	14910	0	0	14910
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	12.2	-1830	0	0	-1830
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-70.7	10605	0	0	10605
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2153.8	-323070	0	0	-323070
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	425.8	-63870	0	0	-63870
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-755.1	113265	0	0	113265
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-166.2	24930	0	0	24930
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	81.6	-12240	0	0	-12240
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	693.4	-104010	0	0	-104010
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	410.7	-61605	0	0	-61605
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	332.1	-49815	0	0	-49815
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	332.6	-49890	0	0	-49890
	34	400 KV PPS NEW(WB)-RANCHI NEW(PG)-II	ER1040A	3019.3	-452895	0	0	-452895
	35	400 KV PPS NEW(WB)-RANCHI NEW(PG)-I	ER1130A	1935	-290250	0	0	-290250
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	15	-2250	0	0	-2250
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-380.1	57015	0	0	57015
	41	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	33.7	-5055	0	0	-5055
	42	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	0	0	0	0	0
		TOTAL		-1643565		-119655	-1763220	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.