



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpcc.gov.in

NO: ERPC/COM-II/VARH/4531-4541

Date: 17.09.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 24.08.2020-30.08.2020

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 04.09.2020.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 24/08/20 to 30/08/20**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	1368600
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	4560
WBSETCL	POOL	2616675

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 24/08/20 to 30/08/20

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-977.5	146625	0	0	146625
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2875	431250	0	0	431250
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1291	193650	0	0	193650
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-20.9	3135	-312.1	-46815	-43680
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-69.6	10440	-160.8	-24120	-13680
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-29.6	4440	-232.6	-34890	-30450
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1333.2	199980	0	0	199980
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-42.8	6420	-0.5	-75	6345
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-57.9	8685	-0.1	-15	8670
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-10.3	1545	0	0	1545
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-346.4	51960	0	0	51960
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0.3	-45	18.5	2775	2730
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-18.9	2835	0	0	2835
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-16.3	2445	0	0	2445
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	70.6	-10590	0.3	45	-10545
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NPS261A	-1342.9	201435	0	0	201435
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1688.7	253305	0	0	253305
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	265.1	-39765	0	0	-39765
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	9.8	-1470	0	0	-1470
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	15.5	-2325	0	0	-2325
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-463.7	69555	0	0	69555
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	988.5	-148275	0	0	-148275
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	990.5	-148575	0	0	-148575
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1083.1	-162465	0	0	-162465
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1043.8	-156570	0	0	-156570
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-2.2	330	-1.3	-195	135
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1798.2	269730	0	0	269730
	28	HV side of 400/220 Patna ICT-2	ER1407A	-2472.3	370845	0	0	370845
	29	HV side of 400/220 Patna ICT-3	ER1231A	-2324.4	348660	0	0	348660
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	117.7	-17655	0	0	-17655
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	115.8	-17370	0	0	-17370
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-764.8	114720	0	0	114720
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-749.7	112455	0	0	112455
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1210.5	-181575	0	0	-181575
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1213.8	-182070	0	0	-182070
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3842.4	576360	0	0	576360
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-4281.2	642180	0	0	642180
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	569.1	-85365	0	0	-85365
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	589.9	-88485	0	0	-88485
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-228.9	34335	-1.4	-210	34125
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2099.7	-314955	0	0	-314955
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-II	ER1376A	2181.5	-327225	0	0	-327225
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-267.5	40125	0	0	40125
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	2228.8	-334320	0	0	-334320
	46	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-4409.4	661410	0	0	661410
		TOTAL		2539755		-103500	2436255	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3615.8	542370	0	0	542370
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3126.4	468960	0	0	468960
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-2599.4	389910	0	0	389910
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2932.2	-439830	0	0	-439830
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	3458.5	-518775	0	0	-518775
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2277.2	-341580	0	0	-341580
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	201.3	-30195	0	0	-30195
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3250.2	-487530	0	0	-487530
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3408.6	-511290	0	0	-511290
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	1476.4	-221460	0	0	-221460
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	1421.1	-213165	0	0	-213165
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	20.5	-3075	0.2	30	-3045
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	19.8	-2970	0	0	-2970
		TOTAL		-1368630		30	-1368600	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1412.8	211920	0	0	211920
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	113.8	-17070	0	0	-17070
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-3680.4	552060	0	0	552060
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	3283.4	-492510	0	0	-492510
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-918.2	137730	0	0	137730
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3930.6	589590	0	0	589590
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3881.8	582270	0	0	582270
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7870.1	1180515	0	0	1180515
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	717.6	-107640	0	0	-107640
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	8763.9	-1314585	0	0	-1314585
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8679	-1301850	0	0	-1301850
		TOTAL		20430		0	20430	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	-56.1	8415	0	0	8415
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-64.7	9705	0	0	9705
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeyapore ICT-1	ER1550A	-2978.1	446715	0	0	446715
	6	HV side meter of 400/220 Jeyapore ICT-2	ER1571A	-4192.7	628905	0	0	628905
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-34.1	5115	0	0	5115
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-5186.6	777990	0	0	777990
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2283	342450	0	0	342450
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1954.8	293220	0	0	293220
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1929.8	289470	0	0	289470
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA (PG)	NP7916A	-1031.1	154665	0	0	154665
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	496.9	-74535	0	0	-74535
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	8556.8	-983520	0	0	-983520
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-I	NP5980A	-2409	361350	0	0	361350
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-II	NP7498A	-1519.9	227985	0	0	227985
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	557.6	-83640	0	0	-83640
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-74.1	11115	7.8	1170	12285
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-72.5	10875	7.6	1140	12015
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-1320.4	198060	0	0	198060
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-67	10050	0	0	10050
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	40	-6000	0	0	-6000
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH (PG)-OPGC-1	ER1117A	-376.5	56475	0	0	56475
	32	400 KV SUNDERGARH (PG)-OPGC-2	ER1119A	-393.3	58995	0	0	58995
		TOTAL		2743860		2310	2746170	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-1	NP6029A	0.00	0	0	0	
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	30.40	-4560	0	0	-4560
		TOTAL		-4560		0	-4560	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-391.2	-58680	-58680
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	137.2	-20580	0	0	-20580
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	93.1	-13965	0	0	-13965
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1486A	-850.3	127545	0	0	127545
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-940.6	141090	0	0	141090
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-107.5	16125	0	0	16125
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1606.8	241020	0	0	241020
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-72.2	10830	0	0	10830
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	1142.8	-171420	0	0	-171420
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGA PUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6708	-1006200	0	0	-1006200
	15	400 KV DURGA PUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	1520.3	-228045	0	0	-228045
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1985.1	297765	0	0	297765
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	524.4	-78660	0	0	-78660
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	12.5	-1875	0	0	-1875
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-28.8	4320	0	0	4320
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3618.6	-542790	0	0	-542790
	21	400 KV DURGA PUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	1122.1	-168315	0	0	-168315
	22	400 KV DURGA PUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL)LINE-I	ER1071A	-603.8	90570	0	0	90570
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL)LINE-II	ER1072A	-69	10350	0	0	10350
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	301.7	-45255	0	0	-45255
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPURE (PG) LINE-I	NP8723A	500.2	-75030	0	0	-75030
	31	400 KV SAGARDIGHI (WB)-BERHAMPURE (PG) LINE-II	NP8724A	379.5	-56925	0	0	-56925
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	595.4	-89310	0	0	-89310
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	613.6	-92040	0	0	-92040
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	4098.2	-614730	0	0	-614730
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	3077	-461550	0	0	-461550
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0.9	-135	0	0	-135
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-1163.2	174480	0	0	174480
	41	HV side of 400/220 KV RAJARHAT (PG) ICT-1	ER1526A	35.1	-5265	0	0	-5265
	42	220 KV GAZOLE (WB)-MALDA (PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE (WB)-MALDA (PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE (WB)-DALKHOLA (PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE (WB)-DALKHOLA (PG)-2	ER1699A	0	0	0	0	0
		TOTAL		-257995		-58680	-2616675	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArh, w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.